

OPERATING DATA REPORT

DOCKET NO. 50-338
 DATE 12-05-84
 COMPLETED BY Joan N. Lee
 TELEPHONE (703) 894-5151 X2527

OPERATING STATUS

1. Unit Name: North Anna 1
2. Reporting Period: November, 1984
3. Licensed Thermal Power (MWt): 2775
4. Nameplate Rating (Gross MWe): 947
5. Design Electrical Rating (Net MWe): 907
6. Maximum Dependable Capacity (Gross MWe): 937
7. Maximum Dependable Capacity (Net MWe): 890
8. If Changes Occur in Capacity Ratings (Items No. 3 thru 7) Since Last Report, Give Reasons:

Master revised due to mathematical error.

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	8,040	56,481
12. Number of Hours Reactor Was Critical	708.6	4,050.6	37,637.4
13. Reactor Reserve Shutdown Hours	0	55.6	3,084.2
14. Hours Generator On-Line	560.1	3,697.1	36,385.7
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1,545,983	9,799,803	94,851,576
17. Gross Electrical Energy Generated (MWH)	519,759	3,309,891	30,694,081
18. Net Electrical Energy Generated (MWH)	494,176	3,140,527	28,971,701
19. Unit Service Factor	77.8	46.0	64.4
20. Unit Availability Factor	77.8	46.0	64.4
21. Unit Capacity Factor (Using MDC Net)	77.1	43.9	57.6
22. Unit Capacity Factor (Using DER Net)	75.7	43.0	56.5
23. Unit Forced Outage Rate	22.2	21.3	13.2
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY _____
 INITIAL ELECTRICITY _____
 COMMERCIAL OPERATION _____