

## UNITED STATES ATOMIC ENERGY COMMISSION DIRECTORATE OF REGULATORY OPERATIONS REGION 1 970 BROAD STREET NEWARK, NEW JERSEY 07102

JUN 1973

D. L. Caphton, Senior Reactor Inspector Directorate of Regulatory Operations, Region I

RO INSPECTION REPORT NO. 50 - 219/73 - 09 JERSEY CENTRAL POWER & LIGHT COMPANY OYSTER CREEK

This inspection with W. Sanders was limited to inspecting the steam dryer for cracks (Re: cracks in steam dryer at Nine Mile Point) and reviewing the video tape of the feedwater sparger inspection (Re: cracks in feedwater spargers at Millstone). I felt the video tape of the feedwater sparger was excellent as far as clarity was concerned. It was obvious that the person in charge took his time and kept the camera in focus. Compared to the video tape of the feedwater sparger inspection made at Nine Mile Point, the video tape at Oyster Creek was outstanding. I'm not saying the video tape at Nine Mile Point was not acceptable, however, I believe smaller defects could have been detected at Oyster Creek.

Based on the above comparison, I feel standards for clarity and detail should be developed for TV inspection of reactor components. The standards should at least include clarity, magnification and contrast.

F. S. Cantrell ony

Reactor Inspector

MAN THEFT

MEMO ROUTE SLIP			See me about this.  Note and return	For signer.	For action,
		INITIALS	RO INSPECTION REPORT NO. 50-219/73-09  JERSEY CENTRAL POWER & LIGHT COMPANY  OYSTER CREEK		
		DATE			
co: RO:HQ (5) DR Central Files		INITIALS	The subject inspection report is forwarded for		
Direc	Standards (3 torate of censing (13)		by this office to the PDR, LPDR, NSIC, DTIE		
RO Regional Direct		tors	and State representatives after review by		
	4	DATE	the licensee	for proprietary in	nformation.
FROM (Name and unit)		REMARKS	The second secon		
R. T. Carlson, RO:I					
PHONE NO.	6/8/73				

USE OTHER SIDE FOR ADDITIONAL REMARKS

- Trisleif

GPO: 1971 O - 445-469