



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION I

~~NEWARK, NEW JERSEY 07102~~  
~~631 Park Ave.~~  
631 Park Ave.  
King of Prussia, Pa. 1906

October 1, 1973

Mr. Schuyler Mott, Librarian  
Ocean County Library  
15 Hooper Avenue  
Toms River, New Jersey 08753

Docket No. 30-219

Gentlemen:

Enclosed are copies of correspondence between Region I, Directorate of Regulatory Operations, and Jersey Central Power and Light Company (JCP&L).

This correspondence is submitted pursuant to arrangements made with the Public Proceedings Branch, Office of the Secretary for use by the public.

Where possible, these materials should be punched and filed in a folder labeled as follows:

Correspondence to and from Applicant or Licensee  
(Excluding Environmental & Antitrust)

Sincerely,

Joe E. Smith  
Administrative Officer

Enclosures:

Ltr from Jersey Central Power & Light Co. to Directorate of Licensing, Wash., D.C. dtd 9/18/73

cc: Central Mail & Files Unit, Document Room Clerk w/e encl.

B/126



UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545

Docket No. 50-219

Jersey Central Power & Light Company  
ATTN: Mr. I. R. Finfrock, Jr.  
Vice President - Generation  
Madison Avenue at Punch Bowl Road  
Morristown, New Jersey 07960

Gentlemen:

Inspections of hydraulic shock suppressors (snubbers) as required by RO Bulletin 73-3 revealed that a large percentage of the seals in Bergen-Patterson units were defective. Reinspections in compliance with RO Bulletin 73-4 indicated that defects can recur in six weeks' time or less.

Two different seal materials have been used in Bergen-Patterson snubbers; a millable gum polyurethane which contains plasticizers and other additives and a molded polyurethane known to be free of these additives. It has been postulated that dissolving of the plasticizer into the silicone hydraulic fluid has caused seal shrinkage and deterioration. Therefore, millable gum polyurethane should not be used in hydraulic snubbers, except on an emergency basis.

The performance and reliability of unadulterated molded polyurethane in a reactor environment has not yet been established. Test data indicate that an incompatibility exists between molded polyurethane and the silicone fluid which may limit the inservice life of the molded material. The use of molded polyurethane seals should, therefore, be considered an interim repair until more data is available or an improved material is established.

Based on the above considerations, we require the following action be taken on all Bergen-Patterson snubbers installed on safety related systems after the shutdown required by RO Bulletin 73-4.

1. Snubbers Inaccessible During Reactor Operation

During the shutdown required by RO Bulletin 73-4, replace seal material in all snubbers inaccessible during reactor operation with material demonstrated to be compatible with the hydraulic

3/12/77

~~8305100075~~

3pp.

7 1 1973

fluid at the operating environment. (If such material is unavailable, the use of molded polyurethane known to be free of additives will be acceptable as an interim repair.) Reinspect these snubbers whenever the reactor is shutdown for 24 hours or longer and snubbers have not been inspected for 30 days, but in no event should the interval between inspections exceed 120 days. Repair defective units before returning to power operation. If unavailability of materials prevents the changeout of all inaccessible snubbers or dictates repairs with millable gum seals, only defective units need be repaired. Under these conditions, reinspect every 30 days until improved seal material is installed which should be accomplished at the earliest practical time.

2. Snubbers Accessible During Reactor Operation


Repair defective snubbers accessible during reactor operation as outlined in 1. above. Reinspect accessible snubbers every 30 days or less and repair defective units as needed.

During the required surveillance, inspect snubbers supplied by manufacturers other than Bergen-Patterson. Report the results of the inspections and corrective action taken to the Directorate of Licensing within 15 days after the inspection. This report should include for each manufacturer the number of snubbers inspected, identification of defective units, and corrective action taken, including specific description of materials used in your repair.

Bergen-Patterson is coordinating a development program to determine a long-term solution to the current snubber problem. Based on the results of this program, the results of your reinspections, and any other pertinent information available, submit to the Directorate of Licensing at an appropriate time, but within one year, your proposed program to improve snubber service life and reliability and proposed changes to your Technical Specifications describing a snubber surveillance program with basis.

We also request that you submit to us within 60 days after your next shutdown information describing snubber temperature and radiation environment at full power.

Sincerely,

  
Donald J. Skovholt  
Assistant Director for  
Operating Reactors  
Directorate of Licensing

cc: see next page

C  
Jersey Central Power & Light  
Company

- 3 -

OCT 1 1973

cc: G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts, Trowbridge  
and Madden  
910 - 17th Street, N. W.  
Washington, D. C. 20006

GPU Service Corporation  
ATTN: Mr. Thomas M. Crimmins  
Safety & Licensing Manager  
260 Cherry Hill Road  
Parsippany, New Jersey 07054

Mr. Kenneth B. Walton  
Brigantine Tutoring  
309 - 21st Street, S.  
Brigantine, New Jersey 08203

Miss Dorothy R. Horner  
Township Clerk  
Township of Ocean  
Waretown, New Jersey 08753

Burtis W. Horner  
Stryker, Tams, and Dill  
55 Madison Avenue  
Morristown, New Jersey 07960

Ocean County Library  
15 Hooper Avenue  
Toms River, New Jersey 08753