

NOV 9 1971

J. G. Keppler, Chief, Reactor Testing & Operations Br.  
Division of Compliance, HQ

CO INSPECTION REPORT NO. 50-219/71-03  
JERSEY CENTRAL POWER AND LIGHT COMPANY  
OYSTER CREEK 1 - BWR

The subject inspection report is forwarded for your information.

This inspection focused on an examination of refueling activities, the licensee's first, and radiation and contamination control practices in effect for the related outage. As in the case of Nine Mile Point (See Inspection Report No. 50-220/71-04.) one area of concern was identified, i.e., a relatively low experience level represented in the GE personnel present. As was stated in the Evaluation Memorandum for the referenced report, our judgment is that the GE experience level situation at these two plants is probably indicative of a more general condition, i.e., thin coverage by GE at the many facilities throughout the country for which they have similar responsibilities. As was the case at Nine Mile Point, the situation at Oyster Creek was found to be acceptable, but only marginally so.

9604160166 960213  
PDR FOIA  
DEKOK95-258 PDR

R. T. Carlson  
Senior Reactor Inspector

Enclosure:  
Subject Inspection Report

cc: E. G. Case, DRS (3)  
R. S. Boyd, DRL (2)  
R. C. DeYoung, DRL (2)  
D. J. Skovholt, DRL (3)  
H. R. Denton, DRS (2)  
A. Giambusso, CO  
L. Kornblith, CO  
R. H. Engelken, CO  
Regional Directors, CO  
DR Central Files

OFFICE ▶	CO <i>JK</i>				
SURNAME ▶	Carlson:smg				
DATE ▶	11/9/71				

9604160166