1973

Jersey Central Power & Light Company Attention: Mr. R. H. Sims Vice President Madison Avenue at Punchbowl Road Morristown, New Jersey 07960

Docket No. 50-219

Gentlemen:

The attached RO Inquiry Report is forwarded to you for your information. This report was previously cleared verbally by Mr. J. Carroll of your staff for proprietary information. Distribution is being made by this office to the Public Document Room and to the Local Public Document Room.

Sincerely,

Robert T. Carlson, Chief Facility Operations Branch

Enclosure:

RO Inquiry Report No. 50-219/73-06Q

cc: Mr. J. Carroll, Station Superintendent

8/250

OFFICE >	RQ	
SURNAME .	Carlson: smg	4/30/73
DATE >		

Form AEC-318 (Rev. 9-53) AECM 0240



HITE CHAPTE

## ATOMIC ENERGY COMMISSION DIRECTORATE OF REGULATORY OPERATIONS REGION 1

## 970 BROAD STREET NEWARK, NEW JERSEY 07102

RO Inquiry Report No. 50-219/73-06Q

Licensee:

Jersey Central Power & Light Company

Madison Avenue at Punchbowl Road

Morristown, New Jersey

License No.:

DPR-16

Facility:

Oyster Creek - BWR

Forked River, New Jersey

Title:

Drain Valve Open on Chromated Water

Tank Truck

Prepared by:

F. S. Cantrell, Reactor Inspector

4/3/73 Date

A. Date and Manner AEC was Informed:

During a meeting with the licensee at Morristown, New Jersey on April 24, 1973.

B. Description of Particular Event or Circumstance:

About 100 gallons of chromated water (800 ppm) containing radio-activity (3.4 % 10<sup>-6</sup> gross activity) was lost to the ground from one of the storage tank trucks used to store chromated water at Oyster Creek. Two mechanics discovered water leaking from the tank truck at about 6:30 a.m. on April 24, 1973, and put a drum under the leak to catch the water. Closer inspection showed that the drain valv. had been opened, allowing the water to drain directly to the ground. The licensee stated that the chromated water storage tanks had been inspected between 5:00 and 6:00 a.m. on April 24 during a routine patrol check, and no evidence of leakage was noted at that time; however, the operator could not state that he specifically observed the valve that was found open.

The chromated water came from the torus and was removed when the torus water level became too high. The torus high level resulted from the testing of relief valves.

## C. Action by Licensee:

38685

- The licensee has initiated an accelerated program to collect well water samples from three wells in the immediate area. (All sample results are less than 0.1 ppm Cr.)
- 2. The licens \_ is drumming the soil that absorbed the chromated water (38 \_ ums have been collected (approximately 280 ft<sup>3</sup>)). A soil sample from the bottom of the hole showed 0.4 ppm Cr. The licensee plans to resume drumming after the heavy rains stop.
- 3. The licensee has initiated an investigation to determine how the valve was opened. (Approximately 50-60 contractor personnel and about 20-25 maintenance personnel, as well as normal shift complement, were on the site during the 12:00 to 8:00 shift on April 24, 1973.)
- 4. The licensee has notified the State of New Jersey of this release of chromated water.
- 5. The licensee has not decided whether to submit a written report of this event to the Commission.

		Melin				
MEMO ROUTE SU	P	See me about this.  Note and return.	For con- Thee.	For action.		
TO (Name and unit)	INITIALS .	RO INQUIRY REPORT NO. 50-219/73-06Q				
H. D. Thornburg, Chief, FS&EB	DATE	Jersey Central Power & Light Co. (Oyster Creek)				
TO (fiame and unit) cc: RO:HQ (5)	INITIALS	The subject inquiry report is forwarded for				
DR Central Files Reg. Standards (3 Directorate of	DATE	your information. Distribution will be made				
Licensing (13) TO (Name and unit)	INITIALS	by this office to the PDR, LPDR, NSIC, DTIE  REMARKS  and State representatives after review by				
	めた	the licensee for proprietary information.				
FROM (Name and unit)	REMARKS					
p. L. Caphton, RO:I						
PHONE NO. DATE 4/30/73						

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO . 1971 O - 445-4

3/251