



# CALCULATION COVER SHEET

PROJECT DAVIS-BESSE, UNIT-1 JOB NO. 12501 CALC. NO. M-8  
 SUBJECT PRESSURIZER SURGE LINE - CLASS-I PIPING ANALYSIS

COMPUTER PROGRAM:  NONE  SCP  OTHER  
 PROGRAM NO(S) ME-101 ME-210 VERSION/RELEASE NO. K1/4-15-84, 5/12-15-82

TOTAL NO. OF SHEETS 8  
(Excluding Attachments)

ATT. NO. 1 = 3 SHTS., ATT. NO. 2 = 14 SHTS., ATT. NO. 3 = 4 SHTS., ATT. NO. 4 = 2 SHTS., ATT. NO. 5 = 1 SHT.

PRELIMINARY CALC.  COMMITTED PRELIMINARY CALC.  
 SUPERSEDED CALC.  FINAL CALC.


01	PRESSURIZER SURGE LINE	SPL	1-31-85	<del>510</del>	1-31-85	MSW	-	1-31-85
NO.	DESCRIPTION	BY	DATE	CHKD.	DATE	APPROVED		DATE
REVISIONS								



# CALCULATION SHEET

JOB NO. 12501 DAVIS-BESSE, UNIT. 1	CALC. NO. M-8	REV. NO. 01	SHEET NO. 1
PRESSURIZER SURGE LINE	ORIGINATOR Siva P. Lingam	DATE 1-30-85	CHECKED [Signature] DATE 1-31-85

AS-BUILT CONDITION OF VERTICAL SNUBBER (PSU-R1) ON PRESSURIZER SURGE LINE



THE PURPOSE OF THIS CALCULATION IS TO CHECK THE PRIMARY PIPE STRESSES (CATASTROPHIC FAILURE) ON THE PRESSURIZER SURGE LINE FOR LONG-TERM OPERATION. CRITERIA EXCLUSIVE OF FINAL CLASS-I FATIGUE ANALYSIS.

ORIGINAL ANALYSIS OF THIS LINE WAS DONE BY B&W ON MAY 3, 1974 (STRESS ANALYSIS OF SURGE LINE, REPORT #6, REV. 1). ALL POINTS WERE ANALYZED BY USING THE SIMPLIFIED METHOD PER USAS B31.7, 1968 (1-705 & TABLE D-201, APPENDIX-D). IN THIS ANALYSIS, VERTICAL SNUBBER PSU-R1 IS CONSIDERED AT THE CENTER LINE OF PIPE.

AS PER NCR 84-180, THE WEST SIDE VERTICAL SNUBBER (CLOSE TO THE WALL) FAILED. THE REASON OF FAILURE IS DETERMINED AS THERMAL INTERFERENCE BETWEEN WALL AND THE FAILED SNUBBER. AS A RESULT, BECHTEL MODIFIED THIS SNUBBER AS SHOWN ABOVE TO MAKE THE REMAINING SNUBBER ALONE CAPABLE OF CARRYING THE ORIGINAL LOAD. HOWEVER THIS MODIFICATION CAUSES AN UNBALANCED MOMENT (TORSION ON PIPE) AT PIPE AND STANCHION INTERFACE.



# CALCULATION SHEET

JOB NO. 12501 DAVIS-BESSE, UNIT 1 CALC. NO. M-9		REV. NO. 01	SHEET NO. 2
PRESSURIZER SURGE LINE			
ORIGINATOR	DATE	CHECKED	DATE
Siva P. Kungam	1-30-85	<i>[Signature]</i>	1-31-85

BECHTEL MADE TWO SEISMIC RUNS OF PRESSURIZER SURGE LINE (BY DECOUPLING FROM HOT LEG), ONE WITH VERTICAL SNUBBER AT THE CENTER LINE OF PIPE AND OTHER WITH VERTICAL SNUBBER MODELED THROUGH STANCHION & TUBE STEEL TO REFLECT THE MODIFICATION AND AT THE SAME TIME CONSIDER THE EFFECT OF AN UNBALANCED MOMENT ON THE SYSTEM AS A WHOLE. THE DYNAMIC PROPERTIES (EIGEN VALUES & EIGEN VECTORS) WERE THEN COMPARED FOR THE TWO RUNS. THERE IS NO SIGNIFICANT CHANGE IN THE DYNAMIC PROPERTIES LEADING TO THE CONCLUSION THAT THE RESULTS OF THE ORIGINAL ANALYSIS REMAIN UNCHANGED INCLUDING NOZZLE LOADS. THE COMPARISON OF EIGEN VALUES (NATURAL FREQUENCIES UPTO 33 Hz) IS SHOWN BELOW (SEE ATTACHMENT NO. 1):

WITH SNUBBER AT CENTER LINE OF PIPE	WITH SNUBBER ACTUALLY MODELED	DIFFERENCE IN %	SOURCE
10.031 Hz.	9.805 Hz.	2.253%	BECHTEL
16.265	16.327	0.381	COMPUTER RUNS
19.021	18.914	0.563	G7399(11-28-84)
21.418	20.054	6.37 (HIGHER MODE)	AND
27.479	26.913	2.06	G7397(11-28-84)

HOWEVER, THE EFFECT OF ADDITIONAL TORSION MOMENT HAS TO BE CHECKED LOCALLY BY ADDING TO THE ORIGINAL RESULTS. SINCE THE MAXIMUM SEISMIC STRESS AND MAX. PRIMARY STRESS INTENSITY (EQ. 9 OF 1-705.1 OF B31.7, 1969) OCCUR VERY CLOSE TO THIS SNUBBER (4 1/4" AWAY) IN THE ORIGINAL ANALYSIS, - THE CORRESPONDING MOMENTS ARE CONSIDERED AT THE SNUBBER AND ARE NOTED BELOW (B&W DATA PT. 3 - SEE ATTACHMENT #2) :

LOAD TYPE	MOMENT IN INCH-POUNDS			TORSIONAL MOMENT (M <sub>x</sub> ) #
	M <sub>x</sub> #	M <sub>y</sub> #	M <sub>z</sub> #	
WEIGHT	12615.24	4661.04	51039.12	—
SEISMIC (OBE)	8872.8	22011.6	244343.04	20400 (2400 x 8.5)
SEISMIC (SSE)	15204.6	38394.	451370.28	33150 (3900 x 8.5)
WEIGHT + OBE	21488.04	26672.64	295382.16	20400
WEIGHT + SSE	27819.84	43055.04	502409.4	33150

GPO 2706 REV 4 82 (ED 83)



# CALCULATION SHEET

JOB NO. 12501 DAVIS-BESSE, UNIT-1 CALC. NO. M-8		REV. NO. 01	SHEET NO. 3
PRESSURIZER SURGE LINE			
ORIGINATOR Siva P. Dingam	DATE 1-30-85	CHECKED [Signature]	DATE 1-31-85

## EQUATION-9

$$B_1 \frac{PD_0}{2t} + B_2 \frac{D_0}{2I} M_x \leq 1.5 S_m \quad (\text{UPSET})$$

$$B_1 \frac{PD_0}{2t} + B_2 \frac{D_0}{2I} M_x \leq 2.25 S_m \quad (\text{FAULTED PER B\&W ANALYSIS})$$

SEE ATTACH. NO. 2, SHT. NO. 13

$B_1 = 1.0$  (conservative as stanchion is on straight pipe) → Ref. Table D.201 of APP. D  
 No hole on the run pipe - the cause only longitudinal pressure stress.

$P = 2500 \text{ psi}$

$D_0 = 10.75''$

$t = 1.0''$

$I = 368 \text{ in}^4$

$$M_x = \sqrt{(31488.04 + 20400)^2 + (26672.64)^2 + (295382.16)^2}$$

$$= 299527.4 \text{ in.-lb. (upset)}$$

$$B_2 = 0.75 C_2 \left[ \frac{1.95}{\left(\frac{ER}{\sigma} \right)^{1/3}} \right] M_x = \sqrt{(27819.84 + 33150)^2 + (43055.04)^2 + (502409.4)^2}$$


$$= 507923.5 \text{ in.-lb. (Faulted)}$$

$B_2 = 1.9875$  (FOR ELBOW)

$B_2 = 1.5$  (FOR WTEE)

$$\sqrt{1.1} = \sqrt{4.875 \times 1.0} = 2.208''$$

ACTUAL DISTANCE BETWEEN ELBOW  
 WELD & NEAREST STANCHION WELD  
 $= 0.9875''$



ASSUMING LINEAR DISTRIBUTION OF STRESS INDEX,

$$\frac{0.9875}{B} = \frac{2.208}{1.2705}$$

$B = 0.5682$

$B = 1.0 + 0.5682 = 1.5682$

$B_2 = 1.5682 \times 1.5 = 2.3523$  (multiplication of overlapping stress index is not required but is implied in note 2 of Table D.201)

If assumed as an unreinforced tee (UTE),  $i = \frac{0.9}{h^{2/3}}$  where

$h = \frac{t_n}{r}$   
 (from class-2)

$t_n = 1.0, r = 4.875$

$i = 2.5877$

$B_2 = 2.5877$  (conservative - no hole on the run pipe)



# CALCULATION SHEET

JOB NO. 12501 DAVIS-BESSE, UNIT-1		CALC. NO. M-8		REV. NO. 01	SHEET NO. 4
PRESSURIZER SURGE LINE					
ORIGINATOR	DATE	CHECKED	DATE		
<i>Siva P. Lingam</i>	1-30-85	<i>Ranjith K. S</i>	1-31-85		

CONSIDER THE HIGHEST VALUE OF  $B_2 = 2.5877$  (UTEE)

$$B_1 \frac{PD_0}{2E} + B_2 \frac{D_0}{2I} M_2 \leq 1.5 S_m$$

$$1.0 \times \frac{2500 \times 10.75}{2 \times 1.0} + 2.5877 \times \frac{10.75}{2 \times 368} \times 299527.4 \leq 24,800 \text{ psi}$$

$$24,759 \leq 24,800 \text{ psi}$$

(UPSET CONDITION)

$$1.0 \times \frac{2500 \times 10.75}{2 \times 1.0} + 2.5877 \times \frac{10.75}{2 \times 368} \times 507923.5 \leq 37,575 \text{ psi}$$

$$32,635 \leq 37,575 \text{ psi}$$

(Faulted condition).  
SEE ATTACH. NO. 2



# CALCULATION SHEET

JOB NO. 12501 DAVIS-BESSE, UNIT-1 CALC. NO. M-8		REV. NO. 01	SHEET NO. 5
PRESSURIZER SURGE LINE			
ORIGINATOR Siva P. Arinam	DATE 1-30-85	CHECKED R. J. [Signature]	DATE 1-31-85

1 BECHTEL PROGRAM ME-210 ALSO CALCULATES THE LOCAL STRESSES  
2 AT THE STANCHION & PIPE INTERFACE. Ref.: WRC-107

3  
4  
5 CHECKS 1A, 1B, 2A & 2B OF ME-210 DEAL WITH UPSET PRIMARY  
6 (CIRCUMFERENTIAL), FAULTED PRIMARY (CIRCUMFERENTIAL), UPSET  
7 PRIMARY (LONGITUDINAL) & FAULTED PRIMARY (LONGITUDINAL)  
8 RESPECTIVELY. (SEE SHT. 4 OF ATTACH. NO. 3)

9  
10 1A →  $\frac{P D_o}{2t} + \text{stresses from ME-210} = 14,030 \text{ psi}$

11  
12  
13  $13437.5 + \text{stresses from ME-210} = 14,030$

14  
15  $\text{stress from ME-210} = 14030 - 13437.5 = 592.5$

16 Applying stress index of 2.5877,

17  
18  
19 1A →  $13437.5 + (2.5877 \times 592.5) = 14,971 \text{ psi} (< 24,720 \text{ psi})$

20  
21 1B →  $13437.5 + 2.5877 \times (14400 - 13437.5) = 15,929 \text{ psi}$   
22  $(< 37,575 \text{ psi})$   
23  $B&N = 2.255$

24 2A →  $\frac{P D_o}{4t} + \text{stresses from ME-210 including ME-101 stresses} = 12,970$

25  
26  $6718.75 + \text{stresses from ME-210 including ME-101 stresses} = 12,970$

27  
28  
29  $\text{stresses from ME-210 including ME-101 stresses} = 6251.25$

30 Applying stress index of 2.5877,

31  
32 2A →  $6718.75 + (2.5877 \times 6251.25) = 22,896 \text{ psi} (< 24,720 \text{ psi})$

33  
34 2B →  $6718.75 + 2.5877 \times (17390 - 6718.75) = 34,332 \text{ psi}$   
35  $(< 37,575 \text{ psi})$   
36



# CALCULATION SHEET

JOB NO. 12501	CALC. NO. M-8	REV. NO. 01	SHEET NO. 6
DAVIS-BESSE UNIT ONE		DATE 1-31-85	CHECKED Siva P. durgam
ORIGINATOR J. J. P. [Signature]	DATE 1-31-85	CHECKED Siva P. durgam	DATE 1-31-85

REANALYSIS USING CODE CASE N-411 RESULTED IN THE SYSTEM EXPERIENCING THE FOLLOWING REDUCTIONS IN DISPLACEMENTS, LOADINGS AND STRESSES (WHEN COMPARED TO THE ORIGINAL ANALYSIS):  
 (CODE CASE N-411 CALLS OUT FOR 5% DAMPING FOR 0-10cps, A LINEAR DECREASE FROM 5% TO 2% DAMPING FOR 10-20cps, AND 2% DAMPING FOR FREQUENCIES GREATER THAN 20cps - SEE ATTACHMENT #4)

SUPPORTS : @ BECHTEL D.P. (42) : 64% REDUCTION IN LOAD (Y-SNUBBER) - PSU-R1  
 @ " " (55) : 11% REDUCTION IN LOAD (X-SNUBBER)  
 @ " " (60) : 70% REDUCTION IN LOAD (Z-SNUBBER)

DISPLACEMENTS : ALL DATA POINTS : 60% TO 75% REDUCTION IN DISPLACEMENT

MOMENTS IN THE PIPE : FOR M<sub>x</sub> : 51% TO 70% REDUCTION IN LOADING  
 FOR M<sub>y</sub> : 62% TO 70% REDUCTION IN LOADING  
 FOR M<sub>z</sub> : 48% TO 70% REDUCTION IN LOADING

STRESSES IN THE PIPE : AN OVERALL REDUCTION OF 64% TO 69% IN STRESSES.

NOZZLE LOADS : FOR HOT LEG (BECHTEL D.P. (5)) : 49% TO 69% REDUCTION IN LOADING  
 FOR PRESSURIZER (BECHTEL D.P. (100)) : 11% TO 70% REDUCTION IN LOADING

THE REDUCTIONS SHOWN ABOVE REFLECT OBE AND SSE CONDITIONS. IN GENERAL, THE MORE SIGNIFICANT LOADINGS EXPERIENCED APPROXIMATELY A 65% REDUCTION IN LOADINGS.

REFER TO : SNUMB N° G0087 DATED 1-30-85 - OBE USING CODE CASE N-411  
 SNUMB N° G0096 DATED 1-31-85 - SSE USING CODE CASE N-411



# CALCULATION SHEET

JOB NO. 12501 DAVIS-BESSE, UNIT-1		CALC. NO. M-8	REV. NO. 01	SHEET NO. 7
PRESSURIZER SURGE LINE				
ORIGINATOR	DATE	CHECKED	DATE	
Siva P. Dingam	1-31-85	[Signature]	1-31-85	

IT IS EVIDENT FROM THE PREVIOUS SHEET THAT AT LEAST 40% REDUCTION IN Y-LOAD, MOMENTS & STRESSES CAN BE ATTAINED FOR CODE CASE N-411 WHICH PERMITS THE USE OF HIGHER DAMPING (5% TO 2% OF CRITICAL DAMPING). APPLYING THIS REDUCTION IN EQUATION-9, WE GET THE FOLLOWING:

$$B_1 \frac{PD_0}{2t} + B_2 \frac{D_0}{2I} M_1 \leq 1.5S_m$$

$$1.0 \times \frac{2500 \times 10.75}{2 \times 110} + 2.5877 \times \frac{10.75}{2 \times 368} \cdot (299527.4) \cdot 0.6 \leq 24,800 \text{ psi}$$

$$20,231 \leq 24,800 \text{ psi}$$

(upset condition)

$$1.0 \times \frac{2500 \times 10.75}{2 \times 110} + 2.5877 \times \frac{10.75}{2 \times 368} \cdot (507923.5) \cdot 0.6 \leq 27,575 \text{ psi}$$

$$24,956 \leq 27,575 \text{ psi}$$

(faulted condition)

IN A SIMILAR WAY, ME-210 STRESSES (CHECKS 1A, 1B, 2A & 2B) WILL BE MUCH WITHIN THE ALLOWABLES.

### CONCLUSIONS

EVEN WITH CONSERVATIVE PRIMARY STRESS INDICES ( $B_1$  FOR AN ELBOW ALTHOUGH STANCHION IS ON A STRAIGHT PIPE AND  $B_2$  FOR AN UNREINFORCED TEE ALTHOUGH THERE IS NO HOLE IN THE PIPE), CONDITION FOR CATASTROPHIC FAILURE IS SATISFIED FOR LONG TERM OPERATION. IN ADDITION, WE HAVE SHOWN THAT SEISMIC ANALYSIS USING 5% DAMPING WOULD REDUCE STRESS LEVELS AN ADDITIONAL 18% (AT LEAST) AND MATERIAL TEST REPORTS SHOW THE ACTUAL YIELD STRENGTH TO BE GREATER THAN THE ALLOWABLE DESIGN VALUES.



TITLE I PRESSR, SURGE LINE  
 PROJECT NUMBER I 12501  
 PROBLEM NUMBER I M8  
 USER I SPL  
 LOAD CASE I SEISI

EIGEN SOLVER I DETERMINANT SEARCH

EIGEN VALUES (natural frequencies)

FREQUENCIES FOR THE SEISI LOAD CASE (EPS)		
19.0313230	16.2666013	21.4183087
	19.0205380	27.4791067

SEISMIC

PERIODS FOR THE SEISI LOAD CASE (SEC)		
.0996877	.0618829	.0525748
		.0866890
		.0363913

WITHOUT BROKEN SNUBBER

PRESSURIZER SURGE LINE

ATTACHMENT NO. 1

PROB. NO. M-8 (01)

SHT. NO. 1 OF 3

Added by: Siva S. Srinivasan Date: 1-30-85

CHK'd by: Langford Date: 1-31-85

WE101/K1

FREQUENCIES AND PERIODS

TITLE I PRESS. SURGE LINE  
PROJECT NUMBER I 12581  
PROBLEM NUMBER I NA  
USER I SPL  
LOAD CASE I SEISI

EIGEN SOLVER I DETERMINANT SEARCH

FREQUENCIES FOR THE SEISI LOAD CASE (CP9) EIGEN VALUES (Natural frequencies)

9.8881866 16.3267060 18.9136366 20.0543240 26.9129386

SEISMIC

PERIODS FOR THE SEISI LOAD CASE (SEC) .0371568  
.1019975 .0612490 .0528719 .0498066

WITH BROKEN SNUBBER

= 2.3% - four frequency

PRESSURIZER SURGE LINE

ATTACHMENT NO. 1

PROB. NO. M-8(01)

SHT. NO. 2 OF 3

Added by: Siva P. Dingam Date: 1-30-85

Checked by: [Signature] Date: 1-31-85



Randy Kies A.P.N.: SIYA LINGAM

**Babcock & Wilcox**

a BETHLEHEM COMPANY

Nuclear Power Generation Division

**GENERAL CALCULATIONS**


ATTACHMENT #2

PROB. NO. M-8 (D1)

SHT. NO. 1 OF 14

Added by: Siva Lingam 1-30-85

Checked by: [Signature] 1-31-85



(0,0,0) at  
C of RV  
at nozzle belt  
elevation.

COORDINATES in inches

STATION	X	Y	Z
16	311.9375	335.0	210.0
3	286.9375	330.0	
1	218.030		
6	139.122		
23	60.214		
36	49.607		
54	23.688		
71	0		

STATION	X	Y	Z
2	252.0	258.1875	411.0
7	267.0	243.1875	
5	286.9375		
15	311.9375		
11			386.0
12			339.0
13			282.0
14			225.0
			210.0

Ref: Piping Final Design Document  
for Toledo Edison Co. & CEE  
Daws Base #1 - BTW Contract  
620-004-50, May 75, Vol 1 of 2

PREPARED BY RP Pollock DATE 6/25/82 DOC NO. \_\_\_\_\_  
 REVIEWED BY \_\_\_\_\_ DATE \_\_\_\_\_ PAGE NO. \_\_\_\_\_

SURGE LINE SUPPRESSOR/HANGER LOADS

(See Figure 4)

<u>Type of Loading</u>	<u>Forces (Kips)</u>			<u>Moments (Ft-Kips)</u>		
	<u>Fx</u>	<u>Fy</u>	<u>Fz</u>	<u>Mx</u>	<u>My</u>	<u>Mz</u>
Dead Weight	0	-3.8	0	0	0	0
OBE	7.5	2.4	3.2	0	0	0
DBE	13.7	3.9	5.8	0	0	0

PROB. NO. M-8(01)

ATTACHMENT # 2

SHT. NO. 2 OF 14

Added by: Siva P. Lingam Date: 1-30-85

Checked by: Rajalal Date: 1-31-85

Introduction

This report contains the stress analysis of the surge line. All points in the surge line are analyzed including the bimetallic weld at the hot leg surge nozzle. The analysis of the intersection at the pressurizer end is contained in pressurizer Design Report "Surge Nozzle Analysis". The branch intersection analysis is contained in this Design Report under a different section "Surge Nozzle".

Results

All points in the surge line satisfy primary stress limits either in accordance with equation 9 or per Appendix F of the B31.7 code.

Per equation 9 simplified analysis

Maximum Primary Stress = 22074.96 psi < 1.5 S<sub>m</sub> = 24800. psi @ 670°F  
Maximum for an elbow (joint 3) = 22074.96 psi < 24800. psi  
Maximum for a straight (joint 1) = 10220.54 psi < 24800. psi

All points in the surge line do not satisfy the 3 S<sub>m</sub> primary plus secondary stress limit. However, calculations are provided showing that an Elastic-Plastic Analysis is applicable.

Maximum primary plus secondary stress (Bimetallic Weld) (joint 54)  
= 75997.62 psi > 3 S<sub>m</sub> = 50100. psi @ 650.°F (PAGE C-11)  
Maximum primary plus secondary stress for an elbow (joint 2)  
= 67368.71 psi > 50100. psi (PAGE C-13)  
Primary plus secondary stress for cycles occurring more than 240 times:  
Joint 2 = 36860.4 psi < 3 S<sub>m</sub> = 50100. psi  
Joint 3 = 33787.9 psi < 3 S<sub>m</sub> = 50100. psi  
Joint 19 = 36929.7 psi < 3 S<sub>m</sub> = 50100. psi

Maximum Usage Factors:

Usage Factor at Bimetallic weld (joint 2) = 0.87 < 1.0 = allowable  
Usage Factor for joint 3 = 0.045 < 1.0 = allowable  
Usage Factor for joint 19 = 0.036 < 1.0 = allowable

PROB. NO. M-8 (01)

ATTACHMENT # 2

SHT. NO. 3 OF 14

Added by: Siva P. Lingam Date: 1-30-85

Checked by: [Signature] Date: 1-31-85

Ref: "Stress Analysis of Surge Line, Report #6, for Toledo Edison Company, Davis-Besse, "620-0014-50, Jun 1972 (Rev 1, 5/3/74). RP 7/2/82 10

This section demonstrates that all points in the surge line satisfy primary stress limits according to either Equation 9 or Appendix F of B31.7. A flexibility analysis was run for dead weight, and either (x + y) or (z + y) earthquakes. The moments generated by this analysis are shown on Pages A-4 thru A-7.

These moments are then combined with design pressure of 2500 psi to generate primary stresses in accordance with equation 9 using applicable indicies. The indicies used are listed in the stress output. Two cases were ran: 1) pressure, deadload, (x + y) earthquake; 2) pressure, deadload, (z + y) earthquake.

The results are then compared to  $1.5 S_m$  at  $670^{\circ}\text{F}$  for SA-376-TP-316 (straights) and A-403-WP-316 (bends). Part of the surge line actually has a design temperature of  $650^{\circ}\text{F}$ .  $S_m = 16,500$  psi. for both materials thus the allowable primary stress is  $1.5 (16,500.) = 24,800.$  psi.

The largest primary stress is 22074.96 psi at joint 3 for the x + y earthquake at an elbow juncture. Complete results are tabulated on Page A-8 and 9.

PROB. NO. M-8 (01)

ATTACHMENT # 2

SHT. No. 4 OF 14

Added by: Siva S. Singam date: 1-30-85

ch'kd by: Vandana date: 1-31-85

STRESS INDICES

(JOINT CLASSIFICATION)

TYPE

DESCRIPTION

- 1 STRAIGHT PIPE, REMOTE FROM WELDS OR OTHER DISCONTINUITIES
- 2 GIRTH BUTT WELD BETWEEN STRAIGHT PIPE OR BETWEEN PIPE AND BUTT-WELDING COMPONENTS. FLUSH
- 3 GIRTH BUTT WELD BETWEEN STRAIGHT PIPE OR BETWEEN PIPE AND BUTT-WELDING COMPONENTS. AS WELDED
- 4 GIRTH FILLET WELD TO SOCKET WELD FITTINGS, SLIP-ON FLANGES, OR SOCKET-WELDING FLANGES
- 5 LONGITUDINAL BUTT WELDS IN STRAIGHT PIPE. FLUSH
- 6 LONGITUDINAL BUTT WELDS IN STRAIGHT PIPE. AS WELDED
- 7 TAPERED TRANSITION JOINTS PER SUBPAR. 1-727.4.2(C) AND FIG.1-727.3.1
- 8 BRANCH CONNECTIONS PER SUBDIV. 1-704.3
- 9 CURVED PIPE OR BUTT-WELDING ELBOWS PER USAS B16.9, USAS B16.28, OR MSS SP48
- 10 BUTT-WELDING TEES PER USAS B16.9 OR MSS SP48
- 11 BUTT-WELDING REDUCERS PER USAS B16.9 OR MSS SP48

PROB. NO. M-8(01)

ATTACHMENT # 2

SHT. NO. 5 OF 14

Added by: Siva P. Kingam Date: 1-30-85

ch'kd by: [Signature] Date: 1-31-85



## SECTION PROPERTIES

SECTION	OUTSIDE RADIUS (IN)	OUTSIDE DIAMETER (IN)	THICKNESS (IN)	MOMENT OF INERTIA (IN <sup>4</sup> )	BEND RADIUS (IN)	DESCRIPTION
1	5.3750	10.7500	1.0000	367.805		SURGE LINE ST.
2	5.3750	10.7500	1.0000	367.805	15.0000	SURGE LINE CR.

PROB. NO. M-8 (01)

ATTACHMENT # 2

SHT. NO. 6 OF 14

Added by: Siva P. Lingam date: 1-30-85

ch'ed by: Randall's date: 1-31-85

## DEAD LOAD MOM. (FT-LBS)

JOINT	M(X)	M(Y)	M(Z)
1	1051.27	190.21	2956.52
2	48.76	575.73	5475.20
3	1051.27	388.42	4253.26
5	11.08	462.85	102.55
6	1051.27	8.60	4545.22
7	11.08	538.05	3365.43
11	4009.10	120.24	1611.11
12	3647.55	121.16	1611.11
13	352.88	362.57	1611.11
14	870.89	426.09	1674.64
15	1437.53	361.65	1611.11
16	1013.59	426.09	1915.25
18	942.24	426.09	1794.94
23	1051.27	206.20	512.79
36	780.06	251.45	142.01
54	1677.71	426.33	2599.77

PROB. NO. M-8 (01)

ATTACHMENT NO. 2

SHT. NO. 7 OF 14

Added by: Siva P. Kungam Date: 1-30-85

ch'ed by: Rampal's Date: 1-31-85

JOINT	H(X)	H(Y)	H(Z)
1	552.91	5774.54	13644.50
2	1091.14	3150.34	8890.93
3	552.91	1462.31	19615.80
5	803.58	3093.78	5837.96
6	552.91	2393.62	4150.89
7	803.58	2984.70	7184.48
11	2332.90	3832.01	5367.42
12	2374.06	4664.09	5367.42
13	1686.72	2087.29	5367.42
14	1926.39	1927.74	5317.74
15	316.78	2491.91	5367.42
16	762.69	1927.74	10767.60
18	2770.96	1927.74	5636.34
23	552.91	2913.27	5693.95
36	737.77	2680.95	7000.95
54	4852.93	7976.70	10344.10

ATTACHMENT # 2

PROB. No. M-8(01)

SHT. NO. 8 OF 14

Added by: Siva P. Lingam Date: 1-30-85

checked by: Kandathil's Date: 1-31-85

3

JOINT	M(X)	M(Y)	M(Z)
1	186.49	1510.79	1828.76
2	314.57	812.57	1047.93
3	186.49	371.99	746.12
5	403.67	702.55	235.87
6	186.49	613.02	711.74
7	403.67	744.95	767.22
11	1145.29	1185.50	496.78
12	881.24	1481.76	496.78
13	948.49	471.82	496.78
14	1066.14	571.52	301.27
15	117.58	410.45	496.78
16	221.74	571.52	445.15
18	773.30	571.52	711.91
23	186.49	780.29	522.38
36	241.32	811.28	768.08
54	1042.90	1347.92	1561.55

PROB. NO. M-8(01)

ATTACHMENT # 2

SHT. NO. 9 OF 14

Added by: Siva P. Dingam Date: 1-30-85

ch'kd by: Vandana's Date: 1-31-85

A-6

Z EARTHQUAKE MOMENTS (FT-LBS)

JOINT	H(X)	H(Y)	H(Z)
1	2433.64	7961.39	4184.12
2	3388.12	8215.63	10092.10
3	2433.64	2335.07	3456.56
5	3399.73	2767.35	1725.99
6	2433.64	4134.19	2241.79
7	3399.79	5695.74	6636.94
11	6557.96	5244.52	943.78
12	8413.33	5365.99	943.78
13	6341.99	2892.85	943.78
14	4395.61	3892.77	1680.56
15	1445.88	3424.23	943.78
16	1675.18	3892.77	2984.50
18	3877.61	3892.77	4513.19
23	2433.64	3949.75	1820.32
36	2629.71	4271.87	1651.72
54	4643.93	9844.89	3448.70

PROB. NO. M-8 (01)

ATTACHMENT # 2

SHT. NO. 10 OF 14

Added by: Siva P. Singam Date: 1-30-85

ch'ed by: Randall's Date: 1-31-85

EQUATION 9 - PRIMARY STRESSES

CONDITION . . . PRESSURE, X+Y EQ, DEAD WT.  
EQ 9

MOMENTS IN FT-LBS.

STRESSES IN PSI.

JOINT	TYPE	HX	HY	HZ	M(II)	B1	B2	PRIMARY STRESS	RATIO TO ALLOWABLE
1	1	1790.67	7475.54	18429.78	19968.65	.5	1.0	10220.54	.413
2	9	1454.47	4538.64	15454.06	16172.28	1.0	2.0	19074.58	.771
3	9	1790.67	2222.71	24615.18	24780.11	1.0	2.0	22074.96	.892
5	9	1223.34	4256.18	6236.38	7648.80	1.0	2.0	16103.60	.651
6	1	1790.67	3011.64	9467.85	10039.13	.5	1.0	8479.26	.343
7	9	1223.34	4271.70	11317.13	12158.18	1.0	2.0	17675.41	.714
11	1	7487.29	5137.75	7475.31	11761.64	.5	1.0	8781.32	.355
12	1	5902.85	6267.01	7475.31	11950.11	.5	1.0	8814.37	.356
13	9	2988.09	2921.68	7475.31	8564.18	1.0	2.0	16422.67	.664
14	9	3863.42	2925.35	7293.65	8756.77	1.0	2.0	16489.80	.666
15	9	1871.89	3264.00	7475.31	8368.87	1.0	2.0	16354.59	.661
16	9	1998.02	2925.35	13127.99	13597.57	1.0	2.0	18177.13	.734
18	1	4486.50	2925.35	8143.19	9746.68	.5	1.0	8427.97	.341
23	9	1790.67	3899.76	6729.12	7980.96	1.0	2.0	16219.38	.655
36	9	1759.15	3743.67	7911.04	8927.17	1.0	2.0	16549.19	.669
54	3	6773.54	9750.94	14505.42	18744.84	.5	1.0	10005.93	.404

PROB. NO. M-8(01)

ATTACHMENT # 2

SHT. NO. 11 OF 14

Added by: Siva P. Arinam date: 1-30-85

ch'ed by: Vijayalakshmi's date: 1-31-85

P-3

EQUATION 9 - PRIMARY STRESSES

CONDITION . . . PRESSURE, Z+Y EQ, DEAD WT.

EQ 9

MOMENTS IN FT-LBS.

STRESSES IN PSI.

JOINT	TYPE	HX	HY	HZ	H(II)	B1	B2	PRIMARY STRESS	RATIO TO ALLOWABLE
1	1	3671.40	9662.39	8969.40	13685.44	.5	1.0	9118.69	.368
2	9	3751.45	9603.93	16655.23	19588.40	1.0	2.0	20265.32	.819
3	9	3671.40	3095.47	8455.93	9724.40	1.0	2.0	16827.08	.680
5	9	3819.54	3932.76	2124.41	5879.51	1.0	2.0	15486.89	.626
6	1	3671.40	4752.21	7498.75	9606.98	.5	1.0	8483.47	.340
7	9	3819.54	6978.74	10769.59	13389.39	1.0	2.0	18104.56	.731
11	1	11712.35	6550.26	3051.67	13762.19	.5	1.0	9132.15	.369
12	1	12942.72	6968.91	3051.67	15013.08	.5	1.0	9351.51	.378
13	9	7643.36	3727.24	3051.67	9034.71	1.0	2.0	16586.68	.670
14	9	6332.64	4890.38	3656.47	8797.04	1.0	2.0	16503.83	.667
15	9	3000.99	4196.32	3051.67	5993.98	1.0	2.0	15526.79	.627
16	9	2910.51	4890.38	5344.89	7807.36	1.0	2.0	16158.87	.653
18	1	5593.15	4890.38	7020.04	10221.55	.5	1.0	8511.25	.344
23	9	3671.40	4936.24	2855.49	6782.30	1.0	2.0	15801.57	.638
36	9	3651.09	5334.59	2561.81	6953.50	1.0	2.0	15861.24	.641
54	3	7364.54	11619.13	7610.02	15721.11	.5	1.0	9475.67	.383

PROB. NO. M-8(01)

ATTACHMENT NO. 2

SHT. NO. 12 OF 14

Added by: Siva P. Singam date: 1-30-85

ch'kd by: Randall's date: 1-31-85

EQUATION 9 - PRIMARY STRESSES

CONDITION . . . X+Y DBE, DEAD WT., PRESSURE  
EQ 9  
MOMENTS IN FT-LBS.

STRESSES IN PSI.

JOINT TYPE		MX	MY	MZ	M(1)	B1	B2	PRIMARY STRESS	RATIO TO ALLOWABLE	ALLOWABLE 2.25 Sm 37,575 KSI
1	1	2318.32	12877.09	33757.68	33424.98	.5	1.0	12580.30	.297	< 37,575 KSI
2	9	2432.40	7482.58	23461.15	24790.29	1.0	2.0	22064.57	.521	< 37,575 KSI
3	9	2318.32	3587.92	41867.45	42004.81	1.0	2.0	28106.76	.664	< " "
5	9	2024.62	7120.80	11374.37	13571.34	1.0	2.0	18167.98	.429	< " "
6	1	2318.32	5246.59	13197.06	14389.71	.5	1.0	9242.19	.218	< " "
7	9	2024.62	7058.11	17759.43	19217.53	1.0	2.0	20136.04	.475	< " "
11	1	9803.24	8767.98	12269.16	17986.47	.5	1.0	9872.94	.233	< " "
12	1	9188.59	10695.21	12269.16	18690.91	.5	1.0	9996.47	.236	< " "
13	9	4692.66	4855.58	12269.16	14004.64	1.0	2.0	18319.02	.433	< " "
14	9	5805.91	4745.36	11995.40	14146.26	1.0	2.0	18368.38	.434	< " "
15	9	2176.89	5534.58	12269.16	13634.61	1.0	2.0	18190.04	.429	< " "
16	9	2717.00	4745.36	22607.09	23259.00	1.0	2.0	21544.76	.509	< " "
18	1	7090.56	4745.36	13224.78	15738.15	.5	1.0	9478.66	.224	< " "
23	9	2318.32	6629.38	11813.46	13743.40	1.0	2.0	18227.96	.430	< " "
36	9	2461.35	6278.92	14193.89	15714.63	1.0	2.0	18915.06	.447	< " "
54	3	10560.31	17027.65	23895.17	31183.98	.5	1.0	12187.31	.288	< " "

PROB. NO. M-8(01)

ATTACHMENT NO. 2

SHT. NO. 13 OF 14

Added by: Siva P. Aringam Date: 1-30-85

ch'ed by: Kanjilal Date: 1-31-85



EQUATION 9 - PRIMARY STRESSES

CONDITION . . . 2 1/2 Y DOE, DEAD WT., PRESSURE  
EQ 9

MOMENTS IN FT-LBS.

STRESSES IN PSI.

JOINT TYPE	HX	HY	HZ	M(I)	O1	O2	PRIMARY STRESS	RATIO TO ALLOWABLE	ALLOWABLE	
									2.25 Sm	KSI
1 1	5835.29	16966.50	13066.77	22195.79	.5	1.0	10611.10	.251	< 37,575	KSI
2 9	6777.76	15954.67	25707.34	31531.99	1.0	2.0	24428.42	.577	"	"
3 9	5835.29	5219.98	11649.67	14036.16	1.0	2.0	18330.00	.433	"	"
5 9	6879.53	6516.00	3684.99	10166.87	1.0	2.0	16981.31	.401	"	"
6 1	5835.29	8501.46	9627.05	14106.93	.5	1.0	9192.61	.217	"	"
7 9	6879.53	12120.27	15735.53	21772.59	1.0	2.0	21028.74	.496	"	"
11 1	17704.10	11469.37	3996.96	21437.92	.5	1.0	10478.20	.247	"	"
12 1	20483.15	12007.76	3996.96	24077.41	.5	1.0	10941.07	.258	"	"
13 9	13398.91	6361.97	3996.96	15360.90	1.0	2.0	18791.76	.444	"	"
14 9	10423.35	8419.97	5193.87	14370.75	1.0	2.0	18440.63	.436	"	"
15 9	4288.30	7278.01	3996.96	9345.30	1.0	2.0	16694.94	.394	"	"
16 9	4423.30	8419.97	8052.70	12462.26	1.0	2.0	17781.40	.420	"	"
18 1	9159.99	8419.97	11124.49	16585.99	.5	1.0	9645.58	.228	"	"
23 9	5835.29	8567.60	4569.77	11326.60	1.0	2.0	17386.25	.410	"	"
36 9	5999.27	9253.94	4190.83	11797.87	1.0	2.0	17549.82	.414	"	"
54 3	11665.48	29521.17	11000.78	20042.64	.5	1.0	11285.70	.266	"	"

PROB. NO. M-8(01)

ATTACHMENT # 2

SHT. NO. 14 OF 14

Added by: Siva P. Lingam date: 1-30-85

ch'ed by: Ranjith date: 1-31-85

A-11



# CALCULATION SHEET

ORIGINATOR Siva P. Singam DATE 11-30-84 CALC. NO. PS/PSU-1 REV. NO. 1  
 PROJECT DAVIS-BESSE UNIT 1 CHECKED [Signature] DATE 12-5-84  
 SUBJECT DATA SHEET FOR LOCAL STRESS CHECK JOB NO. 72501 SHEET NO. 11

FOR LONG T.L.F.11

TO BE FILLED IN BY STRESS GROUP:

STRESS PROBLEM NO. M-8 ISSUE: C2 DATA POINT 40  
 PIPE SUPPORT NO. PSU-R1  
 TYPE OF SUPPORT: VERTICAL  (SNUBBER) X  Z  ANCHOR  SKRU

ATTACH. NO. 3 SHT. NO. 1 OF 4 10" Ø PIPE  
 PROB. NO. M-8 (01)  
 Added by: Siva P. Singam 1-30-85  
 in chkd by: [Signature]  
 SM 16.48 ksi

PIPE WALL THK 1.0 in  
 DESIGN PRESSURE 2500 psig  
 TEMPERATURE 670 °F

PIPE OUTSIDE DIAMETER 10.75 in  
 OPERATING PRESSURE 2750 psig  
 PIPING MATERIAL S.S. SA376-T1316



ME-101 LOAD CASE	SUPPORT LOADS						PIPE STRESS (psig)
	FORCES (lbs)			MOMENTS (lb-in)			
	X	Y	Z	X	Y	Z	
WEIGHT		—					825
ORE		2400					4415
SSE		3900					8203
THERMAL		—					4546
SAN		—					—


NOTE: 1) The stresses are at the center line of pipe.  
 2) The loads are as shown in figure.  
 • KSI FOR ME 210 IMPIT



# CALCULATION SHEET

ORIGINATOR CH [Signature] DATE 11/30/84 CALC NO. PS/PSU-1 REV. NO. 1  
 PROJECT WALIS-BESSE UNIT 1 CHECKED T. Lind DATE 12/11/84  
 SUBJECT ME 210 INPUT DATA JOB NO. 12501  
 SHEET NO. 12

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50




-> TYPE CALL 816566+PROG.210IN

1> TITLE, SUPPORT NUMBER PSU-R1  
 2> NUMBER OF LOADING CASES 3

LOADING COMBINATIONS

CASE NUMBER	TYPE OF COMBINATION	P lbs	ML in-lbs	MC in-lbs	MT in-lbs	VL lbs	VC lbs	COMMENTS
1	WEIGHT+ ORB	2400 ;	0 ;	20400 ;	0 ;	0 ;	0	
2	WEIGHT+ SSE	3900 ;	0 ;	33150 ;	0 ;	0 ;	0	
3	WEIGHT+THRM+ ORB+SAM	2400 ;	0 ;	20400 ;	0 ;	0 ;	0	



GEOMETRIC PARAMETERS  
 $\beta$  AND  $\beta'$  CHECK

$\beta = C1/VD = 5$

$\beta' = C2/VD = 5$

$\beta' = \frac{VD}{1.2 \cdot VTHK} = 6.625$

$0.01 < \beta < 0.5$  IF NOT,  
 $5 < \beta' < 300$  ADJUST VD.

FOR POINT B:  
 $VT = \sqrt{VLT^2 + VTU^2}$

GEOMETRY

PIPE WALL THICKNESS ACTUAL <input checked="" type="checkbox"/> EFFECTIVE <input type="checkbox"/> IN	PIPE DIAMETER ACTUAL MEAN <input type="checkbox"/> ADJUSTED <input checked="" type="checkbox"/> IN	ATTACHMENT DIMENSIONS		SHAPE
		C1 in	C2 in	
1.0 ;	13.25 ;	6.625 ;	6.625 ;	1.0
;	;	;	;	;

ATTACH. NO. 3

SHT. NO. 2 OF 4

PROB. NO. M-8(01)

7> TYPE CALL 816566+PROG.END  
 -> TYPE PLOT ADD 816566+210ORUM.

-> TYPE CALL 816566+PROG.210SUB

ADJUST PAPER, HIT RETURN

Added by: Siva P. Arinjan 1-31-84  
 checked by: [Signature]

ORIGINATOR C.H. Ober...  
 PROJECT DAVY BEEF...  
 UNIT 1

DATE 11/30/84  
 JOB # 12501

CHECKER T. Lin DATE 12/11/84  
 STANDARD COMPUTER PROGRAM ME-210

CALC NUM. PS/PSU-1  
 REV NUM. ...

SHEET -13 OF

VERSION : 5  
 RELEASED : DEC 15, 1982  
 USER MANUAL VERSION : 1  
 THEORETICAL MANUAL VERSION : 1  
 VERIFICATION MANUAL VERSION : 5

B I J L A A R D S T R E S S A N A L Y S I S F O R C Y L I N D E R S

PSU-R1

ATTACH. NO. 3

I N P U T D A T A

SHT. NO. 3 OF 4

PROB. NO. M-8 (01)

	P (LBS)	ML (IN-LBS)	MC (IN-LBS)	MT (IN-LBS)	VL (LBS)	VC (LBS)	MA (FT-LBS)	NB (FT-LBS)
1	2400.	0.	20400.	0.	0.	0.	0.	0.
2	3900.	0.	33150.	0.	0.	0.	0.	0.
3	2400.	0.	20400.	0.	0.	0.	0.	0.

Added by: Siva P. Aringam 1-30-85

	VESTHK (IN)	VESDIA (IN)	C1 (IN)	C2 (IN)	SHAPE	PRESSURE (PSI)	SM (KSI)	BEND R (IN)
1	1.0000	13.2500	6.6250	6.6250	CIRCULAR	.0000	.0000	.0000
2	1.0000	13.2500	6.6250	6.6250	CIRCULAR	.0000	.0000	.0000
3	1.0000	13.2500	6.6250	6.6250	CIRCULAR	.0000	.0000	.0000

ch'd by: T. Lin 1-31-85

MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY

1.0000	-1.18	.63	-1.18	.63	-5.06	3.87	2.71	-2.61
1.0000	-1.91	1.03	-1.91	1.03	-8.21	6.30	4.40	-4.25
1.0000	-1.18	.63	-1.18	.63	-5.06	3.87	2.71	-2.61

ORIGINATOR C.H.O. [Signature]  
 PROJECT DAV. BESE  
UNIT 1

DATE 11/30/84  
 JOB # 12501

CHECKER T. [Signature] DATE 11/1/84  
 STANDARD COMPUTER PROGRAM ME-210

CALC # MM.PS/PSU-1  
 REV NUM 1 SHEET - 14 OF

PROB. NO. M-8(01)  
ATTACH. NO. 3  
 SHT. NO. 4 OF 4

\*\*\*\*\* ME-210 POST-PROCESSOR (VERS. B) 12/8/81 \*\*\*\*\*

DO YOU WANT TO ENTER PRESSURES AND OTHER STRESSES (YES OR NO)? >YES  
 ENTER ACTUAL PIPE O.D. AND WALL (INCHES) O.D.,W? >10.75,1.0  
 ENTER OPERATING AND DESIGN PRESSURE (PSIG) P-OP.,P-DES.? >2750,2500  
 IS ALL DATA O.K. SO FAR (YES OR NO)? >YES  
 ENTER FOLLOWING STRESSES WT, OBE, SSE, THRM, SAM (KSI)? >.825,4.415,8.203,4.546,0.0  
 ENTER SM STRESS ALLOWABLE (KSI)? >16.48  
 IS ALL DATA O.K. (YES OR NO)? >YES  
 PIPE O.D. = 10.75  
 PIPE WALL = 1.000  
 DESIGN PRESSURE = 2500  
 OPERATING PRESSURE = 2750  
 WEIGHT STRESS = .825  
 OBE STRESS = 4.415  
 SSE STRESS = 8.203  
 THERMAL STRESS = 4.546  
 SAM STRESS = 0.000  
 ALLOWABLE STRESS (SM) = 16.480

Added by: Siva P. Arigam 1-30-85  
 ch'kd by: [Signature] 1-30-85

CHECK	VALUE	ALLOWABLE
1A	14.03	24.720
1B	14.40	49.440
2A	12.97	24.720
2B	17.39	49.440
3A	5.06 + 14.78 = <	49.440
3B	5.06 + 17.18 = <	49.440

→ upset primary in circumferential direction  
 → Faulted primary " "  
 → upset primary in longitudinal direction  
 → OK Faulted primary " "

FOR CHECK 3A AND 3B YOU MUST ADD THE MAX PRI + SEC STRESS INTENSITY FROM THE ME-210, RUN FOR LOAD CASE #3 AND MUST STILL BE BELOW THE SPECIFIED ALLOWABLE

Code Case N-411 Alternative Damping Values for Seismic Analysis of Piping  
Section III, Division 1 Class 1, 2, and 3.

Question:

What alternatives to the damping values given in Table N-1230-1, Appendix N,  
Section III Division 1 are acceptable for use in seismic analysis of Class 1, 2  
and 3 piping?

Reply:

It is the opinion of the Committee that for Section III, Division 1, Class 1, 2,  
and 3, construction, the damping value for seismic analysis of piping shown in  
Figure 1 may be used as an alternative to those given in Table N-1230-1,  
Appendix N.

The damping value in Figure 1 is applicable to both OBE and SSE, and is  
independent of pipe diameter.

This Code Case number shall be shown in the documentation for this analysis and  
on the Code Data Report.

PROB. NO. M-8(01)

ATTACH. NO. 4

SHT. NO. 1 OF 2

Added by: Siva P. Lingam date: 1-30-85

ch'kd by: Rajagopalan date: 1-31-85

PROB. NO. M-8 (01)

ATTACH. NO. 4

SHT. NO. 2 OF 2

Added by: Ira P. Kingan 1-30-85

Checked by: [Signature] 1-31-85




Figure 1

Damping Value for Seismic Analysis of Piping  
(Applicable to both OBE & SSE, Independent of Pipe Diameter)




# CALCULATION SHEET

ATTACHMENT # 5

JOB NO. 12501 DAVIS-BESSE, UNIT-1		CALC. NO. M-8		REV. NO. 01	SHEET NO. 1 of 1
PRESSURIZER SURGE LINE					
ORIGINATOR	DATE	CHECKED	DATE		
Siva P. Lingam	1-30-85	[Signature]	1-31-85		

1) ST. VENANT'S PRINCIPLE STATES THAT AT A DISTANCE EQUAL TO OR GREATER THAN THE MEMBER WIDTH (WALL THICKNESS IN THE CASE OF A PIPE) THE MEMBER STRESSES ARE UNAFFECTED BY LOAD APPLICATION OR GEOMETRIC DISCONTINUITY. REFERENCING WELDING RESEARCH COUNCIL (WRC) BULLETIN 198, THE INTERFERENCE DISTANCE TO "ANY OTHER WELD OR DISCONTINUITY" IS DEFINED AS  $\sqrt{2t}$ . SINCE  $\sqrt{2t} = 2.208"$  IS GREATER THAN  $t = 1.0$ , WE EVALUATED THE EFFECT OF ADJACENT DISCONTINUITY OUT TO A DISTANCE OF 2.208"



PLOT OF STRESS INDEX VS. DISTANCE FROM SOURCE  
(REF.: BEER & JOHNSON - "MECHANICS OF MATERIALS", PAGE 79)

AT  $l$ ,  $\frac{\sigma_{max}}{\sigma_{av.}} = 1.027$   
 AT  $\frac{l}{2}$ ,  $\frac{\sigma_{max}}{\sigma_{av.}} = 1.387$   
 AT  $\frac{l}{4}$ ,  $\frac{\sigma_{max}}{\sigma_{av.}} = 2.575$  WHERE  $l =$  MEMBER WIDTH

AS CAN BE SEEN, A LINEAR DISTRIBUTION OF STRESS INDEX AWAY FROM THE POINT OF STRESS CONCENTRATION IS VERY CONSERVATIVE.

2) USE OF CLASS-II FORMULA IN CLASS-I ANALYSIS CAN BE JUSTIFIED BY THE FOLLOWING FORMULA:

$$B, C, K \text{ \& } i = \frac{\sigma}{S} = \frac{\text{Elastic stress}}{\text{nominal stress}}$$

(Ref: D-101 of Appendix-D)