


Figure 2.2-1 Trip Setpoint for Flux -- Δ Flux/Flow

283,340


an approximately 25%

Curve shows trip setpoint for ~~25%~~ flow reduction for three pump operation (290,100 gpm). The actual setpoint will be directly proportional to the actual flow with three pumps.



8502200349 850213
PDR ADOCK 05000346
P PDR

Figure 2.1-2 Reactor Core Safety Limit.



PUMPS OPERATING	REACTOR COOLANT FLOW, GPM
4	380,160 → 387,200
3	283,380 → 290,100

TABLE 3.2-1

DNB MARGIN

Parameter	<u>LIMITS</u>	
	Four Reactor Coolant Pumps Operating	Three Reactor Coolant Pumps Operating
Reactor Coolant Hot Leg Temperature T_H °F	≤ 610	$\leq 610^{(1)}$
Reactor Coolant Pressure, psig. ⁽²⁾	≥ 2062.7	$\geq 2058.7^{(1)}$
Reactor Coolant Flow Rate, gpm ⁽³⁾	$\geq \del{396,000}$ 389,664	$\geq \del{297,340}$ 291,050

(1) Applicable to the loop with 2 Reactor Coolant Pumps Operating.

(2) Limit not applicable during either a THERMAL POWER ramp increase in excess of 5% of RATED THERMAL POWER per minute or a THERMAL POWER step increase of greater than 10% of RATED THERMAL POWER.

(3) These flows include a flow rate uncertainty of 2.5%.

2.1 SAFETY LIMITS

BASES

2.1.1 and 2.1.2 REACTOR CORE

The restrictions of this safety limit prevent overheating of the fuel cladding and possible cladding perforation which would result in the release of fission products to the reactor coolant. Overheating of the fuel cladding is prevented by restricting fuel operation to within the nucleate boiling regime where the heat transfer coefficient is large and the cladding surface temperature is slightly above the coolant saturation temperature.

Operation above the upper boundary of the nucleate boiling regime would result in excessive cladding temperatures because of the onset of departure from nucleate boiling (DNB) and the resultant sharp reduction in heat transfer coefficient. DNB is not a directly measurable parameter during operation and therefore THERMAL POWER and Reactor Coolant Temperature and Pressure have been related to DNB through the S&W-2 DNB correlation. The DNB correlation has been developed to predict the DNB flux and the location of DNB for axially uniform and non-uniform heat flux distributions. The local DNB heat flux ratio, DNBR, defined as the ratio of the heat flux that would cause DNB at a particular core location to the local heat flux, is indicative of the margin to DNB.


The minimum value of the DNBR during steady state operation, normal operational transients, and anticipated transients is limited to 1.30. This value corresponds to a 95 percent probability at a 95 percent confidence level that DNB will not occur and is chosen as an appropriate margin to DNB for all operating conditions.

The curve presented in Figure 2.1-1 represents the conditions at which a minimum DNBR of 1.30 is predicted for the maximum possible thermal power 112% when the reactor coolant flow is 387,160 GPM, which is 108% of design flow rate for four operating reactor coolant pumps. This curve is based on the following hot channel factors with potential fuel densification and fuel rod bowing effects:

$$F_Q = 2.56; \quad F_{AH}^N = 1.71; \quad F_Z^N = 1.50$$

The design limit power peaking factors are the most restrictive calculated at full power for the range from all control rods fully withdrawn to minimum allowable control rod withdrawal, and form the core DNBR design basis.

Basic Figure 2.1 Pressure/Temperature Limits at Maximum Allowable Power for Minimum DNBR



PUMPS	FLOW (GPM)	POWER
4	307,200	1125
3	290,100	80.3%

Handwritten annotations in clouds:

- 380,160 (circled) with an arrow pointing to the '4' pump row.
- 283,980 (circled) with an arrow pointing to the '3' pump row.
- 89.1% (circled) with an arrow pointing to the '80.3%' power value.