

DMP

JAN 30 1985

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Richard P. Crouse
Vice President
Nuclear
Edison Plaza
300 Madison Avenue
Toledo, OH 43652

Gentlemen:

This refers to the routine safety inspection conducted by Mr. T. Ploski and others of this office on January 7-11, 1985, of activities at Davis-Besse Nuclear Power Station, authorized by NRC Operating License No. NPF-3, and to the discussion, which I attended, of our findings with Mr. T. Myers and others of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No items of noncompliance with NRC requirements were identified during the course of this inspection.

However, you are requested to comment in writing, within 30 days of the date of this letter, on those recommendations summarized in the Appendix to this letter and discussed in more detail in Paragraph 2 of the enclosed inspection report. Your comments should include task completion dates where appropriate.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). If we do not hear from you in this regard within the specified periods noted above, a copy of this letter, the enclosures, and your response to this letter will be placed in the Public Document Room.

8502200549 850130
PDR ADOCK 05000346
G PDR

IE01
11

Toledo Edison Company


2

JAN 30 1985

The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,



C. J. Paperiello, Chief
Emergency Preparedness and
Radiological Protection Branch


Enclosures:

1. Appendix - Summary
of Recommendations
2. Inspection Report
No. 50-346/85-02(DRSS)


cc w/encls:

S. Quennoz, Station
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Harold W. Kohn, Ohio EPA
James W. Harris, State of Ohio
Robert H. Quillin, Ohio
Department of Health
D. Matthews, EPB, OIE
W. Weaver, FEMA, RV

RIII


Ploski/lid
01/21/85


RIII


Patterson


RIII


Brown


RIII


Phillips

RIII


Jackiw

RIII


Paperiello
1/30/85

Appendix

RECOMMENDATIONS ON LICENSEE
INITIATIVES FOLLOWING SALP EVALUATIONS

1. Establish a schedule for selecting and training a Lead Emergency Duty Officer (EDO). (Paragraph 2.a)
2. Include, in the 1985 emergency preparedness exercise objective, a demonstration of both a Shift Supervisor and a Shift Technical Advisor functioning as interim - EDO. (Paragraph 2.a.)
3. Develop and implement an action plan for reducing the use of consultants for providing specialized emergency preparedness training. (Paragraph 2.b)
4. Hire one or more qualified instructors to coordinate and administer post-1985 specialized emergency preparedness training. Assign such personnel to Nuclear Training rather than to Nuclear Services. (Paragraph 2.b)
5. Proceduralize the tracking system aspect of the emergency planning staff's scheduling and planning system, including the administrative mechanisms intended to ensure that timely corrective actions are taken on all items being tracked. (Paragraph 2.c)
6. In addition to items identified in NRC inspection reports and the licensee's drill and exercise critiques, the emergency planning staff should also track the implementation of corrective actions being taken on training session recommendations and audit observations. (Paragraph 2.c)
7. Adequate performance of emergency duties should be included in the performance objectives of persons assigned to the emergency response organization. (Paragraph 2.d)
8. Timely completion of all emergency preparedness training for staff personnel should be included in the performance objectives of supervisors of personnel assigned to the emergency response organization. (Paragraph 2.d)