

February 13, 1985
EN 85-11

OFFICE OF INSPECTION AND ENFORCEMENT
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Duke Power Company
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369 and 50-370

Subject: PROPOSED IMPOSITION OF CIVIL PENALTY - \$50,000

This is to inform the Commission that a Notice of Violation and Proposed Imposition of Civil Penalty in the amount of \$50,000 will be issued on or about February 19, 1985 to the Duke Power Company. This action involves the failure of the Upper Head Injection (UHI) accumulator system isolation valves to close at the required UHI accumulator water level.

It should be noted that the licensee has not been specifically informed of the enforcement action. The Regional Administrator has been authorized by the Director, Office of Inspection and Enforcement to sign this action. The schedule of issuance and notification is:

Mailing of Notice	February 19, 1985
Telephone Notification of Licensee	February 19, 1985

A news release has been prepared and will be issued about the time the licensee receives the Notice. The State of North Carolina will be notified.

The licensee has thirty days from the date of the Notice in which to respond. Following NRC evaluation of the response, the civil penalty may be remitted, mitigated, or imposed by Order.

Contact: B. Beach, IE 24766

J. Axelrad, IE 24909

Distribution:

H Street <u>11:10</u>	MNBB <u>11:12</u>	Phillips <u>11:14</u>	EW _____	Willste <u>11:15</u>
Chairman Palladino	EDO	NRR	IE _____	NMSS
Comm. Roberts	DED/ROGR		OIA	RES
Comm. Asselstine	PA		OI	
Comm. Bernthal	ELD		AEOD	
Comm. Zech	RM			
ACRS				
SECY	Air Rights <u>11:16</u>	Regional Offices	MAIL	
CA	SP	RI <u>11:20</u> RIV <u>11:28</u>	ADM: Doc. Mgt. Br.	
PE		RII <u>11:23</u> RV <u>11:30</u>	PDR	
		RIII <u>11:26</u>		

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL FEBRUARY 19, 1985.

8502210015 850213
PDR I&E
EN-85-011 PDR

IE33
0/1