

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. One or more Section D.1 containment isolation valve(s) inoperable.</p>	<p>E.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>E.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours</p> <p>Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days</p>
<p>F. One or more Section D.2 containment isolation valve(s) inoperable.</p>	<p>F.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>F.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours</p> <p>Prior to entering MODE 4 from MODE 5.</p>
<p>G. Required Action and associated Completion Time not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

ATTACHMENT "B"

AMENDMENT NO. 116 APPROVED SPECIFICATIONS
UNIT 3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. One or more Section D.1 containment isolation valve(s) inoperable.</p>	<p>E.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>E.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours</p> <p>Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days</p>
<p>F. One or more Section D.2 containment isolation valve(s) inoperable.</p>	<p>F.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>F.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours</p> <p>Prior to entering MODE 4 from MODE 5.</p>
<p>G. Required Action and associated Completion Time not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

ATTACHMENT "C"
PROPOSED SPECIFICATIONS
Unit 2

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. One or more Section D.1 containment isolation valve(s) inoperable.</p>	<p>E.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>E.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.</p> <p>Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days</p>
<p>F. One or more Section D.2 containment isolation valve(s) inoperable.</p>	<p>F.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>F.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.</p> <p>Prior to entering MODE 4 from MODE 5.</p>
<p>G. Required Action and associated Completion Time not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

ATTACHMENT "D"
PROPOSED SPECIFICATIONS
Unit 3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. One or more Section D.1 containment isolation valve(s) inoperable.</p>	<p>E.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>E.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.</p> <p>Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days</p>
<p>F. One or more Section D.2 containment isolation valve(s) inoperable.</p>	<p>F.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>F.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.</p> <p>Prior to entering MODE 4 from MODE 5.</p>
<p>G. Required Action and associated Completion Time not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>