



**LOUISIANA**  
POWER & LIGHT

142 DELARONDE STREET • P.O. BOX 6008  
NEW ORLEANS, LOUISIANA 70174-6008 • (504) 388-2345

MIDDLE SOUTH  
UTILITIES SYSTEM

February 18, 1985

W3P85-0432  
3-A1.01.04  
3-H1  
A4.05

Director of Nuclear Reactor Regulation  
Attention: Mr. G.W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: Waterford SES Unit 3  
Docket No. 50-382  
Request for Scheduling Exception  
to SPDS, CEPADAS and Regulatory  
Guide 1.47 Implementation

REFERENCES: (1) W3P83-2936 dated September 29, 1983  
(2) W3P84-2565 dated December 26, 1984

Dear Sir:

In Reference (1) LP&L committed to implementing the Safety Parameter Display System (SPDS) and Regulatory Guide 1.47 (Bypassed and Inoperable Status Indication) prior to exceeding five percent power. Through the combination of the Waterford 3 Emergency Plan (Revision 07) and Reference (2), LP&L committed to availability of the SPDS and Computerized Emergency Planning and Data Acquisition System (CEPADAS) in the Emergency Operations Facility (EOF) by February 28, 1985.

SPDS, CEPADAS and Regulatory Guide 1.47 are software implementations on the Plant Monitoring Computer (PMC), a non-safety related system. The PMC employs a redundant computer complex consisting of three central processing units (CPUs) in each complex. LP&L has determined that the third CPU, dedicated to evaluation and analysis, does not incorporate sufficient computing capacity to support the software scheduled for execution. Although no CPU 3 software performs a safety-related function, nor would lack of the software involve an unreviewed safety question or technical specification violation, there remains a need to request relief from the above scheduling commitments on SPDS, CEPADAS and Regulatory Guide 1.47.

To resolve the capacity problem with CPU 3 as well as provide for future computer applications, LP&L has placed an order for a redundant fourth CPU. Delivery is expected in March, 1985, and hardware/software installation and

8502210114 850218  
PDR ADOCK 05000382  
F PDR

*Abol*  
*11*


Mr. G.W. Knighton  
W3P85-0432  
Page 2

testing will be complete by June 30, 1985. In the interim, as detailed in the attached discussion, LP&L requests NRC concurrence that:

1. SPDS display in the control room be limited to Modes 3-6 upon operator demand,
2. SPDS/CEPADAS availability in the TSC/EOF be limited to Modes 3-6 upon demand by control room, TSC or EOF personnel, and
3. Implementation of Regulatory Guide 1.47 requirements be deferred during the interim period.

Should you feel that a discussion would be useful, we request that a meeting be scheduled for the week of February 18, 1985 for the purpose of reaching final resolution. Please feel free to contact me or Mike Meisner (504-595-2832) should you require further information.

Yours very truly,



K.W. Cook  
Nuclear Support & Licensing Manager

KWC/MJM/pcl

Attachment

cc: E.L. Blake, W.M. Stevenson, R.D. Martin, D.M. Crutchfield  
J. Wilson, G.L. Constable

bcc: R.S. Leddick, R.P. Barkhurst, O.D. Hayes, D.E. Dobson, F.J. Drummond,  
T.F. Gerrets, G.G. Hofer (Ebasco), W.A. Cross (LP&L Bethesda Office),  
J.W. Veirs (CE), R.M. Nelson, R.A. Savoie, G.E. Wuller, R.J. Murillo,  
P. Christofakis, P.V. Prasankumar, L.F. Storz, V.D. McAdams,  
D. Kramer, R.G. Azzarello, Project Files, Administrative Support (3),  
Licensing Library

Mr. G.W. Knighton  
W3P85-0432

REQUEST FOR SCHEDULAR EXCEPTION  
TO SPDS, CEPADAS AND REGULATORY  
GUIDE 1.47 IMPLEMENTATION

## I. Introduction

The Waterford 3 Plant Monitoring Computer (PMC), a non-safety related system, employs a redundant computer complex consisting of three central processing units (CPUs) in each complex. LP&L has determined that the third CPU, dedicated to evaluation and analysis, does not incorporate sufficient computing capacity to support the software scheduled for execution. Although no CPU 3 software performs a safety-related function, nor would lack of the software involve an unreviewed safety question or technical specification violation, there remains a need to request relief from certain schedular commitments. Specifically, 5 percent power (and EOF) operability commitments with respect to SPDS and Regulatory Guide 1.47, as well as certain meteorological data collection commitments are affected. The ultimate solution to the computer capacity problem involves the implementation of a fourth CPU for both computer complexes prior to June 30, 1985. The following material will discuss in detail the computer hardware and software involved; the commitments, requirements, technical specifications and safety significance associated with the software; proposed interim solutions; and final resolution and schedule.

## II. Problem Description

### A. Plant Monitoring Computer (PMC)

The PMC is a non-safety related system; for the purpose of design basis accident analysis, all PMC hardware and software is assumed to be unavailable. Additionally, for any control system driven by PMC software, the consequences produced by any credible malfunction would be less severe than any which could be produced by the mechanisms considered as causes of the transients analyzed in FSAR Chapter 15.

The PMC system consists of a dual, three-CPU configuration. In this configuration there are three on-line CPUs and three CPUs off-line for redundancy. The capabilities of the PMC can be divided into major areas corresponding to the three CPUs:

- CPU 1 - interfacing for receiving and sending field input/output
- CPU 2 - alarming, displaying, operator interface (except SPDS/CEPADAS), and data base management
- CPU 3 - performance of nuclear calculations and emergency response software

Further description of the PMC is provided in FSAR Appendix 7.5A.

## B. CPU 3 Capacity

In determining the overall computing capacity necessary for execution of CPU 3 tasks, average usage factors were measured for the individual tasks. These factors, primarily a function of calculation frequency specified for a task, are included in the following table.

<u>CPU 3 Task</u> <sup>1</sup>	<u>Average Usage (%)</u>
NSSS (including COLSS)	50
QSPDS	15
RMS	8
ERF	22-40
SPDS <sup>2</sup>	5
CEPADAS <sup>2</sup>	12
Reg. Guide 1.47 <sup>3</sup>	10
DDC	5
MICDS	0-8
RPC <sup>3</sup>	3
BPMS <sup>3</sup>	5
CECOR Verification File	0-10
UTDV	0-3
Total Minimum Usage	135%

Average usage figures do not take into account the usage peaking due to operator demand or multiple user demand. For that reason total average usage for a CPU should be controlled to a maximum of 75-80%. As will be discussed later, the disparity between CPU 3 capacity and scheduled tasks imposes the necessity for choosing between executing either NSSS software (including COLSS) or emergency response software (ERF, SPDS, CEPADAS), but not both concurrently.

## C. Solution

LP&L has placed an order for the hardware necessary to implement a redundant CPU 4. This will allow CPU 3 tasks to be divided between CPU 3 and CPU 4, providing sufficient computing capacity to execute all scheduled software. The hardware orders were placed in December, 1984 with the expectation of timely delivery, and hardware and software installation, to support the Waterford 3 five percent power schedule. Due to manufacturer schedule slippage, hardware delivery is presently not expected until March 15, 1985. Operability of CPU 4 is now scheduled prior to June 30, 1985.

---

1 Descriptions of each task are included in Section III.

2 Requires ERF software.

3 Estimated average usage.

### III. CPU 3 Software

As previously noted, the software scheduled for CPU 3 is not safety-related, however in some cases regulatory requirements and/or LP&L commitments are affected. In this section, the CPU 3 software is functionally described, regulatory requirements are identified, and the safety significance associated with loss of function is evaluated.

#### A. NSSS

As will be discussed more fully later, LP&L proposes for the interim period prior to CPU 4 operability that NSSS/COLSS software be available during times the PMC is operable in Modes 1 and 2. Following reactor trip the control room personnel will have the option of implementing the emergency response software in preference to NSSS/COLSS. The NSSS software is non-safety related, acting primarily as an operator aid during Modes 1 and 2. Below Mode 2 the NSSS software performs no necessary function either as an operator aid or in support of the Technical Specifications.

The NSSS software incorporates a number of different functions into one package (COLSS is treated separately).

##### 1. CEA Positioning

This module is an operator aid in tracking rod positions, dropped rods, out of sequence groups, regulating group averages, CEA limit checking and alarming, and power dependent and prepower dependent insertion limits.

##### 2. CEA Sequencing

The CEA group sequencing program provides input to the Control Element Drive Mechanism Control System (CEDMCS) in the form of permissive signals. These signals permit sequential insertion and withdrawal of regulating CEA groups by the CEDMCS, with a preprogrammed overlap between consecutive groups during automatic sequential and manual sequential modes of operation.

##### 3. CPC/CEAC Data Acquisition

This program provides data acquisition (a report is available upon operator demand) and cross channel comparisons of input/output data for the CPCs and output data for the CEACs.

##### 4. Fixed In-Core Detectors (FICDs)

This module performs scanning of FICD raw voltage signals from the field and alarming when signals exceed analog to digital converter limits.

5. FICD Correction Calculations

This module processes FICD signals by their sensitivity and background correction factors and calculates neutron flux.

6. FICD Test

This program is used, when COLSS is not scheduled, to calibrate the FICDs.

7. Post Trip Review

The post trip review program provides for a fixed format log of 50 analog data points giving 5 minute pre-trip and 5 minute post-trip reporting at a 2 second resolution.

Regulatory Requirements : Generic Letter 83-28 (Salem ATWS), in Item 1.2, required a description and justification of adequacy of the data and information capability for post-trip review. This included requirements for a sequence of events (SOE) logging capability for digital (on-off) points and a time history for analog variables. The LP&L response (W3P84-0288, dated February 6, 1984) included a detailed description of the Waterford 3 post-trip review information capability including credit for the SOE log (which runs on CPU 2 and is unaffected by the present discussion), the analog post-trip review program, and the SPDS (run on CPU 3). Under the conditions of the proposed interim solution prior to implementation of CPU 4 (discussed later), the post-trip review program will be available until the operator chooses to enable the emergency response software following a reactor trip. SPDS is not necessary to fulfill the post-trip review requirements when the post-trip review program is available.

B. Core Operating Limit Supervisory System (COLSS)

COLSS consists of algorithms to monitor the limiting conditions for operation on: 1) peak linear heat rate, 2) margin to DNB, 3) total core power, and 4) azimuthal tilt. If a limiting condition for operation is exceeded for any of these parameters, the PMC initiates alarms and operator action is taken as required by the Technical Specifications.

Technical Specifications: COLSS is not directly covered by Technical Specifications; however, when COLSS is available Technical Specifications (e.g. 3/4.2 - Power Distribution Limits) allow its use for maintaining margin above the applicable limiting



conditions for operation. Operation without COLSS is acceptable although generally a power penalty results.

Regulatory Requirements : None  
Safety Significance : None - Operation without COLSS presents no safety concern as the safety-related CPCs provide adequate monitoring of the core power distribution. Additionally, the proposed interim solution (discussed later) will include operation of COLSS in Modes 1 and 2.

#### C. QSPDS Data Processing

The QSPDS is a redundant system, separate from the PMC, which processes and displays inadequate core cooling instrumentation and other safety-related input. The QSPDS data processing program in the PMC collects and processes the QSPDS data for use by other PMC software.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - The data from this program is used only as input to other non-safety related software. The proposed interim solution will include operation of this program at all times the PMC is available.

#### D. Radiation Monitoring System (RMS) Processing

The RMS program collects and processes data from the Radiation Monitoring System to be used as input for other PMC programs.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - See Item C, above.

#### E. Emergency Response Facility (ERF)

The ERF software consists of individual functions needed to support the emergency response software (SPDS and CEPADAS). The ERF functions include:

1. Historical data collection - collects data for 2 hour pre-trip and 12 hour post-trip and archives data to tape
2. MMI - Man-Machine Interface needed for SPDS, CEPADAS and historical data
3. CGS - Color Graphics Display needed for SPDS
4. Logs - enables customized logs on demand

Technical Specifications: None  
Regulatory Requirements : See SPDS and CEPADAS, below  
Safety Significance : See SPDS and CEPADAS, below

F. Safety Parameter Display System (SPDS)

"The principal purpose of the SPDS is to aid the control room personnel during abnormal and emergency conditions in determining the safety status of the plant and in assessing whether abnormal conditions warrant corrective action by operators to avoid a degraded core" (NUREG 0737, Supplement 1). A full description of the Waterford 3 SPDS is provided in W3P84-1007, dated April 16, 1984.

Technical Specifications: None

Regulatory Requirements : 1) NUREG 0737, Supplement 1 requires implementation of SPDS on a schedule negotiated with the utility. In response to Supplement 1 (W3P83-2936, dated September 29, 1983) LP&L committed to implement SPDS prior to exceeding 5% power. The SPDS software is presently operational; however, as previously noted, CPU 3 does not have the capacity to run both the emergency response (including SPDS) and NSSS (including COLSS) software concurrently. As will be discussed more fully later, the interim resolution pending CPU 4 operability is to have SPDS available on operator demand following a reactor trip. 2) NUREG 0737, Supplement 1 requires that the TSC and EOF have available those Reg. Guide 1.97 variables essential for performance of their respective functions. In response to this requirement LP&L, in the Emergency Plan (Rev. 07), committed to incorporating the SPDS displays in both the TSC and EOF. Furthermore, in W3P84-2565, dated December 26, 1984 LP&L committed to implementing a fully functional EOF by February 28, 1985. The proposed interim resolution (discussed later) would allow for SPDS display in the TSC and EOF upon operator demand following a reactor trip.

Safety Significance : In accordance with NUREG 0737, Supplement 1, and because of the non-safety related nature of SPDS, control room personnel are trained in assessing plant status both with and without the SPDS. Prior to availability of CPU 4 the operators will have access to the QSPDS - a backup system to the SPDS. The QSPDS, which monitors, processes and displays inadequate core cooling instrumentation (ICCI) information is described in detail in FSAR Appendix 1.9A. In addition to its ICCI function the QSPDS monitors a sufficient subset of the SPDS parameters to provide reliable indication of the status of the five critical safety functions defined in Supplement 1. A listing of those parameters is included in

Attachment 1. Furthermore, CPU 3 will support SPDS in the control room, TSC and EOF during emergency situations (Modes 3-6) when the NSSS/COLSS software is not needed. Based on the foregoing, there is no impact to safety in implementation of the proposed interim resolution.

G. Computerized Emergency Planning and Data Acquisition System (CEPADAS)

CEPADAS uses continuous on-line acquisition (and/or manually inserted data) and processing of radioactive effluent and meteorological monitoring data to provide: 1) radiological effluent reporting, 2) continuous verification and storage of meteorological data, and 3) offsite radiological assessment in the event of an accident.

Technical Specifications: Technical Specification 6.9.1.8 requires submittal of semiannual radioactive effluent release reports, with an annual summary of hour by hour meteorological data on magnetic tape or in the form of joint frequency distributions. CEPADAS, through its processing of meteorological data, was intended to provide the basis for this annual summary. As a backup, meteorological data has been, and will be, collected on strip chart recorders and the graphical data reduced to joint frequency distributions for the semiannual report. LP&L has recently obtained new strip chart recorders for meteorological data to increase data collection reliability. Reporting requirements under the Technical Specification do not begin until initial criticality.

Regulatory Requirements : 1) Regulatory Guide 1.23 specifies that at least the previous 12 hours of 15 minute averages of meteorological data be available in the control room and that the TSC and EOF have access to the data. CEPADAS presently provides this capability. Under the interim proposal CEPADAS will be available in Modes 3-6 upon demand by the control room, TSC or EOF personnel. As a backup, separate software running on CPU 2 will provide, in the control room, the 12 hours of 15 minute averaged meteorological data during any Mode. 2) Regulatory Guide 1.23 specifies that 90% data recovery is required for those meteorological parameters included in the semiannual effluent report. As previously noted, raw data from strip chart recorders will be compiled into joint frequency distributions for the semiannual report, during the interim period when CEPADAS may not be available. 3) In response to FSAR Question 810.009-3 LP&L committed to an operational CEPADAS 45 days prior to

fuel load. The commitment was made to satisfy requirements for monitoring and collecting meteorological data. CEPADAS was tested and run on the PMC for an extended period of time in compliance with this commitment. To the extent that the present situation may be construed as non-compliance with the FSAR commitment, relief is requested as detailed in Section IV.

Safety Significance : None - Under the proposed interim solution, CEPADAS will be available upon demand by the control room, TSC or EOF personnel in Modes 3-6.

#### H. Regulatory Guide 1.47 (Bypassed and Inoperable Status Indication)

The Regulatory Guide 1.47 software is intended to provide automatic indication to the operator of bypassed and inoperable status of safety-related systems in accordance with the Regulatory Guide requirements.

Technical Specifications: None

Regulatory Requirements : Regulatory Guide 1.47 - In W3P83-2936 dated September 29, 1983 LP&L committed to operability of the Reg. Guide 1.47 software and hardware by 5% power.

Safety Significance : None - The Bypassed and Inoperable Status Panel (BISP) is a non-safety related system intended as a backup to administrative procedures. For the interim period prior to CPU 4 availability, the control room personnel will have a diversity of information sources as to the bypassed and inoperable status of safety-related systems. Administrative procedures require, among other things, a status board maintained by the Shift Supervisor (SS), shift turnover status sheets, and SS and control room logs. Should the operator determine that additional status indication is necessary, the BISP may be used in manual mode without computer support.

#### I. Direct Digital Control (DDC)

The DDC software enables PMC control of nine non-safety related temperature/pressure loops within the plant (e.g. main turbine lube oil temperature control).

Technical Specifications: None

Regulatory Requirements : None

Safety Significance : None - All loops are non-safety related and not needed to safely shut down the plant. Panel mounted manual loop control is available in the control room.

J. Moveable In-Core Detectors (MICDS)

The MICDS software controls the positioning of two moveable incore detectors. The system is designed so that either detector can obtain neutron flux data from any position within the core.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - The MICDS is used only to provide confirmatory information on neutron flux data.

K. Reactor Power Cutback (RPC)

The RPC software provides actuation logic to initiate a "step" reduction in reactor power in order to accommodate certain large plant imbalances (e.g. large turbine load rejection) without tripping the reactor. The step reduction in power is accomplished by the simultaneous dropping of one or more preselected groups of full length regulating CEAs into the core.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - with RPC unavailable the reactor will still trip when safety systems determine that a trip is required.

L. Bulk Power Management System (BPMS)

The BPMS program provides pertinent power generation data to Middle South's main control center in Pine Bluff, Arkansas.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - The BPMS provides data off-site for Middle South Utility use only.

M. CECOR Verification File

The CECOR verification file program is used to collect power distribution "snapshots" needed for fuel management and core performance monitoring. It is a program run on demand rather than continuously.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - The CECOR verification file program is run only on an as-needed basis. With NSSS/COLSS software running there is sufficient computing capacity to execute the CECOR verification file as needed.

N. Update Time Dependent Variables (UTDV)

The UTDV program is used following computer restart to update certain time dependent variables according to the length of time the PMC was unavailable.

Technical Specifications: None  
Regulatory Requirements : None  
Safety Significance : None - UTDV will be executed as needed following PMC restart.

IV. Interim Solution

Prior to CPU 4 availability, LP&L proposes an interim solution based operational mode. In summary:

1. Modes 1 and 2: NSSS/COLSS software will be available in CPU 3.
2. Modes 3-6: On operator demand following a reactor trip, the emergency response software will be available in the control room, TSC and EOF.

A. Modes 1 and 2

During Modes 1 and 2 the NSSS/COLSS software will be available in CPU 3. Because COLSS requires a significant amount of CPU 3 computing capacity, ERF/SPDS/CEPADAS software cannot be run. It is important to emphasize, however, that at power operation the need for emergency response software is minimal. The Waterford 3 Operations Group has reviewed this position and concurs that, given the availability of QSPDS, as an interim measure SPDS would be needed only following a reactor trip in emergency situations.

During Modes 1 and 2 the following tasks will execute on CPU 3:

<u>Task</u>	<u>Section III Cross Reference</u>
NSSS	A1-7
COLSS	B
QSPDS	C
RMS	D

B. Modes 3-6

During Modes 3-6 the control room personnel may, on demand, activate SPDS in the control room, TSC and EOF. The process of SPDS activation involves minimal operator involvement. The operator, from the main control room consoles, is only required to insert a value in the PMC database - a process which Waterford 3 operators can perform easily. Upon insertion of the value the ERF/SPDS software will be automatically loaded, initialized and executed, providing the SPDS display in the control room, TSC and EOF within 15 minutes.

This process will be proceduralized for the interim period, and control room personnel will be trained in its use.

Control room personnel, at their option, may also activate CEPADAS although activation does not require control room personnel involvement. CEPADAS may be activated, in Modes 3-6 from either the TSC or EOF, following approved procedures.

Upon operator demand, the following tasks would be executed on CPU 3 during Modes 3-6:

<u>Task</u>	<u>Section III Cross Reference</u>
QSPDS	C
RMS	D
ERF	E
SPDS	F
CEPADAS	G

V. Requested Relief

In implementing the above interim solution LP&L requests relief for the duration of the interim period from the following requirements/commitments.

A. SPDS

LP&L requests a temporary exception to the NUREG 0737 Supplement 1 requirement for continuous control room display of the SPDS. The SPDS will be provided upon operator demand following a plant trip. Additionally, a temporary exception to Waterford 3 Emergency Plan commitments for SPDS availability in the TSC/EOF is requested to the extent that availability is contingent on operator demand following a reactor trip.

B. CEPADAS

LP&L requests a temporary exception to Waterford 3 Emergency Plan commitments for CEPADAS availability in the TSC/EOF to the extent that availability is contingent on operator or TSC/EOF demand. To the extent that the LP&L response to FSAR question 810.009-3 may be construed to require a continuously operable CEPADAS, an exception to this interpretation is requested.

C. Regulatory Guide 1.47

LP&L requests deferral of implementation of the bypassed and inoperable status indication software until CPU 4 is operational.

VI. Schedule for Final Resolution

As previously noted, the redundant CPU 4 is presently scheduled for delivery to the Waterford 3 site on March 15, 1985. Hardware and software installation and testing will be complete by June 30, 1985. LP&L requests NRC concurrence with the proposed solution (Section IV) and exceptions (Section V) for the interim period.



QSPDS

Critical Safety Function

Parameter

---

Reactivity Control

-Neutron Flux  
-Boron Concentration

---

Reactor Core Cooling and RCS Heat Removal

-PZR Pressure  
-PZR Level  
-T-Core Exit  
-Injection Flows  
-Pressure and Temperature  
Saturation Margins  
-Steam Generator Pressure  
-Feedwater Flow  
-Hot and Cold Leg Temperature

---

Radiation Control

-9 Radiation Monitors

---

Containment Conditions

-Containment Pressure  
-Containment Temperature  
-Containment Hydrogen  
Concentration  
-Shutdown Cooling Temperature