


Public Service  
Company of Colorado  
P.O. Box 840  
Denver, CO 80201 - 0840  
(303) 571 - 7511

January 31, 1985  
Fort St. Vrain  
Unit No. 1  
P-85035

Regional Administrator  
Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Attention: Mr. E. H. Johnson



Docket No. 50-267

SUBJECT: Safety Parameter  
Display System

- REFERENCES: 1) PSC Letter, Warembourg  
to Johnson, 11/13/84  
(P-84487)
- 2) NRC Letter, Johnson to  
Lee, 9/14/84 (G-84355)

Dear Mr. Johnson:

In Reference 1 above, we indicated that the following information (quoted from Reference 2) regarding the Safety Parameter Display System Isolators would be provided by 1/31/85:

NRC Request

With regards to isolation devices between the SPDS and safety systems, provide the following information:

- 1.) "Prior to procurement, FSV will conduct an analysis to determine the maximum credible fault (voltage and current) that the isolators will be exposed to during normal operation. The staff advised FSV that the credible fault must be applied to the output of the device in the transverse mode (between signal and return) and other faults should be considered (i.e., open and short circuits)."
- 2.) "The staff requested that the acceptance criteria be identified in their Safety Analysis Report, and the tests results be submitted to the NRC for confirmatory review."

8502210183 650131  
PDR ADOCK 05000267  
F PDR

HOOS.  
RETURN ORIGINAL  
TO RIV

- 3.) "Define the pass/fail acceptance criteria for each type of device."
- 4.) "A description of the measures taken to protect the safety systems from electrical interference (i.e., Electrostatic Coupling, EMI, Common Mode and Crosstalk) that may be generated by the SPDS."

Item 1 is addressed by Attachment 1 to this letter. Items 2 and 3 are addressed by Attachment 2. Item 4 can not be supplied at this time, as we are vendor dependent regarding this information. This information will be supplied as soon as it is available, in any case it should be no later than August, 1985.

If you have any questions regarding this matter, please call Mr. M. H. Holmes at (303) 571-8409.

Very truly yours,

*D. W. Warembourg*  
D. W. Warembourg  
Manager, Nuclear  
Engineering Division

DWW/MEN/ksc

Attachments

Fort St. Vrain Safety Parameter Display System Isolation Device  
Maximum Credible Fault Study

A Maximum Credible Fault Study was conducted to ensure the isolation devices selected for use by the SPDS System would protect associated safety related systems. As we indicated in Reference 1, test configurations and test data will be supplied when available. This is currently scheduled to be no later than August, 1985.

The study analyzed all ports in the isolating devices to ensure all faults were considered.

Isolator Input Faults

The Data Logger Inputs requiring isolation were divided into two categories:

- \* Current Loops - These contain potentials of up to 84 VDC with normal signals of 4 to 20 mA and 10 to 50 mA.
- \* Miscellaneous Circuitry - These contain potentials and outputs up to 20 VDC.

All of these categories are powered from 120 VAC sources. This value was set as a baseline minimum fault potential.

Each category was analyzed for faults (shorts, opens, component value changes) to determine the highest potential that could possibly appear on the output of the circuit and the input of the isolating devices. It was decided to determine both the largest AC and DC potential due to the use of large DC potentials in some circuitry.

The study determined the highest AC potential and current to be 120 VAC 2 amps. The highest DC fault potential was found to be in the current loop category (Ref. Fig. 2). The DC potential and current is 100 VDC 1 amp.

Isolator Cabinet Faults

The maximum fault to be isolated on the output and power ports of the isolating device will be determined by the maximum credible fault available in the isolation cabinet (see Figures 6 & 7). This fault will not be tested in the input side of the isolating device as the required physical separation between IE and non IE sides of the isolating cabinet negates the credibility of this fault appearing on the isolator input.

The data logger input/output cabinets and isolation will be supplied by inverters N-9255 and N-9234 (refer to Fig. 1). These two inverters supply 120 VAC, 109 (RMS) AMPS and 120 VAC, 130 AMPS (RMS) respectively. The worst possible fault would be a direct short on the output of one of the inverters (N-9234) due to its greater current capacity. Actual data on the inverters peak current on fault is unavailable. However, an examination of data from inverters similar to N-9255 and N-9234 shows the output on fault to reach approximately 125% before the current limiting circuit in the inverter begins to control the output (ref. Fig. 3). Cable lengths between the inverters and the equipment are short; therefore, the effect of the cable impedance on the fault current is negligible. Current breakers are in the line but their response time at the current produced will allow the current through to the isolation cabinet (Ref. Fig. 4). A safety switch with Amptrap A13t-2 AMP fuses will be placed in the line to reduce the current available to the isolation cabinet from 162.5 AMPS to 5 AMPS (Ref. Fig. 5).

The maximum credible fault to be tested for at the output and power ports of the isolating device is, therefore, 120 VAC, 5 AMPS (RMS).

The maximum credible faults that are to be tested are:

Input: (1) 120 VAC, 2 AMPS  
(2) 100 VDC, 1 AMP

Output and Power Supply: 120 VAC, 5 AMPS


Isolator Fault Testing Acceptance Criteria


The isolation device will be considered acceptable if the above testing meets the following criteria:

1. Fault on Input (120V, 2A & 100VDC, 1 AMP)
  - a) Associated output does not exceed its normal range.
  - b) No effect on the input and output of the other channels of the device (multichannel devices only)
  - c) No effect on the  $\pm 15$  volt power supply voltage.
2. Fault on Output (120V, 5A)
  - a) Less than 0.5% change in the associated input.
  - b) No effect on the input and output of the other channels of the device (multichannel device only).
  - c) No effect on the  $\pm 15$  volt power supply voltage.
3. Fault on Power Supply (120V, 5A)
  - a) Output on any channel does not exceed its normal range.
  - b) Less than 0.5% change in the input of any channel of the device.

FIG. 1


ISOLATION POWER





TYPICAL CURRENT LOOP

FIG. 2



# STATIC UNINTERRUPTIBLE AC POWER SYSTEMS

SECTION 56.05

Typical Characteristics  
Static Inverters  
14 to 50 KVA single phase  
42.5 to 150 KVA 3 phase

## TYPICAL CHARACTERISTICS

MODEL	INPUT BATTERY VOLTAGE	NOMINAL KVA RATING @ 0.8 P.F.	A-C OUTPUT VOLTAGE	OUTPUT PHASES	A-C OUTPUT AMPERES PHASE @ 0.8 P.F.	CABINET SIZE SEE SEC 56.16	NET WT. LBS.	NO. LOAD D-C AMPS	KVA AT FOLLOWING TEMPERATURES AND P.F.															
									FULL LOAD D-C INPUT AMPS AT MAX KW 0.9 P.F. AND FOLLOWING VOLTS				32° TO 104°F CONVECTION COOLED POWER FACTOR				32° TO 122°F CONVECTION COOLED POWER FACTOR				FORCED AIR COOLING		MIN. RATING KVA	
									Disc. Bat.	Float Volt.	Equal Volt.		0.5 LAG.	0.8 LAG.	0.9 LAG.	1.0	0.5 LAG.	0.8 LAG.	0.9 LAG.	1.0	104°F.	122°F.		
120/14F1	120 Nom. 105-140	14	120V or 120/240V	SINGLE	117 58	(1) W6	1800	14	138	116	108	15	14	13	10	15	14	13	10	110%	110%	15		
120/17F1	120 Nom. 105-140	17	120V or 120/240V		142 71		1800	14	170	141	132	18	17	16	12	16	15	14	10.5	100%	108%	18		
120/21F1	120 Nom. 105-140	21	120V		175		2000	18	202	166	153	22.5	21	19	15	18	17	15	12	110%	110%	23.5		
120/25F1	120 Nom. 105-140	25	120V		208		2500	24	249	203	187	26.5	25	23	18	22.5	21	20	15	110%	110%	31		
120/30F1	120 Nom. 105-140	30	120V or 120/240V		250 125		2900	30	280	234	220	31.5	30	28	21	29	28	26	19.5	110%	110%	37.5		
240/30F1	240 Nom. 210-280	30	120V or 120/240V		250 125		2200	15	140	117	110	31.5	30	28	21	29	28	26	19.5	110%	110%	37.5		
240/50F1	240 Nom. 210-280	50	120V or 120/240V		416 208		(1) W8	4600	25	249	203	187	53	50	46	36	45	42	40	30	106%	106%	62.5	
120/42.5F3	120 Nom. 105-140	42.5	120/208V or 240/416V		117 58		5400	42	414	348	324	45	42.5	39	30	45	42.5	39	30	110%	110%	45		
120/51F3	120 Nom. 105-140	51	120/208V or 240/416V		142 71		5400	42	510	423	396	54	51	48	36	48	45	42	31.5	100%	108%	54		
120/63F3	120 Nom. 105-140	63	120/208V		175		6000	54	606	498	459	67.5	63	57	45	54	51	45	36	110%	110%	70.5		
120/75F3	120 Nom. 105-140	75	120/208V	208	(3) W8	7500	72	747	609	561	79.5	75	69	54	67.5	63	60	45	110%	110%	93			
120/90F3	120 Nom. 105-140	90	120/208V or 240/416V	250 125	8700	90	840	702	660	94.5	90	84	63	87	84	78	58.5	110%	110%	112.5				
240/90F3	240 Nom. 210-280	90	120/208V or 240/416V	250 125	6600	45	420	351	330	94.5	90	84	63	87	84	78	58.5	110%	110%	112.5				
240/100F3	240 Nom. 210-280	100	120/208V or 240/416V	278 139	6750	45	486	388	366	105	100	93	70	96.5	91.5	85	64.5	100%	100%	112.5				
240/150F3	240 Nom. 210-280	150	120/208V or 240/416V	416 208	(3) W8	13 800	75	747	609	561	159	150	138	108	135	126	120	90	106%	106%	187.5			

† Add 15% for shipping weights. ‡ At battery float voltage. § Model 240/100F3 is forced air cooled.  
 ¶ Disc. battery volts 105-120-210. Float volts 129-146-258. Equalize volts 140-158-280. †† Rating is in % of convection cooled ratings at ambient temperatures listed.  
 ††† Values for natural convection cooling 32° to 104°F. power rating. †††† @ 104°F. max. without limit, and any P.F. from 0.5 lagging to unity. ††††† See Automatic Voltage Regulation note below.

### AUTOMATIC SYNCHRONIZING:

Phase of Output Voltage is held within  $\pm 5^\circ$  of sync signal source when the source is between 92 and 138 volts between 58 and 62 Hz.

### AUTOMATIC VOLTAGE REGULATION:

$\pm 1\%$  for any one condition, or  $\pm 2\%$  total regulation for any combination of the following conditions:

- 0-max. continuous rated load, 1.0-0.5 p.f. lagging.\*
- from discharge to equalize battery voltage (see Note above).
- 32-122°F ambient.

DUTY: Continuous

### RANGE OF ADJUSTMENTS:

Voltage  $\pm 4.2\%$   
Frequency  $\pm 2$  Hz

### FREQUENCY STABILITY:

$\pm 6$  Hz, 32-122°F.  
 $\pm 5$  Hz, 50-100°F.

NOTE

### HARMONIC DISTORTION:

5% max. (at nominal freq. & voltage)

### PART LOAD EFFICIENCY, % of F.L. eff.:

1/2 L—90%, 1/4 L—75%

### START-UP PROVISIONS:

Input Circuit Breaker & Pre-charge Switch  
4 second programmed start

### CIRCUIT PROTECTION:

Input - D-C Input CB (per phase)  
Control Circuit - fuses  
Power Semiconductors - current limit fuses (+2 spares)  
Output - Automatic Current Limit (can be disconnected)

### SHORT CIRCUIT OUTPUT CURRENT:

Approx. 125% of unity p.f. F.L. Amperes

### D-C INPUT TRANSIENT TOLERANCE:

4000V for 10 microseconds (40 ohms or greater transient source impedance).

### INSTRUMENTATION:

One a-c voltmeter & One a-c ammeter per phase, 2% accuracy.  
Synchronization verification light

### CONSTRUCTION:

Front and rear access cabinet. Components on vertical pans. Removable with screw driver and wrench. ASA61 Lt. Gray paint.

### CABINET:


Type	DIMENSIONS			CLEARANCES		
	Width	Height	Depth	Front	Overhead	Rear
(1) W6	54"	84"	32 1/2"	27"	24"	27"
(1) W8	64"	84"	48"	36"	30"	36"
(3) W6	162"	84"	32 1/2"	27"	24"	27"
(3) W8	192"	84"	48"	36"	30"	36"

\*Note: Inverter assembled and shipped in three separate W cabinets.

\* Load regulation will be  $\pm 1.5\%$  for inverters marked in A-C Output Voltage Column above, when load is 120V, 2 wire or 120/208V.

FIG. 3







<b>GENERAL ELECTRIC</b> Current Ratings 15, 20 and 30 Amperes TXQL, TXQB & TXQC 15, 20, 30, 40 and 50 Amperes Voltage Ratings 1 and 3 Pole - 120/240 Volts, A-c 2 and 3 Pole - 240 Volts, A-c Frequency Rating 60 Hz	<b>MOLDED-CASE CIRCUIT BREAKER</b> <b>"Q" LINE</b> AMBIENT COMPENSATED Types TQL-AC (2 & 3 Pole), TXQB, TXQ & TXQL (1 & 2 Pole) TQB, THQB, TQC, THQC and THQL-AC (1, 2 & 3 Pole) Long-time Delay and Instantaneous Time-current Curve <small>(Curves show circuit breaker in open air, 10-30°C ambient, wired with conductors of corresponding rating, no prior load. For all other ambient use rating shift index at top of sheet.)</small>	<b>K215-63C</b>  <b>Adjustments</b> Long-time delay thermal trip: not adjustable Instantaneous magnetic trip: not adjustable
	<small>GENERAL ELECTRIC CO., CIRCUIT PROTECTIVE DEVICES DEPT., PLAINVILLE, CONN. 06063</small>	

$$\frac{162.5 \text{ AMPS}}{15 \text{ AMPS}} = 10.83 \text{ MULTIPLES}$$

FIG. 4

# Amp-trap® Form 101

## APPLICATION FORM 101 AMP-TRAP CLEARING I<sup>2</sup>T CORRECTION VS. AVAILABLE CURRENT OR X/R RATIO




1PT - 130 VOLTS OR LESS			
A11X or A11Z	MELTING I <sup>2</sup>	CLEARING I <sup>2</sup> (MSV CIRCUIT)	CLEARING I <sup>2</sup> (120V CIRCUIT)
1	20	18	20
2	24	20	24
3	2.3	2.2	2.3
4	2.9	2.8	2.9
5	3.3	3.2	3.3
6	4.2	4.0	4.2
7	4.8	4.5	4.8
8	5.8	5.4	5.8
10	7.0	6.6	7.0
12	8.4	7.9	8.4
15	10.5	9.9	10.5
20	12.6	11.8	12.6
25	15.8	14.7	15.8
30	18.0	16.6	18.0
35	21.2	19.5	21.2
40	23.4	21.4	23.4
50	29.3	27.2	29.3
60	35.2	33.0	35.2
70	41.1	38.8	41.1
80	47.0	44.6	47.0
90	52.9	50.4	52.9
100	58.8	56.2	58.8
120	70.6	67.0	70.6
150	86.4	81.2	86.4
200	127.2	117.6	127.2

FSV SUPPLY VOLTAGE = 120 VAC or 92% FUSE RATED VOLTAGE  
 FAULT CURRENT = 162.5 AMPS  
 CORRECTION FACTOR = (8/25) (0.34-0.215) + 0.215 = .255  
 $I^2t = 1.5 (0.26) \text{ Amp}^2 \text{ Sec.}$   
 $I^2(.0167) = 1.5 (0.26) \text{ Amp}^2 \text{ Sec.}$   
 $I^2 = \frac{0.39}{.0167} \text{ Amp}^2$   
 $I^2 = 23.35 \text{ Amp}^2$   
 $I = 4.83 \text{ Amp} \approx 5 \text{ Amp}$   
 PEAK LET THROUGH CURRENT = 5 AMP


NOTE: TABLES TAKEN FROM GOULD SCHAWMUT BULLETIN #AT612.

FIG. 5


FAULT ON INPUT



FAULT ON OUTPUT




FAULT ON POWER SUPPLY



ISOLATION TESTING

FIG. 6

### ISOLATION SYSTEM CONFIGURATION



PRELIMINARY CABINET CONFIGURATION  
NOTE: FINAL CONFIGURATION WILL BE  
VENDOR DEPENDENT. FINAL  
CONFIGURATION WILL MEET  
IEEE STD. 384 (1982)

FIG. 7