



Douglas R. Gipson  
Senior Vice President  
Nuclear Generation

Fermi 2  
6400 North Dixie Highway  
Newport, Michigan 48166  
(313) 586-5249

10CFR50.73

April 9, 1996  
NRC-96-0044

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Reference: Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 96-004

Please find enclosed LER 96-004, Revision 0, dated April 9, 1996, for a reportable event regarding operation in a condition prohibited by the Technical Specifications due to high particulate levels found in the Emergency Diesel Generator (EDG) 11 fuel oil. On March 10, 1996 a Notice of Enforcement Discretion was granted for operation for an additional 24 hours beyond the 72 hour Limiting Condition of Operation specified by Technical Specifications concerning this event.

The following commitments are made in this LER:

- A particulate analysis will be performed upon receipt of fuel oil for the EDG's. Procedures will be changed by May 1, 1996. In the interim, night orders are in place for this action.
- The Fuel Oil Storage Tank water drain point will be changed from the pump suction line to the three inch drain line at the bottom of the tank. This action will be completed prior to the next surveillance.


9604170284 960409  
PDR ADOCK 05000341  
S PDR

IF 22  
11

USNRC  
April 9, 1996  
NRC-96-0044  
Page 2

If you have any questions, please contact Mari Jaworsky, Compliance Engineer, at  
(313) 586-1427.

Sincerely,



Enclosure: NRC Forms 366, 366A

cc: T. G. Colburn  
M. J. Jordan  
H. J. Miller  
A. Vogel  
M. V. Yudasz, Jr.  
Region III  
Wayne County Emergency Management Division