

 Teledyne Isotopes
Midwest Laboratory

dba Teledyne Brown Engineering
Environmental Services
700 Landwehr Road
Northbrook, IL 60062-2310
(708) 564-0700 Fax (708) 564-4517

FINAL MONTHLY PROGRESS REPORT
TO
TOLEDO EDISON COMPANY
TOLEDO, OHIO


RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (REMP)
FOR
DAVIS-BESSE NUCLEAR POWER STATION
OAK HARBOR, OHIO

PREPARED AND SUBMITTED
BY
TELEDYNE ISOTOPES MIDWEST LABORATORY
dba TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES

PROJECT NO. 8003

Reporting Period: January - December, 1995

Reviewed and
Approved by:


J.G. Huebner, M.S.
Manager

Date: 2/16/96

Distribution: J. Lochotzki, Toledo Edison (2 copies and Original Raw Data)

TOLEDO

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
List of Tables		iii
1.0 INTRODUCTION		1
2.0 LISTING OF MISSED SAMPLES		2
3.0 DATA TABULATIONS.....		4

Appendices

A Interlaboratory Comparison Program Results	A-1
B Data Reporting Conventions.....	B-1
C Program Deviations	C-1
D Collection Sheets.....	D-1

TOLEDO

LIST OF TABLES

No.	Title	Page
1	Airborne particulates and iodine collected at Location T-1, analysis for gross beta and iodine-131.....	5
2	Airborne particulates and iodine collected at Location T-2, analysis for gross beta and iodine-131.....	6
3	Airborne particulates and iodine collected at Location T-3, analysis for gross beta and iodine-131.....	7
4	Airborne particulates and iodine collected at Location T-4, analysis for gross beta and iodine-131.....	8
5	Airborne particulates and iodine collected at Location T-7, analysis for gross beta and iodine-131.....	9
6	Airborne particulates and iodine collected at Location T-8, analysis for gross beta and iodine-131.....	10
7	Airborne particulates and iodine collected at Location T-9, analysis for gross beta and iodine-131.....	11
8	Airborne particulates and iodine collected at Location T-11, analysis for gross beta and iodine-131.....	12
9	Airborne particulates and iodine collected at Location T-12, analysis for gross beta and iodine-131.....	13
10	Airborne particulates and iodine collected at Location T-27, analysis for gross beta and iodine-131.....	14
11	Airborne particulate data, gross beta analyses, monthly averages, minima and maxima, 1995.....	15
12	Airborne particulate samples, quarterly composites by location, analyses for strontium-89, strontium-90 and gamma-emitting isotopes, 1995	16
13	Area monitors (TLD), quarterly, 1995.....	20
14	Area monitors (TLD), annual, 1995.....	23
15	Milk samples, analysis for strontium-89, strontium-90, iodine-131 and gamma-emitting isotopes	26
16	Milk samples, analysis for calcium, stable potassium, and ratios of strontium-90 (pCi) per gram of calcium and cesium-137 (pCi) per gram of potassium	29

TOLEDO

LIST OF TABLES (continued)

No.	Title	Page
17	Ground water samples, analyses for gross beta, tritium, strontium-89 and strontium-90 and gamma-emitting isotopes, quarterly collections, 1995.....	31
18	Domestic meat samples, analyses for gamma-emitting isotopes	33
19	Wild meat samples, analyses for gamma-emitting isotopes.....	34
20	Green leafy vegetable samples, analyses for strontium-89, strontium-90, iodine-131 and gamma-emitting isotopes	35
21	Fruit samples, analyses for strontium-89, strontium-90, iodine-131 and gamma-emitting isotopes	37
22	Animal-wildlife feed samples, analyses for gamma-emitting isotopes	38
23	Soil samples, analyses for gamma-emitting isotopes	39
24	Treated surface water samples, monthly composites of weekly grab samples, analysis for gross beta, 1995.....	41
25	Treated surface water samples, quarterly composites of weekly grab samples, analysis for tritium, strontium-89, strontium-90 and gamma-emitting isotopes, 1995.....	47
26	Untreated surface water samples, monthly composites of weekly grab samples, analysis for gross beta, tritium and gamma-emitting isotopes, 1995.....	48
27	Untreated surface water samples, quarterly composites of weekly grab samples, analysis for strontium-89 and strontium-90, 1995.....	54
28	Untreated surface lake water samples, monthly composites of weekly grab samples, analysis for gross beta, tritium and gamma-emitting isotopes, 1995.....	55
29	Fish samples, analyses for gross beta and gamma-emitting isotopes.....	59
30	Shoreline sediment samples, analyses for gamma-emitting isotopes	61
31	Egg samples, analyses for gamma-emitting isotopes	63

TOLEDO

LIST OF TABLES (continued)

The following tables are in the Appendices:

Appendix A

	Attachment A: Acceptance criteria for spiked samples.....	A-2
A-1	Interlaboratory Comparison Program Results	A1-1
A-2	Interlaboratory Comparison Program Results, thermoluminescent dosimeters (TLD's).....	A2-1
A-3	Results of the analyses on in-house spiked samples	A3-1
A-4	Results of the analyses on in-house "blank" samples.....	A4-1

Appendix B

B-1	Data Reporting Conventions.....	B-2
-----	---------------------------------	-----

Appendix C

C-1	Program Deviations.....	C-2
-----	-------------------------	-----

Appendix D

D-1	Collection Sheets.....	D-2
-----	------------------------	-----

TOLEDO

1.0 INTRODUCTION

The following constitutes the final Monthly Progress Report for the Radiological Environmental Monitoring Program conducted at the Davis-Besse Nuclear Power Station in Oak Harbor, Ohio. Results of completed analyses are presented in the attached tables. Missing entries indicate analyses that are not completed. These results will appear in subsequent reports.

Data obtained in the program are well within the ranges previously encountered in the program and to be expected in the environmental media sampled.

None of the media sampled contained radioactivity attributable to the operation of the Davis-Besse Nuclear Power Station.

All activities, except gross beta, are decay corrected to the time of collection.

All samples were collected within the scheduled period unless noted otherwise in the Listing of Missed Samples.

TOLEDO

2.0 LISTING OF MISSED SAMPLES

Sample Type	Location	Expected Collection	Date	Reason
TLD	T-80	1st Qtr.		TLD lost in the field.
TLD	T-92	1st Qtr.		TLD lost in the field.
TLD	T-66	2nd Qtr.		TLD lost in the field.
TLD	T-81	2nd Qtr.		TLD lost in the field.
TLD	T-155	3rd Qtr.		TLD lost in the field.
TLD	T-112	4th Qtr.		TLD lost in the field.
TLD	T-66	Annual		TLD lost in the field.
TLD	T-81	Annual		TLD lost in the field.
TLD	T-112	Annual		TLD lost in the field.
TLD	T-155	Annual		TLD lost in the field.

NOTE: Page 3 is intentionally left out.

3.0 DATA TABULATIONS

TOLEDO

Table 1. Airborne particulates and charcoal canisters.

Analyses: Gross beta and iodine-131

Location: T-1

Units: pCi/m³

Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>					<u>0.010</u>
01-09-95	259	0.031 ± 0.003	07-11-95	323	0.014 ± 0.003
01-16-95	257	0.024 ± 0.003	07-18-95	282	0.023 ± 0.003
01-23-95	263	0.015 ± 0.003	07-25-95	274	0.025 ± 0.003
01-30-95	252	0.024 ± 0.003	08-01-95	278	0.024 ± 0.003
02-06-95	258	0.032 ± 0.004	08-08-95	275	0.016 ± 0.003
02-13-95	261	0.026 ± 0.003	08-15-95	277	0.021 ± 0.003
02-21-95	296	0.022 ± 0.003	08-22-95	282	0.022 ± 0.003
02-28-95	283	0.017 ± 0.003	08-29-95	278	0.017 ± 0.003
03-07-95	296	0.015 ± 0.003	09-05-95	283	0.028 ± 0.003
03-14-95	267	0.022 ± 0.003	09-12-95	276	0.024 ± 0.003
03-21-95	259	0.019 ± 0.003	09-19-95	278	0.018 ± 0.003
03-28-95	258	0.014 ± 0.003	09-26-95	275	0.016 ± 0.003
1st Qtr. mean±s.d.	0.022 ± 0.006		10-03-95	284	0.041 ± 0.004
				3rd Qtr. mean±s.d.	0.022 ± 0.007
04-04-95	257	0.021 ± 0.003			
04-11-95	254	0.023 ± 0.003	10-10-95	276	0.015 ± 0.003
04-18-95	261	0.013 ± 0.003	10-17-95	286	0.037 ± 0.004
04-25-95	261	0.011 ± 0.003	10-24-95	284	0.019 ± 0.003
05-02-95	258	0.013 ± 0.003	10-31-95	270	0.016 ± 0.003
05-09-95	261	0.016 ± 0.003	11-07-95	274	0.029 ± 0.003
05-16-95	261	0.014 ± 0.003	11-14-95	279	0.021 ± 0.003
05-23-95	262	0.015 ± 0.003	11-21-95	274	0.018 ± 0.003
05-30-95	259	0.012 ± 0.003	11-28-95	275	0.025 ± 0.003
06-06-95	271	0.012 ± 0.003	12-05-95	274	0.024 ± 0.003
06-13-95	280	0.013 ± 0.003	12-12-95	279	0.024 ± 0.003
06-20-95	292	0.023 ± 0.003	12-19-95	275	0.033 ± 0.003
06-27-95	285	0.018 ± 0.003	12-26-95	276	0.013 ± 0.003
07-03-95	248	0.016 ± 0.003	01-02-96	276	0.022 ± 0.003
2nd Qtr. mean±s.d.	0.016 ± 0.004			4th Qtr. mean±s.d.	0.023 ± 0.007
				Cumulative Average:	0.021
				Previous Annual Average:	0.019

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 2. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-2
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>			<u>0.010</u>		
01-09-95	285	0.026 ± 0.003	07-11-95	320	0.016 ± 0.003
01-16-95	283	0.024 ± 0.003	07-18-95	278	0.028 ± 0.004
01-23-95	285	0.014 ± 0.002	07-25-95	237	0.024 ± 0.004
01-30-95	281	0.022 ± 0.003	08-01-95	241	0.030 ± 0.004
02-06-95	283	0.027 ± 0.003	08-08-95	235	0.019 ± 0.003
02-13-95	283	0.024 ± 0.003	08-15-95	241	0.024 ± 0.004
02-21-95	323	0.026 ± 0.003	08-22-95	238	0.025 ± 0.003
02-28-95	283	0.019 ± 0.003	08-29-95	236	0.023 ± 0.003
03-07-95	276	0.016 ± 0.003	09-05-95	239	0.032 ± 0.004
03-14-95	283	0.023 ± 0.003	09-12-95	240	0.029 ± 0.004
03-21-95	283	0.021 ± 0.003	09-19-95	239	0.026 ± 0.004
03-28-95	283	0.014 ± 0.003	09-26-95	239	0.017 ± 0.003
1st Qtr. mean±s.d.		<u>0.021 ± 0.004</u>	10-03-95	237	0.045 ± 0.004
			<u>3rd Qtr. mean±s.d.</u>		
04-04-95	283	0.020 ± 0.003	10-10-95	241	0.014 ± 0.003
04-11-95	280	0.016 ± 0.003	10-17-95	237	0.034 ± 0.004
04-18-95	285	0.014 ± 0.003	10-24-95	242	0.023 ± 0.004
04-25-95	285	0.008 ± 0.002	10-31-95	242	0.018 ± 0.003
05-02-95	280	0.010 ± 0.003	11-07-95	240	0.027 ± 0.003
05-09-95	285	0.014 ± 0.002	11-14-95	244	0.021 ± 0.004
05-16-95	288	0.011 ± 0.003	11-21-95	243	0.025 ± 0.003
05-23-95	284	0.012 ± 0.003	11-28-95	274	0.020 ± 0.003
05-30-95	280	0.012 ± 0.003	12-05-95	290	0.022 ± 0.003
06-06-95	275	0.011 ± 0.003	12-12-95	285	0.023 ± 0.003
06-13-95	278	0.014 ± 0.003	12-19-95	285	0.031 ± 0.003
06-20-95	278	0.024 ± 0.003	12-26-95	285	0.015 ± 0.003
06-27-95	281	0.018 ± 0.003	01-02-96	291	0.020 ± 0.003
2nd Qtr. mean±s.d.		<u>0.014 ± 0.004</u>	<u>4th Qtr. mean±s.d.</u>		
			<u>0.023 ± 0.006</u>		
Cumulative Average: 0.021 Previous Annual Average: 0.020					

^a Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 3. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-3
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>			<u>0.010</u>		
01-09-95	286	0.028 ± 0.003	07-11-95	360	0.019 ± 0.003
01-16-95	281	0.021 ± 0.003	07-18-95	292	0.024 ± 0.003
01-23-95	290	0.012 ± 0.002	07-25-95	304	0.020 ± 0.003
01-30-95	282	0.022 ± 0.003	08-01-95	301	0.024 ± 0.003
02-06-95	284	0.026 ± 0.003	08-08-95	290	0.015 ± 0.003
02-13-95	290	0.025 ± 0.003	08-15-95	292	0.017 ± 0.003
02-21-95	321	0.025 ± 0.003	08-22-95	289	0.021 ± 0.003
02-28-95	281	0.015 ± 0.003	08-29-95	280	0.016 ± 0.003
03-07-95	281	0.014 ± 0.003	09-05-95	280	0.028 ± 0.003
03-14-95	272	0.023 ± 0.003	09-12-95	282	0.021 ± 0.003
03-21-95	275	0.018 ± 0.003	09-19-95	285	0.018 ± 0.003
03-28-95	274	0.013 ± 0.003	09-26-95	283	0.011 ± 0.003
1st Qtr. mean±s.d. <u>0.020 ± 0.005</u>			10-03-95	281	0.037 ± 0.004
			3rd Qtr. mean±s.d. <u>0.021 ± 0.006</u>		
04-04-95	273	0.019 ± 0.003	10-10-95	285	0.014 ± 0.003
04-11-95	291	0.021 ± 0.003	10-17-95	285	0.027 ± 0.003
04-18-95	291	0.012 ± 0.002	10-24-95	284	0.019 ± 0.003
04-25-95	291	0.009 ± 0.002	10-31-95	286	0.014 ± 0.003
05-02-95	288	0.010 ± 0.002	11-07-95	283	0.024 ± 0.003
05-09-95	296	0.010 ± 0.002	11-14-95	287	0.018 ± 0.003
05-16-95	294	0.012 ± 0.003	11-21-95	284	0.017 ± 0.003
05-23-95	290	0.012 ± 0.003	11-28-95	287	0.022 ± 0.003
05-30-95	291	0.013 ± 0.003	12-05-95	286	0.020 ± 0.003
06-06-95	292	0.011 ± 0.003	12-12-95	290	0.025 ± 0.003
06-13-95	291	0.014 ± 0.003	12-19-95	282	0.034 ± 0.003
06-20-95	288	0.020 ± 0.003	12-26-95	282	0.013 ± 0.003
06-27-95	293	0.015 ± 0.003	01-02-96	281	0.022 ± 0.003
2nd Qtr. mean±s.d. <u>0.014 ± 0.004</u>			4th Qtr. mean±s.d. <u>0.021 ± 0.006</u>		
Cumulative Average: <u>0.019</u> Previous Annual Average: <u>0.020</u>					

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 4. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-4
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>			<u>0.010</u>		
01-09-95	293	0.028 ± 0.003	07-11-95	318	0.017 ± 0.003
01-16-95	251	0.024 ± 0.003	07-18-95	97 ^b	0.017 ± 0.007
01-23-95	287	0.012 ± 0.002	07-25-95	236	0.019 ± 0.003
01-30-95	313	0.022 ± 0.003	08-01-95	280	0.021 ± 0.003
02-06-95	280	0.021 ± 0.003	08-08-95	280	0.016 ± 0.003
02-13-95	281	0.021 ± 0.003	08-15-95	280	0.018 ± 0.003
02-21-95	319	0.021 ± 0.003	08-22-95	282	0.021 ± 0.003
02-28-95	277	0.015 ± 0.003	08-29-95	280	0.018 ± 0.003
03-07-95	276	0.014 ± 0.003	09-05-95	280	0.025 ± 0.003
03-14-95	281	0.016 ± 0.003	09-12-95	280	0.019 ± 0.003
03-21-95	279	0.020 ± 0.003	09-19-95	277	0.018 ± 0.003
03-28-95	281	0.012 ± 0.002	09-26-95	280	0.013 ± 0.003
1st Qtr. mean±s.d.	0.019 ± 0.005		10-03-95	277	0.038 ± 0.004
			<u>3rd Qtr. mean±s.d.</u>		
04-04-95	282	0.018 ± 0.003	10-10-95	280	0.012 ± 0.003
04-11-95	296	0.008 ± 0.002	10-17-95	280	0.032 ± 0.003
04-18-95	278	0.011 ± 0.002	10-24-95	35 ^c	< 0.026
04-25-95	279	0.008 ± 0.002	10-31-95	199	0.016 ± 0.004
05-02-95	275	0.010 ± 0.003	11-07-95	275	0.025 ± 0.003
05-09-95	278	0.012 ± 0.002	11-14-95	282	0.018 ± 0.003
05-16-95	282	0.013 ± 0.003	11-21-95	279	0.022 ± 0.003
05-23-95	276	0.013 ± 0.003	11-28-95	280	0.025 ± 0.003
05-30-95	276	0.012 ± 0.003	12-05-95	280	0.024 ± 0.003
06-06-95	279	0.013 ± 0.003	12-12-95	283	0.025 ± 0.003
06-13-95	277	0.013 ± 0.003	12-19-95	281	0.035 ± 0.003
06-20-95	275	0.023 ± 0.003	12-26-95	284	0.016 ± 0.003
06-27-95	276	0.017 ± 0.003	01-02-96	279	0.023 ± 0.003
07-03-95	240	0.015 ± 0.003	2nd Qtr. mean±s.d.	0.013 ± 0.004	4th Qtr. mean±s.d.
					0.023 ± 0.006
			Cumulative Average:		
			Previous Annual Average:		
					0.019
					0.020

^a Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

^b Low volume due to power failure.

^c Low volume due to power failure; Gross beta required LLD not reached due to low volume.

TOLEDO

Table 5. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-7
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m³)	Gross Beta	Date Collected	Volume (m³)	Gross Beta
Required LLD		<u>0.010</u>			<u>0.010</u>
01-09-95	285	0.030 ± 0.003	07-11-95	325	0.016 ± 0.003
01-16-95	277	0.026 ± 0.003	07-18-95	285	0.024 ± 0.003
01-23-95	281	0.014 ± 0.002	07-25-95	283	0.020 ± 0.003
01-30-95	284	0.020 ± 0.003	08-01-95	284	0.024 ± 0.003
02-06-95	284	0.025 ± 0.003	08-08-95	283	0.015 ± 0.003
02-13-95	288	0.023 ± 0.003	08-15-95	285	0.024 ± 0.003
02-21-95	323	0.027 ± 0.003	08-22-95	296	0.024 ± 0.003
02-28-95	281	0.015 ± 0.003	08-29-95	279	0.014 ± 0.003
03-07-95	284	0.015 ± 0.003	09-05-95	298	0.030 ± 0.003
03-14-95	291	0.022 ± 0.003	09-12-95	289	0.023 ± 0.003
03-21-95	280	0.016 ± 0.003	09-19-95	297	0.020 ± 0.003
03-28-95	289	0.012 ± 0.002	09-26-95	293	0.014 ± 0.003
1st Qtr. mean ± s.d.	0.020 ± 0.006		10-03-95	291	0.036 ± 0.004
			3rd Qtr. mean ± s.d.		0.022 ± 0.006
04-04-95	284	0.018 ± 0.003			
04-11-95	284	0.018 ± 0.003	10-10-95	294	0.013 ± 0.003
04-18-95	284	0.011 ± 0.002	10-17-95	296	0.032 ± 0.003
04-25-95	284	0.008 ± 0.002	10-24-95	295	0.021 ± 0.003
05-02-95	288	0.010 ± 0.002	10-31-95	297	0.014 ± 0.003
05-09-95	286	0.013 ± 0.002	11-07-95	294	0.026 ± 0.003
05-16-95	289	0.015 ± 0.003	11-14-95	293	0.016 ± 0.003
05-23-95	278	0.011 ± 0.003	11-21-95	293	0.017 ± 0.003
05-30-95	279	0.012 ± 0.003	11-28-95	294	0.026 ± 0.003
06-06-95	282	0.012 ± 0.003	12-05-95	295	0.018 ± 0.003
06-13-95	293	0.014 ± 0.003	12-12-95	300	0.025 ± 0.003
06-20-95	267	0.024 ± 0.003	12-19-95	289	0.031 ± 0.003
06-27-95	283	0.019 ± 0.003	12-26-95	298	0.015 ± 0.003
07-03-95	243	0.016 ± 0.003	01-02-96	294	0.021 ± 0.003
2nd Qtr. mean ± s.d.	0.014 ± 0.004		4th Qtr. mean ± s.d.		0.021 ± 0.006

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

Cumulative Average: 0.019
Previous Annual Average: 0.020

TOLEDO

Table 6. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-8
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m³)	Gross Beta	Date Collected	Volume (m³)	Gross Beta
<u>Required LLD</u>		<u>0.010</u>			<u>0.010</u>
01-09-95	289	0.025 ± 0.003	07-11-95	316	0.016 ± 0.003
01-16-95	279	0.025 ± 0.003	07-18-95	274	0.015 ± 0.003
01-23-95	283	0.010 ± 0.002	07-25-95	285	0.021 ± 0.003
01-30-95	284	0.021 ± 0.003	08-01-95	285	0.022 ± 0.003
02-06-95	284	0.025 ± 0.003	08-08-95	285	0.016 ± 0.003
02-13-95	284	0.027 ± 0.003	08-15-95	287	0.022 ± 0.003
02-21-95	328	0.024 ± 0.003	08-22-95	284	0.020 ± 0.003
02-28-95	285	0.013 ± 0.003	08-29-95	286	0.016 ± 0.003
03-07-95	283	0.014 ± 0.003	09-05-95	290	0.026 ± 0.003
03-14-95	284	0.023 ± 0.003	09-12-95	197	0.011 ± 0.004
03-21-95	285	0.021 ± 0.003	09-19-95	288	0.019 ± 0.003
03-28-95	287	0.012 ± 0.002	09-26-95	287	0.016 ± 0.003
1st Qtr. mean±s.d.		<u>0.020 ± 0.006</u>	10-03-95	287	<u>0.039 ± 0.004</u>
					<u>3rd Qtr. mean±s.d.</u> <u>0.020 ± 0.007</u>
04-04-95	281	0.017 ± 0.003	10-10-95	288	0.014 ± 0.003
04-11-95	296	0.008 ± 0.002	10-17-95	292	0.033 ± 0.003
04-18-95	285	0.010 ± 0.002	10-24-95	289	0.021 ± 0.003
04-25-95	285	0.011 ± 0.003	10-31-95	285	0.013 ± 0.003
05-02-95	284	0.009 ± 0.002	11-07-95	287	0.028 ± 0.003
05-09-95	285	0.015 ± 0.002	11-14-95	287	0.017 ± 0.003
05-16-95	290	0.013 ± 0.003	11-21-95	291	0.020 ± 0.003
05-23-95	279	0.012 ± 0.003	11-28-95	286	0.025 ± 0.003
05-30-95	285	0.012 ± 0.003	12-05-95	287	0.023 ± 0.003
06-06-95	285	0.014 ± 0.003	12-12-95	288	0.025 ± 0.003
06-13-95	284	0.013 ± 0.003	12-19-95	285	0.033 ± 0.003
06-20-95	284	0.025 ± 0.003	12-26-95	286	0.014 ± 0.003
06-27-95	284	0.019 ± 0.003	01-02-96	287	0.022 ± 0.003
07-03-95	235	0.015 ± 0.003	2nd Qtr. mean±s.d.	<u>0.014 ± 0.004</u>	4th Qtr. mean±s.d. <u>0.022 ± 0.006</u>
					Cumulative Average: 0.019
					Previous Annual Average: 0.021

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 7. Airborne particulates and charcoal canisters.

Analyses: Gross beta and iodine-131

Location: T-9

Units: pCi/m³

Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>			<u>0.010</u>		
01-09-95	284	0.027 ± 0.003	07-11-95	326	0.015 ± 0.003
01-16-95	278	0.028 ± 0.003	07-18-95	286	0.027 ± 0.003
01-23-95	282	0.012 ± 0.002	07-25-95	279	0.021 ± 0.003
01-30-95	314	0.022 ± 0.003	08-01-95	280	0.027 ± 0.003
02-06-95	242	0.026 ± 0.003	08-08-95	279	0.014 ± 0.003
02-13-95	281	0.024 ± 0.003	08-15-95	281	0.021 ± 0.003
02-21-95	309	0.022 ± 0.003	08-22-95	277	0.022 ± 0.003
02-28-95	276	0.016 ± 0.003	08-29-95	280	0.020 ± 0.003
03-07-95	272	0.014 ± 0.003	09-05-95	283	0.031 ± 0.004
03-14-95	282	0.020 ± 0.003	09-12-95	279	0.021 ± 0.003
03-21-95	280	0.019 ± 0.003	09-19-95	283	0.020 ± 0.003
03-28-95	282	0.012 ± 0.002	09-26-95	282	0.018 ± 0.003
1st Qtr. mean±s.d.	0.020 ± 0.005		10-03-95	280	0.043 ± 0.004
				3rd Qtr. mean±s.d.	0.023 ± 0.007
04-04-95	276	0.019 ± 0.003			
04-11-95	298	0.010 ± 0.002	10-10-95	280	0.015 ± 0.003
04-18-95	273	0.012 ± 0.003	10-17-95	280	0.028 ± 0.003
04-25-95	285	0.011 ± 0.003	10-24-95	281	0.019 ± 0.003
05-02-95	284	0.012 ± 0.003	10-31-95	281	0.015 ± 0.003
05-09-95	282	0.016 ± 0.003	11-07-95	280	0.027 ± 0.003
05-16-95	286	0.013 ± 0.003	11-14-95	280	0.019 ± 0.003
05-23-95	280	0.013 ± 0.003	11-21-95	282	0.021 ± 0.003
05-30-95	285	0.012 ± 0.003	11-28-95	280	0.026 ± 0.003
06-06-95	285	0.011 ± 0.003	12-05-95	279	0.026 ± 0.003
06-13-95	287	0.013 ± 0.003	12-12-95	285	0.025 ± 0.003
06-20-95	282	0.023 ± 0.003	12-19-95	280	0.033 ± 0.003
06-27-95	287	0.019 ± 0.003	12-26-95	279	0.015 ± 0.003
07-03-95	246	0.016 ± 0.003	01-02-96	280	0.023 ± 0.003
2nd Qtr. mean±s.d.	0.014 ± 0.004			4th Qtr. mean±s.d.	0.022 ± 0.005
				Cumulative Average:	0.020
				Previous Annual Average:	0.021

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 8. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-11
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>					<u>0.010</u>
01-09-95	292	0.027 ± 0.003	07-11-95	329	0.016 ± 0.003
01-16-95	289	0.020 ± 0.003	07-18-95	288	0.027 ± 0.003
01-23-95	280	0.014 ± 0.002	07-25-95	286	0.021 ± 0.003
01-30-95	283	0.021 ± 0.003	08-01-95	287	0.027 ± 0.003
02-06-95	286	0.026 ± 0.003	08-08-95	288	0.019 ± 0.003
02-13-95	289	0.025 ± 0.003	08-15-95	288	0.025 ± 0.003
02-21-95	325	0.023 ± 0.003	08-22-95	287	0.024 ± 0.003
02-28-95	276	0.014 ± 0.003	08-29-95	287	0.019 ± 0.003
03-07-95	283	0.016 ± 0.003	09-05-95	287	0.028 ± 0.003
03-14-95	285	0.020 ± 0.003	09-12-95	290	0.024 ± 0.003
03-21-95	285	0.019 ± 0.003	09-19-95	294	0.017 ± 0.003
03-28-95	278	0.013 ± 0.003	09-26-95	290	0.019 ± 0.003
1st Qtr. mean±s.d.			10-03-95	290	0.038 ± 0.004
					3rd Qtr. mean±s.d. 0.023 ± 0.006
04-04-95	281	0.018 ± 0.003	10-10-95	291	0.012 ± 0.003
04-11-95	290	0.011 ± 0.002	10-17-95	295	0.029 ± 0.003
04-18-95	287	0.012 ± 0.002	10-24-95	290	0.019 ± 0.003
04-25-95	292	0.009 ± 0.002	10-31-95	292	0.014 ± 0.003
05-02-95	287	0.011 ± 0.003	11-07-95	290	0.025 ± 0.003
05-09-95	291	0.013 ± 0.002	11-14-95	293	0.021 ± 0.003
05-16-95	293	0.014 ± 0.003	11-21-95	290	0.020 ± 0.003
05-23-95	287	0.012 ± 0.003	11-28-95	293	0.027 ± 0.003
05-30-95	277	0.012 ± 0.003	12-05-95	305	0.023 ± 0.003
06-06-95	293	0.012 ± 0.003	12-12-95	315	0.026 ± 0.003
06-13-95	287	0.013 ± 0.003	12-19-95	265	0.032 ± 0.003
06-20-95	284	0.022 ± 0.003	12-26-95	315	0.016 ± 0.003
06-27-95	285	0.019 ± 0.003	01-02-96	290	0.027 ± 0.003
07-03-95	247	0.014 ± 0.003	4th Qtr. mean±s.d. 0.022 ± 0.006		
2nd Qtr. mean±s.d. 0.014 ± 0.003					
					Cumulative Average: 0.020
					Previous Annual Average: 0.021

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 9. Airborne particulates and charcoal canisters.
 Analyses: Gross beta and iodine-131
 Location: T-12
 Units: pCi/m³
 Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta		
<u>Required LLD</u>		<u>0.010</u>					
01-09-95	281	0.029 ± 0.003	07-11-95	276	0.017 ± 0.003		
01-16-95	279	0.025 ± 0.003	07-18-95	247	0.034 ± 0.004		
01-23-95	304	0.011 ± 0.002	07-25-95	291	0.023 ± 0.003		
01-30-95	309	0.014 ± 0.002	08-01-95	288	0.024 ± 0.003		
02-06-95	310	0.024 ± 0.003	08-08-95	288	0.017 ± 0.003		
02-13-95	309	0.025 ± 0.003	08-15-95	288	0.021 ± 0.003		
02-21-95	351	0.027 ± 0.003	08-22-95	287	0.023 ± 0.003		
02-28-95	311	0.014 ± 0.003	08-29-95	296	0.017 ± 0.003		
03-07-95	301	0.011 ± 0.003	09-05-95	289	0.029 ± 0.003		
03-14-95	309	0.020 ± 0.003	09-12-95	284	0.021 ± 0.003		
03-21-95	310	0.019 ± 0.003	09-19-95	293	0.020 ± 0.003		
03-28-95	311	0.008 ± 0.002	09-26-95	287	0.015 ± 0.003		
1st Qtr. mean±s.d.		<u>0.019 ± 0.007</u>	10-03-95	288	0.039 ± 0.004		
					3rd Qtr. mean±s.d. <u>0.023 ± 0.007</u>		
04-04-95	308	0.018 ± 0.003	10-10-95	287	0.015 ± 0.003		
04-11-95	310	0.017 ± 0.003	10-17-95	288	0.028 ± 0.003		
04-18-95	310	0.012 ± 0.002	10-24-95	285	0.017 ± 0.003		
04-25-95	310	0.008 ± 0.002	10-31-95	288	0.017 ± 0.003		
05-02-95	309	0.011 ± 0.002	11-07-95	288	0.046 ± 0.004		
05-09-95	307	0.015 ± 0.002	11-14-95	292	0.017 ± 0.003		
05-16-95	311	0.014 ± 0.003	11-21-95	289	0.015 ± 0.003		
05-23-95	311	0.014 ± 0.003	11-28-95	289	0.027 ± 0.003		
05-30-95	310	0.013 ± 0.003	12-05-95	267	0.026 ± 0.004		
06-06-95	307	0.013 ± 0.003	12-12-95	277	0.027 ± 0.003		
06-13-95	315	0.012 ± 0.002	12-19-95	271	0.034 ± 0.003		
06-20-95	310	0.024 ± 0.003	12-26-95	273	0.017 ± 0.003		
06-27-95	313	0.017 ± 0.003	01-02-96	273	0.021 ± 0.003		
07-03-95	266	0.014 ± 0.003					
2nd Qtr. mean±s.d.		<u>0.014 ± 0.004</u>					
					4th Qtr. mean±s.d. <u>0.024 ± 0.009</u>		
					Cumulative Average: 0.020		
					Previous Annual Average: 0.020		

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 10. Airborne particulates and charcoal canisters.

Analyses: Gross beta and iodine-131

Location: T-27

Units: pCi/m³

Collection: Continuous, weekly exchange.

Date Collected	Volume (m ³)	Gross Beta	Date Collected	Volume (m ³)	Gross Beta
<u>Required LLD</u>			<u>0.010</u>		
01-09-95	281	0.027 ± 0.003	07-11-95	324	0.017 ± 0.003
01-16-95	284	0.023 ± 0.003	07-18-95	284	0.025 ± 0.003
01-23-95	282	0.014 ± 0.003	07-25-95	278	0.021 ± 0.003
01-30-95	283	0.020 ± 0.003	08-01-95	285	0.022 ± 0.003
02-06-95	281	0.025 ± 0.003	08-08-95	277	0.014 ± 0.003
02-13-95	284	0.024 ± 0.003	08-15-95	281	0.020 ± 0.003
02-21-95	319	0.023 ± 0.003	08-22-95	295	0.021 ± 0.003
02-28-95	277	0.015 ± 0.003	08-29-95	286	0.019 ± 0.003
03-07-95	271	0.016 ± 0.003	09-05-95	298	0.027 ± 0.003
03-14-95	285	0.022 ± 0.003	09-12-95	295	0.022 ± 0.003
03-21-95	281	0.019 ± 0.003	09-19-95	299	0.019 ± 0.003
03-28-95	282	0.011 ± 0.002	09-26-95	288	0.014 ± 0.003
1st Qtr. mean±s.d. 0.020 ± 0.005			10-03-95	291	0.037 ± 0.004
			3rd Qtr. mean±s.d. 0.021 ± 0.006		
04-04-95	282	0.016 ± 0.003	10-10-95	293	0.014 ± 0.003
04-11-95	278	0.018 ± 0.003	10-17-95	297	0.032 ± 0.003
04-18-95	285	0.011 ± 0.002	10-24-95	294	0.020 ± 0.003
04-25-95	289	0.012 ± 0.003	10-31-95	301	0.017 ± 0.003
05-02-95	285	0.011 ± 0.003	11-07-95	290	0.027 ± 0.003
05-09-95	286	0.015 ± 0.002	11-14-95	302	0.020 ± 0.003
05-16-95	286	0.012 ± 0.003	11-21-95	291	0.019 ± 0.003
05-23-95	288	0.010 ± 0.003	11-28-95	290	0.025 ± 0.003
05-30-95	283	0.012 ± 0.003	12-05-95	294	0.025 ± 0.003
06-06-95	284	0.012 ± 0.003	12-12-95	296	0.025 ± 0.003
06-13-95	284	0.014 ± 0.003	12-19-95	287	0.034 ± 0.003
06-20-95	279	0.021 ± 0.003	12-26-95	294	0.017 ± 0.003
06-27-95	283	0.017 ± 0.003	01-02-96	286	0.026 ± 0.003
07-03-95	241	0.017 ± 0.003	4th Qtr. mean±s.d. 0.023 ± 0.006		
2nd Qtr. mean±s.d. 0.014 ± 0.003					
					Cumulative Average: 0.020
					Previous Annual Average: 0.020

* Iodine-131 concentrations are <0.07 pCi/m³ unless otherwise noted in Appendix C.

TOLEDO

Table 11. Airborne particulate data, gross beta analyses, monthly averages, minima, and maxima.

January				April			
Location	Average	Minima	Maxima	Location	Average	Minima	Maxima
<u>Control</u>	0.021	0.011	0.029	<u>Control</u>	0.013	0.008	0.019
T-9	0.022	0.012	0.028	T-9	0.013	0.010	0.019
T-11	0.021	0.014	0.027	T-11	0.012	0.009	0.018
T-12	0.020	0.011	0.029	T-12	0.013	0.008	0.018
T-27	0.021	0.014	0.027	T-27	0.014	0.011	0.018
<u>Indicator</u>	0.022	0.010	0.031	<u>Indicator</u>	0.013	0.008	0.023
T-1	0.024	0.015	0.031	T-1	0.016	0.011	0.023
T-2	0.022	0.014	0.026	T-2	0.014	0.008	0.020
T-3	0.021	0.012	0.028	T-3	0.014	0.009	0.021
T-4	0.022	0.012	0.028	T-4	0.011	0.008	0.018
T-7	0.023	0.014	0.030	T-7	0.013	0.008	0.018
T-8	0.020	0.010	0.025	T-8	0.011	0.008	0.017
February				May			
Location	Average	Minima	Maxima	Location	Average	Minima	Maxima
<u>Control</u>	0.022	0.014	0.027	<u>Control</u>	0.013	0.010	0.016
T-9	0.022	0.016	0.026	T-9	0.014	0.012	0.016
T-11	0.022	0.014	0.026	T-11	0.013	0.012	0.014
T-12	0.023	0.014	0.027	T-12	0.014	0.013	0.015
T-27	0.022	0.015	0.025	T-27	0.012	0.010	0.015
<u>Indicator</u>	0.023	0.013	0.032	<u>Indicator</u>	0.013	0.010	0.016
T-1	0.024	0.017	0.032	T-1	0.014	0.012	0.016
T-2	0.024	0.019	0.027	T-2	0.012	0.011	0.014
T-3	0.023	0.015	0.026	T-3	0.012	0.010	0.013
T-4	0.020	0.015	0.021	T-4	0.013	0.012	0.013
T-7	0.023	0.015	0.027	T-7	0.013	0.011	0.015
T-8	0.022	0.013	0.027	T-8	0.013	0.012	0.015
March				June			
Location	Average	Minima	Maxima	Location	Average	Minima	Maxima
<u>Control</u>	0.016	0.008	0.022	<u>Control</u>	0.016	0.011	0.024
T-9	0.016	0.012	0.020	T-9	0.016	0.011	0.023
T-11	0.017	0.013	0.020	T-11	0.016	0.012	0.022
T-12	0.015	0.008	0.020	T-12	0.016	0.012	0.024
T-27	0.017	0.011	0.022	T-27	0.016	0.012	0.021
<u>Indicator</u>	0.017	0.012	0.023	<u>Indicator</u>	0.016	0.011	0.025
T-1	0.018	0.014	0.022	T-1	0.016	0.012	0.023
T-2	0.019	0.014	0.023	T-2	0.016	0.011	0.024
T-3	0.017	0.013	0.023	T-3	0.015	0.011	0.020
T-4	0.016	0.012	0.020	T-4	0.016	0.013	0.023
T-7	0.016	0.012	0.022	T-7	0.017	0.012	0.024
T-8	0.018	0.012	0.023	T-8	0.017	0.013	0.025

NOTE: Unless otherwise specified, samples collected on the first, second, or third day of a month are grouped with data of the previous month.

TOLEDO

Table 11. Airborne particulate data, gross beta analyses, monthly averages, minima, and maxima.

July				October			
Location	Average	Minima	Maxima	Location	Average	Minima	Maxima
<u>Control</u>	0.023	0.015	0.034	<u>Control</u>	0.019	0.012	0.032
T-9	0.023	0.015	0.027	T-9	0.019	0.015	0.028
T-11	0.023	0.016	0.027	T-11	0.019	0.012	0.029
T-12	0.025	0.017	0.034	T-12	0.019	0.015	0.028
T-27	0.021	0.017	0.025	T-27	0.021	0.014	0.032
<u>Indicator</u>	0.021	0.014	0.030	<u>Indicator</u>	0.020	0.012	0.037
T-1	0.022	0.014	0.025	T-1	0.022	0.015	0.037
T-2	0.025	0.016	0.030	T-2	0.022	0.014	0.034
T-3	0.022	0.019	0.024	T-3	0.019	0.014	0.027
T-4	0.019	0.017	0.021	T-4	0.020	0.012	0.032
T-7	0.021	0.016	0.024	T-7	0.020	0.013	0.032
T-8	0.019	0.015	0.022	T-8	0.020	0.013	0.033
August				November			
Location	Average	Minima	Maxima	Location	Average	Minima	Maxima
<u>Control</u>	0.020	0.014	0.025	<u>Control</u>	0.024	0.015	0.046
T-9	0.019	0.014	0.022	T-9	0.023	0.019	0.027
T-11	0.022	0.019	0.025	T-11	0.023	0.020	0.027
T-12	0.020	0.017	0.023	T-12	0.026	0.015	0.046
T-27	0.019	0.014	0.021	T-27	0.023	0.019	0.027
<u>Indicator</u>	0.019	0.014	0.025	<u>Indicator</u>	0.022	0.016	0.029
T-1	0.019	0.016	0.022	T-1	0.023	0.018	0.029
T-2	0.023	0.019	0.025	T-2	0.023	0.020	0.027
T-3	0.017	0.015	0.021	T-3	0.020	0.017	0.024
T-4	0.018	0.016	0.021	T-4	0.023	0.018	0.025
T-7	0.019	0.014	0.024	T-7	0.021	0.016	0.026
T-8	0.019	0.016	0.022	T-8	0.023	0.017	0.028
September				December			
Location	Average	Minima	Maxima	Location	Average	Minima	Maxima
<u>Control</u>	0.025	0.014	0.043	<u>Control</u>	0.025	0.015	0.034
T-9	0.027	0.018	0.043	T-9	0.024	0.015	0.033
T-11	0.025	0.017	0.038	T-11	0.025	0.016	0.032
T-12	0.025	0.015	0.039	T-12	0.025	0.017	0.034
T-27	0.024	0.014	0.037	T-27	0.025	0.017	0.034
<u>Indicator</u>	0.025	0.011	0.045	<u>Indicator</u>	0.023	0.013	0.035
T-1	0.025	0.016	0.041	T-1	0.023	0.013	0.033
T-2	0.030	0.017	0.045	T-2	0.022	0.015	0.031
T-3	0.023	0.011	0.037	T-3	0.023	0.013	0.034
T-4	0.023	0.013	0.038	T-4	0.025	0.016	0.035
T-7	0.025	0.014	0.036	T-7	0.022	0.015	0.031
T-8	0.022	0.011	0.035	T-8	0.023	0.014	0.033

NOTE: Unless otherwise specified, samples collected on the first, second, or third day of a month are grouped with data of the previous month.

TOLEDO

Table 12. Airborne particulates, quarterly composites of all indicator and all control locations, analyses for strontium-89, strontium-90 and gamma-emitting isotopes.

Sample Description and Concentration (pCi/m ³)					
January - March, 1995					
Lab Code	TAP-2439	TAP-2440	TAP-2441	TAP-2442	TAP-2443
Location	T-1	T-2	T-3	T-4	T-7
Volume(m ³)	2439	3431	3417	3418	3447
Sr-89	<0.0005	<0.0004	<0.0005	<0.0005	<0.0004
Sr-90	<0.0003	<0.0003	<0.0004	<0.0004	<0.0003
Be-7	0.079 ± 0.019	0.074 ± 0.015	0.083 ± 0.017	0.078 ± 0.017	0.087 ± 0.017
K-40	< 0.039	< 0.036	< 0.036	< 0.038	< 0.036
Nb-95	< 0.0007	< 0.0004	< 0.0012	< 0.0006	< 0.0010
Zr-95	< 0.0006	< 0.0009	< 0.0017	< 0.0007	< 0.0006
Ru-103	< 0.0004	< 0.0006	< 0.0004	< 0.0007	< 0.0005
Ru-106	< 0.0063	< 0.0024	< 0.0031	< 0.0035	< 0.0036
Cs-134	< 0.0004	< 0.0003	< 0.0009	< 0.0004	< 0.0003
Cs-137	< 0.0009	< 0.0006	< 0.0009	< 0.0004	< 0.0004
Ce-141	< 0.0020	< 0.0014	< 0.0012	< 0.0017	< 0.0020
Ce-144	< 0.0039	< 0.0034	< 0.0048	< 0.0057	< 0.0054
Lab Code	TAP-2444	TAP-2445	TAP-2446	TAP-2447	TAP-2448
Location	T-8	T-9 (C)	T-11 (C)	T-12 (C)	T-27 (C)
Volume(m ³)	3455	3382	3451	3685	3410
Sr-89	<0.0004	<0.0005	<0.0005	<0.0005	<0.0005
Sr-90	<0.0004	<0.0004	<0.0003	<0.0003	<0.0003
Be-7	0.089 ± 0.016	0.090 ± 0.020	0.087 ± 0.017	0.087 ± 0.017	0.097 ± 0.018
K-40	< 0.037	< 0.037	< 0.036	< 0.045	< 0.036
Nb-95	< 0.0008	< 0.0007	< 0.0009	< 0.0003	< 0.0006
Zr-95	< 0.0006	< 0.0014	< 0.0007	< 0.0006	< 0.0016
Ru-103	< 0.0009	< 0.0003	< 0.0009	< 0.0005	< 0.0006
Ru-106	< 0.0058	< 0.0045	< 0.0031	< 0.0055	< 0.0044
Cs-134	< 0.0003	< 0.0009	< 0.0005	< 0.0005	< 0.0008
Cs-137	< 0.0005	< 0.0005	< 0.0006	< 0.0006	< 0.0010
Ce-141	< 0.0020	< 0.0017	< 0.0015	< 0.0016	< 0.0014
Ce-144	< 0.0055	< 0.0027	< 0.0064	< 0.0052	< 0.0027

TOLEDO

Table 12. Airborne particulates, quarterly composites of all indicator and all control locations, analyses for strontium-89, strontium-90 and gamma-emitting isotopes.

Sample Description and Concentration (pCi/m ³)					
April - June, 1995					
Lab Code	TAP-7598	TAP-7599	TAP-7600	TAP-7602	TAP-7603
Location	T-1	T-2	T-3	T-4	T-7
Volume(m ³)	3710	3901	4025	3869	3924
Sr-89	<0.0004	<0.0005	<0.0009	<0.0005	<0.0005
Sr-90	<0.0003	0.0024±0.0004	<0.0006	<0.0003	<0.0003
Be-7	0.099 ± 0.019	0.084 ± 0.014	0.078 ± 0.011	0.071 ± 0.011	0.082 ± 0.014
K-40	< 0.042	< 0.028	< 0.023	< 0.028	< 0.020
Nb-95	< 0.0013	< 0.0006	< 0.0008	< 0.0004	< 0.0007
Zr-95	< 0.0032	< 0.0022	< 0.0019	< 0.0007	< 0.0009
Ru-103	< 0.0006	< 0.0003	< 0.0004	< 0.0004	< 0.0004
Ru-106	< 0.0096	< 0.0039	< 0.0064	< 0.0051	< 0.0060
Cs-134	< 0.0013	< 0.0007	< 0.0006	< 0.0004	< 0.0008
Cs-137	< 0.0008	< 0.0004	< 0.0004	< 0.0006	< 0.0006
Ce-141	< 0.0016	< 0.0006	< 0.0009	< 0.0007	< 0.0010
Ce-144	< 0.0034	< 0.0024	< 0.0025	< 0.0021	< 0.0040
Lab Code	TAP-7604	TAP-7605	TAP-7606	TAP-7607	TAP-7608
Location	T-8	T-9 (C)	T-11 (C)	T-12 (C)	T-27 (C)
Volume(m ³)	3942	3936	3981	4297	3933
Sr-89	<0.0004	<0.0006	<0.0005	<0.0005	<0.0006
Sr-90	<0.0003	<0.0004	<0.0004	<0.0003	<0.0004
Be-7	0.085 ± 0.013	0.082 ± 0.012	0.089 ± 0.019	0.090 ± 0.018	0.086 ± 0.011
K-40	< 0.028	< 0.024	< 0.048	< 0.034	< 0.026
Nb-95	< 0.0009	< 0.0005	< 0.0006	< 0.0010	< 0.0005
Zr-95	< 0.0019	< 0.0014	< 0.0013	< 0.0019	< 0.0022
Ru-103	< 0.0009	< 0.0007	< 0.0004	< 0.0012	< 0.0004
Ru-106	< 0.0050	< 0.0074	< 0.011	< 0.0044	< 0.0031
Cs-134	< 0.0011	< 0.0008	< 0.0006	< 0.0011	< 0.0008
Cs-137	< 0.0011	< 0.0004	< 0.0010	< 0.0011	< 0.0006
Ce-141	< 0.0015	< 0.0010	< 0.0030	< 0.0010	< 0.0007
Ce-144	< 0.0040	< 0.0025	< 0.0064	< 0.0043	< 0.0014

TOLEDO

Table 12. Airborne particulates, quarterly composites of all indicator and all control locations, analyses for strontium-89, strontium-90 and gamma-emitting isotopes.

Sample Description and Concentration (pCi/m ³)					
July - September, 1995					
Lab Code	TAP-10737	TAP-10738	TAP-10739	TAP-10740	TAP-10741
Location	T-1	T-2	T-3	T-4	T-7
Volume(m ³)	3665	3220	3819	3447	3788
Sr-89	<0.0009	<0.0011	<0.0006	<0.0009	<0.0005
Sr-90	<0.0003	<0.0005	<0.0003	<0.0004	<0.0003
Be-7	0.108 ± 0.018	0.103 ± 0.022	0.090 ± 0.023	0.090 ± 0.017	0.109 ± 0.018
K-40	< 0.037	< 0.043	< 0.035	< 0.038	< 0.036
Nb-95	< 0.0012	< 0.0008	< 0.0007	< 0.0005	< 0.0005
Zr-95	< 0.0007	< 0.0009	< 0.0007	< 0.0008	< 0.0007
Ru-103	< 0.0012	< 0.0019	< 0.0021	< 0.0011	< 0.0012
Ru-106	< 0.0047	< 0.0053	< 0.0066	< 0.0068	< 0.0062
Cs-134	< 0.0004	< 0.0005	< 0.0006	< 0.0004	< 0.0004
Cs-137	< 0.0006	< 0.0005	< 0.0003	< 0.0004	< 0.0004
Ce-141	< 0.0023	< 0.0021	< 0.0011	< 0.0014	< 0.0025
Ce-144	< 0.0066	< 0.0065	< 0.0060	< 0.0067	< 0.0024
Lab Code	TAP-10742	TAP-10743	TAP-10744	TAP-10745	TAP-10746
Location	T-8	T-9 (C)	T-11 (C)	T-12 (C)	T-27 (C)
Volume(m ³)	3651	3695	3791	3702	3781
Sr-89	<0.0006	<0.0007	<0.0008	<0.0007	<0.0006
Sr-90	<0.0003	<0.0004	<0.0006	<0.0005	<0.0003
Be-7	0.083 ± 0.019	0.094 ± 0.016	0.097 ± 0.019	0.096 ± 0.019	0.099 ± 0.020
K-40	< 0.036	< 0.036	< 0.035	< 0.041	< 0.035
Nb-95	< 0.0005	< 0.0005	< 0.0014	< 0.0005	< 0.0013
Zr-95	< 0.0017	< 0.0007	< 0.0007	< 0.0012	< 0.0007
Ru-103	< 0.0007	< 0.0012	< 0.0007	< 0.0010	< 0.0010
Ru-106	< 0.0067	< 0.0092	< 0.0027	< 0.0066	< 0.0038
Cs-134	< 0.0004	< 0.0013	< 0.0005	< 0.0004	< 0.0005
Cs-137	< 0.0009	< 0.0009	< 0.0004	< 0.0007	< 0.0006
Ce-141	< 0.0029	< 0.0022	< 0.0026	< 0.0023	< 0.0023
Ce-144	< 0.0067	< 0.0026	< 0.0059	< 0.0070	< 0.0062

TOLEDO

Table 12. Airborne particulates, quarterly composites of all indicator and all control locations, analyses for strontium-89, strontium-90 and gamma-emitting isotopes.

Sample Description and Concentration (pCi/m ³)					
October - December, 1995					
Lab Code	TAP-12993	TAP-12994	TAP-12995	TAP-12996	TAP-12997
Location	T-1	T-2	T-3	T-4	T-7
Volume(m ³)	3598	3399	3702	3317	3832
Sr-89	<0.0007	<0.0007	<0.0003	<0.0004	<0.0004
Sr-90	<0.0004	<0.0003	<0.0003	<0.0004	<0.0005
Be-7	0.073 ± 0.014	0.065 ± 0.013	0.054 ± 0.016	0.059 ± 0.012	0.052 ± 0.011
K-40	<0.030	<0.028	<0.043	<0.026	<0.024
Nb-95	<0.0010	<0.0009	<0.0019	<0.0004	<0.0013
Zr-95	<0.0023	<0.0011	<0.0037	<0.0011	<0.0028
Ru-103	<0.0005	<0.0007	<0.0015	<0.0005	<0.0007
Ru-106	<0.0047	<0.0087	<0.0150	<0.0046	<0.0063
Cs-134	<0.0011	<0.0005	<0.0007	<0.0009	<0.0008
Cs-137	<0.0005	<0.0005	<0.0015	<0.0007	<0.0006
Ce-141	<0.0019	<0.0017	<0.0011	<0.0007	<0.0014
Ce-144	<0.0051	<0.0053	<0.0043	<0.0030	<0.0044
Lab Code	TAP-12998	TAP-12999	TAP-13000	TAP-13001	TAP-13002
Location	T-8	T-9 (C)	T-11 (C)	T-12 (C)	T-27 (C)
Volume(m ³)	3738	3647	3824	3667	3815
Sr-89	<0.0006	<0.0008	<0.0004	<0.0005	<0.0005
Sr-90	<0.0003	<0.0003	<0.0003	<0.0005	<0.0005
Be-7	0.058 ± 0.009	0.076 ± 0.020	0.055 ± 0.010	0.062 ± 0.013	0.057 ± 0.012
K-40	<0.024	<0.040	<0.023	<0.021	<0.021
Nb-95	<0.0011	<0.0010	<0.0005	<0.0013	<0.0012
Zr-95	<0.0017	<0.0028	<0.0016	<0.0021	<0.0010
Ru-103	<0.0008	<0.0011	<0.0007	<0.0007	<0.0007
Ru-106	<0.0042	<0.0094	<0.0058	<0.0028	<0.0048
Cs-134	<0.0006	<0.0009	<0.0008	<0.0006	<0.0007
Cs-137	<0.0004	<0.0012	<0.0006	<0.0012	<0.0003
Ce-141	<0.0017	<0.0021	<0.0007	<0.0013	<0.0011
Ce-144	<0.0050	<0.0068	<0.0038	<0.0032	<0.0027

TOLEDO

Table 13. Area monitors (TLD), quarterly, 1995

Location	mR/91 Days			
	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
<u>Indicator</u>				
T-1	10.5 ± 0.3	10.8 ± 0.2	11.1 ± 0.2	11.4 ± 0.2
T-2	11.1 ± 0.4	10.9 ± 0.2	11.5 ± 0.2	11.3 ± 0.3
T-3	11.1 ± 0.3	10.1 ± 0.2	11.1 ± 0.2	10.6 ± 0.3
T-4	12.5 ± 0.3	12.4 ± 0.2	13.0 ± 0.2	14.0 ± 0.2
T-5	11.3 ± 0.3	11.2 ± 0.2	12.6 ± 0.4	12.3 ± 0.3
T-6	10.3 ± 0.3	8.9 ± 0.3	9.7 ± 0.3	10.0 ± 0.3
T-7	13.5 ± 0.3	11.5 ± 0.2	12.9 ± 0.3	14.0 ± 0.2
T-8	19.5 ± 0.3	17.3 ± 0.2	20.2 ± 0.2	19.5 ± 0.3
T-10	13.4 ± 0.3	12.9 ± 0.4	13.8 ± 0.4	14.4 ± 0.2
T-38	11.2 ± 0.3	9.6 ± 0.2	10.8 ± 0.2	10.2 ± 0.3
T-39	12.2 ± 0.6	11.3 ± 0.3	13.9 ± 0.4	14.1 ± 0.3
T-40	12.1 ± 0.3	11.5 ± 0.2	13.0 ± 0.3	14.0 ± 0.3
T-41	10.7 ± 0.4	10.8 ± 0.2	11.9 ± 0.2	12.3 ± 0.3
T-42	9.7 ± 0.3	8.7 ± 0.2	11.4 ± 0.2	10.7 ± 0.2
T-43	12.6 ± 0.3	12.1 ± 0.3	16.1 ± 0.2	14.5 ± 0.2
T-44	13.5 ± 0.3	13.6 ± 0.3	16.3 ± 0.4	16.6 ± 0.2
T-45	18.4 ± 0.3	14.2 ± 0.3	18.3 ± 0.3	18.7 ± 0.3
T-46	12.3 ± 0.6	10.5 ± 0.2	12.2 ± 0.3	12.3 ± 0.4
T-47	9.6 ± 0.3	7.6 ± 0.3	9.0 ± 0.5	9.6 ± 0.2
T-48	15.0 ± 0.3	12.8 ± 0.3	13.8 ± 0.4	14.1 ± 0.2
T-49	11.6 ± 0.5	9.3 ± 0.3	10.8 ± 0.2	10.5 ± 0.3
T-50	17.8 ± 0.3	14.8 ± 0.2	17.0 ± 0.3	17.6 ± 0.2
T-51	15.2 ± 0.4	14.7 ± 0.5	16.0 ± 0.3	14.2 ± 0.2
T-52	18.9 ± 0.4	15.8 ± 0.2	20.0 ± 0.2	19.8 ± 0.4
T-53	16.5 ± 0.6	13.9 ± 0.3	16.6 ± 0.4	16.5 ± 0.3
T-54	16.6 ± 0.4	14.3 ± 0.3	17.5 ± 0.3	16.7 ± 0.3
T-55	14.3 ± 0.3	11.6 ± 0.3	12.7 ± 0.2	14.0 ± 0.4
Mean ± s.d.	13.4 ± 2.9	12.0 ± 2.3	13.8 ± 3.1	13.8 ± 3.0
<u>Control</u>				
T-9	10.8 ± 0.3	10.8 ± 0.2	11.8 ± 0.2	12.3 ± 0.5
T-11	12.5 ± 0.3	11.6 ± 0.2	11.4 ± 0.2	13.2 ± 0.2
T-12	16.5 ± 0.5	16.0 ± 0.2	19.7 ± 0.2	17.8 ± 0.2
T-23	13.5 ± 0.2	20.4 ± 0.7	15.0 ± 0.2	14.3 ± 0.3
T-24	15.5 ± 0.3	13.9 ± 0.3	16.8 ± 0.2	14.9 ± 0.3
T-27	15.6 ± 1.0	15.3 ± 0.3	16.3 ± 0.2	16.5 ± 0.4
Mean ± s.d.	14.1 ± 2.2	14.7 ± 3.5	15.2 ± 3.2	14.8 ± 2.0

TOLEDO

Table 13. Area monitors (TLD), quarterly, 1995

Location	mR/91 Days			
	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
<u>Indicator</u>				
T-60	9.4 ± 0.2	11.9 ± 0.2	10.9 ± 0.5	10.8 ± 0.3
T-61	10.5 ± 0.1*	10.5 ± 0.1*	10.9 ± 0.3	10.4 ± 0.3
T-62	9.3 ± 0.2	10.1 ± 0.3	11.1 ± 0.3	9.2 ± 0.3
T-65	11.9 ± 0.3	13.1 ± 0.2	14.6 ± 0.4	12.6 ± 0.3
T-66	16.1 ± 0.3	ND ^b	15.7 ± 0.4	15.1 ± 0.4
T-67	16.3 ± 0.3	17.0 ± 0.2	18.8 ± 0.4	15.9 ± 0.2
T-68	12.3 ± 0.4	18.3 ± 0.2	15.7 ± 0.4	13.7 ± 0.3
T-69	15.1 ± 0.2	15.4 ± 0.2	17.7 ± 0.3	14.9 ± 0.4
T-71	13.2 ± 0.2	15.7 ± 0.2	16.7 ± 0.2	16.7 ± 0.3
T-73	11.0 ± 0.2	12.7 ± 0.2	14.1 ± 0.3	11.3 ± 0.3
T-74	9.4 ± 0.2	11.3 ± 0.2	11.5 ± 0.2	11.1 ± 0.4
T-75	12.6 ± 0.3	12.9 ± 0.3	13.9 ± 0.2	12.6 ± 0.3
T-76	8.1 ± 0.3	9.3 ± 0.2	10.0 ± 0.3	8.4 ± 0.2
T-91	12.4 ± 0.2	13.0 ± 0.3	15.4 ± 0.2	12.8 ± 0.3
T-92	ND ^b	10.2 ± 0.3	11.3 ± 0.2	10.3 ± 0.3
T-93	10.2 ± 0.2	10.5 ± 0.2	11.4 ± 0.2	9.2 ± 0.3
T-94	11.7 ± 0.3	13.6 ± 0.2	16.7 ± 0.2	13.6 ± 0.2
T-112	11.5 ± 0.4	12.4 ± 0.3	14.6 ± 0.3	ND ^b
T-121	15.4 ± 0.4	14.9 ± 0.3	15.9 ± 0.3	15.2 ± 0.4
T-122	14.4 ± 0.2	13.2 ± 0.4	15.5 ± 0.4	15.0 ± 0.4
T-123	11.6 ± 0.3	13.5 ± 0.4	14.3 ± 0.3	14.7 ± 0.3
T-125	12.0 ± 0.4	14.3 ± 0.2	15.9 ± 0.3	15.4 ± 0.3
T-126	11.3 ± 0.3	12.7 ± 0.3	14.1 ± 0.2	14.1 ± 0.3
T-127	14.8 ± 0.2	15.1 ± 0.3	16.4 ± 0.7	16.6 ± 0.2
T-128	12.8 ± 0.2	14.3 ± 0.4	17.9 ± 0.3	15.4 ± 0.4
T-150	11.5 ± 0.3	11.7 ± 0.2	11.7 ± 0.2	13.0 ± 0.2
T-151	13.4 ± 0.2	13.6 ± 0.2	15.5 ± 0.4	15.1 ± 0.4
T-153	15.5 ± 0.4	15.9 ± 0.2	18.1 ± 0.4	17.6 ± 0.3
T-154	12.2 ± 0.3	12.8 ± 0.3	14.9 ± 0.3	13.0 ± 0.3
T-201	11.3 ± 0.3	11.2 ± 0.3	12.0 ± 0.3	12.2 ± 0.2
T-202	10.5 ± 0.3	11.6 ± 0.3	12.1 ± 0.2	12.2 ± 0.3
T-203	10.7 ± 0.3	11.7 ± 0.3	12.4 ± 0.3	12.9 ± 0.2
T-204	12.5 ± 0.2	11.9 ± 0.3	12.4 ± 0.3	11.9 ± 0.2
T-205	12.9 ± 0.3	12.0 ± 0.3	12.3 ± 0.3	13.4 ± 0.3
T-206	9.5 ± 0.2	8.5 ± 0.3	9.1 ± 0.3	8.7 ± 0.2
T-207	8.6 ± 0.3	7.4 ± 0.3	9.3 ± 0.4	8.5 ± 0.3
T-208	9.7 ± 0.2	8.9 ± 0.4	9.9 ± 0.3	9.5 ± 0.2
Mean ± s.d.	12.0 ± 2.1	12.6 ± 2.4	13.8 ± 2.7	12.9 ± 2.5

*TLD placed 01-09-95; removed 07-24-95 due to possible interference with eagles nest.

Results are prorated to 91 days.

^b ND - No data; TLD lost in the field.

TOLEDO

Table 13. Area monitors (TLD), quarterly, 1995

Location	mR/91 Days			
	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
<u>Control</u>				
T-95	14.0 ± 0.2	14.9 ± 0.4	17.4 ± 0.2	13.6 ± 0.2
T-100	13.6 ± 0.3	13.6 ± 0.3	15.4 ± 0.3	13.2 ± 0.3
T-111	12.3 ± 0.3	14.8 ± 0.3	17.3 ± 0.3	15.0 ± 0.3
T-124	8.9 ± 0.2	11.5 ± 0.2	12.3 ± 0.2	12.2 ± 0.3
T-155	12.5 ± 0.2	12.8 ± 0.2	ND*	13.1 ± 0.4
Mean ± s.d.	12.3 ± 2.0	13.5 ± 1.4	15.6 ± 2.4	13.4 ± 1.0
<u>QC</u>				
T-80	ND*	8.8 ± 0.2	9.4 ± 0.2	8.5 ± 0.3
T-81	15.3 ± 0.2	ND*	14.0 ± 0.3	13.2 ± 0.2
T-82	8.2 ± 0.3	8.2 ± 0.2	8.6 ± 0.3	7.6 ± 0.2
T-83	9.7 ± 0.2	10.3 ± 0.2	10.5 ± 0.2	9.2 ± 0.2
T-84	11.2 ± 0.3	11.4 ± 0.2	12.1 ± 0.2	10.7 ± 0.3
T-85	12.3 ± 0.2	11.3 ± 0.2	12.5 ± 0.2	10.2 ± 0.2
T-86	15.3 ± 0.2	17.2 ± 0.2	18.2 ± 0.3	15.0 ± 0.5
T-88	16.0 ± 0.3	15.3 ± 0.2	16.8 ± 0.2	15.0 ± 0.3
T-89	15.0 ± 0.4	14.3 ± 0.5	15.8 ± 0.3	14.4 ± 0.3
T-113	12.1 ± 0.3	12.6 ± 0.3	15.1 ± 0.4	12.9 ± 0.3
T-114	9.6 ± 0.3	12.0 ± 0.3	13.1 ± 0.5	12.5 ± 0.3
T-115	12.5 ± 0.2	13.2 ± 0.2	14.2 ± 0.3	13.4 ± 0.3
T-116	16.3 ± 0.3	15.0 ± 0.2	14.9 ± 0.3	14.6 ± 0.4
T-117	12.0 ± 0.2	12.3 ± 0.4	14.1 ± 0.2	13.4 ± 0.3
T-118	15.9 ± 0.3	16.7 ± 0.3	18.6 ± 0.3	16.8 ± 0.3
T-119	11.8 ± 0.3	11.0 ± 0.2	12.5 ± 0.2	12.3 ± 0.2
T-120	13.3 ± 0.2	11.7 ± 0.2	14.1 ± 0.2	13.2 ± 0.3
T-200	11.7 ± 0.3	14.0 ± 0.3	14.1 ± 0.3	12.2 ± 0.2
Mean ± s.d.	12.8 ± 2.5	12.7 ± 2.5	13.8 ± 2.7	12.5 ± 2.4
<u>Shield</u>				
T-87	5.0 ± 0.2	5.3 ± 0.2	4.4 ± 0.2	5.1 ± 0.4

* ND - No data; TLD lost in the field.

TOLEDO

Table 14. Area monitors (TLD), Annual, 1995.

Location	mR/365 Days Annual
<u>Indicator</u>	
T-1	44.9 ± 1.2
T-2	45.0 ± 0.6
T-3	43.4 ± 0.6
T-4	55.2 ± 0.6
T-5	47.2 ± 0.6
T-6	40.0 ± 0.6
T-7	53.5 ± 0.6
T-8	77.1 ± 0.6
T-10	51.4 ± 0.6
T-38	42.7 ± 0.6
T-39	47.6 ± 0.6
T-40	50.0 ± 0.6
T-41	45.3 ± 0.6
T-42	39.4 ± 0.6
T-43	55.1 ± 0.6
T-44	62.2 ± 0.6
T-45	70.6 ± 0.6
T-46	54.2 ± 0.6
T-47	36.6 ± 0.9
T-48	56.3 ± 0.6
T-49	41.2 ± 0.6
T-50	68.6 ± 0.6
T-51	62.0 ± 0.6
T-52	67.7 ± 0.9
T-53	61.6 ± 0.6
T-54	66.5 ± 0.6
T-55	51.3 ± 0.6
Mean ± s.d.	53.2 ± 10.8
<u>Control</u>	
T-9	47.1 ± 0.7
T-11	56.3 ± 0.6
T-12	74.7 ± 0.7
T-23	53.6 ± 0.6
T-24	66.2 ± 0.6
T-27	65.4 ± 0.6
Mean ± s.d.	60.6 ± 10.0

TOLEDO

Table 14. Area monitors (TLD), Annual, 1995.

Location	mR/365 days Annual
Indicator	
T-60	48.0 ± 0.9
T-61	43.9 ± 0.6
T-62	42.7 ± 0.6
T-65	58.8 ± 0.6
T-66	ND*
T-67	73.8 ± 0.6
T-68	61.6 ± 0.6
T-69	70.2 ± 0.6
T-71	63.4 ± 0.6
T-73	55.2 ± 0.6
T-74	47.5 ± 0.6
T-75	58.9 ± 0.6
T-76	45.3 ± 0.8
T-91	64.2 ± 0.7
T-92	44.5 ± 0.7
T-93	52.0 ± 0.6
T-94	67.3 ± 0.6
T-112	ND*
T-121	71.9 ± 0.7
T-122	58.4 ± 0.7
T-123	60.4 ± 0.6
T-125	62.6 ± 0.6
T-126	53.7 ± 0.6
T-127	67.6 ± 0.8
T-128	70.2 ± 0.6
T-150	52.4 ± 0.6
T-151	65.0 ± 0.6
T-153	72.0 ± 0.7
T-154	58.7 ± 0.6
T-201	48.7 ± 0.6
T-202	46.5 ± 0.6
T-203	48.7 ± 0.6
T-204	49.6 ± 0.6
T-205	51.6 ± 0.6
T-206	35.8 ± 0.6
T-207	35.7 ± 0.6
T-208	38.6 ± 0.6
Mean ± s.d.	58.5 ± 9.5

* ND - No data; TLD lost in the field.

TOLEDO

Table 14. Area monitors (TLD), Annual, 1995.

Location	mR/365 days
	Annual
<u>Control</u>	
T-95	71.9 ± 0.8
T-100	66.6 ± 0.7
T-111	69.4 ± 1.2
T-124	52.6 ± 0.8
T-155	ND*
Mean ± s.d.	65.1 ± 8.6
<u>QC</u>	
T-80	39.6 ± 0.6
T-81	ND*
T-82	42.4 ± 0.7
T-83	46.8 ± 0.6
T-84	52.0 ± 0.9
T-85	56.8 ± 0.9
T-86	76.2 ± 0.6
T-88	74.9 ± 0.6
T-89	71.1 ± 0.6
T-113	57.5 ± 0.6
T-114	51.1 ± 0.6
T-115	57.6 ± 0.6
T-116	71.2 ± 0.6
T-117	52.5 ± 0.7
T-118	74.4 ± 0.7
T-119	55.7 ± 1.1
T-120	55.0 ± 0.6
T-200	55.2 ± 0.7
Mean ± s.d.	58.2 ± 11.4
<u>Shield</u>	
T-87	23.0 ± 0.6

* ND - No data; TLD lost in the field.

TOLEDO

Table 15. Milk samples, analysis for strontium-89, strontium-90, iodine-131 and gamma-emitting isotopes.
Collection: Monthly

Collection Date	Lab Code	Sr-89	Sr-90	I-131	Ba-La-140	Cs-137	K-40
-----------------	----------	-------	-------	-------	-----------	--------	------

T-24 (C) Sandusky, 21.0 mi SE of Station

01-31-95	- 0711	<0.5	1.1 ± 0.3	< 0.4	< 10	< 10	1510 ± 120
03-01-95	- 1510	<0.5	1.1 ± 0.3	< 0.4	< 10	< 10	1580 ± 140
03-29-95	- 2085	<0.4	0.8 ± 0.2	< 0.4	< 10	< 10	1460 ± 200
04-27-95	- 3150	<0.6	1.0 ± 0.4	< 0.5	< 10	< 10	1470 ± 90
05-31-95	- 5646	<0.5	1.2 ± 0.3	< 0.2	< 10	< 10	1390 ± 100
06-28-95	- 7113	<0.5	1.2 ± 0.4	< 0.3	< 10	< 10	1370 ± 170
07-26-95	- 8100	<0.5	2.8 ± 0.6	< 0.5	< 10	< 10	1390 ± 160
08-30-95	- 9150	<0.4	1.1 ± 0.3	< 0.3	< 10	< 10	1610 ± 180
09-27-95	- 10030	<0.5	1.4 ± 0.4	< 0.5	< 10	< 10	1420 ± 100
10-30-95	- 11476, 7	<0.8	1.2 ± 0.4	< 0.4	< 10	< 10	1400 ± 90
11-29-95	- 12089	<0.4	1.2 ± 0.4	< 0.5	< 10	< 10	1380 ± 170
12-27-95	- 12811	<0.4	0.7 ± 0.3	<0.3	<10	<10	1440 ± 150

TOLEDO

Table 16. Milk, analysis for stable potassium, stable calcium, and ratios of strontium-90 (pCi) per gram of calcium and cesium-137 (pCi) per gram of potassium.
Collection: Monthly

Collection Date	Lab Code	Calcium (g/L)	Potassium (g/L)	Ratios	
				Sr-90 (pCi/L) per gram Ca	Cs-137 (pCi/L) per gram K
01-31-95	TMI - 0711	1.00	1.75 ± 0.14	1.10	<5.73
03-01-95	- 1510	0.90	1.83 ± 0.16	1.22	<5.47
03-29-95	- 2085	1.04	1.69 ± 0.23	0.77	<5.92
04-27-95	- 3150	0.89	1.70 ± 0.10	1.12	<5.88
05-31-95	- 5646	0.78	1.61 ± 0.12	1.54	<6.22
06-28-95	- 7113	0.83	1.58 ± 0.20	1.45	<6.31
07-26-95	- 8100	0.85	1.61 ± 0.18	3.29	<6.22
08-30-95	- 9150	0.78	1.86 ± 0.21	1.41	<5.37
09-27-95	- 10030	0.87	1.64 ± 0.12	1.61	<6.09
10-30-95	- 10476, 7	0.86	1.62 ± 0.10	0.91	<6.18
11-29-95	- 12089	0.95	1.60 ± 0.20	1.26	<6.27
12-27-95	- 12811	0.93	1.66 ± 0.17	0.75	<6.01

NOTE: Page 28 through 30 are intentionally left out.

TOLEDO

Table 17. Ground water samples, analyses for gross beta, tritium, strontium-89, strontium-90 and gamma-emitting isotopes.
Collection: Quarterly, 1995.

Sample Description and Concentration (pCi/L)				
<u>T-7</u>				
Lab Code	TWW-0275	TWW-3355	TWW-7881	TWW-10934
Collection Period	1st. Qtr.	2nd. Qtr.	3rd. Qtr.	4th. Qtr.
Gross beta	2.9 ± 0.3	3.5 ± 0.3 ^b	3.0 ± 0.6	3.0 ± 0.6
H-3	<330	<330	<330	<330
Sr-89	<0.9	<1.2	<0.7	<1.1
Sr-90	0.8±0.4	<0.6	<0.5	0.8±0.4
Cs-137	<10	<10	<10	<10
<u>T-54</u>				
Lab Code	TWW-0277	TWW-3357	TWW-7883	TWW-10936
Collection Period	1st. Qtr.	2nd. Qtr.	3rd. Qtr.	4th. Qtr.
Gross beta	3.4 ± 2.0 ^a	5.6 ± 2.5 ^b	3.2 ± 0.8	3.9 ± 2.6
H-3	<330	<330	<330	<330
Sr-89	<0.8	<0.7	<0.4	<1.1
Sr-90	<0.7	<0.6	<0.3	0.6±0.4
Cs-137	<10	<10	<10	<10

^a Sample was counted longer for better statistics.

^b Corrected data.

TOLEDO

Table 17. Ground water samples, analyses for gross beta, tritium, strontium-89, strontium-90 and gamma-emitting isotopes (continued).

Sample Description and Concentration (pCi/L)				
<u>T-27 (C)</u>				
Lab Code	TWW-0276	TWW-3356	TWW-7882	TWW-10935
Collection Period	1st. Qtr.	2nd. Qtr.	3rd. Qtr.	4th. Qtr.
Gross beta	8.9 ± 1.5 ^a	4.6 ± 1.2	1.4 ± 1.0	<2.0
H-3	<330	<330	<330	<330
Sr-89	<0.9	<1.2	<1.1	<0.9
Sr-90	<0.6	<0.7	<0.8	<0.4
Cs-137	<10	<10	<10	<10
<u>T-141 (QC)</u>				
Lab Code	TWW-0278	TWW-3358	TWW-7884	TWW-10937
Collection Period	1st. Qtr.	2nd. Qtr.	3rd. Qtr.	4th. Qtr.
Gross beta	<2.1 ^b	4.6 ± 2.6 ^c	3.5 ± 0.8	<3.7
H-3	<330	<330	<330	<330
Sr-89	<0.9	<0.7	<0.4	<1.0
Sr-90	<0.6	<0.4	<0.4	<0.5
Cs-137	<10	<10	<10	<10

^a Sample was reanalyzed; result of reanalysis is 6.0±1.3 pCi/L.

^b Sample was counted longer for better statistics.

^c Corrected data.

TOLEDO

Table 18. Domestic meat samples, analysis for gamma-emitting isotopes.

Collection: Annually

Location	Date Collected	Lab Code	Sample Type	Activity (pCi/g wet)	
				K-40	Cs-137
T-34	10-11-95	TME-10917	Chicken	2.81±0.39	<0.017
T-198	10-11-95	TME-10918	Chicken	2.77±0.36	<0.010

NOTE: Page 34 is intentionally left out.

TOLEDO

Table 20. Green leafy vegetables, analyses for strontium-89, strontium-90, iodine 131 and gamma-emitting isotopes.
Collection: Monthly in season.

Sample Description and Concentration (pCi/g wet)				
Location	T-17	T-19	T-19	T-37
Collection Date	07-19-95	07-19-95	07-19-95	07-19-95
Lab Code	TVE-7877	TVE-7878	TVE-7879	TVE-7880
Type	Kale	Beet Greens	Cabbage	Cabbage
Sr-89	<0.0043	<0.0023	<0.0031	<0.0013
Sr-90	<0.0030	<0.0017	0.0041±0.0015	0.0012±0.0006
I-131	<0.010	<0.010	<0.012	<0.014
K-40	2.95±0.25	5.72±0.41	3.33±0.30	2.16±0.26
Nb-95	<0.007	<0.010	<0.007	<0.008
Zr-95	<0.011	<0.030	<0.014	<0.022
Cs-137	<0.008	<0.013	<0.007	<0.011
Ce-141	<0.012	<0.022	<0.017	<0.009
Ce-144	<0.057	<0.082	<0.081	<0.037
Location	T-17	T-19	T-37	
Collection Date	08-17-95	08-17-95	08-17-95	
Lab Code	TVE-8801	TVE-8802, 3	TVE-8804	
Type	Cabbage	Cabbage	Cabbage	
Sr-89	<0.0015	<0.0019	<0.0009	
Sr-90	0.0008±0.0005	0.0012±0.0005	0.0007±0.0003	
I-131	<0.012	<0.016	<0.021	
K-40	2.97±0.36	2.30±0.19	2.49±0.35	
Nb-95	<0.014	<0.005	<0.005	
Zr-95	<0.012	<0.011	<0.033	
Cs-137	<0.007	<0.011	<0.015	
Ce-141	<0.014	<0.019	<0.019	
Ce-144	<0.12	<0.053	<0.062	
Location	T-17	T-19	T-37	
Collection Date	09-18-95	09-18-95	09-18-95	
Lab Code	TVE-9727	TVE-9728	TVE-9731	
Type	Chinese Cabbage	Broccoli	Cabbage	
Sr-89	<0.0031	<0.0067	<0.0017	
Sr-90	<0.0013	0.0056±0.0025	<0.0009	
I-131	<0.017	<0.012	<0.007	
K-40	2.85±0.26	3.89±0.28	2.03±0.28	
Nb-95	<0.008	<0.009	<0.009	
Zr-95	<0.018	<0.011	<0.018	
Cs-137	<0.008	<0.007	<0.012	
Ce-141	<0.015	<0.007	<0.013	
Ce-144	<0.048	<0.050	<0.072	

TOLEDO

Table 20. Green leafy vegetables, analyses for strontium-89, strontium-90, iodine 131 and gamma-emitting isotopes (continued).

Sample Description and Concentration ($\mu\text{Ci/g}$ wet)			
Location	T-17	T-19	T-37
Collection Date	10-20-95	10-20-95	10-20-95
Lab Code	TVE-11270	TVE-10271	TVE-10272
Type	Cabbage	Cabbage	Cabbage
Sr-89	<0.0049	<0.0050	<0.0043
Sr-90	0.0028±0.0014	0.0033±0.0014	<0.018
I-131	<0.017	<0.013	<0.011
K-40	1.78±0.23	2.74±0.22	1.90±0.22
Nb-95	<0.009	<0.007	<0.007
Zr-95	<0.018	<0.011	<0.013
Cs-137	<0.008	<0.004	<0.006
Ce-141	<0.016	<0.011	<0.018
Ce-144	<0.036	<0.063	<0.041
Location			
Collection Date			
Lab Code			
Type			
Sr-89			
Sr-90			
I-131			
K-40			
Nb-95			
Zr-95			
Cs-137			
Ce-141			
Ce-144			
Location			
Collection Date			
Lab Code			
Type			
Sr-89			
Sr-90			
I-131			
K-40			
Nb-95			
Zr-95			
Cs-137			
Ce-141			
Ce-144			

TOLEDO

Table 21. Fruit samples, analyses for strontium-89, strontium-90, iodine 131 and gamma-emitting isotopes.
Collection: Monthly in season.

Sample Description and Concentration (pCi/g wet)			
Location	T-8	T-25	T-37
Collection Date	09-18-95	09-18-95	09-18-95
Lab Code	TVE-9726	TVE-9729	TVE-9730
Type	Apples	Pears	Apples
Sr-89	<0.0009	<0.0016	<0.0012
Sr-90	0.0005±0.0002	<0.0007	<0.0007
I-131	<0.015	<0.014	<0.011
K-40	1.11±0.21	1.09±0.20	1.20±0.19
Nb-95	<0.008	<0.013	<0.005
Zr-95	<0.014	<0.008	<0.011
Cs-137	<0.009	<0.009	<0.012
Ce-141	<0.017	<0.012	<0.027
Ce-144	<0.046	<0.072	<0.067
Location	T-173		
Collection Date	10-20-95		
Lab Code	TVE-11273		
Type	Grapes		
Sr-89	<0.0065		
Sr-90	0.0036±0.0021		
I-131	<0.021		
K-40	3.04±0.33		
Nb-95	<0.012		
Zr-95	<0.023		
Cs-137	<0.011		
Ce-141	<0.025		
Ce-144	<0.065		
Location			
Collection Date			
Lab Code			
Type			
Sr-89			
Sr-90			
I-131			
K-40			
Nb-95			
Zr-95			
Cs-137			
Ce-141			
Ce-144			

TOLEDO

Table 22. Animal-wildlife feed samples, analyses for gamma-emitting isotopes.
Collection: Semimnually

Sample Description and Concentration (pCi/g wet)				
Location	T-31	T-34	T-197	T-198
Collection Date	10-11-95	10-11-95	10-11-95	10-11-95
Lab Code	TWL-10915	TCF-10913	TCF-10914	TWL-10916
Type	Cattails	Chicken Feed	Chicken Feed	Cattails
Be-7	0.47±0.21	<0.072	<0.062	0.62±0.34
K-40	1.35±0.29	5.34±0.23	4.68±0.30	1.54±0.33
Nb-95	<0.012	<0.010	<0.013	<0.017
Zr-95	<0.027	<0.016	<0.026	<0.051
Ru-103	<0.017	<0.008	<0.007	<0.021
Ru-106	<0.18	<0.059	<0.074	<0.086
Cs-137	<0.021	<0.006	<0.007	<0.024
Ce-141	<0.037	<0.020	<0.022	<0.057
Ce-144	<0.11	<0.045	<0.083	<0.13
Location				
Collection Date				
Lab Code				
Type				
Be-7				
K-40				
Nb-95				
Zr-95				
Ru-103				
Ru-106				
Cs-137				
Ce-141				
Ce-144				

TOLEDO

Table 23. Soil samples, analysis for gamma-emitting isotopes.
Collection: Annually

Sample Description and Concentration (pCi/g dry)					
Location	T-1	T-2	T-3	T-4	T-7
Collection Date	08-08-95	05-19-95	05-19-95	05-12-95	05-19-95
Lab Code	TSO-8583	TSO-5174	TSO-5175	TSO-5176	TSO-5177
Be-7	<0.26	<0.42	<0.58	<0.61	<0.32
K-40	1.56±0.22	9.24±0.74	20.25±1.16	20.61±1.21	9.87±0.60
Nb-95	<0.010	<0.064	<0.11	<0.097	<0.067
Zr-95	<0.014	<0.093	<0.062	<0.13	<0.031
Ru-103	<0.007	<0.054	<0.063	<0.080	<0.025
Ru-106	<0.044	<0.16	<0.36	<0.35	<0.23
Cs-137	0.052±0.013	0.20±0.03	0.073±0.039	0.16±0.06	<0.019
Ce-141	<0.021	<0.18	<0.20	<0.14	<0.057
Ce-144	<0.050	<0.22	<0.29	<0.22	<0.18
Location	T-8	T-9(C)	T-11(C)	T-12(C)	T-27(C)
Collection Date	05-19-95	05-19-95	05-16-95	05-16-95	05-12-95
Lab Code	TSO-5178, 9	TSO-5180	TSO-5181	TSO-5182	TSO-5183
Be-7	<0.57	<0.60	<0.58	<0.63	<0.81
K-40	21.35±0.39	22.41±1.12	19.15±1.17	19.08±1.05	20.55±1.31
Nb-95	<0.056	<0.13	<0.098	<0.14	<0.077
Zr-95	<0.097	<0.077	<0.056	<0.10	<0.13
Ru-103	<0.036	<0.070	<0.036	<0.045	<0.058
Ru-106	<0.29	<0.25	<0.32	<0.37	<0.47
Cs-137	0.83±0.05	0.81±0.06	0.11±0.05	0.37±0.05	0.23±0.07
Ce-141	<0.10	<0.12	<0.14	<0.19	<0.24
Ce-144	<0.23	<0.28	<0.33	<0.24	<0.35
Location					
Collection Date					
Lab Code					
Be-7					
K-40					
Nb-95					
Zr-95					
Ru-103					
Ru-106					
Cs-137					
Ce-141					
Ce-144					

TOLEDO

Table 23. Soil samples, analysis for gamma-emitting isotopes (continued).

Sample Description and Concentration (pCi/g dry)					
Location	T-1	T-2	T-3	T-4	T-7
Collection Date	11-08-95	11-08-95	11-08-95	11-08-95	11-08-95
Lab Code	TSO-12104, 5	TSO-12106	TSO-12107	TSO-12108	TSO-12109
Be-7	0.93±0.36	<0.39	<0.78	<0.95	<0.43
K-40	5.99±0.45	17.34±0.76	18.57±1.38	29.20±1.64	10.36±0.85
Nb-95	<0.043	<0.073	<0.13	<0.21	<0.039
Zr-95	<0.063	<0.084	<0.088	<0.18	<0.085
Ru-103	<0.032	<0.027	<0.094	<0.060	<0.068
Ru-106	<0.18	<0.12	<0.25	<0.43	<0.23
Cs-137	0.51±0.04	0.72±0.05	1.22±0.10	<0.064	<0.028
Ce-141	<0.088	<0.066	<0.15	<0.22	<0.089
Ce-144	<0.11	<0.16	<0.28	<0.44	<0.21
Location	T-8	T-9(C)	T-11(C)	T-12(C)	T-27(C)
Collection Date	11-08-95	11-08-95	11-07-95	11-07-95	11-07-95
Lab Code	TSO-12110	TSO-12111	TSO-12112	TSO-12113	TSO-12114
Be-7	<0.91	0.52±0.30	<0.89	<0.39	<0.84
K-40	26.40±1.68	24.92±0.92	22.77±1.59	21.92±0.85	22.55±1.55
Nb-95	<0.21	<0.034	<0.21	<0.086	<0.14
Zr-95	<0.17	<0.064	<0.15	<0.050	<0.13
Ru-103	<0.072	<0.056	<0.064	<0.037	<0.12
Ru-106	<0.48	<0.15	<0.41	<0.10	<0.46
Cs-137	1.35±0.11	0.87±0.05	0.19±0.08	0.32±0.04	0.28±0.08
Ce-141	<0.26	<0.053	<0.22	<0.12	<0.28
Ce-144	<0.44	<0.23	<0.42	<0.20	<0.45
Location					
Collection Date					
Lab Code					
Be-7					
K-40					
Nb-95					
Zr-95					
Ru-103					
Ru-106					
Cs-137					
Ce-141					
Ce-144					

TOLEDO

Table 24. Treated surface water samples, monthly composites of weekly grab samples, analysis for gross beta, 1995 (continued).

Collection Period	Lab Code	Gross Beta Concentration (pCi/L)
<u>T-12 (C)</u>		
January	TSWT - 0713	1.5 ± 0.5
February	- 1512	1.4 ± 0.5
March	- 2087	1.9 ± 0.4
1st. Qtr. mean±s.d.		1.6 ± 0.3
April	TSWT - 3341	1.7 ± 0.5
May	- 5648	1.7 ± 0.5
June	- 7089	2.1 ± 0.5
2nd. Qtr. mean±s.d.		1.8 ± 0.2
July	TSWT - 8306	1.6 ± 0.5
August	- 9152	1.3 ± 0.4
September	- 10032	1.9 ± 0.4
3rd. Qtr. mean±s.d.		1.6 ± 0.3
October	TSWT - 11479	2.0 ± 0.5
November	- 12091	1.8 ± 0.5
December	- 12813	2.1 ± 0.5
4th. Qtr. mean±s.d.		2.0 ± 0.2

TOLEDO

Table 24. Treated surface water samples, monthly composites of weekly grab samples, analysis for gross beta, 1995 (continued).

Collection Period	Lab Code	Gross Beta Concentration (pCi/L)
T-28		
January	TSWT - 0714	1.7 ± 0.5
February	- 1513	1.5 ± 0.4
March	- 2088	1.6 ± 0.5
1st. Qtr. mean±s.d.		1.6 ± 0.1
April	TSWT - 3342	2.2 ± 0.5
May	- 5649	1.6 ± 0.5
June	- 7090	1.8 ± 0.5
2nd. Qtr. mean±s.d.		1.9 ± 0.3
July	TSWT - 8307	1.6 ± 0.5
August	- 9153	2.2 ± 0.5
September	- 10033, 4	1.8 ± 0.3
3rd. Qtr. mean±s.d.		1.9 ± 0.3
October	TSWT - 11480	1.9 ± 0.5
November	- 12092	2.2 ± 0.5
December	- 12814	2.7 ± 0.5
4th. Qtr. mean±s.d.		2.3 ± 0.4

TOLEDO

Table 24. Treated surface water samples, monthly composites of weekly grab samples, analysis for gross beta, 1995 (continued).

Collection Period	Lab Code	Gross Beta Concentration (pCi/L)
T-50		
January	TSWT - 0715, 6	2.3 ± 0.4
February	- 1514	2.1 ± 0.5
March	- 2089	2.3 ± 0.5
1st. Qtr. mean±s.d.		2.2 ± 0.1
April	TSWT - 3343, 4	2.7 ± 0.4
May	- 5650	2.0 ± 0.5
June	- 7091	2.1 ± 0.5
2nd. Qtr. mean±s.d.		2.3 ± 0.4
July	TSWT - 8308	1.8 ± 0.5
August	- 9154	1.6 ± 0.4
September	- 10035	2.0 ± 0.5
3rd. Qtr. mean±s.d.		1.8 ± 0.2
October	TSWT - 11481	1.9 ± 0.5
November	- 12093	2.1 ± 0.5
December	- 12815	2.4 ± 0.5
4th. Qtr. mean±s.d.		2.1 ± 0.3

NOTE: Page 45 is intentionally left out.

TOLEDO

Table 24. Treated surface water samples, monthly composites of weekly grab samples, analysis for gross beta, 1995 (continued).

Collection Period	Lab Code	Gross Beta Concentration (pCi/L)
<u>T-143 (QC) </u>		
January	NS*	-
February	TSWT - 1515, 6	2.1 ± 0.4
March	- 2090	<u>2.0 ± 0.5</u>
1st. Qtr. mean±s.d.		2.1 ± 0.1
April	TSWT - 3345	2.1 ± 0.5
May	- 5651	2.3 ± 0.6
June	- 7092	<u>1.8 ± 0.6</u>
2nd. Qtr. mean±s.d.		2.1 ± 0.3
July	TSWT - 8309	1.6 ± 0.5
August	- 9155	1.9 ± 0.4
September	- 10036	<u>2.2 ± 0.5</u>
3rd. Qtr. mean±s.d.		1.9 ± 0.3
October	TSWT - 11482	1.9 ± 0.5
November	- 12094	2.1 ± 0.5
December	- 12816	<u>2.1 ± 0.5</u>
4th. Qtr. mean±s.d.		2.0 ± 0.1

* NS = No sample; Sample not received.

TOLEDO

Table 25. Treated surface water samples, quarterly composites of weekly grab samples, analysis for tritium, strontium-89, strontium-90 and gamma-emitting isotopes, 1995.

Collection Period	Lab Code	Concentration (pCi/L)			
		H-3	Sr-89	Sr-90	Cs-137
<u>Control</u>					
<u>T-11(C)</u>					
1st Quarter	TSWT - 2186	<330	< 0.7	0.8 ± 0.4	<10
	- 7820	<330	< 0.9	< 0.4	<10
2nd. Quarter	- 10507	<330	< 0.7	0.6 ± 0.3	<10
3rd. Quarter	- 13041	<330	< 1.1	0.7 ± 0.3	<10
4th. Quarter		<330	< 1.1	0.7 ± 0.1	<10
Annual means±s.d.					
<u>T-12</u>					
1st Quarter	TSWT - 2187	<330	< 0.8	0.8 ± 0.4	<10
	- 7821	<330	< 1.0	< 0.6	<10
2nd. Quarter	- 10508	<330	< 0.7	< 0.5	<10
3rd. Quarter	- 13042	<330	< 0.9	0.5 ± 0.3	<10
4th. Quarter		<330	< 1.0	0.7 ± 0.2	<10
Annual means±s.d.					
<u>Indicator</u>					
<u>T-28</u>					
1st Quarter	TSWT - 2188	<330	< 0.7	< 0.5	<10
	- 7822	<330	< 1.4	< 0.6	<10
2nd. Quarter	- 10509	<330	< 0.8	0.5 ± 0.3	<10
3rd. Quarter	- 13043	<330	< 0.8	< 0.5	<10
4th. Quarter		<330	< 1.4	0.5 ± 0.0	<10
Annual means±s.d.					
<u>T-50</u>					
1st Quarter	TSWT - 2189	<330	< 0.9	0.6 ± 0.3	<10
	- 7823	<330	< 1.3	0.7 ± 0.4	<10
2nd. Quarter	- 10510	<330	< 0.7	1.6 ± 0.4	<10
3rd. Quarter	- 13044	<330	< 0.7	0.7 ± 0.4	<10
4th. Quarter		<330	< 1.3	0.9 ± 0.4	<10
Annual means±s.d.					

TOLEDO

Table 26. Untreated surface water samples, monthly composites of weekly grab, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995.

Collection Period	Lab Code	Concentration (pCi/L)		
		Gross Beta	H-3	Cs-137
<u>T-11 (C)</u>				
January	TSWU - 0721	2.1 ± 0.5	<330	<10
February	- 1519	2.2 ± 0.5	<330	<10
March	- 2093	2.2 ± 0.5	<330	<10
1st. Qtr. mean±s.d.		2.2 ± 0.1	<330	<10
April	TSWU - 3348	2.1 ± 0.5	<330	<10
May	- 5654	2.7 ± 0.5	<330	<10
June	- 7096	2.0 ± 0.5	<330	<10
2nd. Qtr. mean±s.d.		2.3 ± 0.4	<330	<10
July	TSWU - 8313	1.7 ± 0.5	<330	<10
August	- 9158	2.2 ± 0.5	<330	<10
September	- 10040	1.9 ± 0.5	<330	<10
3rd. Qtr. mean±s.d.		1.9 ± 0.3	<330	<10
October	TSWU - 11485	1.9 ± 0.5	<330	<10
November	- 12097	2.4 ± 0.5	<330	<10
December	- 12819	2.7 ± 0.5	<330	<10
4th. Qtr. mean±s.d.		2.3 ± 0.4	<330	<10

TOLEDO

Table 26. Untreated surface water samples, monthly composites of weekly grab, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995 (continued).

Collection Period	Lab Code	Concentration (pCi/L)		
		Gross Beta	H-3	Cs-137
<u>I-12 (C)</u>				
January	TSWU - 0722	2.1 ± 0.5	<330	<10
February	- 1520	2.7 ± 0.5	<330	<10
March	- 2094	3.3 ± 0.5	<330	<10
1st. Qtr. mean±s.d.		2.7 ± 0.6	<330	<10
April	TSWU - 3349	2.6 ± 0.6	<330	<10
May	- 5655	2.5 ± 0.5	<330	<10
June	- 7097	2.6 ± 0.5	<330	<10
2nd. Qtr. mean±s.d.		2.6 ± 0.1	<330	<10
July	TSWU - 8314	2.0 ± 0.5	<330	<10
August	- 9159	2.4 ± 0.4	<330	<10
September	- 10041	2.4 ± 0.5	<330	<10
3rd. Qtr. mean±s.d.		2.3 ± 0.2	<330	<10
October	TSWU - 11486	2.0 ± 0.5	<330	<10
November	- 12098	2.3 ± 0.5	<330	<10
December	- 12820,1	2.4 ± 0.4	<330	<10
4th. Qtr. mean±s.d.		2.2 ± 0.2	<330	<10

TOLEDO

Table 26. Untreated surface water samples, monthly composites of weekly grab, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995 (continued).

Collection Period	Lab Code	Concentration (pCi/L)		
		Gross Beta	H-3	Cs-137
<u>T-3</u>				
January	TSWU - 0719	2.2 ± 0.5	<330	<10
February	- 1517	3.6 ± 0.6	<330	<10
March	- 2091	2.9 ± 0.5	<330	<10
1st. Qtr. mean±s.d.		2.9 ± 0.7	<330	<10
April	TSWU - 3346	4.0 ± 0.6	<330	<10
May	- 5652	2.8 ± 0.5	<330	<10
June	- 7094	3.2 ± 0.8	<330	<10
2nd. Qtr. mean±s.d.		3.3 ± 0.6	<330	<10
July	TSWU - 8311	2.3 ± 0.5	<330	<10
August	- 9156	2.6 ± 0.5	<330	<10
September	- 10038	2.9 ± 0.5	<330	<10
3rd. Qtr. mean±s.d.		2.6 ± 0.3	<330	<10
October	TSWU - 11483	3.1 ± 0.5	<330	<10
November	- 12095	3.9 ± 0.6	<330	<10
December	- 12817	2.8 ± 0.5	<330	<10
4th. Qtr. mean±s.d.		3.3 ± 0.6	<330	<10

TOLEDO

Table 26. Untreated surface water samples, monthly composites of weekly grab, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995 (continued).

Collection Period	Lab Code	Concentration (pCi/L)		
		Gross Beta	H-3	Cs-137
<u>T-28</u>				
January	TSWU - 0724	1.7 ± 0.5	<330	<10
February	- 1522	2.3 ± 0.5	<330	<10
March	- 2096	2.8 ± 0.5	<330	<10
1st. Qtr. mean±s.d.		2.3 ± 0.6	<330	<10
April	TSWU - 3351	2.0 ± 0.5	<330	<10
May	- 5657	2.3 ± 0.5	<330	<10
June	- 7099	2.6 ± 0.5	<330	<10
2nd. Qtr. mean±s.d.		2.3 ± 0.3	<330	<10
July	TSWU - 8316	1.7 ± 0.5	<330	<10
August	- 9160	2.2 ± 0.5	340±89	<10
September	- 10043	2.4 ± 0.5	<330	<10
3rd. Qtr. mean±s.d.		2.1 ± 0.4	<330	<10
October	TSWU - 11488	2.1 ± 0.5	<330	<10
November	- 12100	2.6 ± 0.5	<330	<10
December	- 12823	2.6 ± 0.5	<330	<10
4th. Qtr. mean±s.d.		2.4 ± 0.3	<330	<10

TOLEDO

Table 26. Untreated surface water samples, monthly composites of weekly grab, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995 (continued).

Collection Period	Lab Code	Concentration (pCi/L)		
		Gross Beta	H-3	Cs-137
<u>T-50</u>				
January	TSWU - 0725	2.1 ± 0.5	<330	<10
February	- 1523	2.8 ± 0.5	<330	<10
March	- 2097	2.5 ± 0.5	<330	<10
1st. Qtr. mean±s.d.		2.5 ± 0.4	<330	<10
April	TSWU - 3352	2.6 ± 0.6	<330	<10
May	- 5658	2.5 ± 0.5	<330	<10
June	- 7100	2.1 ± 0.5	<330	<10
2nd. Qtr. mean±s.d.		2.4 ± 0.3	<330	<10
July	TSWU - 8317	1.9 ± 0.5	330±98	<10
August	- 9161	2.6 ± 0.4	<330	<10
September	- 10044	2.2 ± 0.5	<330	<10
3rd. Qtr. mean±s.d.		2.2 ± 0.4	<330	<10
October	TSWU - 11489	2.5 ± 0.5	<330	<10
November	- 12101	3.0 ± 0.5	<330	<10
December	- 12824	3.2 ± 0.6	<330	<10
4th. Qtr. mean±s.d.		2.9 ± 0.4	<330	<10

TOLEDO

Table 26. Untreated surface water samples, monthly composites of weekly grab, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995 (continued).

Collection Period	Lab Code	Concentration (pCi/L)		
		Gross Beta	H-3	Cs-137
<u>T-145 (OC)</u>				
January	TSWU - 0726	2.0 ± 0.5	<330	<10
February	- 1524	2.8 ± 0.5	<330	<10
March	- 2098	3.1 ± 0.5	<330	<10
1st. Qtr. mean±s.d.		2.6 ± 0.6	<330	<10
April	TSWU - 3353	3.0 ± 0.5	<330	<10
May	- 5659	2.0 ± 0.5	<330	<10
June	- 7101, 2	2.1 ± 0.3	<330	<10
2nd. Qtr. mean±s.d.		2.4 ± 0.6	<330	<10
July	TSWU - 8318, 9	1.9 ± 0.3	<330	<10
August	- 9162, 3	2.7 ± 0.4	<330	<10
September	- 10045	2.4 ± 0.5	<330	<10
3rd. Qtr. mean±s.d.		2.3 ± 0.4	<330	<10
October	TSWU - 11490	2.6 ± 0.5	<330	<10
November	- 12102	2.6 ± 0.5	<330	<10
December	- 12825	2.7 ± 0.5	<330	<10
4th. Qtr. mean±s.d.		2.6 ± 0.1	<330	<10

TOLEDO

Table 27. Untreated surface water samples, quarterly composites of weekly grab samples, analysis for strontium-89, and strontium-90, 1995.

Collection Period	Lab Code	Concentration (pCi/L)	
		Sr-89	Sr-90
<u>Control</u>			
T-11			
1st Quarter	TSWU - 2538	<0.7	<0.5
2nd. Quarter	- 7825	<1.1	<0.4
3rd. Quarter	- 10850	<0.9	0.8±0.3
4th. Quarter	- 13046	<0.6	0.5±0.3
Annual mean±s.d.		<1.1	0.5±0.0
T-12			
1st Quarter	TSWU - 2539	<0.7	<0.4
2nd. Quarter	- 7826	<0.9	<0.6
3rd. Quarter	- 10851	<1.0	0.6±0.4
4th. Quarter	- 13047	<0.6	<0.4
Annual mean±s.d.		<1.0	0.6±0.0
<u>Indicator</u>			
T-3			
1st Quarter	TSWU - 2537	<0.8	<0.5
2nd. Quarter	- 7824	<0.9	<0.5
3rd. Quarter	- 10849	<0.9	<0.6
4th. Quarter	- 13045	<0.5	0.5±0.3
Annual mean±s.d.		<0.9	0.5±0.0
T-28			
1st Quarter	TSWU - 2540	<0.7	<0.4
2nd. Quarter	- 7827	<0.7	<0.5
3rd. Quarter	- 10852	<1.0	<0.6
4th. Quarter	- 13048	<0.5	<0.5
Annual mean±s.d.		<1.0	<0.6
T-50			
1st Quarter	TSWU - 2541	<0.7	<0.4
2nd. Quarter	- 7828, 9	<0.8	<0.5
3rd. Quarter	- 10853	<1.3	<0.9
4th. Quarter	- 13049	<0.6	0.8±0.3
Annual mean±s.d.		<1.3	0.8±0.0

TOLEDO

Table 28. Untreated surface lake water samples, monthly composites of weekly grab samples, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995.

Location	Period	Lab Code	Concentration (pCi/L)		
			Gross Beta	H-3	Cs-137
T-131	(May)	TSWU - 5661	2.5 ± 0.6	1,234±117	< 10
	(June)	- 7103	2.1 ± 0.5	< 330	< 10
	(July)	- 8320	2.2 ± 0.7	< 330	< 10
	(August)	- 9166	2.7 ± 0.6	< 330	< 10
	(September)	- 10046	2.3 ± 0.6	< 330	< 10
	(October)	- 10923, 4	2.5 ± 0.4	893±77	< 10
T-132	(May)	TSWU - 5662	2.4 ± 0.6	724±101	< 10
	(June)	- 7104	3.1 ± 0.6	< 330	< 10
	(July)	- 8321	2.7 ± 0.7	< 330	< 10
	(August)	- 9167	2.4 ± 0.6	< 330	< 10
	(September)	- 10047	2.8 ± 0.6	< 330	< 10
	(October)	- 10925	2.2 ± 0.6	< 330	< 10
T-133	(May)	TSWU - 5663, 4	2.5 ± 0.4	871±74	< 10
	(June)	- 7105	2.8 ± 0.7	< 330	< 10
	(July)	- 8322	3.5 ± 0.7	< 330	< 10
	(August)	- 9168	2.2 ± 0.6	< 330	< 10
	(September)	- 10048	2.5 ± 0.6	< 330	< 10
	(October)	- 10926	2.1 ± 0.6	< 330	< 10
T-134	(May)	TSWU - 5665	2.4 ± 0.6	375±87	< 10
	(June)	- 7106	2.3 ± 0.5	< 330	< 10
	(July)	- 8323	2.2 ± 0.7	< 330	< 10
	(August)	- 9169	2.1 ± 0.6	< 330	< 10
	(September)	- 10049	1.9 ± 0.6	< 330	< 10
	(October)	- 10927	2.2 ± 0.6	< 330	< 10
T-135	(May)	TSWU - 5666	3.0 ± 0.6	< 330	< 10
	(June)	- 7107	4.3 ± 0.8	< 330	< 10
	(July)	- 8324	2.0 ± 0.6	< 330	< 10
	(August)	- 9170	2.2 ± 0.6	< 330	< 10
	(September)	- 10050	2.2 ± 0.6	< 330	< 10
	(October)	- 10928	2.7 ± 0.6	< 330	< 10

TOLEDO

Table 28. Untreated surface lake water samples, monthly composites of weekly grab samples, analyses for gross beta, tritium, and gamma-emitting isotopes, 1995.

Location	Period	Lab Code	Concentration (pCi/L)			
			Gross Beta	H-3	Cs-137	
T-137	(May)	TSWU	- 5667	2.9 ± 0.6	< 330	< 10
	(June)		- 7108	2.9 ± 0.7	< 330	< 10
	(July)		- 8325	2.4 ± 0.6	< 330	< 10
	(August)		- 9171	2.6 ± 0.6	< 330	< 10
	(September)		- 10051	3.2 ± 0.7	< 330	< 10
	(October)		- 10929	2.2 ± 0.6	< 330	< 10
T-152	(May)	TSWU	- 5668	2.3 ± 0.6	< 330	< 10
	(June)		- 7109	2.8 ± 0.5	< 330	< 10
	(July)		- 8326	3.6 ± 0.7	< 330	< 10
	(August)		- 9172	4.7 ± 0.7	< 330	< 10
	(September)		- 10052	3.3 ± 0.7	< 330	< 10
	(October)		- 10930	5.4 ± 0.7	< 330	< 10
T-158	(May)	TSWU	- 5669	3.1 ± 0.6	< 330	< 10
	(June)		- 7110	2.2 ± 0.5	< 330	< 10
	(July)		- 8327	2.9 ± 0.7	< 330	< 10
	(August)		- 9173	1.6 ± 0.5	< 330	< 10
	(September)		- 10053	2.6 ± 0.6	< 330	< 10
	(October)		- 10931	1.6 ± 0.5	< 330	< 10
T-162	(May)	TSWU	- 5670	3.6 ± 0.7	< 330	< 10
	(June)		- 7111	2.0 ± 0.5	< 330	< 10
	(July)		- 8328	3.2 ± 0.7	345±100	< 10
	(August)		- 9174	3.0 ± 0.7	628±102	< 10
	(September)		- 10054, 5	2.9 ± 0.5	< 330	< 10
	(October)		- 10932	2.3 ± 0.6	< 330	< 10
T-167	(May)	TSWU	- 5671	2.3 ± 0.6	< 330	< 10
	(June)		- 7112	2.1 ± 0.5	< 330	< 10
	(July)		- 8329	1.8 ± 0.6	< 330	< 10
	(August)		- 9175	2.4 ± 0.6	< 330	< 10
	(September)		- 10056	1.9 ± 0.6	< 330	< 10
	(October)		- 10933	2.6 ± 0.6	< 330	< 10

NOTE: Pages 57 and 58 are intentionally left out.

TOLEDO

Table 29. Fish samples, analysis for gross beta and gamma-emitting isotopes.
Collection: Semiannually

Sample Description and Concentration (pCi/g wet)						
Location	Indicator			Control		
	T-33 (Lake Erie 1.5 mi NE of Station)			T-35		
Collection Date	05-23-95	05-23-95	05-23-95	05-24-95	05-24-95	05-24-95
Lab Code	TF-5167	TF-5168	TF-5169	TF-5170	TF-5171	TF-5172
Sample Type	Carp	Walleye	White Bass	White Perch	Carp	Walleye
Gross beta	3.55±0.11	3.04±0.09	2.59±0.09	2.75±0.09	3.59±0.11	3.69±0.10
K-40	3.20±0.34	3.23±0.36	2.59±0.37	2.83±0.46	3.08±0.31	3.37±0.43
Cs-137	<0.013	<0.015	<0.013	<0.019	<0.011	<0.024

Location	_____	_____
Collection Date	_____	_____
Lab Code	_____	_____
Sample Type	_____	_____
Gross beta	_____	_____
K-40	_____	_____
Cs-137	_____	_____

Note: Page 60 is intentionally left out.

TOLEDO

Table 30. Shoreline sediment samples, analysis for gamma-emitting isotopes.
Collection: Semiannually

Sample Description and Concentration (pCi/g dry)				
Location	T-3	T-4	T-4P	T-27(C)
Collection Date	05-12-95	05-12-95	05-12-95	05-12-95
Lab Code	TSS-5184	TSS-5185	TSS-5186	TSS-5187
K-40	19.15±0.85	12.18±0.74	22.41±1.35	14.18±0.85
Mn-54	<0.029	<0.027	<0.033	<0.033
Co-58	<0.053	<0.051	<0.080	<0.060
Co-60	<0.025	<0.016	<0.049	<0.027
Cs-134	<0.055	<0.056	<0.11	<0.055
Cs-137	<0.028	<0.029	<0.048	<0.032
Location	T-132	T-3	T-4	T-4P
Collection Date	05-12-95	10-30-95	10-30-95	10-30-95
Lab Code	TSS-5188	TSS-11492	TSS-11493	TSS-11494
K-40	12.76±0.77	13.96±0.51	13.08±0.47	27.09±0.66
Mn-54	<0.026	<0.011	<0.013	<0.023
Co-58	<0.051	<0.021	<0.013	<0.038
Co-60	<0.012	<0.013	<0.013	<0.030
Cs-134	<0.052	<0.031	<0.038	<0.059
Cs-137	<0.020	<0.011	<0.014	<0.033
Location	T-27	T-132		
Collection Date	10-30-95	10-30-95		
Lab Code	TSS-11495	TSS-11496		
K-40	13.22±0.55	12.31±0.50		
Mn-54	<0.012	<0.013		
Co-58	<0.021	<0.024		
Co-60	<0.014	<0.012		
Cs-134	<0.033	<0.032		
Cs-137	<0.012	<0.013		

Note: Pages 62 and 63 are intentionally left out.

APPENDIX A
INTERLABORATORY COMPARISON PROGRAM RESULTS

NOTE: Teledyne's Midwest Laboratory participates in intercomparison studies administered by U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada. The results are reported in Appendix A. Also reported are results of International Intercomparison and Teledyne testing of TLD's, as well as, in-house spikes, blanks and duplicates. Appendix A is updated four times a year; the complete Appendix is included in March, June, September and December monthly progress reports only. Please refer to March, June, September and December progress reports for information.

January, 1995 through December, 1995

Appendix A

Interlaboratory Comparison Program Results

Teledyne's Midwest Laboratory (formerly Hazleton Environmental Sciences) has participated in interlaboratory comparison (crosscheck) programs since the formulation of its quality control program in December 1971. These programs are operated by agencies which supply environmental type samples (e.g., milk or water) containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on the laboratory's analytical procedures and to alert it to any possible problems.

Participant laboratories measure the concentration of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

The results in Table A-1 were obtained through participation in the environmental sample crosscheck program, for milk, water and air filters during the past twelve months. Data for previous years is available upon request.

This program is conducted by the U.S. Environmental Protection Agency Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, Las Vegas, Nevada.

The results in Table A-2 were obtained for Thermoluminescent Dosimeters (TLDs), since 1976 via various International Intercomparisons of Environmental Dosimeters under the sponsorships listed in Table A-2. Also Teledyne testing results are listed.

Table A-3 lists results of the analyses on in-house "spiked" samples for the past twelve months. Data for previous years available upon request.

Table A-4 lists results of the analyses on in-house "blank" samples for the past twelve months. Data for previous years available upon request.

Table A-5 lists results of the in-house "duplicate" program for the past twelve months. Acceptance is based on the difference of the results being less than the sum of the errors. Data for previous years available upon request.

Attachment A lists acceptance criteria for "spiked" samples.

Out-of-limit results are explained directly below the result.

12-31-95

ATTACHMENT A

ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES*

Analysis	Level	One Standard Deviation for single determinations
Gamma Emitters	5 to 100 pCi/liter or kg >100 pCi/liter or kg	5.0 pCi/liter 5% of known value
Strontium-89 ^b	5 to 50 pCi/liter or kg >50 pCi/liter or kg	5.0 pCi/liter 10% of known value
Strontium-90 ^b	2 to 30 pCi/liter or kg >30 pCi/liter or kg	5.0 pCi/liter 10% of known value
Potassium	>0.1 g/liter or kg	5% of known value
Gross alpha	≤20 pCi/liter >20 pCi/liter	5.0 pCi/liter 25% of known value
Gross beta	≤100 pCi/liter >100 pCi/liter	5.0 pCi/liter 5% of known value
Tritium	≤4,000 pCi/liter >4,000 pCi/liter	1s = (pCi/liter) = $169.85 \times (\text{known})^{0.0933}$ 10% of known value
Radium-226,-228	<0.1 pCi/liter	15% of known value
Plutonium	0.1 pCi/liter, gram, or sample	10% of known value
Iodine-131, Iodine-129 ^b	≤55 pCi/liter >55 pCi/liter	6.0 pCi/liter 10% of known value
Uranium-238, Nickel-64 ^b	≤35 pCi/liter >35 pCi/liter	6.0 pCi/liter 15% of known value
Technetium-99 ^b		
Iron-55 ^b	50 to 100 pCi/liter >100 pCi/liter	10 pCi/liter 10% of known value
Others ^b	-	20% of known value

* From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year, 1981-1982, EPA-600/4-81-004.

^b Teledyne limit.

Table A-1. U.S. Environmental Protection Agency's crosscheck program, comparison of EPA and Teledyne's Midwest Laboratory results for various sample media^a.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/L ^b		
				Teledyne Results ± 2 Sigma ^c	EPA Result ^d 1s, N=1	Control Limits
STW-723	WATER	Jan, 1995	Sr-89	17.7 \pm 1.5	20.0 \pm 0	11.3 - 28.7
STW-723	WATER	Jan, 1995	Sr-90	13.7 \pm 0.6	15.0 \pm 5.0	6.3 - 23.7
STW-724	WATER	Jan, 1995	Gr. Alpha	4.3 \pm 0.6	5.0 \pm 5.0	0.0 - 13.7
STW-724	WATER	Jan, 1995	Gr. Beta	4.7 \pm 0.6	5.0 \pm 5.0	0.0 - 13.7
STW-725	WATER	Feb, 1995	I-131	99.0 \pm 4.4	100.0 \pm 10.0	82.7 - 117.3
STW-726	WATER	Feb, 1995	Ra-226	19.2 \pm 0.4	19.1 \pm 2.9	14.1 - 24.1
STW-726	WATER	Feb, 1995	Ra-228	19.2 \pm 2.0	20.0 \pm 5.0	11.3 - 28.7
STW-726	WATER	Feb, 1995	Uranium	24.9 \pm 0.2	25.5 \pm 3.0	20.3 - 30.7
STW-727	WATER	Mar, 1995	H-3	7,460.0 \pm 87.2	7,435.0 \pm 744.0	6,144.2 - 8,725.8
STW-728	WATER	Mar, 1995	Pu-239	11.0 \pm 0.6	11.1 \pm 1.1	9.2 - 13.0
STW-729	WATER	Apr, 1995	Gr. Alpha	41.7 \pm 0.6	47.5 \pm 11.9	26.9 - 68.1
STW-729	WATER	Apr, 1995	Ra-226	13.4 \pm 0.5	14.9 \pm 2.2	11.1 - 18.7
STW-729	WATER	Apr, 1995	Ra-228	13.1 \pm 2.4	15.8 \pm 4.0	8.9 - 22.7
STW-729	WATER	Apr, 1995	Uranium	9.5 \pm 0.6	10.0 \pm 3.0	4.8 - 15.2
STW-730	WATER	Apr, 1995	Co-60	29.0 \pm 1.7	29.0 \pm 5.0	20.3 - 37.7
STW-730	WATER	Apr, 1995	Cs-134	17.3 \pm 1.2	20.0 \pm 5.0	11.3 - 28.7
STW-730	WATER	Apr, 1995	Cs-137	11.0 \pm 1.0	11.0 \pm 5.0	2.3 - 19.7
STW-730	WATER	Apr, 1995	Gr. Beta	74.8 \pm 3.2	86.6 \pm 10.0	69.3 - 103.9
STW-730	WATER	Apr, 1995	Sr-89	17.0 \pm 0.0	20.0 \pm 5.0	11.3 - 28.7
STW-730	WATER	Apr, 1995	Sr-90	12.7 \pm 1.2	15.0 \pm 5.0	6.3 - 23.7
STW-732	WATER	Jun, 1995	Ra-226	14.7 \pm 0.3	14.8 \pm 2.2	11.0 - 18.6
STW-732	WATER	Jun, 1995	Ra-228	11.9 \pm 0.6	15.0 \pm 3.8	8.4 - 21.6
STW-732	WATER	Jun, 1995	Uranium	13.9 \pm 0.3	15.2 \pm 3.0	10.0 - 20.4
STW-735	WATER	Jul, 1995	Gr. Alpha	16.4 \pm 2.4	27.5 \pm 6.9	15.5 - 39.5
STW-735	WATER	Jul, 1995	Gr. Beta	16.8 \pm 1.0	19.4 \pm 5.0	10.7 - 28.1
STW-736	WATER	Aug, 1995	H-3	4,773.7 \pm 49.9	4,872.0 \pm 487.0	4,027.1 - 5,716.9

^a Results obtained by Teledyne Brown Engineering Environmental Services Midwest Laboratory as a participant in the environmental sample crosscheck program operated by the Intercomparison and Calibration Section, Quality Assurance Branch, Environmental Monitoring and Support Laboratory, U.S. Environmental Protection Agency (EPA), Las Vegas, Nevada.

^b All results are in pCi/L, except for elemental potassium (K) data in milk, which are in mg/L; air filter samples, which are in pCi/Filter.

^c Unless otherwise indicated, the TBEESML results are given as the mean \pm 2 standard deviations for three determinations.

^d USEPA results are presented as the known values and expected laboratory precision (1s, 1 determination) and control limits as defined by the EPA.

Table A-2. Crosscheck program results; Thermoluminescent Dosimeters. (TLDs).

Lab Code	TLD Type	Date	Measurement	mR		
				Teledyne Results ± 2 Sigma	Known Value ± 2 Sigma	Average ± 2 Sigma (All Participants)
<u>2nd International Intercomparison</u>						
115-2	CaF ₂ : Mn Bulb	Apr, 1976	Field	17.0 ± 1.9	17.1	16.4 ± 7.7
115-2	CaF ₂ : Mn Bulb	Apr, 1976	Lab	20.8 ± 4.1	21.3	18.8 ± 7.6
Second International Intercomparison of Environmental Dosimeters conducted in April of 1976 by the Health and Safety Laboratory (HASL), New York, New York, and the School of Public Health of the University of Texas, Houston, Texas.						
<u>3rd International Intercomparison</u>						
115-3	CaF ₂ : Mn Bulb	Jun, 1977	Field	30.7 ± 3.2	34.9 ± 4.8	31.5 ± 3.0
115-3	CaF ₂ : Mn Bulb	Jun, 1977	Lab	89.6 ± 6.4	91.7 ± 14.6	86.2 ± 24.0
Third International Intercomparison of Environmental Dosimeters conducted in the summer of 1977 by Oak Ridge National Laboratory and the School of Public Health of the University of Texas, Houston, Texas.						
<u>4th International Intercomparison</u>						
115-4	CaF ₂ : Mn Bulb	Jun, 1979	Field	14.1 ± 1.1	14.1 ± 1.4	16.0 ± 9.0
115-4	CaF ₂ : Mn Bulb	Jun, 1979	Lab, High	40.4 ± 1.4	45.8 ± 9.2	43.9 ± 13.2
115-4	CaF ₂ : Mn Bulb	Jun, 1979	Lab, Low	9.8 ± 1.3	12.2 ± 2.4	12.0 ± 7.4
Fourth International Intercomparison of Environmental Dosimeters conducted in the summer of 1979 by the School of Public Health of the University of Texas, Houston, Texas.						
<u>5th International Intercomparison</u>						
115-5A	CaF ₂ : Mn Bulb	Oct, 1980	Field	31.4 ± 1.8	30.0 ± 6.0	30.2 ± 14.6
115-5A	CaF ₂ : Mn Bulb	Oct, 1980	Lab, End	96.6 ± 5.8	88.4 ± 8.8	90.7 ± 31.2
115-5A	CaF ₂ : Mn Bulb	Oct, 1980	Lab, Start	77.4 ± 5.8	75.2 ± 7.6	75.8 ± 40.4
Fifth International Intercomparison of Environmental Dosimeters conducted in the fall of 1980 at Idaho Falls, Idaho and sponsored by the School of Public Health of the University of Texas, Houston, Texas and the Environmental Measurements Laboratory, New York, New York, U.S. Department of Energy.						
<u>5th International Intercomparison</u>						
115-5B	LiF-100 Chips	Oct, 1980	Field	30.3 ± 4.8	30.0 ± 6.0	30.2 ± 14.6
115-5B	LiF-100 Chips	Oct, 1980	Lab, End	85.4 ± 11.7	88.4 ± 8.8	90.7 ± 31.2
115-5B	LiF-100 Chips	Oct, 1980	Lab, Start	81.1 ± 7.4	75.2 ± 7.6	75.8 ± 40.4
Fifth International Intercomparison of Environmental Dosimeters conducted in the fall of 1980 at Idaho Falls, Idaho and sponsored by the School of Public Health of the University of Texas, Houston, Texas and the Environmental Measurements Laboratory, New York, New York, U.S. Department of Energy.						
<u>6th International Intercomparison</u>						
115-6	Teledyne did not participate in the Sixth International Intercomparison of Environmental Dosimeters.					
<u>7th International Intercomparison</u>						
115-7A	LiF-100 Chips	Jun, 1984	Field	75.4 ± 2.6	75.8 ± 6.0	75.1 ± 29.8

Table A-2. Crosscheck program results; Thermoluminescent Dosimeters. (TLDs).

Lab Code	TLD Type	Date	Measurement	mR		
				Teledyne Results ± 2 Sigma	Known Value ± 2 Sigma	Average ± 2 Sigma (All Participants)
115-7A	LiF-100 Chips	Jun, 1984	Lab, Co-60	80.0 ± 3.5	79.9 ± 4.0	77.9 ± 27.6
115-7A	LiF-100 Chips	Jun, 1984	Lab, Cs-137	66.6 ± 2.5	75.0 ± 3.8	73.0 ± 22.2
Seventh International Intercomparison of Environmental Dosimeters conducted in the spring and summer of 1984 at Las Vegas, Nevada, and sponsored by the U.S. Department of Energy, The Nuclear Regulatory Commission, and the U.S. Environmental Protection Agency.						
<u>7th International Intercomparison</u>						
115-7B	LiF-100 Chips	Jun, 1984	Field	71.5 ± 2.6	75.8 ± 6.0	75.1 ± 29.8
115-7B	LiF-100 Chips	Jun, 1984	Lab, Co-60	84.8 ± 6.4	79.9 ± 4.0	77.9 ± 27.6
115-7B	LiF-100 Chips	Jun, 1984	Lab, Cs-137	78.8 ± 1.6	75.0 ± 3.8	73.0 ± 22.2
Seventh International Intercomparison of Environmental Dosimeters conducted in the spring and summer of 1984 at Las Vegas, Nevada, and sponsored by the U.S. Department of Energy, The Nuclear Regulatory Commission, and the U.S. Environmental Protection Agency.						
<u>7th International Intercomparison</u>						
115-7C	CaSO ₄ : Dy Cards	Jun, 1984	Field	76.8 ± 2.7	75.8 ± 6.0	75.1 ± 29.8
115-7C	CaSO ₄ : Dy Cards	Jun, 1984	Lab, Co-60	82.5 ± 3.7	79.9 ± 4.0	77.9 ± 27.6
115-7C	CaSO ₄ : Dy Cards	Jun, 1984	Lab, Cs-137	79.0 ± 3.2	75.0 ± 3.8	73.0 ± 22.2
Seventh International Intercomparison of Environmental Dosimeters conducted in the spring and summer of 1984 at Las Vegas, Nevada, and sponsored by the U.S. Department of Energy, The Nuclear Regulatory Commission, and the U.S. Environmental Protection Agency.						
<u>8th International Intercomparison</u>						
115-8A	LiF-100 Chips	Jan, 1986	Field, Site 1	29.5 ± 1.4	29.7 ± 1.5	28.9 ± 12.4
115-8A	LiF-100 Chips	Jan, 1986	Field, Site 2	11.3 ± 0.8	10.4 ± 0.5	10.1 ± 9.1
115-8A	LiF-100 Chips	Jan, 1986	Lab, Cs-137	13.7 ± 0.9	17.2 ± 0.9	16.2 ± 6.8
Eighth International Intercomparison of Environmental Dosimeters conducted in the fall and winter of 1985-1986 at New York, New York, and sponsored by the U.S. Department of Energy.						
<u>8th International Intercomparison</u>						
115-8B	LiF-100 Chips	Jan, 1986	Field, Site 1	32.3 ± 1.2	29.7 ± 1.5	28.9 ± 12.4
115-8B	LiF-100 Chips	Jan, 1986	Field, Site 2	9.0 ± 1.0	10.4 ± 0.5	10.1 ± 9.0
115-8B	LiF-100 Chips	Jan, 1986	Lab, Cs-137	15.8 ± 0.9	17.2 ± 0.9	16.2 ± 6.8
Eighth International Intercomparison of Environmental Dosimeters conducted in the fall and winter of 1985-1986 at New York, New York, and sponsored by the U.S. Department of Energy.						
<u>8th International Intercomparison</u>						
115-8C	CaSO ₄ : Dy Cards	Jan, 1986	Field, Site 1	32.2 ± 0.7	29.7 ± 1.5	28.9 ± 12.4

Table A-2. Crosscheck program results; Thermoluminescent Dosimeters. (TLDs).

Lab Code	TLD Type	Date	Measurement	mR		
				Teledyne Results ± 2 Sigma	Known Value ± 2 Sigma	Average ± 2 Sigma (All Participants)
115-8C	CaSO ₄ : Dy Cards	Jan, 1986	Field, Site 2	10.6 ± 0.6	10.4 ± 0.5	10.1 ± 9.0
115-8C	CaSO ₄ : Dy Cards	Jan, 1986	Lab, Cs-137	18.1 ± 0.8	17.2 ± 0.9	16.2 ± 6.8

Eighth International Intercomparison of Environmental Dosimeters conducted in the fall and winter of 1985-1986 at New York, New York, and sponsored by the U.S. Department of Energy.

9th International Intercomparison

115-9

The Ninth International Intercomparison of Environmental Dosimeters was not available to Teledyne's Midwest Laboratory.

10th International Intercomparison

115-10A	LiF-100 Chips	Aug, 1993	Field	25.7 ± 1.4	27.0 ± 1.6	26.4 ± 10.2
115-10A	LiF-100 Chips	Aug, 1993	Lab, 1	22.7 ± 1.6	25.9 ± 1.3	25.0 ± 9.4
115-10A	LiF-100 Chips	Aug, 1993	Lab, 2	62.7 ± 2.6	72.7 ± 1.9	69.8 ± 20.3

The Tenth International Intercomparison of Environmental Dosimeters conducted in 1993 at Idaho State University and sponsored by the U.S. Department of Energy and the Idaho State University.

10th International Intercomparison

115-10B	CaSO ₄ : Dy Cards	Aug, 1993	Field	26.0 ± 2.3	27.0 ± 1.6	26.4 ± 10.2
115-10B	CaSO ₄ : Dy Cards	Aug, 1993	Lab, 1	24.1 ± 1.7	25.9 ± 1.3	25.0 ± 9.4
115-10B	CaSO ₄ : Dy Cards	Aug, 1993	Lab, 2	69.2 ± 3.0	72.7 ± 1.9	69.8 ± 20.3

The Tenth International Intercomparison of Environmental Dosimeters conducted in 1993 at Idaho Stat University and sponsored by the U.S. Department of Energy and the Idaho Stat University.

Teledyne Testing

89-1	LiF-100 Chips	Sep, 1989	Lab	21.0 ± 0.4	22.4	ND
------	---------------	-----------	-----	------------	------	----

ND = No Data; Teledyne Testing was only performed by Teledyne.

Chips were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in September, 1989.

Teledyne Testing

89-2	Teledyne CaSO ₄ : Dy Cards	Nov, 1989	Lab	20.9 ± 1.0	20.3	ND
------	---	-----------	-----	------------	------	----

ND = No Data; Teledyne Testing was only performed by Teledyne.

Cards were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in June, 1990.

Table A-2. Crosscheck program results; Thermoluminescent Dosimeters. (TLDs).

Lab Code	TLD Type	Date	Measurement	mR		
				Teledyne Results ± 2 Sigma	Known Value ± 2 Sigma	Average ± 2 Sigma (All Participants)
Teledyne Testing						
90-1	Teledyne CaSO ₄ ; Dy Cards	Jun, 1990	Lab	20.6 ± 1.4	19.6	ND
ND = No Data; Teledyne Testing was only performed by Teledyne. Cards were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in June, 1990.						
Teledyne Testing						
90-2	Teledyne CaSO ₄ ; Dy Cards	Jun, 1990	Lab	100.8 ± 4.3	100.0	ND
ND = No Data; Teledyne Testing was only performed by Teledyne. Cards were irradiated by Dosimetry Associates, Inc., Northville, MI, in October, 1990.						
Teledyne Testing						
91-1	Teledyne CaSO ₄ ; Dy Cards	Oct, 1990	Lab, 1	33.4 ± 2.0	32.0	ND
91-1	Teledyne CaSO ₄ ; Dy Cards	Oct, 1990	Lab, 2	55.2 ± 4.7	58.8	ND
91-1	Teledyne CaSO ₄ ; Dy Cards	Oct, 1990	Lab, 3	87.8 ± 6.2	85.5	ND
ND = No Data; Teledyne Testing was only performed by Teledyne. Cards were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in October, 1991.						
Teledyne Testing						
92-1	LiF-100 Chips	Feb, 1992	Lab, 1	11.1 ± 0.2	10.7	ND
92-1	LiF-100 Chips	Feb, 1992	Lab, 2	25.6 ± 0.5	25.4	ND
92-1	LiF-100 Chips	Feb, 1992	Lab, 3	46.4 ± 0.5	46.3	ND
ND = No Data; Teledyne Testing was only performed by Teledyne. Chips were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in February, 1992.						
Teledyne Testing						
92-2	Teledyne CaSO ₄ ; Dy Cards	Apr, 1992	Reader 1, #1	20.1 ± 0.1	20.1	ND
92-2	Teledyne CaSO ₄ ; Dy Cards	Apr, 1992	Reader 1, #2	40.6 ± 0.1	40.0	ND

Table A-2. Crosscheck program results; Thermoluminescent Dosimeters. (TLDs).

Lab Code	TLD Type	Date	Measurement	mR		
				Teledyne Results ± 2 Sigma	Known Value ± 2 Sigma	Average ± 2 Sigma (All Participants)
92-2	Teledyne CaSo ₄ : Dy Cards	Apr, 1992	Reader 1, #3	60.0 ± 1.3	60.3	ND
92-2	Teledyne CaSo ₄ : Dy Cards	Apr, 1992	Reader 2, #1	20.3 ± 0.3	20.1	ND
92-2	Teledyne CaSo ₄ : Dy Cards	Apr, 1992	Reader 2, #2	39.2 ± 0.3	40.0	ND
92-2	Teledyne CaSo ₄ : Dy Cards	Apr, 1992	Reader 2, #3	60.7 ± 0.4	60.3	ND

ND = No Data; Teledyne Testing was only performed by Teledyne.

Cards were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in April, 1992.

Teledyne Testing

93-1	Teledyne LiF-100 Chips	Mar, 1993	Lab, 1	10.0 ± 1.0	10.2	ND
93-1	Teledyne LiF-100 Chips	Mar, 1993	Lab, 2	25.2 ± 2.2	25.5	ND
93-1	Teledyne LiF-100 Chips	Mar, 1993	Lab, 3	42.7 ± 5.7	45.9	ND

ND = No Data; Teledyne Testing was only performed by Teledyne.

Chips were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in March, 1993. Due to a potential error of 10-12% when cards where irradiated, results of the testing on the cards will not be published. Data is available upon request.

Teledyne Testing

94-1	Teledyne LiF-100 Chips	Nov, 1994	Lab, 1	15.6 ± 0.4	14.9	ND
94-1	Teledyne LiF-100 Chips	Nov, 1994	Lab, 2	30.2 ± 0.4	29.8	ND
94-1	Teledyne LiF-100 Chips	Nov, 1994	Lab, 3	59.2 ± 0.3	59.7	ND
94-1	Teledyne CaSo ₄ : Dy Cards	Nov, 1994	Reader 1, #1	14.9 ± 0.1	14.9	ND
94-1	Teledyne CaSo ₄ : Dy Cards	Nov, 1994	Reader 1, #2	30.8 ± 0.1	29.8	ND

Table A-1. Crosscheck program results; Thermoluminescent Dosimeters. (TLDs).

Lab Code	TLD Type	Date	Measurement	mR		
				Teledyne Results ± 2 Sigma	Known Value ± 2 Sigma	Average ± 2 Sigma (All Participants)
94-1	Teledyne CaSO ₄ : Dy Cards	Nov, 1994	Reader 1, #3	58.9 ± 0.3	59.7	ND
94-1	Teledyne CaSO ₄ : Dy Cards	Nov, 1994	Reader 2, #1	15.4 ± 0.2	14.9	ND
94-1	Teledyne CaSO ₄ : Dy Cards	Nov, 1994	Reader 2, #2	31.4 ± 0.2	29.8	ND
94-1	Teledyne CaSO ₄ : Dy Cards	Nov, 1994	Reader 2, #3	60.1 ± 0.3	59.7	ND

ND = No Data; Teledyne Testing was only performed by Teledyne.

Cards were irradiated by Teledyne Isotopes, Inc., Westwood, New Jersey, in November, 1994.

Table A-3. In-house "spike" samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/L ^a		
				Teledyne Results 2s, n=1 ^b	Known Activity	Control ^c Limits
SPW-7569	WATER	Jul, 1995	H-3	25806.9 ± 447.7	26669.0	21335.2 - 32002.8
SPAP-10967	AIR FILTER	Nov, 1995	Gr. Beta	7.3 ± 0.0	8.0	0.0 - 18.0
SPAP-2513	AIR FILTER	Apr, 1995	Gr. Beta	7.5 ± 0.0	8.1	0.0 - 18.1
SPAP-2542	AIR FILTER	Apr, 1995	Cs-137	2.3 ± 2.1	1.9	1.2 - 2.7
SPAP-284	AIR FILTER	Jan, 1995	Cs-137	2.2 ± 0.0	1.9	1.2 - 2.7
SPAP-284	AIR FILTER	Jan, 1995	I-131(g)	2.2 ± 0.0	1.9	1.2 - 2.7
SPAP-408	AIR FILTER	Jan, 1995	Gr. Beta	7.5 ± 0.0	8.1	0.0 - 18.1
SPAP-7554	AIR FILTER	Jul, 1995	Gr. Beta	7.3 ± 0.0	8.1	0.0 - 18.1
SPAP-7557	AIR FILTER	Jul, 1995	Cs-137	2.3 ± 0.0	1.9	1.2 - 2.7
SPCH-11238	CHARCOAL CANISTER	Oct, 1995	I-131(g)	0.8 ± 0.0	0.8	0.5 - 1.1
SPCH-5964	CHARCOAL CANISTER	Jun, 1995	I-131(g)	2.2 ± 0.1	2.3	1.4 - 3.3
SPCH-717	CHARCOAL CANISTER	Jan, 1995	I-131(g)	2.9 ± 0.1	2.5	1.5 - 3.4
SPF-10921	FISH	Oct, 1995	Co-60	0.7 ± 0.0	0.8	0.5 - 1.1
SPF-10921	FISH	Oct, 1995	Cs-134	0.5 ± 0.0	0.6	0.3 - 0.8
SPF-10921	FISH	Oct, 1995	Cs-137	0.9 ± 0.1	0.9	0.5 - 1.2
SPF-3708	FISH	May, 1995	Cs-134	0.1 ± 0.0	0.1	0.1 - 0.2
SPF-3708	FISH	May, 1995	Cs-137	0.2 ± 0.0	0.2	0.1 - 0.2
SPMI-205	MILK	Jan, 1995	Cs-137	51.2 ± 7.5	49.4	39.4 - 59.4
SPMI-205	MILK	Jan, 1995	Sr-89	19.4 ± 3.4	23.1	13.1 - 33.1
SPMI-205	MILK	Jan, 1995	Sr-90	26.2 ± 1.3	28.1	18.1 - 38.1
SPMI-2988	MILK	Apr, 1995	Cs-134	37.0 ± 1.8	40.7	30.7 - 50.7
SPMI-2988	MILK	Apr, 1995	Cs-137	62.4 ± 3.1	54.5	44.5 - 64.5
SPMI-2988	MILK	Apr, 1995	Sr-89	32.6 ± 3.3	36.5	26.5 - 46.5
SPMI-2988	MILK	Apr, 1995	Sr-90	25.6 ± 1.6	24.9	14.9 - 34.9
SPMI-6838	MILK	Jun, 1995	I-131	38.5 ± 0.5	39.6	27.6 - 51.6
SPMI-707	MILK	Jan, 1995	I-131	80.3 ± 1.4	86.0	68.8 - 103.2
SPMI-707	MILK	Jan, 1995	I-131(g)	84.8 ± 10.4	86.0	51.6 - 96.0
SPMI-7525	MILK	Jul, 1995	Cs-134	31.5 ± 2.5	34.4	24.4 - 44.4
SPMI-7525	MILK	Jul, 1995	Cs-137	50.2 ± 4.0	43.4	33.4 - 53.4
SPMI-7525	MILK	Jul, 1995	I-131(g)	44.7 ± 5.4	45.6	27.4 - 55.6
SPMI-7525	MILK	Jul, 1995	Sr-90	28.0 ± 1.4	27.9	17.9 - 37.9
SPSO-5130	SOIL	May, 1995	Cs-134	0.3 ± 0.0	0.3	0.2 - 0.4
SPSO-5130	SOIL	May, 1995	Cs-137	0.5 ± 0.0	0.5	0.3 - 0.7

Table A-3. In-house "spike" samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/L ^a		
				Teledyne Results 2s, n=1 ^b	Known Activity	Control ^c Limits
SPVE-6006	VEGETATION	Jun, 1995	I-131(g)	0.6±0.0	0.5	0.3 - 0.8
SPVE-7190	VEGETATION	Jul, 1995	I-131(g)	1.1±0.0	1.0	0.6 - 1.4
SPVE-729	VEGETATION	Feb, 1995	I-131(g)	1.9±0.1	1.9	1.1 - 2.6
SPW-1204	WATER	Feb, 1995	Ra-226	6.9±0.1	6.9	4.8 - 9.0
SPW-12079	WATER	Nov, 1995	H-3	27963.4±445.5	29315.0	23452.0 - 35178.0
SPW-12084	WATER	Nov, 1995	Gr. Alpha	75.3±3.2	82.8	41.4 - 124.2
SPW-12084	WATER	Nov, 1995	Gr. Beta	86.9±2.5	86.3	76.3 - 96.3
SPW-1790	WATER	Mar, 1995	Sr-89	0.9±3.9	42.7	32.7 - 52.7
The raw data was reviewed and found to be free of errors. The sample was repeated with similar results. An Investigation was conducted to determine the cause of this deviation. No apparent cause was found for this discrepancy. It was determined the "spike" was prepared improperly. Another "spike" was prepared and analyzed (See SPW-6388). No further action is planned.						
SPW-1790	WATER	Mar, 1995	Sr-90	31.4±1.8	39.1	31.3 - 46.9
The raw data was reviewed and found to be free of errors. The sample was repeated with similar results. An Investigation was conducted to determine the cause of this deviation. No apparent cause was found for this discrepancy. It was determined the "spike" was prepared improperly. Another "spike" was prepared and analyzed (See SPW-6388). No further action is planned.						
SPW-2544	WATER	Apr, 1995	H-3	9656.2±291.8	9333.0	7466.4 - 11199.6
SPW-2652	WATER	Apr, 1995	Co-60	23.8±2.4	24.8	14.8 - 34.8
SPW-2652	WATER	Apr, 1995	Cs-134	29.3±2.3	30.8	20.8 - 40.8
SPW-2652	WATER	Apr, 1995	Cs-137	42.3±3.9	40.9	30.9 - 50.9
SPW-286	WATER	Jan, 1995	H-3	40929.9±5594.5	40871.0	32696.8 - 49045.2
SPW-289	WATER	Jan, 1995	Co-60	250.5±14.1	247.5	222.8 - 272.3
SPW-289	WATER	Jan, 1995	Cs-134	290.5±14.4	321.3	289.2 - 353.4
SPW-289	WATER	Jan, 1995	Cs-137	387.7±21.2	394.3	354.9 - 433.7
SPW-3051	WATER	Mar, 1995	Gr. Alpha	88.5±3.7	82.9	41.5 - 124.4
SPW-3051	WATER	Apr, 1995	Gr. Alpha	88.0±3.8	82.9	41.5 - 124.4
SPW-3051	WATER	Mar, 1995	Gr. Beta	83.0±2.3	87.2	77.2 - 97.2
SPW-3051	WATER	Apr, 1995	Gr. Beta	79.6±2.3	87.2	77.2 - 97.2
SPW-3589	WATER	May, 1995	Fe-55	2033.7±500.2	2274.0	1819.2 - 2728.8
SPW-5608	WATER	Jun, 1995	I-131	78.8±2.3	85.5	68.4 - 102.6
SPW-6005	WATER	Jun, 1995	I-131	48.2±1.9	46.8	34.8 - 58.8
SPW-6008	WATER	May, 1995	Gr. Alpha	17.3±1.4	20.7	10.4 - 31.1
SPW-6008	WATER	May, 1995	Gr. Beta	21.2±1.0	21.8	11.8 - 31.8
SPW-6388	WATER	May, 1995	Sr-89	18.7±2.4	21.2	11.2 - 31.2
SPW-6388	WATER	May, 1995	Sr-90	21.2±1.1	23.2	13.2 - 33.2

Table A-3. In-house "spike" samples.

Lab Code	Sample Type	Date Collected	Analysis	Concentration in pCi/L ^a		
				Teledyne Results 2s, n=1 ^b	Known Activity	Control ^c Limits
SPW-6398	WATER	May, 1995	Sr-89	18.7±2.4	21.2	11.2 - 31.2
SPW-6398	WATER	May, 1995	Sr-90	21.2±1.1	23.2	13.2 - 33.2
SPW-6839	WATER	Jun, 1995	I-131	34.9±0.5	39.5	27.5 - 51.5
SPW-8179	WATER	Jul, 1995	Fe-55	2.3±0.4	2.1	0.0 - 22.1
SPW-9981	WATER	Sep, 1995	Sr-89	34.6±4.9	39.0	29.0 - 49.0
SPW-9981	WATER	Sep, 1995	Sr-90	20.3±1.3	20.0	10.0 - 30.0

^a All results are in pCi/L, except for elemental potassium (K) in milk, which are in mg/L; air filter samples, which are in pCi/Filter; and food products, which are in mg/kg.

^b All samples are the results of single determinations.

^c Control limits are based on Attachment A, page A2 of this report.

NOTE: For fish, Jello is used for the spike matrix. For vegetation, Sawdust is used for the spike matrix.

Table A-4. In-house "blank" samples.

Lab Code	Sample Type	Sample Date	Analysis	Concentration pCi/L ^a		
				Teledyne Results (4.66 Sigma)		Acceptance Criteria (4.66 Sigma)
				LLD	Activity ^b	
SPAP-10968	AIR FILTER	Nov 1995	Gr. Beta	<0.4	0.61 ± 0.26	< 3.2
SPAP-2514	AIR FILTER	Apr 1995	Gr. Beta	<0.3	0.03 ± 0.25	< 3.2
SPAP-2543	AIR FILTER	Apr 1995	Co-60	<4.4	0.39 ± 2.20	< 10.0
SPAP-2543	AIR FILTER	Apr 1995	Cs-134	<1.9	0.05 ± 2.11	< 10.0
SPAP-2543	AIR FILTER	Apr 1995	Cs-137	<1.1	-1.24 ± 1.83	< 10.0
SPAP-283	AIR FILTER	Jan 1995	Co-60	<2.7	-0.36 ± 1.40	< 10.0
SPAP-283	AIR FILTER	Jan 1995	Cs-134	<1.5	-0.67 ± 1.33	< 10.0
SPAP-283	AIR FILTER	Jan 1995	Cs-137	<2.4	0.46 ± 1.33	< 10.0
SPAP-409	AIR FILTER	Jan 1995	Gr. Beta	<0.5	0.02 ± 0.28	< 3.2
SPAP-7556	AIR FILTER	Jul 1995	Gr. Beta	<1.0	0.06 ± 0.55	< 3.2
SPAP-7558	AIR FILTER	Jul 1995	Co-60	<4.2	0.39 ± 3.06	< 10.0
SPAP-7558	AIR FILTER	Jul 1995	Co-60	<4.2	0.04 ± 3.07	< 10.0
SPAP-7558	AIR FILTER	Jul 1995	Cs-134	<3.0	-1.23 ± 2.45	< 10.0
SPAP-7558	AIR FILTER	Jul 1995	Cs-137	<3.5	1.18 ± 2.04	< 10.0
SPCH-11238	CHARCOAL CANISTER	Oct 1995	I-131(g)	<1.9	-0.00 ± 0.01	< 9.6
SPCH-287	CHARCOAL CANISTER	Jan 1995	I-131(g)	<2.3	-1.98 ± 3.12	< 9.6
SPCH-5975	CHARCOAL CANISTER	Jun 1995	I-131(g)	<3.0	-0.71 ± 2.68	< 9.6
SPF-10922	FISH	Oct 1995	Co-60	<5.4	5.74 ± 4.70	< 10.0
SPF-10922	FISH	Oct 1995	Cs-134	<8.9	2.47 ± 5.44	< 10.0
SPF-10922	FISH	Oct 1995	Cs-137	<5.4	-2.44 ± 5.08	< 10.0
SPF-3709	FISH	May 1995	Co-60	<8.4	2.21 ± 5.97	< 10.0
SPF-3709	FISH	May 1995	Cs-134	<1.3	6.79 ± 8.55	< 10.0
SPF-3709	FISH	May 1995	Cs-137	<1.3	3.61 ± 7.81	< 10.0
SPM-204	MILK	Jan 1995	Co-60	<5.3	0.41 ± 3.48	< 10.0
SPM-204	MILK	Jan 1995	Cs-134	<4.4	-0.07 ± 2.05	< 10.0
SPM-204	MILK	Jan 1995	Cs-137	<4.3	1.32 ± 2.53	< 10.0
SPM-204	MILK	Jan 1995	I-131	<0.5	-0.03 ± 0.22	< 0.5
SPM-204	MILK	Jan 1995	Sr-89	<0.8	0.14 ± 1.08	< 5.0
SPM-204	MILK	Jan 1995	Sr-90	N/A	1.46 ± 0.48	< 1.0
Low level of Sr-90 concentration in milk (1.5 pCi/L) is not unusual.						
SPMI-10920	MILK	Oct 1995	Co-60	<3.8	-0.45 ± 5.05	< 10.0
SPMI-10920	MILK	Oct 1995	Cs-134	<3.5	-2.79 ± 4.35	< 10.0

Table A-4. In-house "blank" samples.

Lab Code	Sample Type	Sample Date	Analysis	Concentration pCi/L ^a		Acceptance Criteria (4.66 Sigma)
				LLD	Teledyne Results (4.66 Sigma) Activity ^b	
SPMI-10920	MILK	Oct 1995	Cs-137	<6.0	1.55 ± 4.13	< 10.0
SPMI-2987	MILK	Apr 1995	Cs-134	<3.4	0.37 ± 1.89	< 10.0
SPMI-2987	MILK	Apr 1995	Cs-137	<3.3	1.29 ± 1.75	< 10.0
SPMI-2987	MILK	Apr 1995	Sr-89	<0.4	0.06 ± 0.62	< 5.0
SPMI-2987	MILK	Apr 1995	Sr-90	N/A	1.47 ± 0.38	< 1.0
Low level of Sr-90 concentration in milk (1-5 pCi/L) is not unusual.						
SPMI-7526	MILK	Jul 1995	Co-60	<5.8	1.19 ± 3.34	< 10.0
SPMI-7526	MILK	Jul 1995	Cs-134	<5.1	0.48 ± 2.76	< 10.0
SPMI-7526	MILK	Jul 1995	Cs-137	<3.7	0.98 ± 2.39	< 10.0
SPMI-7526	MILK	Jul 1995	I-131	<0.5	0.00 ± 0.23	< 0.5
SPMI-7526	MILK	Jul 1995	Sr-89	<0.6	-0.19 ± 0.82	< 5.0
SPMI-7526	MILK	Jul 1995	Sr-90	N/A	1.35 ± 0.36	< 1.0
Low level of Sr-90 concentration in milk (1-5 pCi/L) is not unusual.						
SPSO-11225	SOIL	Oct 1995	Cs-134	<0.034	0.00 ± 0.02	< 10.0
SPSO-11225	SOIL	Oct 1995	Cs-137	<0.019	-0.00 ± 0.01	< 10.0
SPSO-5131	SOIL	May 1995	Cs-134	<0.034	0.01 ± 0.01	< 10.0
SPSO-5131	SOIL	May 1995	Cs-137	<0.012	0.00 ± 0.01	< 10.0
SPVE-6007	VEGETATION	Jun 1995	I-131(g)	<0.009	0.00 ± 0.01	< 20.0
SPVE-7191	VEGETATION	Jul 1995	I-131(g)	<0.005	-0.00 ± 0.00	< 20.0
SPVE-728	VEGETATION	Jan 1995	I-131(g)	<12.0	2.33 ± 7.54	< 20.0
SPW-1106	WATER	Feb 1995	Ni-63	<12.0	0.25 ± 6.31	< 20.0
SPW-12080	WATER	Nov 1995	H-3	<149	23.01 ± 74.94	< 200.0
SPW-12082	WATER	Nov 1995	Co-60	<2.1	0.62 ± 1.13	< 10.0
SPW-12082	WATER	Nov 1995	Cs-134	<1.9	0.02 ± 1.28	< 10.0
SPW-12082	WATER	Nov 1995	Cs-137	<2.4	1.53 ± 1.22	< 10.0
SPW-12082	WATER	Nov 1995	Gr. Alpha	<0.6	0.19 ± 0.43	< 1.0
SPW-12082	WATER	Nov 1995	Gr. Beta	<1.7	0.06 ± 1.11	< 3.2
SPW-2545	WATER	Apr 1995	H-3	<169	97.76 ± 88.37	< 200.0
SPW-2651	WATER	Apr 1995	Co-60	<3.17	-1.08 ± 2.45	< 10.0
SPW-2651	WATER	Apr 1995	Cs-134	<3.32	0.29 ± 2.57	< 10.0
SPW-2651	WATER	Apr 1995	Cs-137	<3.56	-0.92 ± 2.64	< 10.0
SPW-285	WATER	Jan 1995	H-3	<165.0	-48.53 ± 84.76	< 200.0
SPW-288	WATER	Jan 1995	Co-60	<2.3	-0.11 ± 2.02	< 10.0
SPW-288	WATER	Jan 1995	Cs-134	<3.5	-0.19 ± 2.61	< 10.0

Table A-4. In-house "blank" samples.

Lab Code	Sample Type	Sample Date	Analysis	Concentration pCi/L ^a .		
				Teledyne Results (4.66 Sigma)		Acceptance Criteria (4.66 Sigma)
				LLD	Activity ^b	
SPW-288	WATER	Jan 1995	Cs-137	<4.7	0.98 ± 2.54	<10.0
SPW-3052	WATER	Mar 1995	Gr. Alpha	<0.6	0.49 ± 0.43	<1.0
SPW-3052	WATER	Apr 1995	Gr. Alpha	<0.7	0.23 ± 0.47	<1.0
SPW-3052	WATER	Mar 1995	Gr. Beta	<1.4	3.05 ± 0.98	<3.2
SPW-3052	WATER	Apr 1995	Gr. Beta	<1.7	-0.02 ± 1.09	<3.2
SPW-3590	WATER	May 1995	Fe-55	<602.0	0.00 ± 365.40	<1000.0
SPW-6011	WATER	Jun 1995	I-131	<0.4	-0.03 ± 0.19	<0.5
SPW-7570	WATER	Jul 1995	H-3	<164	51.58 ± 83.71	<200.0
SPW-8180	WATER	Jul 1995	Fe-55	<0.4	0.00 ± 0.27	<1000.0
SPW-8931	WATER	Aug 1995	Ra-228	<1.0	0.58 ± 0.61	<1.0
SPW-957	WATER	Feb 1995	Co-60	<3.7	-1.25 ± 3.02	<10.0
SPW-957	WATER	Feb 1995	Cs-134	<5.2	0.76 ± 2.77	<10.0
SPW-957	WATER	Feb 1995	Cs-137	<3.6	-1.38 ± 2.65	<10.0
SPW-9982	WATER	Sep 1995	Sr-89	<0.8	0.52 ± 0.76	<5.0
SPW-9982	WATER	Sep 1995	Sr-90	<0.4	0.21 ± 0.21	<1.0

^a Liquid sample results are reported in pCi/Liter, air filter sample results are in pCi/filter, charcoal sample results are in pCi/charcoal, and solid sample results are in pCi/kilogram.

^b The activity reported is the net activity result.

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
WW-62, 63	Jan, 1995	Gr. Beta	1.4160 ± 0.4220	1.2900 ± 0.4000	1.3530 ± 0.2907
WW-62, 63	Jan, 1995	H-3	22.5635 ± 80.8891	18.8029 ± 80.7140	20.6832 ± 57.1354
WW-41, 42	Jan, 1995	Gr. Alpha	5.0970 ± 2.5260	2.4790 ± 2.1920	3.7880 ± 1.6722
WW-41, 42	Jan, 1995	Gr. Beta	4.6720 ± 0.8260	4.9650 ± 0.8770	4.8185 ± 0.6024
WW-41, 42	Jan, 1995	H-3	30.0800 ± 81.2250	-47.0000 ± 77.7750	-8.4600 ± 56.2282
WW-41, 42	Jan, 1995	K-40	1.3840 ± 0.2076	1.7300 ± 0.2595	1.5570 ± 0.1662
WW-41, 42	Jan, 1995	Sr-89	-0.3474 ± 0.5730	-0.0685 ± 0.5382	-0.2079 ± 0.3931
WW-41, 42	Jan, 1995	Sr-90	0.2017 ± 0.2519	0.1389 ± 0.2174	0.1703 ± 0.1664
CF-20, 21	Jan, 1995	Be-7	0.4327 ± 0.1200	0.4741 ± 0.1250	0.4534 ± 0.0866
CF-20, 21	Jan, 1995	Gr. Beta	2.9120 ± 0.0930	2.9920 ± 0.0920	2.9520 ± 0.0654
CF-20, 21	Jan, 1995	K-40	4.0808 ± 0.3060	3.7714 ± 0.3050	3.9261 ± 0.2160
CF-20, 21	Jan, 1995	Sr-89	0.0013 ± 0.0043	0.0000 ± 0.0058	0.0007 ± 0.0036
CF-20, 21	Jan, 1995	Sr-90	0.0017 ± 0.0011	0.0026 ± 0.0015	0.0021 ± 0.0009
CW-105, 106	Jan, 1995	Gr. Beta	5.4370 ± 0.9970	6.1900 ± 1.0260	5.8135 ± 0.7153
CW-105, 106	Jan, 1995	Gr. Beta	0.0490 ± 0.4360	0.0590 ± 0.4360	0.0540 ± 0.3083
MI-83, 84	Jan, 1995	Co-60	-0.3330 ± 2.5300	0.6530 ± 2.1700	0.1600 ± 1.6666
MI-83, 84	Jan, 1995	Cs-137	-1.1400 ± 2.2700	0.0761 ± 1.8700	-0.5320 ± 1.4705
MI-83, 84	Jan, 1995	I-131(G)	-1.9100 ± 3.2000	1.4700 ± 2.4700	-0.2200 ± 2.0212
MI-187, 188	Jan, 1995	I-131	0.1496 ± 0.2574	0.2682 ± 0.3828	0.2089 ± 0.2306
MI-187, 188	Jan, 1995	K-40	1,573.0000 ± 138.0000	1,426.0000 ± 177.0000	1,499.5000 ± 112.2197
SW-213, 214	Jan, 1995	H-3	5,939.6340 ± 241.2390	6,091.2412 ± 232.8063	6,015.4376 ± 167.6269
WW-240, 241	Jan, 1995	H-3	39.8030 ± 80.3410	9.9510 ± 78.9420	24.8770 ± 56.3172
WW-316, 317	Jan, 1995	H-3	17,618.0000 ± 377.0000	17,390.0000 ± 381.0000	17,504.0000 ± 267.9972
MI-295, 296	Jan, 1995	Co-60	-1.0900 ± 2.3700	0.2510 ± 2.8000	-0.4195 ± 1.8342
MI-295, 296	Jan, 1995	Cs-134	-0.6360 ± 1.8100	0.7830 ± 2.4400	0.0735 ± 1.5190
MI-295, 296	Jan, 1995	Cs-137	0.5200 ± 1.8200	1.2900 ± 2.6800	0.9050 ± 1.6198
MI-295, 296	Jan, 1995	I-131	0.1300 ± 0.2600	0.2300 ± 0.3400	0.1800 ± 0.2140
MI-295, 296	Jan, 1995	I-131(g)	-0.3970 ± 2.3600	-0.0386 ± 4.3000	-0.2178 ± 2.4525
MI-295, 296	Jan, 1995	K-40	1,449.1000 ± 91.2000	1,311.8000 ± 108.0000	1,380.4500 ± 70.6779
MI-295, 296	Jan, 1995	La-140	0.6220 ± 1.6900	-1.1800 ± 2.5000	-0.2790 ± 1.5088
MI-295, 296	Jan, 1995	Sr-89	0.2267 ± 0.7985	0.1552 ± 0.9326	0.1909 ± 0.6139
MI-295, 296	Jan, 1995	Sr-90	1.3813 ± 0.3839	1.6174 ± 0.4296	1.4993 ± 0.2881
LW-609, 610	Jan, 1995	Gr. Beta	2.6380 ± 0.7310	1.6940 ± 0.6930	2.1660 ± 0.5036
LW-344, 345	Jan, 1995	Co-60	-0.1680 ± 1.8700	1.5200 ± 3.1100	0.6760 ± 1.8145
LW-344, 345	Jan, 1995	Cs-137	0.3820 ± 1.9200	-0.1570 ± 2.9500	0.1125 ± 1.7599
LW-344, 345	Jan, 1995	Gr. Beta	3.2810 ± 0.9440	3.3500 ± 0.9390	3.3155 ± 0.6657

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L*		
			First Result	Second Result	Averaged Result
MI-374, 375	Jan, 1995	I-131	-0.0572 ± 0.2162	-0.0743 ± 0.2780	-0.0658 ± 0.1761
MI-374, 375	Jan, 1995	K-40	1,250.0000 ± 150.0000	1,286.5000 ± 141.0000	1,268.2500 ± 102.9332
SW-463, 464	Jan, 1995	Gr. Beta	1.8970 ± 0.5970	1.9470 ± 0.6020	1.9220 ± 0.4239
SW-463, 464	Jan, 1995	H-3	35.5580 ± 80.3070	7.4860 ± 78.9880	21.5220 ± 56.3212
WWU-860, 861	Jan, 1995	Gr. Alpha	0.3000 ± 0.6000	0.2000 ± 0.3000	0.2500 ± 0.3354
WWU-860, 861	Jan, 1995	Gr. Beta	0.8450 ± 1.3200	1.7600 ± 1.3500	1.3025 ± 0.9440
WWU-860, 861	Jan, 1995	K-40	61.8050 ± 32.9000	70.9860 ± 36.2000	66.3955 ± 24.4584
SW-586, 587	Jan, 1995	Co-60	-2.1600 ± 2.2900	1.9400 ± 2.7500	-0.1100 ± 1.7893
SW-586, 587	Jan, 1995	Cs-137	0.5590 ± 2.3400	1.5000 ± 2.8800	1.0295 ± 1.8554
WW-547, 548	Jan, 1995	H-3	602.5630 ± 102.9290	619.5980 ± 103.5540	611.0805 ± 73.0031
SWT-715, 716	Jan, 1995	Gr. Beta	2.3000 ± 0.6000	2.3000 ± 0.5000	2.3000 ± 0.3905
SW-694, 695	Feb, 1995	Gr. Beta	3.9100 ± 0.7450	4.1790 ± 0.7550	4.0445 ± 0.5303
WW-736, 737	Feb, 1995	H-3	9,951.8722 ± 284.2655	10,200.7626 ± 287.5238	10,076.3174 ± 202.1613
WW-763, 764	Feb, 1995	H-3	584.4290 ± 101.0550	707.1020 ± 105.5380	645.7655 ± 73.0589
MI-881, 882	Feb, 1995	I-131	0.1760 ± 0.2567	0.1552 ± 0.2852	0.1656 ± 0.1919
MI-881, 882	Feb, 1995	K-40	1,340.4000 ± 164.0000	1,492.0000 ± 101.0000	1,416.2000 ± 96.3027
MI-838, 839	Feb, 1995	Co-60	0.9670 ± 2.6500	-0.4760 ± 3.8100	0.2455 ± 2.3205
MI-838, 839	Feb, 1995	Cs-134	-0.0557 ± 2.2800	-1.4200 ± 3.0900	-0.7379 ± 1.9201
MI-838, 839	Feb, 1995	Cs-137	-0.4380 ± 2.5500	-0.4370 ± 3.0900	-0.4375 ± 2.0032
MI-838, 839	Feb, 1995	I-131	0.1283 ± 0.1951	0.0880 ± 0.1984	0.1081 ± 0.1391
MI-838, 839	Feb, 1995	I-131(g)	-0.2560 ± 2.5800	-0.5630 ± 3.1800	-0.4095 ± 2.0475
MI-838, 839	Feb, 1995	K-40	1,298.6000 ± 99.4000	1,232.5000 ± 125.0000	1,265.5500 ± 79.8520
MI-838, 839	Feb, 1995	Sr-89	0.5302 ± 0.5774	0.5000 ± 0.6000	0.5151 ± 0.4164
MI-838, 839	Feb, 1995	Sr-90	0.8186 ± 0.2809	0.8000 ± 0.3000	0.8093 ± 0.2055
MI-937, 938	Feb, 1995	I-131	-0.0083 ± 0.1800	-0.0270 ± 0.1800	-0.0177 ± 0.1273
MI-937, 938	Feb, 1995	K-40	1,451.8000 ± 69.6000	1,456.6000 ± 141.0000	1,454.2000 ± 78.6212
SW-904, 905	Feb, 1995	H-3	640.3425 ± 104.5679	597.4040 ± 103.0233	618.8733 ± 73.3966
MI-1216, 1217	Feb, 1995	I-131	0.2640 ± 0.2740	0.1160 ± 0.2600	0.1900 ± 0.1889
MI-1216, 1217	Feb, 1995	K-40	1,583.0000 ± 131.0000	1,493.6000 ± 174.0000	1,538.3000 ± 108.9002
SW-1237, 1238	Feb, 1995	H-3	55.3942 ± 97.3964	4.8591 ± 95.3581	30.1267 ± 68.1528
SW-1264, 1265	Feb, 1995	H-3	67.0910 ± 81.1760	109.2630 ± 83.1440	88.1770 ± 58.1001
G-1343, 1344	Feb, 1995	Be-7	11.4490 ± 0.2850	11.8800 ± 0.2560	11.6645 ± 0.1915
G-1343, 1344	Feb, 1995	K-40	2.9844 ± 0.2420	3.0269 ± 0.2250	3.0057 ± 0.1652
SW-1494, 1495	Feb, 1995	Co-60	-2.1900 ± 4.1200	0.0565 ± 3.4400	-1.0668 ± 2.6837
SW-1494, 1495	Feb, 1995	Cs-137	3.4500 ± 3.6600	0.2430 ± 3.5700	1.8465 ± 2.5564
SW-1367, 1368	Feb, 1995	H-3	560.3183 ± 103.1109	606.1104 ± 104.7919	583.2144 ± 73.507

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
WW-1394, 1395	Feb, 1995	H-3	47.8810 ± 80.1790	-24.8930 ± 76.6250	11.4940 ± 55.4528
SWT-1515, 1516	Feb, 1995	Gr. Beta	2.4460 ± 0.5250	1.6920 ± 0.5000	2.0690 ± 0.3625
WW-1536, 1537	Feb, 1995	H-3	2,874.3025 ± 167.5000	2,924.0574 ± 168.6330	2,899.1800 ± 118.8416
WW-1563, 1564	Mar, 1995	H-3	33.5160 ± 82.6640	39.5490 ± 82.9570	36.5325 ± 58.5560
WW-1618, 1619	Mar, 1995	Co-60	2.8000 ± 1.5000	2.2000 ± 4.6000	2.5000 ± 2.4192
WW-1618, 1619	Mar, 1995	Cs-137	-0.9000 ± 1.7000	-2.5000 ± 3.2000	-1.7000 ± 1.8118
WW-1618, 1619	Mar, 1995	H-3	4,333.0000 ± 204.0000	4,457.0000 ± 206.0000	4,395.0000 ± 144.9586
MI-1663, 1664	Mar, 1995	Co-60	1.9500 ± 3.2400	-1.5300 ± 2.7200	0.2100 ± 2.1152
MI-1663, 1664	Mar, 1995	Cs-134	0.1690 ± 2.7700	-1.1300 ± 2.0500	-0.4805 ± 1.7230
MI-1663, 1664	Mar, 1995	Cs-137	-0.0737 ± 2.7400	0.9210 ± 2.4100	0.4237 ± 1.8245
MI-1663, 1664	Mar, 1995	I-131	0.1226 ± 0.2720	0.2261 ± 0.3010	0.1744 ± 0.2028
MI-1663, 1664	Mar, 1995	I-131(g)	-0.4090 ± 3.7100	0.1220 ± 3.4200	-0.1435 ± 2.5229
MI-1663, 1664	Mar, 1995	K-40	1,592.1000 ± 124.0000	1,555.6000 ± 118.0000	1,573.8500 ± 85.5862
MI-1663, 1664	Mar, 1995	La-140	-1.6500 ± 3.1000	-0.2240 ± 2.6800	-0.9370 ± 2.0489
MI-1663, 1664	Mar, 1995	Sr-89	0.5984 ± 0.6672	0.5889 ± 0.7467	0.5937 ± 0.5007
MI-1663, 1664	Mar, 1995	Sr-90	1.3624 ± 0.3718	1.5034 ± 0.4517	1.4329 ± 0.2925
WW-1684, 1685	Mar, 1995	Gr. Beta	4.9280 ± 0.7420	5.0100 ± 0.7400	4.9690 ± 0.5240
WW-1684, 1685	Mar, 1995	H-3	81.7160 ± 84.9140	85.7340 ± 85.1040	83.7250 ± 60.1105
LW-1707, 1708	Mar, 1995	Co-58	0.4070 ± 3.0300	0.0486 ± 2.8500	0.2278 ± 2.0799
LW-1707, 1708	Mar, 1995	Co-60	1.0600 ± 2.8900	1.5000 ± 2.7000	1.2800 ± 1.9775
LW-1707, 1708	Mar, 1995	Cs-134	-1.8600 ± 3.0500	-1.5400 ± 2.8300	-1.7000 ± 2.0803
LW-1707, 1708	Mar, 1995	Cs-137	2.5900 ± 2.9600	-1.3700 ± 2.5100	0.6100 ± 1.9405
LW-1707, 1708	Mar, 1995	Fe-59	5.5200 ± 6.1500	-6.6900 ± 6.1500	-0.5850 ± 4.3487
LW-1707, 1708	Mar, 1995	Gr. Beta	1.9570 ± 0.4850	2.1270 ± 0.4760	2.0420 ± 0.3398
LW-1707, 1708	Mar, 1995	I-131	0.2350 ± 0.2925	-0.0500 ± 0.2859	0.0925 ± 0.2045
LW-1707, 1708	Mar, 1995	I-131(g)	-0.6900 ± 6.6800	-0.6210 ± 6.2000	-0.6555 ± 4.5569
LW-1707, 1708	Mar, 1995	K-40	79.3000 ± 42.8000	75.3000 ± 39.2000	77.3000 ± 29.0193
LW-1707, 1708	Mar, 1995	La-140	-3.5900 ± 5.0900	1.2800 ± 4.5800	-1.1550 ± 3.4236
LW-1707, 1708	Mar, 1995	Mn-54	-1.9300 ± 3.1200	0.7640 ± 2.5200	-0.5830 ± 2.0053
LW-1707, 1708	Mar, 1995	Ru-103	-0.1320 ± 3.3400	-0.7770 ± 2.9700	-0.4545 ± 2.2348
LW-1707, 1708	Mar, 1995	Zn-65	-2.6700 ± 6.4700	-1.7400 ± 5.7700	-2.2050 ± 4.3346
LW-1707, 1708	Mar, 1995	Zr-Nb-95	-0.2680 ± 3.0600	-3.2400 ± 2.7200	-1.7540 ± 2.0471
SW-1762, 1763	Mar, 1995	H-3	104.4150 ± 89.3960	92.2110 ± 88.8390	98.3130 ± 63.0159
SO-1861, 1862	Mar, 1995	Cs-137	0.2587 ± 0.0414	0.2481 ± 0.0248	0.2534 ± 0.0241
SO-1861, 1862	Mar, 1995	K-40	11.7290 ± 0.5530	11.2500 ± 0.4990	11.4895 ± 0.3724
SO-1861, 1862	Mar, 1995	Ra-226	1.6890 ± 0.3970	1.5274 ± 0.2730	1.6082 ± 0.2409

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
SW-1919, 1920	Mar, 1995	H-3	-9.1230 ± 85.2000	66.6680 ± 88.8670	28.7725 ± 61.5556
SW-1919, 1920	Mar, 1995	H-3	-9.1230 ± 85.2005	66.6679 ± 88.8672	28.7725 ± 61.5559
WWU-2031, 2032	Mar, 1995	Gr. Alpha	1.9830 ± 2.2510	3.0330 ± 2.4400	2.5080 ± 1.6599
WWU-2031, 2032	Mar, 1995	Gr. Beta	1.2540 ± 1.9270	2.1120 ± 1.9680	1.6830 ± 1.3772
CW-1997, 1998	Mar, 1995	Gr. Beta	2.6670 ± 0.9880	2.3100 ± 1.3570	2.4885 ± 0.8393
CW-1997, 1998	Mar, 1995	Gr. Beta	-0.5301 ± 0.9521	0.6351 ± 1.1355	0.0525 ± 0.7409
AP-2784, 2785	Mar, 1995	Co-60	-0.0004 ± 0.0006	-0.0003 ± 0.0005	-0.0003 ± 0.0004
AP-2784, 2785	Mar, 1995	Cs-137	-0.0003 ± 0.0006	0.0001 ± 0.0004	-0.0001 ± 0.0004
MI-2083, 2084	Mar, 1995	I-131	0.0210 ± 0.1920	0.0150 ± 0.1850	0.0180 ± 0.1333
MI-2083, 2084	Mar, 1995	K-40	1,273.9000 ± 69.7000	1,328.9000 ± 59.8000	1,301.4000 ± 45.9188
MI-2083, 2084	Mar, 1995	Sr-90	1.5850 ± 0.4530	1.8040 ± 0.5520	1.6945 ± 0.3570
SW-2104, 2105	Mar, 1995	Gr. Beta	1.6690 ± 0.5320	1.7090 ± 0.5640	1.6890 ± 0.3877
SW-2200, 2201	Mar, 1995	H-3	33.7710 ± 85.6270	54.0340 ± 86.5810	43.9025 ± 60.8857
SW-2355, 2356	Mar, 1995	Co-60	0.6430 ± 1.5100	0.8670 ± 1.5800	0.7550 ± 1.0928
SW-2355, 2356	Mar, 1995	Cs-137	2.2000 ± 1.5400	0.0533 ± 1.8500	1.1267 ± 1.2035
AP-2453, 2454	Mar, 1995	Sr-89	0.0002 ± 0.0006	-0.0001 ± 0.0006	0.0000 ± 0.0004
AP-2453, 2454	Mar, 1995	Sr-90	0.0000 ± 0.0002	0.0001 ± 0.0003	0.0001 ± 0.0002
AP-2805, 2806	Mar, 1995	Co-60	-0.0001 ± 0.0004	0.0002 ± 0.0003	0.0000 ± 0.0002
AP-2805, 2806	Mar, 1995	Cs-137	0.0002 ± 0.0004	0.0000 ± 0.0004	0.0001 ± 0.0003
SW-2221, 2222	Mar, 1995	K-40	149.6900 ± 74.4000	119.3800 ± 46.7000	134.5350 ± 43.9211
PW-2248, 2249	Mar, 1995	H-3	154.6240 ± 91.0610	164.7520 ± 91.5110	159.6880 ± 64.5491
PW-2271, 2272	Mar, 1995	Co-60	-0.4760 ± 1.9800	-1.2100 ± 2.8900	-0.8430 ± 1.7516
PW-2271, 2272	Mar, 1995	Cs-137	0.9590 ± 2.0500	0.8750 ± 3.4600	0.9170 ± 2.0109
MI-2149, 2150	Apr, 1995	Co-60	-1.2100 ± 2.2200	0.6560 ± 2.6900	-0.2770 ± 1.7439
MI-2149, 2150	Apr, 1995	Cs-137	0.1650 ± 2.0400	2.3100 ± 2.2200	1.2375 ± 1.5075
MI-2149, 2150	Apr, 1995	I-131(G)	0.0888 ± 2.2200	0.3000 ± 2.5100	0.1944 ± 1.6754
WW-2313, 2314	Apr, 1995	Gr. Beta	0.5850 ± 0.4990	0.9810 ± 0.5230	0.7830 ± 0.3614
CW-2401, 2402	Apr, 1995	Gr. Beta	1.7069 ± 1.2973	3.4661 ± 1.4515	2.5865 ± 0.9734
CW-2401, 2402	Apr, 1995	Gr. Beta	0.0096 ± 1.1238	0.4760 ± 1.1031	0.2428 ± 0.7874
SL-2567, 2568	Apr, 1995	K-40	1.4123 ± 0.4360	1.7225 ± 0.3760	1.5674 ± 0.2879
WW-2432, 2433	Apr, 1995	H-3	-21.5803 ± 82.7489	2.6975 ± 83.9276	-9.4414 ± 58.9305
WW-2659, 2660	Apr, 1995	Gr. Beta	0.5450 ± 0.6040	0.3970 ± 0.4440	0.4710 ± 0.3748
WW-2659, 2660	Apr, 1995	H-3	38.3900 ± 87.4520	133.3540 ± 91.7350	85.8720 ± 63.3703
MI-2713, 2714	Apr, 1995	I-131	0.3870 ± 0.5277	0.1686 ± 0.2430	0.2778 ± 0.2905
MI-2713, 2714	Apr, 1995	K-40	1,420.9000 ± 137.0000	1,420.0000 ± 137.0000	1,420.4500 ± 96.8736
CW-2739, 2740	Apr, 1995	Gr. Beta	13.7987 ± 2.0770	14.3132 ± 2.1038	14.0560 ± 1.4782

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
CW-2739, 2740	Apr, 1995	Gr. Beta	5.0526 ± 1.5206	2.2742 ± 1.3431	3.6634 ± 1.0144
SW-2686, 2687	Apr, 1995	H-3	52.6753 ± 86.9675	2.0260 ± 84.5748	27.3506 ± 60.6552
WW-3447, 3448	Apr, 1995	Gr. Alpha	-0.2920 ± 1.6860	-1.4650 ± 1.6480	-0.8785 ± 1.1788
WW-3447, 3448	Apr, 1995	Gr. Beta	1.2340 ± 1.7000	3.1840 ± 1.8140	2.2090 ± 1.2430
CW-2835, 2836	Apr, 1995	Gr. Beta	1.9571 ± 1.4080	2.7378 ± 1.4641	2.3474 ± 1.0157
CW-2835, 2836	Apr, 1995	Gr. Beta	0.1817 ± 1.1916	0.8185 ± 1.2403	0.5001 ± 0.8600
CW-2918, 2919	Apr, 1995	Gr. Beta	5.3065 ± 1.6254	4.2821 ± 1.5611	4.7943 ± 1.1268
CW-2918, 2919	Apr, 1995	Gr. Beta	2.0988 ± 1.3349	0.7752 ± 1.2404	1.4370 ± 0.9111
F-3552, 3553	Apr, 1995	K-40	3.1142 ± 0.4410	2.8860 ± 0.2410	3.0001 ± 0.2513
F-3552, 3553	Apr, 1995	Sr-89	-0.0061 ± 0.0064	0.0011 ± 0.0080	-0.0025 ± 0.0051
F-3552, 3553	Apr, 1995	Sr-90	0.0023 ± 0.0029	0.0005 ± 0.0036	0.0014 ± 0.0023
SWT-3343, 3344	Apr, 1995	Gr. Beta	2.3310 ± 0.5190	2.9830 ± 0.4800	2.6570 ± 0.3535
G-3133, 3134	Apr, 1995	K-40	6.5000 ± 0.1740	6.0532 ± 0.3120	6.2766 ± 0.1786
SW-3403, 3404	Apr, 1995	H-3	159.5512 ± 90.5914	72.7069 ± 86.6327	116.1290 ± 62.6738
WW-3424, 3425	Apr, 1995	H-3	442.5093 ± 116.7309	430.4409 ± 116.3142	436.4751 ± 82.3940
LW-3682, 3683	Apr, 1995	Gr. Beta	2.0500 ± 0.5760	1.5240 ± 0.5500	1.7870 ± 0.3982
LW-3682, 3683	Apr, 1995	Gr. Beta	2.0501 ± 0.6760	1.5244 ± 0.5500	1.7872 ± 0.4358
LW-3682, 3683	Apr, 1995	H-3	139.9350 ± 91.1490	75.0380 ± 88.2140	107.4865 ± 63.4229
LW-3682, 3683	Apr, 1995	H-3	75.0378 ± 88.2143	139.9353 ± 91.1494	107.4865 ± 63.4231
SO-3531, 3532	May, 1995	Cs-137	0.1624 ± 0.0246	0.1418 ± 0.0306	0.1521 ± 0.0196
SO-3531, 3532	May, 1995	Gr. Alpha	6.8662 ± 3.5751	9.2164 ± 3.8687	8.0413 ± 2.6338
SO-3531, 3532	May, 1995	Gr. Beta	17.0973 ± 3.0829	18.8034 ± 3.1329	17.9503 ± 2.1977
SO-3531, 3532	May, 1995	K-40	25.0380 ± 0.7710	23.8180 ± 0.6600	24.4280 ± 0.5075
SO-3531, 3532	May, 1995	Sr-89	-0.0129 ± 0.0215	0.0014 ± 0.0202	-0.0057 ± 0.0147
SO-3531, 3532	May, 1995	Sr-90	0.0261 ± 0.0109	0.0122 ± 0.0093	0.0191 ± 0.0072
WW-3577, 3578	May, 1995	Co-60	-0.2530 ± 2.2200	0.5410 ± 2.5800	0.1440 ± 1.7018
WW-3577, 3578	May, 1995	Cs-137	1.1500 ± 2.2000	-1.6400 ± 2.9200	-0.2450 ± 1.8280
WW-3577, 3578	May, 1995	H-3	33.5750 ± 90.9827	58.7563 ± 92.0487	46.1657 ± 64.7125
MI-3598, 3599	May, 1995	I-131	0.2288 ± 0.3515	0.2122 ± 0.3043	0.2205 ± 0.2324
MI-3598, 3599	May, 1995	K-40	1,349.0000 ± 112.0000	1,297.4000 ± 151.0000	1,323.2000 ± 94.0013
MI-3809, 3810	May, 1995	Co-60	-0.3700 ± 2.9600	0.1820 ± 2.9600	-0.0940 ± 2.0930
MI-3809, 3810	May, 1995	Cs-137	0.9060 ± 2.5000	0.1380 ± 2.3600	0.5220 ± 1.7190
MI-3809, 3810	May, 1995	I-131	0.1445 ± 0.1573	0.1738 ± 0.2057	0.1592 ± 0.1295
CW-3838, 3839	May, 1995	Gr. Beta	1.9922 ± 1.3549	3.4291 ± 1.4650	2.7106 ± 0.9977
CW-3838, 3839	May, 1995	Gr. Beta	-0.7347 ± 1.2274	-1.0782 ± 1.2004	-0.9064 ± 0.8584
F-4309, 4310	May, 1995	Co-60	-0.0017 ± 0.0093	-0.0032 ± 0.0166	-0.0024 ± 0.0095

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
F-4309, 4310	May, 1995	Cs-137	0.0028 ± 0.0089	0.0012 ± 0.0133	0.0020 ± 0.0080
F-4288, 4289	May, 1995	Co-60	0.0038 ± 0.0097	0.0012 ± 0.0088	0.0025 ± 0.0065
F-4288, 4289	May, 1995	Cs-137	0.0002 ± 0.0067	0.0022 ± 0.0062	0.0012 ± 0.0045
F-4330, 4331	May, 1995	Co-60	0.0018 ± 0.0046	0.0031 ± 0.0050	0.0024 ± 0.0034
F-4330, 4331	May, 1995	Cs-137	0.0001 ± 0.0042	-0.0007 ± 0.0038	-0.0003 ± 0.0028
MI-4377, 4378	May, 1995	Co-60	0.9480 ± 1.7400	2.2200 ± 2.6600	1.5840 ± 1.5893
MI-4377, 4378	May, 1995	Cs-134	0.7830 ± 1.4900	-0.2080 ± 2.3000	0.2875 ± 1.3702
MI-4377, 4378	May, 1995	Cs-137	0.8740 ± 1.3800	0.6430 ± 2.1400	0.7585 ± 1.2732
MI-4377, 4378	May, 1995	I-131	-0.0785 ± 0.1490	-0.0420 ± 0.1498	-0.0602 ± 0.1056
MI-4377, 4378	May, 1995	I-131(g)	0.1700 ± 1.3000	-1.1200 ± 2.6200	-0.4750 ± 1.4624
MI-4377, 4378	May, 1995	K-40	1,385.1000 ± 63.2000	1,344.3000 ± 92.5000	1,364.7000 ± 56.0145
MI-4377, 4378	May, 1995	Sr-89	-0.0069 ± 0.7313	0.0069 ± 1.1490	0.0000 ± 0.6810
MI-4377, 4378	May, 1995	Sr-90	1.2729 ± 0.4414	1.3229 ± 0.6414	1.2979 ± 0.3893
MI-4544, 4545	May, 1995	I-131	0.0524 ± 0.2867	0.0574 ± 0.2367	0.0549 ± 0.1859
MI-4544, 4545	May, 1995	K-40	1,410.0000 ± 72.3000	1,359.0000 ± 65.7000	1,384.5000 ± 48.8461
MI-4544, 4545	May, 1995	Sr-90	2.1444 ± 0.5153	1.2741 ± 0.4112	1.7093 ± 0.3296
G-4604, 4605	May, 1995	Be-7	1.9338 ± 0.3520	1.7467 ± 0.3580	1.8403 ± 0.2510
G-4604, 4605	May, 1995	Co-60	-0.0112 ± 0.0217	-0.0175 ± 0.0189	-0.0144 ± 0.0144
G-4604, 4605	May, 1995	Cs-134	0.0076 ± 0.0165	0.0079 ± 0.0163	0.0078 ± 0.0116
G-4604, 4605	May, 1995	Cs-137	0.1303 ± 0.0332	0.1283 ± 0.0420	0.1293 ± 0.0268
G-4604, 4605	May, 1995	Gr. Beta	3.9523 ± 0.1425	3.9500 ± 0.1562	3.9512 ± 0.1057
G-4604, 4605	May, 1995	I-131(g)	0.0101 ± 0.0227	0.0055 ± 0.0263	0.0078 ± 0.0174
G-4604, 4605	May, 1995	K-40	5.1487 ± 0.6580	5.1002 ± 0.6970	5.1245 ± 0.4793
CW-4575, 4576	May, 1995	Gr. Beta	1.9783 ± 1.1888	2.8278 ± 1.2558	2.4030 ± 0.8646
CW-4575, 4576	May, 1995	Gr. Beta	-0.2059 ± 1.0000	-0.5589 ± 0.9721	-0.3824 ± 0.6973
MI-4695, 4696	May, 1995	I-131	0.1049 ± 0.1737	0.0942 ± 0.1607	0.0995 ± 0.1183
MI-4695, 4696	May, 1995	K-40	1,568.8000 ± 114.0000	1,573.1000 ± 50.1000	1,570.9500 ± 62.2616
MI-4716, 4717	May, 1995	Sr-89	-0.2701 ± 0.7584	-0.0499 ± 0.8752	-0.1600 ± 0.5790
MI-4716, 4717	May, 1995	Sr-90	1.1720 ± 0.4391	1.6280 ± 0.4432	1.4000 ± 0.3119
G-4814, 4815	May, 1995	Be-7	0.6081 ± 0.2520	0.5837 ± 0.1750	0.5959 ± 0.1534
G-4814, 4815	May, 1995	K-40	5.8319 ± 0.6100	5.1295 ± 0.5050	5.4807 ± 0.3960
WW-4784, 4785	May, 1995	H-3	18,665.3086 ± 390.2155	18,274.9314 ± 386.3294	18,470.1200 ± 274.5535
SW-4759, 4760	May, 1995	H-3	3,679.8217 ± 213.9409	3,817.7847 ± 217.0401	3,748.8032 ± 152.3787
SO-5178, 5179	May, 1995	Cs-137	0.8481 ± 0.0691	0.8110 ± 0.0710	0.8296 ± 0.0495
SO-5178, 5179	May, 1995	K-40	19.9200 ± 1.08	22.0860 ± 1.1800	21.0030 ± 0.7998
SWU-5663, 5664	May, 1995	Gr. Beta	2.4654 ± 0.61	2.5106 ± 0.6258	2.4880 ± 0.4404

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
SWU-5663, 5664	May, 1995	H-3	867.2182 ± 104.9067	865.5032 ± 104.8506	866.3607 ± 74.1604
BS - 6983, 6984	May, 1995	Gr. Beta	7.3555 ± 1.2333	8.0347 ± 1.4183	7.6951 ± 0.9397
BS - 6983, 6984	May, 1995	Gr. Beta	7.3555 ± 1.2333	8.0347 ± 1.4183	7.6951 ± 0.9397
BS - 6983, 6984	May, 1995	K-40	8.3490 ± 0.3090	8.5309 ± 0.0683	8.4400 ± 0.1582
BS - 6983, 6984	May, 1995	K-40	8.3490 ± 0.3090	8.5309 ± 0.0683	8.4400 ± 0.1582
BS-6983, 6984	May, 1995	Cs-137	0.0074 ± 0.0008	0.0094 ± 0.0024	0.0084 ± 0.0013
BS-6983, 6984	May, 1995	Gr. Beta	7.3555 ± 1.2333	8.0347 ± 1.4183	7.6951 ± 0.9397
FS-6983, 6984	May, 1995	K-40	8.3490 ± 0.3090	8.5309 ± 0.0683	8.4400 ± 0.1582
BS - 5494, 5495	May, 1995	Cs-137	0.5929 ± 0.0319	0.5876 ± 0.0378	0.5903 ± 0.0247
BS - 5494, 5495	May, 1995	Cs-137	0.5929 ± 0.0319	0.5876 ± 0.0378	0.5903 ± 0.0247
BS - 5494, 5495	May, 1995	K-40	21.0920 ± 0.6570	21.3050 ± 0.7070	21.1985 ± 0.4826
BS - 5494, 5495	May, 1995	K-40	21.0920 ± 0.6570	21.3050 ± 0.7070	21.1985 ± 0.4826
BS-5494, 5495	May, 1995	Cs-137	0.5929 ± 0.0319	0.5876 ± 0.0378	0.5903 ± 0.0247
BS-5494, 5495	May, 1995	K-40	21.0920 ± 0.6570	21.3050 ± 0.7070	21.1985 ± 0.4826
F-5025, 5026	May, 1995	Co-60	0.0024 ± 0.0064	0.0028 ± 0.0077	0.0026 ± 0.0050
F-5025, 5026	May, 1995	Cs-137	-0.0006 ± 0.0050	-0.0038 ± 0.0063	-0.0022 ± 0.0040
F-5385, 5386	May, 1995	K-40	2.5044 ± 0.3450	2.5992 ± 0.3830	2.5518 ± 0.2577
F-5046, 5047	May, 1995	Co-60	0.0012 ± 0.0067	-0.0021 ± 0.0073	-0.0004 ± 0.0049
F-5046, 5047	May, 1995	Cs-137	0.0018 ± 0.0053	-0.0003 ± 0.0046	0.0007 ± 0.0035
WW-5244, 5245	May, 1995	H-3	608.3574 ± 96.3200	463.5639 ± 91.1176	535.9606 ± 66.2947
SW-6013, 6014	May, 1995	Co-60	0.8080 ± 2.2000	1.5300 ± 3.0300	1.1690 ± 1.8722
SW-6013, 6014	May, 1995	Cs-137	-0.6750 ± 2.3000	0.4560 ± 2.3200	-0.1095 ± 1.6334
MI-5620, 5621	May, 1995	I-131	0.1589 ± 0.1736	0.0147 ± 0.1644	0.0868 ± 0.1196
MI-5620, 5621	May, 1995	K-40	1,526.2000 ± 119.0000	1,449.3000 ± 162.0000	1,487.7500 ± 100.5050
WW - 5642, 5643	May, 1995	Gr. Alpha	2.3120 ± 2.3250	2.3120 ± 2.3250	2.3120 ± 1.6440
WW - 5642, 5643	May, 1995	Gr. Beta	2.3120 ± 3.2540	2.3120 ± 3.2540	2.3120 ± 2.3009
WW - 5642, 5643	May, 1995	K-40	94.3550 ± 19.8000	58.9910 ± 29.5000	76.6730 ± 17.7644
DW-5738, 5739	May, 1995	Gr. Beta	2.5151 ± 1.1685	3.5614 ± 1.2103	3.0383 ± 0.8411
DW-5738, 5739	May, 1995	I-131	-0.0458 ± 0.1650	-0.0284 ± 0.1486	-0.0371 ± 0.1110
LW-6327, 6328	May, 1995	Gr. Beta	6.4501 ± 1.0293	6.6100 ± 1.0327	6.5300 ± 0.7290
W-6398, 6399	May, 1995	Sr-89	15.1044 ± 3.8169	18.1475 ± 2.7239	16.6259 ± 2.3446
W-6398, 6399	May, 1995	Sr-90	25.0828 ± 1.8532	24.4207 ± 1.3058	24.7518 ± 1.1335
WW-6184, 6185	Jun, 1995	Gr. Beta	6.0148 ± 1.1147	7.4613 ± 1.3560	6.7380 ± 0.8777
WW-6184, 6185	Jun, 1995	H-3	86.1439 ± 78.3469	106.9572 ± 79.2631	96.5505 ± 55.7245
MI-5684, 5685	Jun, 1995	Co-60	0.0976 ± 2.9600	0.4260 ± 4.6300	0.2618 ± 2.7477
MI-5684, 5685	Jun, 1995	Cs-137	1.8400 ± 2.6500	-0.9210 ± 3.2400	0.4595 ± 2.0929

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
MI-5684, 5685	Jun, 1995	I-131	0.0829 ± 0.1477	-0.0025 ± 0.1466	0.0402 ± 0.1041
CW-5713, 5714	Jun, 1995	Gr. Beta	3.1068 ± 1.4397	3.2557 ± 1.4487	3.1812 ± 1.0212
CW-5713, 5714	Jun, 1995	Gr. Beta	0.0491 ± 1.4849	0.3925 ± 1.5076	0.2208 ± 1.0580
SL-5832, 5833	Jun, 1995	Co-60	0.0410 ± 0.0114	0.0585 ± 0.0182	0.0498 ± 0.0107
SL-5832, 5833	Jun, 1995	Cs-137	0.0550 ± 0.0124	0.0499 ± 0.0215	0.0525 ± 0.0124
SL-5832, 5833	Jun, 1995	Gr. Beta	4.6800 ± 0.4800	4.6800 ± 0.4800	4.6800 ± 0.3394
SL-5832, 5833	Jun, 1995	K-40	2.9035 ± 0.2750	2.4429 ± 0.3290	2.6732 ± 0.2144
SL-5832, 5833	Jun, 1995	Sr-89	0.0106 ± 0.0261	0.0048 ± 0.0336	0.0077 ± 0.0213
SL-5832, 5833	Jun, 1995	Sr-90	0.0102 ± 0.0114	0.0164 ± 0.0148	0.0133 ± 0.0093
WW-5992, 5993	Jun, 1995	Co-60	0.3950 ± 1.2200	0.9060 ± 2.6500	0.6505 ± 1.4587
WW-5992, 5993	Jun, 1995	Cs-137	-1.4000 ± 1.3800	-1.4400 ± 3.0300	-1.4200 ± 1.6647
WW-5992, 5993	Jun, 1995	H-3	67.0084 ± 76.1576	94.0370 ± 77.3473	80.5227 ± 54.2738
SL-6205, 6206	Jun, 1995	Co-60	0.0029 ± 0.0088	0.0111 ± 0.0120	0.0070 ± 0.0074
SL-6205, 6206	Jun, 1995	Cs-134	0.0033 ± 0.0070	0.0002 ± 0.0096	0.0018 ± 0.0059
SL-6205, 6206	Jun, 1995	Cs-137	0.0138 ± 0.0091	0.0174 ± 0.0104	0.0156 ± 0.0069
SL-6205, 6206	Jun, 1995	Gr. Beta	3.3400 ± 0.1000	3.3400 ± 0.1000	3.3400 ± 0.0707
SL-6205, 6206	Jun, 1995	I-131(g)	-0.0060 ± 0.0135	-0.0003 ± 0.0197	-0.0031 ± 0.0119
SL-6205, 6206	Jun, 1995	K-40	3.3386 ± 0.3100	3.3294 ± 0.3780	3.3340 ± 0.2444
SW-6256, 6257	Jun, 1995	H-3	423.9034 ± 92.0134	585.0329 ± 97.8935	504.4682 ± 67.1744
MI-6277, 6278	Jun, 1995	I-131	0.0926 ± 0.1619	0.0532 ± 0.2284	0.0729 ± 0.1400
MI-6277, 6278	Jun, 1995	K-40	1,285.5000 ± 152.0000	1,355.2000 ± 114.0000	1,320.3500 ± 95.0000
SW-6232, 6233	Jun, 1995	H-3	68.3732 ± 79.4680	136.7465 ± 82.4296	102.5599 ± 57.2490
VE-6348, 6349	Jun, 1995	Gr. Alpha	0.3230 ± 0.0990	0.1780 ± 0.0520	0.2505 ± 0.0559
VE-6348, 6349	Jun, 1995	Gr. Beta	3.2970 ± 0.1410	3.4170 ± 0.0920	3.3570 ± 0.0842
VE-6348, 6349	Jun, 1995	K-40	3.1425 ± 0.3310	2.9775 ± 0.3350	3.0600 ± 0.2355
MI-6419, 6420	Jun, 1995	I-131	0.1154 ± 0.1633	0.1197 ± 0.1806	0.1175 ± 0.1217
MI-6419, 6420	Jun, 1995	K-40	1,457.2000 ± 175.0000	1,339.3000 ± 150.0000	1,398.2500 ± 115.2443
MI-6521, 6522	Jun, 1995	I-131	0.0534 ± 0.1511	0.0344 ± 0.1784	0.0439 ± 0.1169
MI-6521, 6522	Jun, 1995	K-40	1,475.4000 ± 123.0000	1,274.6000 ± 160.0000	1,375.0000 ± 100.9071
SL-6500, 6501	Jun, 1995	K-40	1.8001 ± 0.4550	2.1667 ± 0.5460	1.9834 ± 0.3554
MI-6446, 6447	Jun, 1995	Co-60	0.1640 ± 4.8700	0.4440 ± 2.8200	0.3040 ± 2.8138
MI-6446, 6447	Jun, 1995	Cs-137	1.3000 ± 3.3600	0.0563 ± 2.1800	0.6782 ± 2.0026
MI-6446, 6447	Jun, 1995	I-131	-0.0433 ± 0.2077	0.0000 ± 0.2377	-0.0217 ± 0.1578
CW-6474, 6475	Jun, 1995	Gr. Beta	2.8423 ± 1.4039	3.1674 ± 1.4145	3.0049 ± 0.9965
CW-6474, 6475	Jun, 1995	Gr. Beta	0.0000 ± 1.1519	0.0909 ± 1.1588	0.0455 ± 0.8170
MI-6564, 6565	Jun, 1995	I-131	0.2460 ± 0.2607	0.0948 ± 0.2353	0.1704 ± 0.1756

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
BS-6960, 6961	Jun, 1995	Cs-137	0.0752 ± 0.0292	0.0475 ± 0.0274	0.0613 ± 0.0200
BS-6960, 6961	Jun, 1995	K-40	17.6680 ± 0.8700	17.0190 ± 1.0600	17.3435 ± 0.6857
WW-6861, 6862	Jun, 1995	H-3	1,422.4460 ± 128.0232	1,505.1361 ± 130.2761	1,463.7910 ± 91.3261
MI-6840, 6841	Jun, 1995	I-131	0.1583 ± 0.2131	0.0509 ± 0.1801	0.1046 ± 0.1395
LW-6889, 6890	Jun, 1995	Co-60	-2.4000 ± 3.4100	1.4300 ± 1.7400	-0.4850 ± 1.9141
LW-6889, 6890	Jun, 1995	Cs-137	-0.5210 ± 3.0300	0.1410 ± 2.1900	-0.1900 ± 1.8693
LW-6889, 6890	Jun, 1995	Gr. Beta	3.0131 ± 0.8315	3.0285 ± 0.8358	3.0208 ± 0.5895
SW-7053, 7054	Jun, 1995	H-3	73.2226 ± 75.6858	126.8001 ± 78.1734	100.0114 ± 54.4046
SW-7011, 7012	Jun, 1995	H-3	203.5633 ± 81.5943	226.7766 ± 82.6041	215.1699 ± 58.0540
MI-7032, 7033	Jun, 1995	I-131	0.2720 ± 0.2879	-0.0925 ± 0.2629	0.0897 ± 0.1949
MI-7032, 7033	Jun, 1995	K-40	1,577.6000 ± 127.0000	1,522.8000 ± 164.0000	1,550.2000 ± 103.7123
SWU-7101, 7102	Jun, 1995	Gr. Beta	1.9679 ± 0.4592	2.1339 ± 0.5061	2.0509 ± 0.3417
SWU-7101, 7102	Jun, 1995	H-3	118.5873 ± 85.7967	92.6463 ± 84.6688	105.6168 ± 60.2700
SWU - 7828, 7829	Jun, 1995	Sr-89	0.5896 ± 0.7987	0.0977 ± 0.6691	0.3436 ± 0.5210
SWU - 7828, 7829	Jun, 1995	Sr-90	0.2398 ± 0.3028	0.1937 ± 0.2742	0.2168 ± 0.2042
SWU - 7828, 7829	Jun, 1995	Sr-90	0.2398 ± 0.3028	0.1937 ± 0.2742	0.2168 ± 0.2042
SWU-7828, 7829	Jun, 1995	Sr-89	0.5896 ± 0.7987	0.0977 ± 0.6691	0.3436 ± 0.5210
SWU-7828, 7829	Jun, 1995	Sr-89	0.5896 ± 0.7987	0.0977 ± 0.6691	0.3436 ± 0.5210
SWU-7828, 7829	Jun, 1995	Sr-89	0.5896 ± 0.7987	0.0977 ± 0.6691	0.3436 ± 0.5210
SWU-7828, 7829	Jun, 1995	Sr-89	0.5896 ± 0.7987	0.0977 ± 0.6691	0.3436 ± 0.5210
SWU-7828, 7829	Jun, 1995	Sr-90	0.2398 ± 0.3028	0.1937 ± 0.2742	0.2168 ± 0.2042
SWU-7828, 7829	Jun, 1995	Sr-90	0.2398 ± 0.3028	0.1937 ± 0.2742	0.2168 ± 0.2042
SWU-7828, 7829	Jun, 1995	Sr-90	0.2398 ± 0.3028	0.1937 ± 0.2742	0.2168 ± 0.2042
AP-8111, 8112	Jun, 1995	Co-60	-0.0002 ± 0.0007	0.0004 ± 0.0007	0.0001 ± 0.0005
AP-8111, 8112	Jun, 1995	Cs-137	-0.0002 ± 0.0007	0.0004 ± 0.0005	0.0001 ± 0.0004
SW-7080, 7081	Jun, 1995	Gr. Beta	2.3011 ± 0.5921	2.6708 ± 0.6113	2.4860 ± 0.4255
SW-7080, 7081	Jun, 1995	K-40	61.2620 ± 28.3000	95.4390 ± 26.0000	78.3505 ± 19.2152
WWT-7122, 7123	Jun, 1995	H-3	3.8386 ± 81.4299	-13.4353 ± 80.6115	-4.7983 ± 57.2910
LW-7239, 7240	Jun, 1995	Gr. Beta	2.5177 ± 0.0580	2.4081 ± 0.6061	2.4629 ± 0.3044
WW-7143, 7144	Jun, 1995	H-3	539.1386 ± 103.3228	436.4159 ± 99.5398	487.7772 ± 71.7352
PW-7174, 7175	Jun, 1995	H-3	144.0732 ± 84.2861	121.4242 ± 83.2655	132.7487 ± 59.2395
SW-7216, 7217	Jun, 1995	H-3	20.3728 ± 81.4069	62.9704 ± 83.3227	41.6716 ± 58.2446
WW-7281, 7282	Jun, 1995	Gr. Beta	1.8051 ± 0.3271	2.1056 ± 0.5796	1.9553 ± 0.3328
WW-7281, 7282	Jun, 1995	H-3	-24.3250 ± 75.1716	10.3381 ± 76.8357	-6.9934 ± 53.7459
SW-7381, 7388	Jul, 1995	Co-60	1.0200 ± 1.9000	0.1530 ± 1.6700	0.5865 ± 1.2648

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L*		
			First Result	Second Result	Averaged Result
SW-7387, 7388	Jul, 1995	Cs-137	0.5600 ± 2.3400	-0.8650 ± 2.0400	-0.1525 ± 1.5522
AP-8133, 8134	Jul, 1995	Co-60	-0.0000 ± 0.0005	0.0003 ± 0.0006	0.0001 ± 0.0004
AP-8133, 8134	Jul, 1995	Cs-137	-0.0001 ± 0.0004	0.0000 ± 0.0005	-0.0001 ± 0.0003
AP-7600, 7601	Jul, 1995	Sr-89	0.0008 ± 0.0008	0.0010 ± 0.0008	0.0009 ± 0.0005
AP-7600, 7601	Jul, 1995	Sr-90	-0.0001 ± 0.0003	0.0005 ± 0.0003	0.0002 ± 0.0002
MI-7260, 7261	Jul, 1995	Co-60	0.3390 ± 2.9100	0.5630 ± 5.2400	0.4510 ± 2.9969
MI-7260, 7261	Jul, 1995	Cs-137	1.6600 ± 2.5900	-1.4600 ± 3.3700	0.1000 ± 2.1251
MI-7260, 7261	Jul, 1995	I-131	0.1745 ± 0.1944	0.1004 ± 0.1792	0.1374 ± 0.1322
WW-7454, 7455	Jul, 1995	H-3	7,142.7529 ± 243.6211	6,985.4236 ± 241.2186	7,064.0882 ± 171.4188
LW-7487, 7488	Jul, 1995	K-40	48.0000 ± 14.4000	95.7520 ± 39.9000	71.8760 ± 21.2095
LW-7487, 7488	Jul, 1995	K-40	48.0000 ± 14.4000	95.7520 ± 39.9000	71.8760 ± 21.2095
LW-7487, 7488	Jul, 1995	Co-60	0.4460 ± 1.0700	0.3830 ± 3.0000	0.4145 ± 1.5926
LW-7487, 7488	Jul, 1995	Cs-134	0.1230 ± 1.0600	-2.3900 ± 3.0100	-1.1335 ± 1.5956
LW-7487, 7488	Jul, 1995	Cs-137	0.4920 ± 1.1000	-2.2200 ± 2.8400	-0.8640 ± 1.5228
LW-7487, 7488	Jul, 1995	Gr. Beta	2.1095 ± 0.4725	1.8520 ± 0.4810	1.9807 ± 0.3371
LW-7487, 7488	Jul, 1995	I-131	0.2323 ± 0.2677	-0.0343 ± 0.2508	0.0990 ± 0.1834
LW-7487, 7488	Jul, 1995	I-131(g)	0.3390 ± 2.4400	0.9230 ± 10.5000	0.6310 ± 5.3899
LW-7487, 7488	Jul, 1995	K-40	48.0000 ± 14.4000	95.7520 ± 39.9000	71.8760 ± 21.2095
LW-7487, 7488	Jul, 1995	K-40	48.0000 ± 14.4000	95.7520 ± 39.9000	71.8760 ± 21.2095
LW-7487, 7488	Jul, 1995	K-40	48.0000 ± 14.4000	95.7520 ± 39.9000	71.8760 ± 21.2095
LW-7487, 7488	Jul, 1995	K-40	48.0000 ± 14.4000	95.7520 ± 39.9000	71.8760 ± 21.2095
SW-7323, 7324	Jul, 1995	Gr. Beta	2.3224 ± 0.7511	2.5774 ± 0.7631	2.4499 ± 0.5354
SW-7323, 7324	Jul, 1995	H-3	77.8879 ± 83.9931	48.4345 ± 82.6045	63.1612 ± 58.9032
F-7366, 7367	Jul, 1995	Co-60	0.0092 ± 0.0141	0.0061 ± 0.0119	0.0076 ± 0.0092
F-7366, 7367	Jul, 1995	Cs-137	0.0115 ± 0.0108	0.0019 ± 0.0111	0.0067 ± 0.0077
MI-7510, 7511	Jul, 1995	I-131	0.3443 ± 0.3987	0.1361 ± 0.3508	0.2402 ± 0.2655
F-7344, 7345	Jul, 1995	Co-60	0.0037 ± 0.0077	-0.0071 ± 0.0119	-0.0017 ± 0.0071
F-7344, 7345	Jul, 1995	Cs-137	0.0023 ± 0.0057	0.0024 ± 0.0097	0.0023 ± 0.0056
MI-7429, 7430	Jul, 1995	I-131	-0.1525 ± 0.3171	0.1594 ± 0.2283	0.0035 ± 0.1953
F-8154, 8155	Jul, 1995	Gr. Beta	2.3081 ± 0.0743	2.2522 ± 0.0730	2.2802 ± 0.0521
F-8154, 8155	Jul, 1995	K-40	2.2313 ± 0.2640	2.1161 ± 0.4420	2.1737 ± 0.2574
MI-7575, 7576	Jul, 1995	Co-60	-1.0000 ± 2.8600	1.6000 ± 3.1700	0.3000 ± 2.1347
MI-7575, 7576	Jul, 1995	Cs-134	1.7300 ± 2.4200	-0.6220 ± 2.3600	0.5540 ± 1.6901
MI-7575, 7576	Jul, 1995	Cs-137	-0.7550 ± 2.5100	1.2800 ± 2.3800	0.2625 ± 1.7295
MI-7575, 7576	Jul, 1995	I-131	0.1795 ± 0.2309	0.0704 ± 0.2260	0.1250 ± 0.1616
MI-7575, 7576	Jul, 1995	I-131(g)	0.8570 ± 2.2400	0.8540 ± 2.4400	0.8555 ± 1.6561

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
MI-7575, 7576	Jul, 1995	K-40	1,481.9000 ± 111.0000	1,398.8000 ± 106.0000	1,440.3500 ± 76.7414
MI-7575, 7576	Jul, 1995	Sr-89	0.6192 ± 0.9862	-0.5435 ± 0.9244	0.0378 ± 0.6758
MI-7575, 7576	Jul, 1995	Sr-90	1.2363 ± 0.4155	1.7902 ± 0.4124	1.5133 ± 0.2927
WWT-7621, 7622	Jul, 1995	I-131	0.0940 ± 0.2062	0.0628 ± 0.2223	0.0784 ± 0.1516
MI-7739, 7740	Jul, 1995	Co-60	0.8900 ± 4.9100	-0.5720 ± 4.5800	0.1590 ± 3.3572
MI-7739, 7740	Jul, 1995	Cs-137	0.8600 ± 3.7300	-0.4130 ± 3.1400	0.2235 ± 2.4379
MI-7739, 7740	Jul, 1995	I-131	0.1928 ± 0.2674	-0.0475 ± 0.2351	0.0727 ± 0.1780
G-7805, 7806	Jul, 1995	Co-60	-0.0049 ± 0.0159	0.0015 ± 0.0156	-0.0017 ± 0.0111
G-7805, 7806	Jul, 1995	Cs-134	-0.0076 ± 0.0157	0.0025 ± 0.0094	-0.0025 ± 0.0091
G-7805, 7806	Jul, 1995	Cs-137	0.0045 ± 0.0140	0.0006 ± 0.0118	0.0026 ± 0.0092
G-7805, 7806	Jul, 1995	Gr. Beta	5.0973 ± 0.1994	5.1127 ± 0.2103	5.1050 ± 0.1449
G-7805, 7806	Jul, 1995	I-131(g)	-0.0048 ± 0.0205	-0.0183 ± 0.0205	-0.0115 ± 0.0145
G-7805, 7806	Jul, 1995	K-40	6.0481 ± 0.5610	5.8484 ± 0.5100	5.9483 ± 0.3791
CW-7648, 7649	Jul, 1995	Gr. Beta	6.6883 ± 1.7265	6.7478 ± 1.7419	6.7181 ± 1.2263
CW-7648, 7649	Jul, 1995	Gr. Beta	0.7444 ± 1.2623	0.2325 ± 1.2230	0.4885 ± 0.8788
CW-7648, 7649	Jul, 1995	H-3	-64.4182 ± 97.4643	-70.1870 ± 97.2364	-67.3026 ± 68.8371
WW-7673, 7674	Jul, 1995	Gr. Beta	14.1451 ± 2.2254	14.2212 ± 2.2315	14.1831 ± 1.5757
WW-7673, 7674	Jul, 1995	H-3	15.3145 ± 81.7571	36.3720 ± 82.7373	25.8432 ± 58.1586
MI-7896, 7897	Jul, 1995	Sr-89	0.3508 ± 0.9697	0.1856 ± 0.8702	0.2682 ± 0.6514
MI-7896, 7897	Jul, 1995	Sr-90	1.7110 ± 0.4271	1.2961 ± 0.3929	1.5036 ± 0.2902
WW-7967, 7968	Jul, 1995	H-3	109.4679 ± 84.6270	70.8322 ± 82.8444	90.1500 ± 59.2134
MI-7922, 7923	Jul, 1995	Co-60	0.5680 ± 3.1300	-1.0500 ± 4.4600	-0.2410 ± 2.7244
MI-7922, 7923	Jul, 1995	Cs-137	1.2100 ± 2.8600	-0.5040 ± 3.4200	0.3530 ± 2.2291
MI-7922, 7923	Jul, 1995	I-131	0.0502 ± 0.1932	0.0416 ± 0.2336	0.0459 ± 0.1516
LW-7944, 7945	Jul, 1995	Co-60	0.0830 ± 2.2000	1.3000 ± 1.8900	0.6915 ± 1.4502
LW-7944, 7945	Jul, 1995	Cs-137	0.6400 ± 2.2200	-1.3800 ± 1.8200	-0.3700 ± 1.4353
LW-7944, 7945	Jul, 1995	Gr. Beta	4.1332 ± 0.9251	3.9971 ± 0.9393	4.0652 ± 0.6592
SW-8704, 8705	Jul, 1995	Co-60	0.1830 ± 2.4900	0.9840 ± 1.7900	0.5835 ± 1.5333
SW-8704, 8705	Jul, 1995	Cs-137	0.2640 ± 3.4500	-0.6630 ± 1.9100	-0.1995 ± 1.9717
WW-8196, 8197	Jul, 1995	H-3	51.226 ± 87.9172	176.0234 ± 93.3551	113.7230 ± 64.1183
SWU-8318, 8319	Jul, 1995	Gr. Beta	1.9584 ± 0.4714	1.9228 ± 0.4731	1.9406 ± 0.3340
SWU-8318, 8319	Jul, 1995	H-3	102.7030 ± 103.6806	35.5141 ± 101.1620	69.1086 ± 72.4283
SWU-8318, 8319	Jul, 1995	K-40	93.2530 ± 39.7000	99.7420 ± 49.1000	96.4975 ± 31.5710
SP-8540, 8541	Jul, 1995	Gr. Alpha	5.1903 ± 1.3072	3.8567 ± 1.0701	4.5235 ± 0.8447
SP-8540, 8541	Jul, 1995	Sr-89	1,443.0886 ± 42.0809	1,419.4750 ± 35.3491	1,431.2818 ± 27.4789
SP-8540, 8541	Jul, 1995	Sr-90	15.7496 ± 3.7553	19.4328 ± 4.1309	17.5912 ± 2.7914

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
VE-8090, 8091	Jul, 1995	Gr. Beta	2.3819 ± 0.0781	2.3059 ± 0.0779	2.3439 ± 0.0552
VE-8090, 8091	Jul, 1995	K-40	2.8208 ± 0.1176	2.7639 ± 0.1330	2.7924 ± 0.0886
SW-8175, 8176	Jul, 1995	Gr. Alpha	0.5000 ± 0.6000	0.6583 ± 0.8198	0.5791 ± 0.5080
SW-8175, 8176	Jul, 1995	Gr. Beta	0.8100 ± 1.1000	0.8265 ± 1.0847	0.8182 ± 0.7724
SW-8175, 8176	Jul, 1995	K-40	89.8150 ± 23.8000	67.3590 ± 39.3000	78.5870 ± 22.9724
SW-8251, 8252	Jul, 1995	H-3	86.7952 ± 78.8856	43.9921 ± 76.9259	65.3937 ± 55.0921
SW-8606, 8607	Jul, 1995	Co-60	0.1320 ± 1.7100	-0.2180 ± 2.6000	-0.0430 ± 1.5560
SW-8606, 8607	Jul, 1995	Cs-137	-1.0400 ± 2.0400	-0.6580 ± 2.2400	-0.8490 ± 1.5149
G - 8272, 8273	Aug, 1995	K-40	6.7487 ± 0.6490	6.6636 ± 0.9730	6.7062 ± 0.5848
G - 8272, 8273	Aug, 1995	Sr-89	0.0014 ± 0.0091	-0.0007 ± 0.0029	0.0004 ± 0.0048
G - 8272, 8273	Aug, 1995	Sr-90	0.0023 ± 0.0029	0.0016 ± 0.0012	0.0034 ± 0.0016
G-8272, 8273	Aug, 1995	Gr. Beta	6.2167 ± 0.2594	5.9667 ± 0.2551	6.0917 ± 0.1819
MI-8293, 8294	Aug, 1995	I-131	-0.1058 ± 0.1908	0.0093 ± 0.2009	-0.0483 ± 0.1385
MI-8389, 8390	Aug, 1995		-0.0127 ± 0.1267	0.1153 ± 0.1318	0.0513 ± 0.0914
MI-8389, 8390	Aug, 1995	K-40	1,543.8000 ± 120.0000	1,369.6000 ± 162.0000	1,456.7000 ± 100.8018
MI-8413, 8414	Aug, 1995	Co-60	0.2940 ± 3.1400	-2.3500 ± 5.2200	-1.0280 ± 3.0458
MI-8413, 8414	Aug, 1995	Cs-137	-0.7370 ± 2.8900	-1.3600 ± 3.3100	-1.0485 ± 2.1971
MI-8413, 8414	Aug, 1995	I-131	0.1142 ± 0.2124	0.0598 ± 0.2344	0.0870 ± 0.1581
LW-8440, 8441	Aug, 1995	Co-60	0.1030 ± 2.3800	1.0300 ± 1.8100	0.5665 ± 1.4950
LW-8440, 8441	Aug, 1995	Cs-137	0.7760 ± 1.9900	0.3890 ± 2.0500	0.1935 ± 1.4285
LW-8440, 8441	Aug, 1995	Gr. Beta	3.3064 ± 1.1388	4.6623 ± 1.2154	3.9844 ± 0.8327
WW-8518, 8519	Aug, 1995	Co-60	1.4700 ± 3.1400	-1.8100 ± 2.9800	-0.1700 ± 2.1645
WW-8518, 8519	Aug, 1995	Cs-137	1.7100 ± 2.8700	0.4430 ± 2.7700	1.0765 ± 1.9944
WW-8518, 8519	Aug, 1995	H-3	10.6795 ± 74.0469	-19.5791 ± 72.5777	-4.4498 ± 51.8422
VE-8564, 8565	Aug, 1995	Co-60	0.0053 ± 0.0122	0.0054 ± 0.0128	0.0053 ± 0.0088
VE-8564, 8565	Aug, 1995	Cs-137	0.0038 ± 0.0093	-0.0003 ± 0.0082	0.0018 ± 0.0062
MI-8585, 8586	Aug, 1995	Co-60	-0.4810 ± 4.0600	1.8800 ± 2.5900	0.6995 ± 2.4079
MI-8585, 8586	Aug, 1995	Cs-134	0.1220 ± 3.5000	0.9370 ± 2.2700	0.5295 ± 2.0858
MI-8585, 8586	Aug, 1995	Cs-137	1.7700 ± 3.6400	0.2160 ± 2.0700	0.9930 ± 2.0937
MI-8585, 8586	Aug, 1995	I-131	-0.2002 ± 0.2079	0.0732 ± 0.1900	-0.0635 ± 0.1408
MI-8585, 8586	Aug, 1995	I-131(g)	0.1360 ± 9.0300	2.4300 ± 6.8100	1.2830 ± 5.6550
MI-8585, 8586	Aug, 1995	K-40	1,454.6000 ± 150.0000	1,478.2000 ± 104.0000	1,466.4000 ± 91.2634
MI-8585, 8586	Aug, 1995	Sr-89	0.1158 ± 1.1111	-0.0833 ± 0.9491	0.0162 ± 0.7306
MI-8585, 8586	Aug, 1995	Sr-90	1.9078 ± 0.4296	1.6029 ± 0.3807	1.7553 ± 0.2870
MI-8674, 8675	Aug, 1995	Co-60	-0.7910 ± 3.2300	0.4890 ± 3.3400	-0.1510 ± 2.3232
MI-8674, 8675	Aug, 1995	Cs-137	0.7690 ± 2.4300	0.4160 ± 2.4000	0.5925 ± 1.7077

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
MI-8674, 8675	Aug, 1995	I-131	0.1471 ± 0.2525	-0.0869 ± 0.2167	0.0301 ± 0.1664
SW-8648, 8649	Aug, 1995	H-3	35.5546 ± 75.1429	21.3328 ± 74.4670	28.4437 ± 52.8956
F-8754, 8755	Aug, 1995	Co-60	0.0009 ± 0.0110	0.0031 ± 0.0106	0.0020 ± 0.0076
F-8754, 8755	Aug, 1995	Cs-134	-0.0026 ± 0.0090	-0.0022 ± 0.0087	-0.0024 ± 0.0063
F-8754, 8755	Aug, 1995	Cs-137	0.0528 ± 0.0207	0.0563 ± 0.0171	0.0546 ± 0.0134
F-8754, 8755	Aug, 1995	Gr. Beta	13.1178 ± 0.3041	12.6488 ± 0.2780	12.8833 ± 0.2060
F-8754, 8755	Aug, 1995	I-131(g)	0.0026 ± 0.0139	0.0013 ± 0.0121	0.0019 ± 0.0092
F-8754, 8755	Aug, 1995	K-40	2.8119 ± 0.3670	3.2605 ± 0.3670	3.0362 ± 0.2595
VE-8946, 8947	Aug, 1995	Gr. Alpha	0.2000 ± 0.0800	0.2018 ± 0.0786	0.2009 ± 0.0561
VE-8946, 8947	Aug, 1995	Gr. Beta	4.3000 ± 0.1500	4.3179 ± 0.1511	4.3089 ± 0.1065
VE-8946, 8947	Aug, 1995	K-40	3.9615 ± 0.2670	4.0418 ± 0.3300	4.0017 ± 0.2122
VE - 8802, 8803	Aug, 1995	Sr-89	-0.0001 ± 0.0018	-0.0004 ± 0.0022	-0.0002 ± 0.0014
VE - 8802, 8803	Aug, 1995	Sr-90	0.0011 ± 0.0006	0.0013 ± 0.0007	0.0012 ± 0.0005
VE-8802, 8803	Aug, 1995	K-40	2.3052 ± 0.2360	2.3039 ± 0.3070	2.3046 ± 0.1936
MI-8845, 8846	Aug, 1995	I-131	0.0098 ± 0.1785	0.0835 ± 0.1740	0.0467 ± 0.1246
CW-8873, 8874	Aug, 1995	Gr. Beta	1.8586 ± 1.3992	4.2592 ± 1.5511	3.0589 ± 1.0445
CW-8873, 8874	Aug, 1995	Gr. Beta	-0.6043 ± 1.1348	-0.0465 ± 1.1799	-0.3254 ± 0.8185
MI-8902, 8903	Aug, 1995	I-131	-0.0387 ± 0.2325	0.1320 ± 0.3198	0.0466 ± 0.1977
VE-9035, 9036	Aug, 1995	K-40	2.1934 ± 0.2790	2.3847 ± 0.3380	2.2891 ± 0.2191
SW-9056, 9057	Aug, 1995	H-3	140.7425 ± 79.5937	55.2281 ± 75.6687	97.9853 ± 54.9111
MI-9113, 9114	Aug, 1995	I-131	0.2205 ± 0.3289	0.2711 ± 0.2835	0.2458 ± 0.2171
LW-9079, 9080	Aug, 1995	Co-60	0.8410 ± 2.8400	0.1630 ± 2.9900	0.5020 ± 2.0619
LW-9079, 9080	Aug, 1995	Cs-137	0.7700 ± 2.7700	-0.5330 ± 2.6700	0.1185 ± 1.9237
LW-9079, 9080	Aug, 1995	Gr. Beta	2.7566 ± 0.8607	2.6961 ± 0.8549	2.7264 ± 0.6065
SW-9183, 9184	Aug, 1995	Co-60	-0.3280 ± 3.0000	2.2200 ± 4.0400	0.9460 ± 2.5160
SW-9183, 9184	Aug, 1995	Cs-137	0.8200 ± 3.4400	0.2580 ± 4.3700	0.5390 ± 2.7808
SWU-9162, 9163	Aug, 1995	Gr. Beta	2.5000 ± 0.5000	2.5094 ± 0.5480	2.5047 ± 0.3709
SWU-9162, 9163	Aug, 1995	H-3	152.0000 ± 88.0000	157.4341 ± 83.7394	154.7170 ± 60.7377
WW-9276, 9277	Aug, 1995	H-3	1,636.0299 ± 130.9904	1,680.8118 ± 132.2095	1,658.4209 ± 93.0562
VE-9210, 9211	Aug, 1995	Gr. Beta	4.1000 ± 0.2000	4.0920 ± 0.1675	4.0960 ± 0.1304
VE-9210, 9211	Aug, 1995	K-40	4.6449 ± 0.1090	4.6203 ± 0.1150	4.6326 ± 0.0792
DW-9371, 9372	Aug, 1995	Gr. Beta	4.9900 ± 1.1960	4.5327 ± 1.1679	4.7613 ± 0.8358
DW-9371, 9372	Aug, 1995	I-131	0.1312 ± 0.2093	0.1381 ± 0.1961	0.1346 ± 0.1434
MI-9297, 9298	Aug, 1995	I-131	0.0434 ± 0.1996	0.0510 ± 0.2134	0.0472 ± 0.1461
MI-9297, 9298	Aug, 1995	K-40	1,727.8000 ± 180.0000	1,602.7000 ± 172.0000	1,665.2500 ± 124.4829
WW-9252, 9253	Sep, 1995	H-3	530.8948 ± 98.7085	538.0449 ± 98.9671	534.4698 ± 69.8889

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
MI-9327, 9328	Sep, 1995	I-131	0.1442 ± 0.1680	0.0972 ± 0.1575	0.1207 ± 0.1151
WW-9396, 9397	Sep, 1995	Co-60	2.0600 ± 2.4700	0.6870 ± 2.9500	1.3735 ± 1.9238
WW-9396, 9397	Sep, 1995	Cs-137	2.6700 ± 2.7300	0.7790 ± 2.5900	1.7245 ± 1.8816
WW-9396, 9397	Sep, 1995	Gr. Beta	0.6947 ± 1.3597	1.7640 ± 1.3095	1.2293 ± 0.9439
WW-9396, 9397	Sep, 1995	H-3	14.9063 ± 76.6085	48.8927 ± 78.1795	31.8995 ± 54.7287
SW - 10075, 10076	Sep, 1995	H-3	262.0954 ± 87.9940	265.6857 ± 88.1404	263.8905 ± 62.2730
SW - 10075, 10076	Sep, 1995	Sr-89	-1.1140 ± 0.9865	0.7627 ± 0.9505	-0.1756 ± 0.6849
SW - 10075, 10076	Sep, 1995	Sr-90	0.6409 ± 0.2630	0.3425 ± 0.2113	0.4917 ± 0.1687
MI-9350, 9351	Sep, 1995	I-131	-0.0990 ± 0.1565	0.0745 ± 0.1638	-0.0123 ± 0.1133
MI-9350, 9351	Sep, 1995	K-40	1,335.3000 ± 163.0000	1,521.4000 ± 179.0000	1,428.3500 ± 121.0475
MI - 9463, 9464	Sep, 1995	I-131	0.1059 ± 0.1889	0.0550 ± 0.1695	0.0804 ± 0.1269
MI-9463, 9464	Sep, 1995	K-40	1,814.9000 ± 139.0000	1,743.1000 ± 180.0000	1,779.0000 ± 113.7113
BS - 9710, 9711	Sep, 1995	K-40	8.3415 ± 0.3890	8.7853 ± 0.3190	8.5634 ± 0.2515
CW - 9486, 9487	Sep, 1995	Gr. Beta	0.3695 ± 1.1728	-0.8827 ± 1.4122	-0.2566 ± 0.9179
CW-9486, 9487	Sep, 1995	Gr. Beta	3.1540 ± 1.5156	3.4306 ± 1.5908	3.2923 ± 1.0986
SO - 9562, 9563	Sep, 1995	Cs-137	0.4189 ± 0.0216	0.4786 ± 0.0443	0.4488 ± 0.0246
SO - 9562, 9563	Sep, 1995	K-40	14.9730 ± 0.4070	15.6780 ± 0.6540	15.3255 ± 0.3852
VE-9515, 9516	Sep, 1995	Co-60	-0.0018 ± 0.0107	-0.0046 ± 0.0074	-0.0032 ± 0.0065
VE-9515, 9516	Sep, 1995	Cs-137	-0.0003 ± 0.0080	-0.0017 ± 0.0071	-0.0010 ± 0.0054
MI-9611, 9612	Sep, 1995	I-131	0.1395 ± 0.2011	0.0905 ± 0.2020	0.1150 ± 0.1425
MI-9611, 9612	Sep, 1995	K-40	1,463.6000 ± 163.0000	1,381.6000 ± 117.0000	1,422.6000 ± 100.3220
SW-9583, 9584	Sep, 1995	H-3	191.7867 ± 84.3836	59.5611 ± 78.5845	125.6739 ± 57.6544
LW - 9632, 9633	Sep, 1995	Gr. Beta	4.9397 ± 0.8738	4.1679 ± 0.7956	4.5538 ± 0.5909
LW-9632, 9633	Sep, 1995	Co-60	0.2420 ± 2.5400	0.6900 ± 1.8800	0.4660 ± 1.5800
LW-9632, 9633	Sep, 1995	Cs-134	-0.9850 ± 2.5000	0.2670 ± 2.3000	-0.3590 ± 1.6985
LW-9632, 9633	Sep, 1995	Cs-137	0.7330 ± 2.7300	1.9600 ± 2.0000	1.3465 ± 1.6921
LW-9632, 9633	Sep, 1995	I-131	-0.0233 ± 0.1923	0.1754 ± 0.2465	0.0761 ± 0.1563
LW-9632, 9633	Sep, 1995	I-131(g)	-1.2000 ± 7.8600	-1.7800 ± 6.9200	-1.4900 ± 5.2361
LW-9632, 9633	Sep, 1995	K-40	73.2000 ± 35.1000	84.4840 ± 38.9000	78.8420 ± 26.1974
MI-9677, 9678	Sep, 1995	I-131	0.1492 ± 0.1575	-0.0782 ± 0.2124	0.0355 ± 0.1322
MI-9677, 9678	Sep, 1995	K-40	1,579.6000 ± 149.0000	1,387.5000 ± 150.0000	1,483.5500 ± 105.7131
CW-9654, 9655	Sep, 1995	Gr. Beta	3.8956 ± 1.4702	4.0324 ± 1.4561	3.9640 ± 1.0346
CW-9654, 9655	Sep, 1995	Gr. Beta	-0.4258 ± 1.0721	0.1637 ± 1.0778	-0.1311 ± 0.7601
MI-9758, 9759	Sep, 1995	Co-60	0.0531 ± 2.3000	-1.0600 ± 5.6200	-0.5035 ± 3.0362
MI-9758, 9759	Sep, 1995	Cs-137	0.1530 ± 2.1000	3.3300 ± 4.1300	1.7415 ± 2.3166
MI-9758, 9759	Sep, 1995	I-131	0.0357 ± 0.1262	0.1303 ± 0.1374	0.0830 ± 0.0933

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L'		
			First Result	Second Result	Averaged Result
VE-9781, 9782	Sep, 1995	K-40	3.6858 ± 0.3040	3.8621 ± 0.3830	3.7740 ± 0.2445
WW - 9917, 9918	Sep, 1995	Gr. Alpha	1.0000 ± 1.2000	0.1895 ± 1.3470	0.3948 ± 0.9020
WW - 9917, 9918	Sep, 1995	Gr. Beta	2.0000 ± 1.6000	1.4626 ± 1.5372	1.7313 ± 1.1094
WW - 9917, 9918	Sep, 1995	K-40	61.5990 ± 27.2000	55.4580 ± 30.1000	58.5285 ± 20.2845
SWU - 10054, 10055	Sep, 1995	Gr. Beta	2.8699 ± 0.6506	2.9815 ± 0.6273	2.9257 ± 0.4519
SWU - 10054, 10055	Sep, 1995	H-3	272.2258 ± 86.5578	186.8216 ± 82.9725	229.5237 ± 59.9514
CW-9848, 9849	Sep, 1995	Gr. Beta	10.0958 ± 2.0529	10.6091 ± 2.0035	10.3525 ± 1.4343
CW-9848, 9849	Sep, 1995	Gr. Beta	0.6483 ± 1.1139	0.0874 ± 1.0548	0.3678 ± 0.7670
CW-9848, 9849	Sep, 1995	H-3	2.3592 ± 75.6414	-2.9490 ± 75.3926	-0.2949 ± 53.3987
MI-9873, 9874	Sep, 1995	I-131	0.1317 ± 0.1666	0.2502 ± 0.2503	0.1909 ± 0.1503
SW - 10174, 10175	Sep, 1995	Co-60	-0.2100 ± 1.9300	0.0995 ± 3.2500	-0.0553 ± 1.8899
SW - 10174, 10175	Sep, 1995	Cs-137	-0.0756 ± 2.9100	-0.1070 ± 2.8500	-0.0913 ± 2.0366
WW-9988, 9989	Sep, 1995	H-3	126.1391 ± 81.1795	18.2725 ± 76.3358	72.2058 ± 55.7164
SWT - 10033, 10034	Sep, 1995	Gr. Beta	1.7710 ± 0.4680	1.9280 ± 0.4610	1.8495 ± 0.3285
P-10216, 10217	Sep, 1995	H-3	76.4356 ± 78.6697	74.6580 ± 78.5893	75.5468 ± 55.5994
SW-10261, 10262	Sep, 1995	H-3	279.1447 ± 88.4376	300.6173 ± 89.3023	289.8810 ± 62.8413
VE - 10012, 10013	Sep, 1995	Gr. Beta	5.6577 ± 0.3023	5.0000 ± 0.4415	5.3288 ± 0.2675
MI-10120, 10121	Sep, 1995	I-131	0.1055 ± 0.1292	0.0027 ± 0.1196	0.0541 ± 0.0880
MI-10120, 10121	Sep, 1995	K-40	1,446.6000 ± 163.0000	1,300.9000 ± 145.0000	1,373.7500 ± 109.0802
SW-10195, 10196	Sep, 1995	H-3	-19.5632 ± 74.6957	103.1512 ± 80.3270	41.7940 ± 54.8450
CW - 10240, 10241	Sep, 1995	Gr. Beta	2.7919 ± 1.4430	3.6514 ± 1.5144	3.2216 ± 1.0459
CW - 10240, 10241	Sep, 1995	Gr. Beta	0.5909 ± 1.1545	2.4180 ± 1.3151	1.5045 ± 0.8750
SW-10150, 10151	Sep, 1995	H-3	119.1208 ± 81.0078	129.7884 ± 81.4747	124.4546 ± 57.4465
SW - 10282, 10283	Oct, 1995	Gr. Beta	2.1771 ± 0.4791	1.8939 ± 0.4661	2.0355 ± 0.3342
WW - 10349, 10350	Oct, 1995	H-3	64.9002 ± 80.1767	47.3596 ± 79.4055	56.1299 ± 56.4215
WW-10349, 10350	Oct, 1995	Co-60	0.0850 ± 1.2400	1.4900 ± 2.0900	0.7875 ± 1.2151
WW-10349, 10350	Oct, 1995	Cs-137	0.7540 ± 1.1500	0.0703 ± 2.2400	0.4122 ± 1.2590
VE-10370, 10371	Oct, 1995	K-40	3.3443 ± 0.4620	3.2897 ± 0.4770	3.3170 ± 0.3320
F-10491, 10492	Oct, 1995	Co-60	-0.0087 ± 0.0120	0.0051 ± 0.0078	-0.0018 ± 0.0072
F-10491, 10492	Oct, 1995	Cs-137	-0.0053 ± 0.0105	-0.0009 ± 0.0056	-0.0031 ± 0.0059
AP - 10752, 10753	Oct, 1995	Co-60	-0.0006 ± 0.0006	-0.0007 ± 0.0005	-0.0007 ± 0.0004
AP - 10752, 10753	Oct, 1995	Cs-134	0.0007 ± 0.0004	0.0003 ± 0.0007	0.0005 ± 0.0004
AP - 10752, 10753	Oct, 1995	Cs-137	-0.0004 ± 0.0005	0.0000 ± 0.0005	-0.0002 ± 0.0003
AP - 10752, 10753	Oct, 1995	I-131(g)	0.0016 ± 0.0034	-0.0005 ± 0.0047	0.0005 ± 0.0029
AP - 10752, 10753	Oct, 1995	K-40	0.0344 ± 0.0103	0.0436 ± 0.0113	0.0390 ± 0.0076
AP - 11141, 11142	Oct, 1995	Co-60	0.0001 ± 0.0004	0.0002 ± 0.0007	0.0001 ± 0.0002

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
AP - 11141, 11142	Oct, 1995	Cs-137	0.0000 ± 0.0003	0.0003 ± 0.0004	0.0002 ± 0.0002
MI - 10324, 10325	Oct, 1995	Co-60	0.3420 ± 2.2000	-1.0200 ± 3.2000	-0.3390 ± 1.9416
MI - 10324, 10325	Oct, 1995	Cs-134	1.4400 ± 1.9300	-1.0300 ± 2.5800	0.2050 ± 1.6110
MI - 10324, 10325	Oct, 1995	Cs-137	0.3320 ± 2.0800	0.9930 ± 2.5600	0.6625 ± 1.6492
MI - 10324, 10325	Oct, 1995	I-131	0.1255 ± 0.1379	0.0629 ± 0.2061	0.0942 ± 0.1240
MI - 10324, 10325	Oct, 1995	I-131(g)	-0.8920 ± 2.6900	1.1700 ± 3.2900	0.1390 ± 2.1249
MI - 10324, 10325	Oct, 1995	K-40	1,440.7000 ± 88.9000	1,432.5000 ± 120.0000	1,436.6000 ± 74.6713
MI - 10324, 10325	Oct, 1995	Sr-89	-0.4912 ± 0.9456	-1.3268 ± 0.8823	-0.9090 ± 0.6466
MI - 10324, 10325	Oct, 1995	Sr-90	1.6952 ± 0.3864	1.7252 ± 0.3803	1.7102 ± 0.2711
WWU-10392, 10393	Oct, 1995	I-131	0.0442 ± 0.1674	0.0223 ± 0.1698	0.0333 ± 0.1192
F-10470, 10471	Oct, 1995	Co-60	0.0049 ± 0.0063	0.0037 ± 0.0052	0.0043 ± 0.0041
F-10470, 10471	Oct, 1995	Cs-137	0.0003 ± 0.0050	0.0020 ± 0.0037	0.0011 ± 0.0031
SW - 10413, 10414	Oct, 1995	H-3	41.1376 ± 77.3777	62.2941 ± 78.3358	51.759 ± 55.0541
WW-10437, 10438	Oct, 1995	H-3	81.6446 ± 78.1486	-10.6493 ± 73.8374	35.4977 ± 53.7568
MI - 10512, 10513	Oct, 1995	I-131	0.0662 ± 0.1335	0.0996 ± 0.1517	0.0829 ± 0.1010
SO - 10577, 10578	Oct, 1995	Co-60	0.0033 ± 0.0117	0.0032 ± 0.0142	0.0033 ± 0.0092
SO - 10577, 10578	Oct, 1995	Cs-134	0.0204 ± 0.0110	0.0277 ± 0.0128	0.0241 ± 0.0084
SO - 10577, 10578	Oct, 1995	Cs-137	0.1528 ± 0.0249	0.1687 ± 0.0241	0.1608 ± 0.0173
SO - 10577, 10578	Oct, 1995	Gr. Beta	18.4120 ± 3.0080	20.0560 ± 3.0020	19.2340 ± 2.1249
SO - 10577, 10578	Oct, 1995	K-40	19.0300 ± 0.5920	18.4690 ± 0.6160	18.7495 ± 0.4272
MI - 10598, 10599	Oct, 1995	I-131	0.0233 ± 0.1528	-0.1143 ± 0.1290	-0.0455 ± 0.1000
F - 10666, 10667	Oct, 1995	Co-60	-0.0011 ± 0.0149	0.0022 ± 0.0134	0.0005 ± 0.0100
F - 10666, 10667	Oct, 1995	Cs-137	0.0062 ± 0.0109	0.0088 ± 0.0102	0.0075 ± 0.0075
WW - 11206, 11207	Oct, 1995	H-3	144.1480 ± 82.0522	298.7082 ± 106.1128	221.4281 ± 67.0681
F - 10687, 10688	Oct, 1995	Co-60	-0.0056 ± 0.0092	0.0052 ± 0.0111	-0.0002 ± 0.0072
F - 10687, 10688	Oct, 1995	Cs-137	0.0051 ± 0.0081	-0.0007 ± 0.0102	0.0022 ± 0.0065
MI - 10710, 10711	Oct, 1995	I-131	-0.0702 ± 0.1760	0.0060 ± 0.1746	-0.0321 ± 0.1240
WW - 10797, 10798	Oct, 1995	H-3	255.7388 ± 88.0244	190.9283 ± 85.4061	223.3336 ± 61.3239
F - 10882, 10883	Oct, 1995	K-40	2.4355 ± 0.2770	2.3158 ± 0.4530	2.3757 ± 0.2655
CW - 10826, 10827	Oct, 1995	Gr. Beta	1.9841 ± 1.3273	1.1082 ± 1.2551	1.5461 ± 0.9134
SWU - 10923, 10924	Oct, 1995	Gr. Beta	2.3790 ± 0.5752	2.7204 ± 0.5897	2.5497 ± 0.4119
SWU - 10923, 10924	Oct, 1995	H-3	908.5097 ± 108.7289	878.3050 ± 107.7372	893.4074 ± 76.5331
F - 10969, 10970	Oct, 1995	Cs-137	0.0391 ± 0.0173	0.0589 ± 0.0281	0.0490 ± 0.0165
F - 10969, 10970	Oct, 1995	Gr. Beta	2.3088 ± 0.6750	2.1970 ± 0.0758	2.2529 ± 0.0533
F - 10969, 10970	Oct, 1995	K-40	2.1279 ± 0.3500	1.8750 ± 0.4010	2.0015 ± 0.2661
CW - 10773, 10774	Oct, 1995	Gr. Beta	8.4208 ± 1.8580	9.9060 ± 2.0352	9.1634 ± 1.3779

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
CW - 10773, 10774	Oct, 1995	Gr. Beta	-0.2668 ± 1.0986	0.8745 ± 1.1142	0.3039 ± 0.7824
CW - 10773, 10774	Oct, 1995	H-3	51.6603 ± 77.7745	67.5106 ± 78.4891	59.5854 ± 55.2481
CW - 10858, 10859	Oct, 1995	Gr. Beta	3.8461 ± 1.5209	5.5313 ± 1.6346	4.6887 ± 1.1163
CW - 10858, 10859	Oct, 1995	Gr. Beta	0.1646 ± 1.1055	-0.2698 ± 1.0572	-0.0526 ± 0.7648
BS - 11056, 11057	Oct, 1995	Cs-137	0.3037 ± 0.0214	0.3183 ± 0.0167	0.3110 ± 0.0136
BS - 11056, 11057	Oct, 1995	K-40	18.5050 ± 0.4060	18.2890 ± 0.3850	18.3970 ± 0.2798
F - 11078, 11079	Oct, 1995	K-40	2.6694 ± 0.1700	2.7062 ± 0.1140	2.6878 ± 0.1023
CW - 11261, 11262	Oct, 1995	Gr. Beta	3.4182 ± 1.5101	3.8050 ± 1.4573	3.6116 ± 1.0493
CW - 11261, 11262	Oct, 1995	Gr. Beta	-0.9607 ± 0.9909	-0.1199 ± 1.1241	-0.5403 ± 0.7492
MI - 11162, 11163	Oct, 1995	I-131	0.2163 ± 0.2174	0.0872 ± 0.2019	0.1517 ± 0.1483
LW - 11185, 11186	Oct, 1995	Co-60	0.2560 ± 2.0000	0.0639 ± 3.9000	0.1600 ± 2.1915
LW - 11185, 11186	Oct, 1995	Cs-137	0.9690 ± 1.9600	1.3800 ± 3.2600	1.1745 ± 1.9019
LW - 11185, 11186	Oct, 1995	Gr. Beta	7.9276 ± 1.3579	6.7150 ± 1.2839	7.3213 ± 0.9344
MI - 11284, 11285	Oct, 1995	I-131	0.1805 ± 0.2626	0.1868 ± 0.2352	0.1837 ± 0.1763
MI - 11284, 11285	Oct, 1995	K-40	1,759.4000 ± 182.0000	1,581.9000 ± 164.0000	1,670.6500 ± 122.4949
DW - 11565, 11566	Oct, 1995	Gr. Beta	2.3856 ± 0.4715	2.6159 ± 0.5003	2.5008 ± 0.3437
DW - 11565, 11566	Oct, 1995	I-131	-0.1047 ± 0.3170	0.1835 ± 0.2833	0.0394 ± 0.2126
SW - 11309, 11310	Oct, 1995	Gr. Alpha	0.5829 ± 0.5262	1.1580 ± 0.6097	0.8705 ± 0.4027
SW - 11309, 11310	Oct, 1995	Gr. Beta	3.1323 ± 0.6596	2.5628 ± 0.6351	2.8475 ± 0.4579
MI - 11351, 11352	Oct, 1995	I-131	0.0319 ± 0.2455	0.0097 ± 0.2195	0.0208 ± 0.1647
MI - 11351, 11352	Oct, 1995	K-40	1,492.6000 ± 166.0000	1,431.8000 ± 160.0000	1,462.2000 ± 115.2779
SW - 11330, 11331	Oct, 1995	H-3	83.4709 ± 77.8239	106.3960 ± 78.8560	94.9335 ± 55.3959
MI - 11407, 11408	Oct, 1995	I-131	-0.1272 ± 0.1871	0.1059 ± 0.1876	-0.0106 ± 0.1325
MI - 11433, 11434	Nov, 1995	I-131	-0.0607 ± 0.1789	0.1317 ± 0.1462	0.0355 ± 0.1155
MI - 11433, 11434	Nov, 1995	K-40	1,446.0000 ± 167.0000	1,450.8000 ± 119.0000	1,448.4000 ± 102.5305
MI - 11433, 11434	Nov, 1995	Sr-89	-0.0542 ± 1.2560	-0.0961 ± 1.1700	-0.0752 ± 0.8583
MI - 11433, 11434	Nov, 1995	Sr-90	1.9383 ± 0.4889	1.8933 ± 0.4555	1.9158 ± 0.3341
BS - 11453, 11454	Nov, 1995	Gr. Beta	8.3022 ± 1.4598	7.0981 ± 1.3963	7.7002 ± 1.0100
BS - 11453, 11454	Nov, 1995	K-40	13.4130 ± 0.6950	14.3840 ± 1.0200	13.8985 ± 0.6171
MI - 11476, 11477	Nov, 1995	I-131	-0.0379 ± 0.1804	0.0878 ± 0.2013	0.0250 ± 0.1352
MI - 11476, 11477	Nov, 1995	K-40	1,425.6000 ± 155.0000	1,379.5000 ± 93.1000	1,402.5500 ± 90.4055
MI - 11476, 11477	Nov, 1995	Sr-89	0.1529 ± 1.5801	0.6656 ± 1.1518	0.4092 ± 0.9777
MI - 11476, 11477	Nov, 1995	Sr-90	1.5845 ± 0.6297	0.7492 ± 0.4308	1.1668 ± 0.3815
WW - 11657, 11658	Nov, 1995	Gr. Beta	0.3756 ± 0.4690	0.4697 ± 0.5060	0.4226 ± 0.3450
WW - 11657, 11658	Nov, 1995	H-3	110.2042 ± 79.0344	172.1940 ± 81.6909	141.1991 ± 56.8327
SW - 11519, 11520	Nov, 1995	H-3	86.0705 ± 77.9529	10.3285 ± 74.5326	48.1995 ± 53.9253

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
WW - 11837, 11838	Nov, 1995	Co-60	0.6630 ± 1.5100	0.0996 ± 3.2500	0.3813 ± 1.7918
WW - 11837, 11838	Nov, 1995	Cs-137	0.0882 ± 1.6800	-0.5360 ± 2.9800	-0.2239 ± 1.7105
MI - 11588, 11589	Nov, 1995	K-40	1,282.9000 ± 161.0000	1,390.4000 ± 145.0000	1,336.6500 ± 108.3351
MI - 11611, 11612	Nov, 1995	I-131	0.0368 ± 0.2007	0.1136 ± 0.2056	0.0752 ± 0.1437
MI - 11611, 11612	Nov, 1995	K-40	1,368.1000 ± 112.0000	1,291.1000 ± 158.0000	1,329.6000 ± 96.8349
CW - 11678, 11679	Nov, 1995	Gr. Beta	2.6565 ± 1.5123	2.0599 ± 1.3520	2.3582 ± 1.0143
MI - 11786, 11787	Nov, 1995	I-131	0.0519 ± 0.1914	-0.0830 ± 0.1791	-0.0156 ± 0.1311
MI - 11786, 11787	Nov, 1995	K-40	1,493.0000 ± 100.0000	1,459.1000 ± 170.0000	1,476.0500 ± 98.6154
CW - 11865, 11866	Nov, 1995	Gr. Beta	1.9803 ± 1.4093	1.1128 ± 1.3439	1.5466 ± 0.9737
LW - 11926, 11927	Nov, 1995	Co-60	-0.6990 ± 2.1700	-1.3700 ± 3.3200	-1.0345 ± 1.9831
LW - 11926, 11927	Nov, 1995	Cs-137	1.3600 ± 2.0100	1.6800 ± 2.6800	1.5200 ± 1.6750
LW - 11926, 11927	Nov, 1995	Gr. Beta	3.5794 ± 0.9059	4.2705 ± 0.9513	3.9250 ± 0.6568
PW - 12451, 12452	Nov, 1995	Co-60	0.1370 ± 1.6290	1.5900 ± 2.0060	0.8635 ± 1.2869
PW - 12451, 12452	Nov, 1995	Cs-137	-1.0900 ± 1.7200	0.8750 ± 2.5000	-0.1075 ± 1.5173
WW - 12659, 12660	Nov, 1995	H-3	10,454.1364 ± 283.5019	10,315.0095 ± 281.7458	10,384.5729 ± 199.8462
G - 12184, 12185	Nov, 1995	K-40	7.1257 ± 0.4820	7.2496 ± 0.5540	7.1877 ± 0.3672
DW - 12229, 12230	Nov, 1995	Gr. Beta	1.4868 ± 0.4353	1.5192 ± 0.4562	1.5030 ± 0.3153
DW - 12229, 12230	Nov, 1995	H-3	48.3898 ± 76.5630	70.8565 ± 77.5707	59.6232 ± 54.4957
SO - 12430, 12431	Dec, 1995	Cs-137	0.2060 ± 0.0696	0.1746 ± 0.0629	0.1903 ± 0.0469
SO - 12430, 12431	Dec, 1995	Gr. Alpha	15.7026 ± 4.4545	10.9075 ± 4.1010	13.3051 ± 3.0274
SO - 12430, 12431	Dec, 1995	Gr. Beta	22.3778 ± 2.8536	23.0769 ± 2.9630	22.7273 ± 2.0568
SO - 12430, 12431	Dec, 1995	K-40	16.6990 ± 1.3000	17.6620 ± 1.3500	17.1805 ± 0.9371
LW - 12152, 12153	Dec, 1995	Co-60	1.4300 ± 3.3200	3.3800 ± 2.1000	2.4050 ± 1.9642
LW - 12152, 12153	Dec, 1995	Cs-137	-0.1400 ± 3.1900	0.3640 ± 2.8500	0.1120 ± 2.1388
LW - 12152, 12153	Dec, 1995	Gr. Beta	5.1509 ± 1.3079	4.8804 ± 1.1924	5.0157 ± 0.8849
MI - 12250, 12251	Dec, 1995	I-131	0.1190 ± 0.1943	0.1981 ± 0.2178	0.1586 ± 0.1460
MI - 12250, 12251	Dec, 1995	K-40	1,470.3000 ± 163.0000	1,386.6000 ± 126.0000	1,428.4500 ± 103.0109
WW - 12298, 12299	Dec, 1995	Co-60	0.4210 ± 2.3800	0.1770 ± 4.0900	0.2990 ± 2.3660
WW - 12298, 12299	Dec, 1995	Cs-137	0.1580 ± 2.0500	1.5200 ± 2.7700	0.8390 ± 1.7230
WW - 12298, 12299	Dec, 1995	H-3	42.7622 ± 77.9643	99.7786 ± 80.5282	71.2704 ± 56.0429
LW - 12380, 12381	Dec, 1995	Co-60	1.2700 ± 2.4400	2.2300 ± 2.2300	1.7500 ± 1.6528
LW - 12380, 12381	Dec, 1995	Cs-134	0.5120 ± 2.1300	1.9500 ± 2.2200	1.2310 ± 1.5383
LW - 12380, 12381	Dec, 1995	Cs-137	0.8060 ± 2.5100	1.2200 ± 2.4400	1.0130 ± 1.7503
LW - 12380, 12381	Dec, 1995	I-131	0.0861 ± 0.1243	0.1222 ± 0.2055	0.1041 ± 0.1201
LW - 12380, 12381	Dec, 1995	I-131(g)	-7.3600 ± 13.8000	4.7100 ± 13.4000	-1.3250 ± 9.6177
LW - 12380, 12381	Dec, 1995	K-40	129.0000 ± 41.2000	133.0000 ± 34.7000	131.0000 ± 26.9329

Table A-5. In-house "duplicate" samples.

Lab Codes ^b	Sample Date	Analysis	Concentration in pCi/L ^a		
			First Result	Second Result	Averaged Result
MI - 12325, 12326	Dec, 1995	I-131	-0.1263 ± 0.2456	0.1598 ± 0.2063	0.0167 ± 0.1604
MI - 12325, 12326	Dec, 1995	K-40	1.409.0000 ± 172.0000	1,438.6000 ± 169.0000	1,423.8000 ± 120.5664
WW - 12347, 12348	Dec, 1995	H-3	77.2534 ± 78.8630	87.6308 ± 79.3168	82.4421 ± 55.9252
F - 12688, 12689	Dec, 1995	Co-60	0.0009 ± 0.0117	0.0011 ± 0.0141	0.0010 ± 0.0092
F - 12688, 12689	Dec, 1995	Cs-134	0.0044 ± 0.0094	-0.0069 ± 0.0138	-0.0013 ± 0.0084
F - 12688, 12689	Dec, 1995	Cs-137	0.0366 ± 0.0179	0.0266 ± 0.0149	0.0316 ± 0.0116
F - 12688, 12689	Dec, 1995	I-131(g)	-0.0050 ± 0.0244	0.0254 ± 0.0422	0.0102 ± 0.0244
F - 12688, 12689	Dec, 1995	K-40	2.4139 ± 0.3400	2.5180 ± 0.3700	2.4660 ± 0.2512
PW - 12945, 12946	Dec, 1995	Co-60	0.2950 ± 2.7700	1.4000 ± 1.9600	0.8475 ± 1.6967
PW - 12945, 12946	Dec, 1995	Cs-137	1.4900 ± 2.5600	0.1240 ± 2.1900	0.8070 ± 1.6845

^a All concentrations are reported in pCi/liter, except solid samples, which are reported in pCi/gram.

^b Lab codes are comprised of the sample media and the sample numbers. Client codes have been eliminated to protect client anonymity.

APPENDIX B
DATA REPORTING CONVENTIONS

Data Reporting Conventions

1.0 All activities except gross alpha and gross beta are decay corrected to collection time or the end of the collection period.

2.0 Single Measurements

Each single measurement is reported as follows:

$$x \pm s$$

where x = value of the measurement;

$s = 2\sigma$ counting uncertainty (corresponding to the 95% confidence level).

In cases where the activity is found to be below the lower limit of detection L it is reported as

$$<L$$

where L = the lower limit of detection based on 4.66σ uncertainty for a background sample.

3.0 Duplicate analyses

3.1 Individual results:

$$x_1 \pm s_1$$

$$x_2 \pm s_2$$

Reported result:

$$x \pm s$$

where $x = (1/2)(x_1 + x_2)$

$$s = (1/2) \sqrt{\frac{x_1^2}{s_1^2} + \frac{x_2^2}{s_2^2}}$$

3.2 Individual results:

$$<L_1$$

$$<L_2$$

Reported result:

$$<L$$

where L = lower of L_1 and L_2

3.3 Individual results:

$$x \pm s$$

$$<L$$

Reported result:

$$x \pm s \text{ if } x \geq L;$$

$$<L \text{ otherwise}$$

4.0. Computation of Averages and Standard Deviations

- 4.1 Averages and standard deviations listed in the tables are computed from all of the individual measurements over the period averaged; for example, an annual standard deviation would not be the average of quarterly standard deviations. The average \bar{x} and standard deviation(s) of a set of n numbers $x_1, x_2 \dots x_n$ are defined as follows:

$$\bar{x} = \frac{1}{n} \sum x$$
$$s = \sqrt{\frac{\sum (\bar{x} - x_i)^2}{n-1}}$$

- 4.2 Values below the highest lower limit of detection are not included in the average.
- 4.3 If all of the values in the averaging group are less than the highest LLD, the highest LLD is reported.
- 4.4 If all but one of the values are less than the highest LLD, the single value x and associated two sigma error is reported.
- 4.5 In rounding off, the following rules are followed:
- 4.5.1. If the figure following those to be retained is less than 5, the figure is dropped, and the retained figures are kept unchanged. As an example, 11.443 is rounded off to 11.44.
- 4.5.2. If the figure following those to be retained is greater than or equal to 5, the figure is dropped and the last retained figure is raised by 1. As an example, 11.446 is rounded off to 11.45.

TOLEDO

APPENDIX C

AIRBONE IODINE, ELEVATED LLD's

TOLEDO

Table C-1. Airborne iodine, elevated LLD's, 1995

Date Collected	Location	I-131 (pCi/m ³)	Comments
10-24-95	T-4	<0.08	I-131 required LLD not reached due to low volume.

APPENDIX D
COLLECTION SHEETS

AI/AP DATA SHEET

ED 8091-1

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
SAMPLING LOCATION/ NUMBER		START	STOP	DIFFERENCE	REMARKS
T- 11	DATE	11-28-95	12-5-95		
	TIME	0808	0803	167.9	
ECP #	ELAPSED TIMER	0	167.9	167.9	
12	GAS METER	60	66	NA	
	PUMP LEAK TEST	24			
T- 4	DATE	11-28-95	12-5-95		
	TIME	0914	0907	167.9	
ECP #	ELAPSED TIMER	0	167.8	167.8	
4	GAS METER	60	60	NA	
	PUMP LEAK TEST	24			
T- 3	DATE	11-28-95	12-5-95		
	TIME	0929	0918	167.8	
ECP #	ELAPSED TIMER	0	167.8	167.8	
6	GAS METER	62	63	NA	
	PUMP LEAK TEST	22			
T- 2	DATE	11-28-95	12-5-95		
	TIME	0934	0934	167.8	
ECP #	ELAPSED TIMER	0	167.8	167.8	
2	GAS METER	60	62	NA	
	PUMP LEAK TEST	25			
T- 1	DATE	11-28-95	12-5-95		
	TIME	0950	0931	167.6	
ECP #	ELAPSED TIMER	0	167.7	167.7	
16	GAS METER	58	58	NA	
	PUMP LEAK TEST	23			
T- 7	DATE	11-28-95	12-5-95		
	TIME	1027	0954	167.4	
ECP #	ELAPSED TIMER	0	167.4	167.4	
17	GAS METER	61	62	NA	
	PUMP LEAK TEST	24			

PREPARED BY

Jay Hasselbach

DATE

12-5-95

REVIEWED BY

DATE

RECEIVED DEC 08 1995

AI/AP DATA SHEET

ED 8091-1

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
SAMPLING LOCATION/ NUMBER		START	STOP	Difference	REMARKS
T- 8	DATE	11-28-95	12-5-95		
	TIME	1038	1026	167.8	1.
ECP # 5	ELAPSED TIMER	0	167.8	167.8	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	21			
T- 9	DATE	11-28-95	12-5-95		
	TIME	1055	1043	167.8	
ECP # 8	ELAPSED TIMER	0	167.8	167.8	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	23			
T- 27	DATE	11-28-95	12-5-95		
	TIME	1154	1204	168.2	
ECP # 1	ELAPSED TIMER	0	168.2	168.2	
	GAS METER	63	63	NA	
	PUMP LEAK TEST	24			
T- 12	DATE	11-28-95	12-5-95		
	TIME	1224	1238	168.2	
ECP # 11	ELAPSED TIMER	0	168.2	168.2	
	GAS METER	60	57	NA	
	PUMP LEAK TEST	24			
T-	DATE				
	TIME				
ECP #	ELAPSED TIMER				
	GAS METER				
	PUMP LEAK TEST				
T-	DATE				
	TIME	NA			
ECP #	ELAPSED TIMER				
	GAS METER				
	PUMP LEAK TEST				

PREPARED BY

J. Hasselbach

DATE

12-5-95

REVIEWED BY

DATE

RECEIVED DEC 08 1995

AI/AP DATA SHEET

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
SAMPLING LOCATION/ NUMBER		START	STOP	DIFFERENCE	REMARKS
T- 8	DATE	12-5-95	12-12-95		
	TIME	1227	1043	168.3	
ECP # 5	ELAPSED TIMER	0	168.3	168.3	
	GAS METER	40	60	NA	
	PUMP LEAK TEST	21			
T- 9	DATE	12-5-95	12-12-95		
	TIME	1044	1101	168.3	
ECP # 8	ELAPSED TIMER	0	168.3	168.3	
	GAS METER	60	62	NA	
	PUMP LEAK TEST	24			
T- 27	DATE	12-5-95	12-12-95		
	TIME	1210	1226	168.3	
ECP # 1	ELAPSED TIMER	0	168.2	168.2	
	GAS METER	63	64	NA	
	PUMP LEAK TEST	25			
T- 12	DATE	12-5-95	12-12-95		
	TIME	1240	1259	168.3	
ECP # 11	ELAPSED TIMER	0	168.3	168.3	
	GAS METER	60	63	NA	
	PUMP LEAK TEST	25			
T-	DATE				
	TIME				
ECP #	ELAPSED TIMER		N		
	GAS METER				
	PUMP LEAK TEST				
T-	DATE		A		
	TIME				
ECP #	ELAPSED TIMER				
	GAS METER				
	PUMP LEAK TEST				
PREPARED BY		DATE	REVIEWED BY		DATE
J. Hasselbach		12-13-95			

RECEIVED DEC 15 1995

Amo

AV/AP DATA SHEET

ED 8091-1

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
SAMPLING LOCATION/ NUMBER		START	STOP	DIFFERENCE	REMARKS
T- 11	DATE	12-5-95	12-12-95		
	TIME	0804	0818	168.2	
ECP #	ELAPSED TIMER	0	168.2	168.2	
12	GAS METER	60	70	NA	
	PUMP LEAK TEST	25			
T- 1	DATE	12-5-95	12-12-95		
	TIME	0908	0939	168.5	
ECP #	ELAPSED TIMER	0	168.5	168.5	
4	GAS METER	40	61	NA	
	PUMP LEAK TEST	24			
T- 3	DATE	12-5-95	12-12-95		
	TIME	0920	168.6 ^{FM} 0953	168.4	
ECP #	ELAPSED TIMER	0	168.6	168.6	
6	GAS METER	62	64	NA	
	PUMP LEAK TEST	32			
T- 2	DATE	12-5-95	12-12-95		
	TIME	0924	0959	168.7	
ECP #	ELAPSED TIMER	0	168.7	168.7	
2	GAS METER	60	60	NA	
	PUMP LEAK TEST	25			
T- 1	DATE	12-5-95	12-12-95		
	TIME	0932	0914	167.7	
ECP #	ELAPSED TIMER	0	167.7	167.7	
14	GAS METER	58	60	NA	
	PUMP LEAK TEST	25			
T- 7	DATE	12-5-95	12-12-95		
	TIME	0957	1020	168.6	
ECP #	ELAPSED TIMER	0	168.5	168.5	
17	GAS METER	61	63	NA	
	PUMP LEAK TEST	23			

PREPARED BY

J. Hasselbach

DATE

12-13-95

REVIEWED BY

DATE

RECEIVED DEC 15 1995

lmm

AV/AP DATA SHEET

ED 8091-1

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
SAMPLING LOCATION/ NUMBER		START	STOP	DIFFERENCE	REMARKS
T- 11	DATE	12-12-95	12-19-95		
	TIME	0821	0758	167.6	
ECP # 12	ELAPSED TIMER	0	167.6	167.6	
	GAS METER	21460	50	NA	
	PUMP LEAK TEST	25			
T- 4	DATE	12-12-95	12-19-95		
	TIME	0941	1023	168.7	
ECP # 4	ELAPSED TIMER	0	168.7	168.7	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	25			
T- 3	DATE	12-12-95	12-19-95		
	TIME	0955	0928	167.5	
ECP # 6	ELAPSED TIMER	0	167.6	167.6	
	GAS METER	62	61	NA	
	PUMP LEAK TEST	22			
T- 2	DATE	12-12-95	12-19-95		
	TIME	1000	0935	167.6	
ECP # 2	ELAPSED TIMER	0	167.6	167.6	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	24			
T- 1	DATE	12-12-95	12-19-95		
	TIME	0915	0941	168.4	
ECP # 16	ELAPSED TIMER	0	168.4	168.4	
	GAS METER	58	58	NA	
	PUMP LEAK TEST	25			
T- 7	DATE	12-12-95	12-19-95		
	TIME	1031	1040	168.2	
ECP # 17	ELAPSED TIMER	0	168.2	168.2	
	GAS METER	61	59	NA	
	PUMP LEAK TEST	23			

PREPARED BY

J Hasselbach

DATE

12-19-95

REVIEWED BY

DATE

Rec'd DEC 27 1995
Erne

AV/AP DATA SHEET

START TEST PERSONNEL:
Hasselbach

STOP TEST PERSONNEL: Hasselbach			
SAMPLING LOCATION/NUMBER	START	STOP	Difference
T-11 DATE 12-19-95	12-26-95	168.12	
TIME 0759	0806		
ECP# ELAPSED TIMER 0	168.1	NONE	
GAS METER 60	70	NA	
T-12 PUMP LEAK TEST 25			
DATE 12-19-95	12-26-95	167.57	
TIME 1024	0956		
ECP# ELAPSED TIMER 0	167.5	NONE	
GAS METER 60	62	NA	
T-4 PUMP LEAK TEST 24			
DATE 12-19-95	12-26-95	167.83	
TIME 0930	0920		
ECP# ELAPSED TIMER 0	167.9	NONE	
GAS METER 62	61	NA	
T-6 PUMP LEAK TEST 22			
DATE 12-19-95	12-26-95	167.9	
TIME 0734	0726		
ECP# ELAPSED TIMER 0	167.8	NONE	
GAS METER 60	60	NA	
T-2 PUMP LEAK TEST 26			
DATE 12-19-95	12-26-95	167.83	
TIME 0942	0850		
ECP# ELAPSED TIMER 0	167.2	NONE	
GAS METER 58	59	NA	
T-14 PUMP LEAK TEST 24			
DATE 12-19-95	12-26-95	167.27	
TIME 1042	1011		
ECP# ELAPSED TIMER 0	167.5	NONE	
GAS METER 61	63	NA	
T-17 PUMP LEAK TEST 22			
PREPARED BY STEVE McNEIL	DATE 12-27-95	REVIEWED BY	DATE

RECEIVED DEC 29 1995
Lima

AV/AP DATA SHEET

START TEST PERSONNEL:
Hasselbach

STOP TEST PERSONNEL: Hasselbach			
SAMPLING LOCATION/NUMBER	START	STOP	Difference
T-8 DATE 12-19-95	12-26-95	168.15	
TIME 1044	0		
ECP# ELAPSED TIMER 5	168.2	168.2	
GAS METER 59	59	NA	
T-5 PUMP LEAK TEST 21			
DATE 12-19-95	12-26-95	167.95	
TIME 1102	0		
ECP# ELAPSED TIMER 6	168.2	168.2	
GAS METER 60	60	NA	
T-9 DATE 12-19-95	12-26-95	167.95	
TIME 1102	0		
ECP# ELAPSED TIMER 6	168.2	168.2	
GAS METER 60	60	NA	
T-22 DATE 12-19-95	12-26-95	167.95	
TIME 1123	0		
ECP# ELAPSED TIMER 7	167.2	167.2	
GAS METER 61	61	NA	
T-27 DATE 12-19-95	12-26-95	167.95	
TIME 1140	0		
ECP# ELAPSED TIMER 8	167.2	167.2	
GAS METER 62	62	NA	
T-1 DATE 12-19-95	12-26-95	167.95	
TIME 1151	0		
ECP# ELAPSED TIMER 9	167.3	167.3	
GAS METER 63	63	NA	
T-11 DATE 12-19-95	12-26-95	167.95	
TIME 1201	0		
ECP# ELAPSED TIMER 10	167.3	167.3	
GAS METER 64	64	NA	
T-12 DATE 12-19-95	12-26-95	167.95	
TIME 1217	0		
ECP# ELAPSED TIMER 11	167.3	167.3	
GAS METER 65	65	NA	
T-13 DATE 12-19-95	12-26-95	167.95	
TIME 1231	0		
ECP# ELAPSED TIMER 12	167.3	167.3	
GAS METER 66	66	NA	
T-14 DATE 12-19-95	12-26-95	167.95	
TIME 1247	0		
ECP# ELAPSED TIMER 13	167.3	167.3	
GAS METER 67	67	NA	
T-15 DATE 12-19-95	12-26-95	167.95	
TIME 1253	0		
ECP# ELAPSED TIMER 14	167.3	167.3	
GAS METER 68	68	NA	
T-16 DATE 12-19-95	12-26-95	167.95	
TIME 1309	0		
ECP# ELAPSED TIMER 15	167.3	167.3	
GAS METER 69	69	NA	
T-17 DATE 12-19-95	12-26-95	167.95	
TIME 1325	0		
ECP# ELAPSED TIMER 16	167.3	167.3	
GAS METER 70	70	NA	
T-18 DATE 12-19-95	12-26-95	167.95	
TIME 1341	0		
ECP# ELAPSED TIMER 17	167.3	167.3	
GAS METER 71	71	NA	
T-19 DATE 12-19-95	12-26-95	167.95	
TIME 1357	0		
ECP# ELAPSED TIMER 18	167.3	167.3	
GAS METER 72	72	NA	
T-20 DATE 12-19-95	12-26-95	167.95	
TIME 1413	0		
ECP# ELAPSED TIMER 19	167.3	167.3	
GAS METER 73	73	NA	
T-21 DATE 12-19-95	12-26-95	167.95	
TIME 1429	0		
ECP# ELAPSED TIMER 20	167.3	167.3	
GAS METER 74	74	NA	
T-22 DATE 12-19-95	12-26-95	167.95	
TIME 1445	0		
ECP# ELAPSED TIMER 21	167.3	167.3	
GAS METER 75	75	NA	
T-23 DATE 12-19-95	12-26-95	167.95	
TIME 1451	0		
ECP# ELAPSED TIMER 22	167.3	167.3	
GAS METER 76	76	NA	
T-24 DATE 12-19-95	12-26-95	167.95	
TIME 1507	0		
ECP# ELAPSED TIMER 23	167.3	167.3	
GAS METER 77	77	NA	
T-25 DATE 12-19-95	12-26-95	167.95	
TIME 1523	0		
ECP# ELAPSED TIMER 24	167.3	167.3	
GAS METER 78	78	NA	
T-26 DATE 12-19-95	12-26-95	167.95	
TIME 1539	0		
ECP# ELAPSED TIMER 25	167.3	167.3	
GAS METER 79	79	NA	
T-27 DATE 12-19-95	12-26-95	167.95	
TIME 1555	0		
ECP# ELAPSED TIMER 26	167.3	167.3	
GAS METER 80	80	NA	
T-28 DATE 12-19-95	12-26-95	167.95	
TIME 1611	0		
ECP# ELAPSED TIMER 27	167.3	167.3	
GAS METER 81	81	NA	
T-29 DATE 12-19-95	12-26-95	167.95	
TIME 1627	0		
ECP# ELAPSED TIMER 28	167.3	167.3	
GAS METER 82	82	NA	
T-30 DATE 12-19-95	12-26-95	167.95	
TIME 1643	0		
ECP# ELAPSED TIMER 29	167.3	167.3	
GAS METER 83	83	NA	
T-31 DATE 12-19-95	12-26-95	167.95	
TIME 1659	0		
ECP# ELAPSED TIMER 30	167.3	167.3	
GAS METER 84	84	NA	
T-32 DATE 12-19-95	12-26-95	167.95	
TIME 1715	0		
ECP# ELAPSED TIMER 31	167.3	167.3	
GAS METER 85	85	NA	
T-33 DATE 12-19-95	12-26-95	167.95	
TIME 1731	0		
ECP# ELAPSED TIMER 32	167.3	167.3	
GAS METER 86	86	NA	
T-34 DATE 12-19-95	12-26-95	167.95	
TIME 1747	0		
ECP# ELAPSED TIMER 33	167.3	167.3	
GAS METER 87	87	NA	
T-35 DATE 12-19-95	12-26-95	167.95	
TIME 1753	0		
ECP# ELAPSED TIMER 34	167.3	167.3	
GAS METER 88	88	NA	
T-36 DATE 12-19-95	12-26-95	167.95	
TIME 1809	0		
ECP# ELAPSED TIMER 35	167.3	167.3	
GAS METER 89	89	NA	
T-37 DATE 12-19-95	12-26-95	167.95	
TIME 1825	0		
ECP# ELAPSED TIMER 36	167.3	167.3	
GAS METER 90	90	NA	
T-38 DATE 12-19-95	12-26-95	167.95	
TIME 1841	0		
ECP# ELAPSED TIMER 37	167.3	167.3	
GAS METER 91	91	NA	
T-39 DATE 12-19-95	12-26-95	167.95	
TIME 1857	0		
ECP# ELAPSED TIMER 38	167.3	167.3	
GAS METER 92	92	NA	
T-40 DATE 12-19-95	12-26-95	167.95	
TIME 1913	0		
ECP# ELAPSED TIMER 39	167.3	167.3	
GAS METER 93	93	NA	
T-41 DATE 12-19-95	12-26-95	167.95	
TIME 1929	0		
ECP# ELAPSED TIMER 40	167.3	167.3	
GAS METER 94	94	NA	
T-42 DATE 12-19-95	12-26-95	167.95	
TIME 1945	0		
ECP# ELAPSED TIMER 41	167.3	167.3	
GAS METER 95	95	NA	
T-43 DATE 12-19-95	12-26-95	167.95	
TIME 1951	0		
ECP# ELAPSED TIMER 42	167.3	167.3	
GAS METER 96	96	NA	
T-44 DATE 12-19-95	12-26-95	167.95	
TIME 2007	0		
ECP# ELAPSED TIMER 43	167.3	167.3	
GAS METER 97	97	NA	
T-45 DATE 12-19-95	12-26-95	167.95	
TIME 2023	0		
ECP# ELAPSED TIMER 44	167.3	167.3	
GAS METER 98	98	NA	
T-46 DATE 12-19-95	12-26-95	167.95	
TIME 2039	0		
ECP# ELAPSED TIMER 45	167.3	167.3	
GAS METER 99	99	NA	
T-47 DATE 12-19-95	12-26-95	167.95	
TIME 2055	0		
ECP# ELAPSED TIMER 46	167.3	167.3	
GAS METER 100	100	NA	
T-48 DATE 12-19-95	12-26-95	167.95	
TIME 2111	0		
ECP# ELAPSED TIMER 47	167.3	167.3	
GAS METER 101	101	NA	
T-49 DATE 12-19-95	12-26-95	167.95	
TIME 2127	0		
ECP# ELAPSED TIMER 48	167.3	167.3	
GAS METER 102	102	NA	
T-50 DATE 12-19-95	12-26-95	167.95	
TIME 2143	0		
ECP# ELAPSED TIMER 49	167.3	167.3	
GAS METER 103	103	NA	
T-51 DATE 12-19-95	12-26-95	167.95	
TIME 2159	0		
ECP# ELAPSED TIMER 50	167.3	167.3	
GAS METER 104	104	NA	
T-52 DATE 12-19-95	12-26-95	167.95	
TIME 2215	0		
ECP# ELAPSED TIMER 51	167.3	167.3	
GAS METER 105	105	NA	
T-53 DATE 12-19-95	12-26-95	167.95	
TIME 2231	0		
ECP# ELAPSED TIMER 52	167.3	167.3	
GAS METER 106	106	NA	
T-54 DATE 12-19-95	12-26-95	167.95	
TIME 2247	0		
ECP# ELAPSED TIMER 53	167.3	167.3	
GAS METER 107	107	NA	
T-55 DATE 12-19-95	12-26-95	167.95	
TIME 2253	0		
ECP# ELAPSED TIMER 54	167.3	167.3	
GAS METER 108	108	NA	
T-56 DATE 12-19-95	12-26-95	167.95	
TIME 2309	0		
ECP# ELAPSED TIMER 55	167.3	167.3	
GAS METER 109	109	NA	
T-57 DATE 12-19-95	12-26-95	167.95	
TIME 2325	0		
ECP# ELAPSED TIMER 56	167.3	167.3	
GAS METER 110	110	NA	
T-58 DATE 12-19-95	12-26-95	167.95	
TIME 2341	0		
ECP# ELAPSED TIMER 57	167.3	167.3	
GAS METER 111	111	NA	
T-59 DATE 12-19-95	12-26-95	167.95	
TIME 2357	0		
ECP# ELAPSED TIMER 58	167.3	167.3	
GAS METER 112	112	NA	
T-60 DATE 12-19-95	12-26-95	167.95	
TIME 2359	0		
ECP# ELAPSED TIMER 59	167.3	167.3	
GAS METER 113	113	NA	
T-61 DATE 12-19-95	12-26-95	167.95	
TIME 2359	0		
ECP# ELAPSED TIMER 60	167.3	167.3	
GAS METER 114	114	NA	
T-62 DATE 12-19-95	12-26-95	167.95	
TIME 2359	0		
ECP# ELAPSED TIMER 61	167.3	167.3	
GAS METER 115	115	NA	
T-63 DATE 12-19-95	12-26-95	167.95	
TIME 2359	0		
ECP# ELAPSED TIMER 62	167.3	167.3	
GAS METER 116	116	NA	
T-64 DATE 12-19-95	12-26-95	167.	

AI/AP DATA SHEET

START TEST PERSONNEL:

HASSELBACH

STOP TEST PERSONNEL:

HASSELBACH

SAMPLING LOCATION/ NUMBER	START	STOP	DIFFERENCE	REMARKS
T-8 ECP # 5	DATE 12-19-95 TIME 1054 ELAPSED TIMER 0 GAS METER 60 PUMP LEAK TEST 22	12-26-95 1023 167.5 60 22	167.48 167.5 NA	NONE
T-9 ECP # 8	DATE 12-19-95 TIME 1118 ELAPSED TIMER 0 GAS METER 60 PUMP LEAK TEST 24	12-26-95 1042 167.3 60 24	167.4 167.3 NA	NONE
T-27 ECP # 1	DATE 12-19-95 TIME 1141 ELAPSED TIMER 0 GAS METER 63 PUMP LEAK TEST 25	12-26-95 1148 168.1 63 25	168.12 168.1 NA	NONE
T-12 ECP # 11	DATE 12-19-95 TIME 1219 ELAPSED TIMER 0 GAS METER 60 PUMP LEAK TEST 24	12-26-95 1219 168.0 60 24	168.0 168.0 NA	NONE
T- DATE ECP # ELAPSED TIMER GAS METER PUMP LEAK TEST	TIME N	A		
T- DATE ECP # ELAPSED TIMER GAS METER PUMP LEAK TEST	TIME .			
PREPARED BY STEVE HELMER	DATE 12-27-95	REVIEWED BY	DATE	

RECEIVED DEC 29 1995

lmr

Radiological Environmental Monitoring Program (REMP)
 Davis-Besse Nuclear Power Station
 Week of 12-25-95

Sample Type	Sampling Location	Quantity	Remarks
SWT	T-28	19.91	none
SWT	T-50		
SWT	T-11		
SWT	T-12		
SWT	T-143		
SWU	T-28		
MIL	T-248		

Also enclosed: AI/AP Data Sheets (x)
 Pump Calibration Data Sheets (x)
 Sample Collection Data Sheets (x) (required only when
 sheets include data on TLD Collection)

The following samples were scheduled for collection, but were missed:

Sample Type	Sampling Location	Scheduled Collection Date	Reason Missed
SWU	T-40	12-26-95	WINTER Weather Safety hazard
SWU	T-50	12-26-95	Water Plant Personnel Did Not Take Sample
SWU	T-16	12-26-95	WINTER Weather Safety hazard *

Package Prepared by: STEVE HELMER Date: 12-27-95 Time: 10:00
 Package Shipped via: Greyhound Date: 12-27-95 Time: 12:00
 Remarks: NONE

This portion to be completed by personnel at the contractor laboratory.
 Package Received by: ELLIOTT FISHER Date: 12-29-95 Time: 15:00

Integrity of samples listed above was (check one) Satisfactory Unsatisfactory
 (specify below)

Remarks: * Received T-50, * T-16 not received

Please return the completed original copy of this packing list. Please attach photocopies of any shipping receipts associated with the above shipment

AI/AP DATA SHEET

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
Hasselbach		HELMER			
SAMPLING LOCATION/ NUMBER		START	STOP	DIFFERENCE	REMARKS
T- 8	DATE	12-26-95	1-2-96		
	TIME	1025	1030	168.08	
ECP # 5	ELAPSED TIMER	0	168.2	168.2	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	21			
T- 9	DATE	12-26-95	1-2-96		
	TIME	1044	1050	168.1	
ECP # 8	ELAPSED TIMER	0	168.1	168.1	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	24			
T- 27	DATE	12-26-95	1-2-96		
	TIME	1149	1145	167.93	
ECP # 1	ELAPSED TIMER	0	168.0	168.0	
	GAS METER	63	60	NA	
	PUMP LEAK TEST	24			
T- 12	DATE	12-26-95	1-2-96		
	TIME	1220	1212	167.97	
ECP # 11	ELAPSED TIMER	0	168.0	168.0	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	25			
T-	DATE				
	TIME				
ECP #	ELAPSED TIMER	N			
	GAS METER				
	PUMP LEAK TEST	A			
PREPARED BY <i>Steve A. Helmer</i>	DATE 1-2-96	REVIEWED BY <i>lma</i>	DATE		

RECEIVED JAN 06 1996

PACKING LIST
 Radiological Environmental Monitoring Program (REMP)
 Davis-Besse Nuclear Power Station
 Week of 12-25-95

Sample Type	Sampling Location	Quantity	Remarks
SW4	T-14	1 gal	None
SW4	T-3		
SW4	T-12		
SW4	T-11		
SW4	T-145		
SW4	T-50	3 QTS	See Below
SW4	T-4P	3 QTS	See Below
MIL	T-248	1 gal	

Also enclosed: AI/AP Data Sheets (x O)
 Pump Calibration Data Sheets (x O)
 Sample Collection Data Sheets (x O) (required only when sheets include data on TLD Collection)

The following samples were scheduled for collection, but were missed:

Sample Type	Sampling Location	Scheduled Collection Date	Reason Missed
-------------	-------------------	---------------------------	---------------

See other packing list regarding T-4P; T-50; T-16

Package Prepared by: *Steve Helmer* Date: 12-27-95 Time: 10:00
 Package Shipped via: *Craytread* Date: 12-27-95 Time: 13:00
 Remarks: None

This portion to be completed by personnel at the contractor laboratory.
 Package Received by: *Callie Saar* Date: 1-2-96 Time: 15:00

Integrity of samples listed above was (check one) Satisfactory Unsatisfactory
 (specify below): _____

Remarks: _____

Please retain the completed original copy of this packing list. Please attach photocopies of any shipping receipts associated with the above shipment.

AI/AP DATA SHEET

ED 8091-1

START TEST PERSONNEL:		STOP TEST PERSONNEL:			
SAMPLING LOCATION/ NUMBER		START	STOP	DIFFERENCE	REMARKS
T- 11 ECP # 12	DATE	12-26-95	1-2-96		NONE
	TIME	0808	0800	167.87	
	ELAPSED TIMER	0	167.9	167.9	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	24			
T- 1 ECP # 16	DATE	12-26-95	1-2-96		NONE
	TIME	0859	0942	168.72	
	ELAPSED TIMER	0	168.9	168.9	
	GAS METER	58	58	NA	
	PUMP LEAK TEST	25			
T- 3 ECP # 6	DATE	12-26-95	1-2-96		NONE
	TIME	0922	0934	168.2	
	ELAPSED TIMER	0	168.3	168.3	
	GAS METER	62	60	NA	
	PUMP LEAK TEST	22			
T- 2 ECP # 2	DATE	12-26-95	1-2-96		NONE
	TIME	0928	0938	168.17	
	ELAPSED TIMER	0	168.3	168.3	
	GAS METER	60	62	NA	
	PUMP LEAK TEST	24			
T- 4 ECP # 4	DATE	12-26-95	1-2-96		NONE
	TIME	1000	0925	167.25	
	ELAPSED TIMER	0	167.9	167.9	
	GAS METER	60	60	NA	
	PUMP LEAK TEST	24			
T- 7 ECP # 17	DATE	12-26-95	1-2-96		NONE
	TIME	1012	1023	168.18	
	ELAPSED TIMER	0	168.3	168.3	
	GAS METER	61	61	NA	
	PUMP LEAK TEST	23			
PREPARED BY <i>Stephen A. Helmer</i>		DATE 1-2-96	REVIEWED BY <i>lmo</i>		DATE

RECEIVED JAN 03 1996

lmo