



UNITED STATES
ATOMIC ENERGY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION 1
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

SEP 9 1974

Jersey Central Power and Light Company
Attention: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

License No. DPR-16
Docket No. 50-219

Reference: Your letters dated August 6, 1974 and June 12, 1974
In response to our letters dated May 16, 1974 and July 2, 1974

Gentlemen:

Thank you for informing us of the corrective and preventive actions you documented in response to our correspondence. Based on a telephone discussion between Mr. D. A. Ross of your staff and Mr. R. C. Haynes of this office on September 5, we understand that measures will be provided in your in-service inspection program to assure the proper calibration of the ultrasonic equipment. Specifically, the basic calibration reflectors used shall be in accordance with the requirements of Section III, Appendix IX of the ASME Boiler and Pressure Vessel Code.

The above actions will be examined during our next inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,

Robert T. Carlson, Chief
Facility Construction and Engineering
Support Branch

cc: J. T. Carroll, Station Superintendent
A. Z. Roisman, Counsel for Citizens Committee for Protection of
the Environment

3/471

OFFICE ▶	CRESS				
SURNAME ▶	Walton/mjd	Haynes	Heifshman	Carlson	O'Reilly
DATE ▶	9/6/74	9/9/74	9/9/74	9/9/74	

Jersey Central Power and Light Company

-2-

bcc: RO Chief, FS&EB
RO:HQ (4)
RO Files
Central Mail & Files
DL (4)
RS
PDR
Local PDR
NSIC
TIC
State of New Jersey
Reg Reg Reading Room
OGC