

Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111

General



Public Utilities Corporation

July 9, 1975

Mr. J. P. O'Reilly, Director
United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region 1
631 Park Avenue
King of Prussia, PA. 19406

Dear Mr. O'Reilly:

Subject: Forked River Nuclear Generating Station
Docket No. 50-363
Response to IE Bulletin 75-06

Your letter dated May 30, 1975 requested a response concerning the use of Westinghouse Type OT-2 Control Switches in safety related systems at our facility. It has been determined that this type of equipment has not been purchased to date. We will direct the Architect Engineer to utilize Westinghouse Type OT-2 Control Switches only if properly modified to preclude the return spring problem.

Very truly yours,

Ivan R. Finfroek, Jr.
Ivan R. Finfroek, Jr.
Vice President

pk

blcc: Mr. T. M. Crimmins, Jr.
Mr. G. A. Lari
Mr. M. K. Pastor
Mr. W. F. Schmauss
Mr. R. L. Williams
Mr. R. F. Wilson