

ENCLOSURE 1

Description of Violation

Jersey Central Power & Light Company  
Morristown, New Jersey 07960  
Docket No. 50-219  
License No. DPR-16

One activity under your license appears to be in violation of AEC regulations and license requirements. This apparent violation is considered to be of Category II severity.

Technical Specification 7.2.C states that "Standing instructions to the operating staff shall require that the procedures identified ... are to be followed ..." The subject procedures are contained in Section 900, Oyster Creek Nuclear Electric Generating Station Procedures Manual. Section 903.7, states in part, "copies of the RWP will then be distributed to ... the job location".

Contrary to the above, on October 30, 1974, a designated radiation area (RWP required for entry) was observed to have no RWP distributed to the job location.