

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

85 FEB 4 P12:59  
January 28, 1985

TELEPHONE  
(704) 373-4531


Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Re: Catawba Nuclear Station, Unit 1  
Docket No. 50-413

Dear Mr. O'Reilly:

Pursuant to Technical Specification 3.1.1.3, Action Statement a.3, please find attached a Special Report concerning the Moderator Temperature Coefficient being more positive than  $0 \Delta k/k/^\circ F$ .

Very truly yours,



Hal B. Tucker

RWO:mjf

Attachment

cc: Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

NRC Resident Inspector  
Catawba Nuclear Station

Palmetto Alliance  
2135½ Devine Street  
Columbia, South Carolina 29205

Mr. Jesse L. Riley  
Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28207

Robert Guild, Esq.  
P. O. Box 12097  
Charleston, South Carolina 29412

8502210304 850128  
PDR ADOCK 05000413  
S PDR

OFFICIAL COPY

TE 22/11

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
SPECIAL REPORT


During Zero Power Physics Testing on Unit 1 Cycle 1, the all rod withdrawn isothermal temperature coefficient was measured as  $-1.75 \text{ pcm}/^\circ\text{F}$ . This corresponds to a Moderator Temperature Coefficient (MTC) of  $-0.02 \text{ pcm}/^\circ\text{F}$  (assuming a  $-1.73 \text{ pcm}/^\circ\text{F}$  vendor predicted Doppler Coefficient). Technical Specification 3.1.1.3 requires the MTC to be less than zero. Because of measurement uncertainties, Duke Power Company feels it pertinent to establish interim control rod withdrawal limits pursuant to Technical Specification 3.1.1.3 Action Statement a.1 for all Mode 1 or 2 operation not covered by Special Test Exception 3.10.3. These rod withdrawal limits are based on maintaining a negative MTC at all times.

These limits will be placed in appropriate operating procedures and will remain in effect until such time that sufficient reactor poisons have built up to preclude a positive MTC. We expect this to occur at approximately 3500 MWD/MTU ( $\approx 85 \text{ EFPD}$ ) at Hot Zero Power, All Rods Out, Xenon free conditions.

Since the attached rod withdrawal limits will ensure a negative MTC during power operation, the health and safety of the public are not affected.

OP/1/R/6700/01  
UNIT ONE DATA BOOK  
CURVE 1.2.1  
TEMPORARY CONTROL ROD  
WITHDRAWAL LIMITS

SOURCE PT/1/A/4150/20  
PREPARED BY C.B. Thiele  
APPROVED BY *[Signature]*  
EFFECTIVE DATE 1/15/85



NOTE: Acceptable operation below each curve ensures the MTCX0 pcm/°F