

V2B-L

AUG 28 1974

DISTRIBUTION
AEC PDR
Local PDR
Docket
ORB#3 Rdg
KRGoller
TJCarter
OGC
✓RO (3)
GLear
JIRiesland
SATEets
TR BCs
JRBuchanan
TBAbernathy
SVarga
ACRS (16)
extra cps

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Gentlemen:

We have reviewed your letter, dated May 7, 1974, in response to our letter dated February 12, 1974 regarding the Jersey Central Power and Light Company (JCP&L) Quality Assurance (QA) Plan relating to the Oyster Creek Nuclear Generating Station.

Your response to our February 12, 1974 letter is not acceptable for the following reasons:

- (1) You did not adequately describe the General Public Utility Service Company (GPUSC)/JCP&L interface for QA activities; and
- (2) You did not provide a commitment to utilize the (a) "Guidance on Quality Assurance Requirements During the Operations Phase of Nuclear Power Plants" (Orange Book), dated October 26, 1973; (b) "Guidance on Quality Assurance Requirements During Design and Procurement Phase of Nuclear Power Plants - Revision 1" (Gray Book), WASH-1283, dated May 24, 1974; and (c) "Guidance on Quality Assurance Requirements During the Construction Phase of Nuclear Power Plants" (Green Book), WASH-1309, dated May 10, 1974, applicable to activities such as plant modifications.

You are requested to amend the Operational Quality Assurance Program Plan in the Oyster Creek FDSAR to include a description of the GPUSC/JCP&L interface for QA Program activities, and to include a commitment to comply with the provisions contained in paragraph (2) above.

In the event you do not elect to commit to utilize the provisions contained in paragraph (2) above, you shall identify specific exceptions and describe acceptable alternatives.

9604170355 960213
PDR FOIA
DEKOK95-258 PDR

9/477

I


OFFICE ➤	ORB#3	ORB#3	ORB#3	XXXXXXXXL:ORS
SURNAME ➤	SATEets	JIRiesland	GLear	KRGoller
DATE ➤	8/26/74	8/26/74	8/27/74	8/27/74

AUG 28 1974

Jersey Central Power & Light Co. - 2 -

Please submit your response within 30 days of the date of this letter. One signed original and 39 copies of your submittal are required for our review.

Sincerely,

A handwritten signature in cursive script that reads "George Lear" followed by a horizontal line.

George Lear, Chief
Operating Reactors Branch #3
Directorate of Licensing

cc: See next page

AUG 8 1974

Jersey Central Power & Light Co. -3-

CC:

Jersey Central Power & Light Company
ATTN: Mr. Thomas M. Crimmins, Jr.
Safety and Licensing Manager
GPU Service Corporation
260 Cherry Hill Road
Parsippany, New Jersey 07054

Mr. George F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
910 - 17th Street, N. W.
Washington, D. C. 20016

The Honorable W. M. Mason
Mayor, Lacey Township
P. O. Box 475
Forked River, New Jersey 08731

Ocean County Library
15 Hooper Avenue
Toms River, New Jersey 08753

Honorable William F. Hyland
Attorney General
State of New Jersey
State House Annex
Trenton, New Jersey 08601