

C



Jersey Central Power & Light Company

MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 539-6111

January 4, 1973


Mr. James P. O'Reilly, Director
Directorate of Regulatory Operations, Region 1
United States Atomic Energy Commission
970 Broad Street
Newark, New Jersey 07102

Dear Mr. O'Reilly:

Subject: Oyster Creek Station
Docket No. 50-219
Bulletin No. 72-3 -- Limatorque Valve Operators

In accordance with your letter dated December 1, 1972, an investigation was conducted into the model numbers and vintages of the Limatorque Valve Operators installed in safety-related systems at the Oyster Creek site. A thorough check of all available records indicate that all of the operators were shipped prior to the end of 1968. This fact was also verified during conversations with representatives of the Philadelphia Gear Corporation. Based on the above, no further action is planned.

Very truly yours,



Donald A. Ross
Manager, Nuclear Generating Stations

pk

9604170388 960213
PDR FOIA
DEKOK95-258 PDR

B/353