

V-2BL

OCT 30 1974

DISTRIBUTION:
 AEC PDR
 Local DPR
 Docket File
 KR Goller
 TJCarter
 Gowsley
 ORB Reading
 SATeets
 OGC
 RO (3) ✓
 Glear
 ACRS (16)

Docket No. 50-219

Jersey Central Power & Light Company
 ATTN: Mr. I. R. Finfrock, Jr.
 Vice President - Generation
 Madison Avenue at Punch Bowl Road
 Morristown, New Jersey 07960

Gentlemen:

In our letter to you, dated October 1, 1974, we identified certain assurances we would require from you concerning the Oyster Creek gaseous radioactive waste facility before we could approve your proposed modifications. One of the requirements which we identified was that: "You provide assurance that the delay time for release of fission products from a rupture of the pipe will not be less than 60 minutes". Because the statement is not clear and has given rise to misinterpretation this requirement is reworded to read as follows: "You provide assurance that the delay time for noble gases passing through the delay pipe is not less than 60 minutes".

Sincerely,

Original Signed

George Lear, Chief
 Operating Reactors Branch #3
 Directorate of Licensing

cc: See next page

9604170428 960213
 PDR FOIA
 DEKOK95-258 PDR

B/449

I

OFFICE	ORB#3	ORB#3	L:TR		
SURNAME	Gowsley:km	Glear GL	BGrimes		
DATE	10/21/74	10/29/74	10/ /74		

9604170428

OCT 30 1974

Jersey Central Power & Light Co. -2-

cc:

George F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
910 - 17th Street, N. W.
Washington, D. C. 20016

Jersey Central Power & Light Company
ATTN: Mr. Thomas M. Crimmins, Jr.
Safety and Licenising Manager
GPU Service Corporation
260 Cherry Hill Road
Parsippany, New Jersey 07054

The Honorable W. M. Mason
Mayor, Lacey Township
P. O. Box 475
Forked River, New Jersey 08731

Ocean County Library
15 Hooper Avenue
Toms River, New Jersey 08753