

DMB

FEB 12 1985

Docket No. 50-266
Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. C. W. Fay
Vice President
Nuclear Power Department
231 West Michigan, Room 308
Milwaukee, WI 53201

Gentlemen:

Enclosed is a copy of the Notice of Violation for Inspection Reports
No. 50-266/84-22 and No. 50-301/84-20 per you request on February 7, 1985.

Sincerely,

C. J. Paperiello, Chief
Emergency Preparedness and
Radiological Protection Branch

Enclosure: As stated

cc w/o encl:
J. J. Zach, Plant Manager
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
John J. Duffy, Chief
Boiler Section
Ness Flores, Chairperson
Wisconsin Public Service
Commission

8502220064 850212
PDR ADOCK 05000266
Q PDR

7806

RIII

Paul/as
02/12/85

RIII

Greger

RIII

Paperiello
2/12/85

11

Appendix

NOTICE OF VIOLATION

Wisconsin Electric Power Company

Docket No. 50-266

Docket No. 50-301

As a result of the inspection conducted on December 3-7 and 26, 1984, and in accordance with the General Policy and Procedures for NRC Enforcement Actions, (10 CFR Part 2, Appendix C), the following violation was identified:

Technical Specification 15.4.1 requires that instruments which are part of the radiation monitoring system be calibrated each refueling outage. Technical Specification 15.1.f.3 defines instrument calibration, in part, as the adjustment of an instrument channel output so that it responds, within acceptable range and accuracy, to a known value(s) of the parameter which the instrument monitors. Calibration shall encompass the entire instrument including actuation, alarm, or trip.


Contrary to the above, liquid and gaseous effluent monitors, which are part of the radiation monitoring system, have not been properly calibrated. Since the initial multi-point calibration, the licensee has performed only one point calibrations on these instruments. This method does not verify monitor response over the range of the instrument.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

January 11, 1985

Dated



C. J. Paperfello, Chief
Emergency Preparedness and
Radiological Protection
Branch