

~~TOP SECRET~~

OFFICIAL USE ONLY
NOT FOR PUBLIC DISCLOSURE

ENCLOSURE
DESCRIPTION OF VIOLATION

Jersey Central Power and Light Company
Docket Number: 50-219
License Number: DPR-16

One activity under your license appears to be in violation of AEC requirements. This apparent violation is considered to be of Category II severity:

10 CFR 70.51(d) requires that a physical inventory of all special nuclear material be conducted at intervals not to exceed twelve months.

Contrary to the above, approximately twelve (12) fuel pins each containing SNM, have not been inventoried since January 5, 1973.