APPENDIX A

NOTICE OF VIOLATION

GPU Nuclear Corporation Oyster Creek Nuclear Generating Station

Docket No. 50-219 License No. DPR-50

As a result of the inspection conducted on September 5 - October 15, 1984, and in accordance with the revised NRC Enforcement Policy (10 CFR 2, Appendix C), published in the Federal Register on March 8, 1984 (49 FR 8583), the following violation was identified:

Technical Specification 6.8.1 requires that written procedures shall be established, implemented, and maintained.

Oyster Creek Station Procedure 105, Conduct of Maintenance, which provides the standard administrative, management and radiological control practices for the planning and conduct of maintenance at Oyster Creek, Section 6.4 describes the job order section of the Maintenance and Construction Short Form as identifying the maintenance work requirements and special instructions.

Maintenance and Construction Short Form 02877, dated September 28, 1984, written to verify the proper installation of the Emergency Service Water Pressure Gauges on top of the Containment Spray Heat Exchangers in the Job Order Section stated, in part, "Insure isolation root valves are left open and gauges operable."

Contrary to the above, following the gauge replacement, the Emergency Service Water Pressure Gauges were not operable in that the gauge root valves V-3-527, V-3-528, V-3-520, and V-3-521 were left closed.

This is a Severity Level V violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, GPU Nuclear Corporation is hereby required to submit to this office within 30 days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

