

THE CONNECTICUT LIGHT AND POWER COMPANY WESTERN MASSACHUSETTS ELECTRIC COMPANY HOLYOKE WATER POWER COMPANY NORTHEAST UTILITIES SERVICE COMPANY NORTHEAST NUCLEAR ENERGY COMPANY General Offices . Selden Street, Berlin, Connecticut

P.O. BOX 270 HARTFORD, CONNECTICUT 06141-0270 (203) 666-6911

February 8, 1985

Docket No. 50-423 F0672A

Dr. Thomas E. Murley Regional Administrator Region 1 U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

Dear Dr. Murley:

8502220124 850205 PDR ADOCK 05000423

Millstone Nuclear Power Station, Unit No. 3 Reporting of Potential Significant Deficiencies in Design and Construction: Westinghouse 7300 Process Control Cabinets (SD-69)

In a January 11, 1985 telephone conversation between your Mr. T. Rebelowski and our Mr. G. M. Olsen, Northeast Nuclear Energy Company (NNECO) reported a potential significant deficiency in the construction of Millstone Unit No. 3 as required by 10CFR50.55(e). The potential significant deficiency involves Westinghouse 7300 process control cabinets.

The safety-related power supplies for the Millstone Unit No. 3 Westinghouse 7390 process control cabinets are fied directly to the control grade auxiliary relay racks by non-safety-related cable. IEEE Standard 384-1974 sets forth criteria for the separation of safety-related and non-safety-related circuits regarding isolation devices. A NNECO engineering evaluation determined that this isolation does not exist between the power supplies and the relay racks.

Westinghouse is in the process of evaluating this particular configuration, therefore, we are not able to provide you with a final report at this time. We will provide you with an update on this matter by March 28, 1985.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Counsil Senior Vice President

cc: Mr. J. M. Taylor, Director Division of Inspection and Enforcement U. S. Nuclear Regulatory Commission Phillips Building 7920 Norfolk Avenue Bethusda, MD 20814

PDR