

OPERATING DATA REPORT

DOCKET NO. 50-413
 DATE 02-15-85
 COMPLETED BY J.A. Reavis
 TELEPHONE 704-373-7567

OPERATING STATUS

1. Unit Name: Catawba 1
2. Reporting Period: January 1 - January 31, 1985
3. Licensed Thermal Power (Mwt): 3411
4. Nameplate Rating (Gross MWe): 1305
5. Design Electrical Rating (Net MWe): 1145
6. Maximum Dependable Capacity (Gross MWe): _____
7. Maximum Dependable Capacity (Net MWe): 1145
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons.
None

Notes * Nameplate Rating (Gross MWe) calculated as 1450.000 MVA x .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period			
12. Number Of Hours Reactor Was Critical			
13. Reactor Reserve Shutdown Hours			
14. Hours Generator On-Line			
15. Unit Reserve Shutdown Hours			
16. Gross Thermal Energy Generated (MWH)			
17. Gross Electrical Energy Generated (MWH)	Not in Commercial Operation		
18. Net Electrical Energy Generated (MWH)			
19. Unit Service Factor			
20. Unit Availability Factor			
21. Unit Capacity Factor (Using MDC Net)			
22. Unit Capacity Factor (Using DER Net)			
23. Unit Forced Outage Rate			
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	<u>01-07-85</u>	_____
INITIAL ELECTRICITY	<u>01-19-85</u>	_____
COMMERCIAL OPERATION	<u>05-85</u>	_____

8502220179 850131
 PDR ADOCK 05000413
 R PDR

IE24 (9/77)
 1/1

CATAWBA NUCLEAR STATION

Monthly Operating Status Report

1. Personnel Exposure:

For the month of December, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

TELEPHONE
(704) 373-4531

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

February 15, 1985

Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Document Control Desk

Re: Catawba Nuclear Station
Docket No. 50-413

Dear Sir:

Please find attached information concerning the performance and operating status of the Catawba Nuclear Station for the month of January 1985.

Very truly yours,

H.B. Tucker
Hal B. Tucker

JAR:scs
Attachments

cc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region 11
101 Marietta Street, Suite 2900
Atlanta, Georgia 30323

Mr. Phil Ross
U. S. Nuclear Regulatory Commission
MNBB-5715
Washington, D. C. 20555

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Resident Inspector
Catawba Nuclear Station

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

Robert Guild, Esq.
Attorney-At-Law
P. O. Box 2097
Charleston, South Carolina 29412

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Ms. Judy Dovers
Nuclear Assurance Corporation
5720 Peachtree Parkway
Norcross, Georgia 30092

IE24
1/1