

T-1377

# UNITED STATES NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF:

DOCKET NO:

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
SUBCOMMITTEE ON GESSAR II AND  
RELIABILITY AND PROBABILISTIC ASSESSMENT

OPEN SESSION

LOCATION: INGLEWOOD, CALIFORNIA

PAGES: 1 - 113 and  
211 - 220

(Pages 113.1 - 210  
(and 221 - 343

DATE: THURSDAY, FEBRUARY 14, 1985

(CLOSED SESSION,  
(bound separately)

TR-04 of 1

Delete B. White, add LPDR, return original to B. White,  
H St.

ACE-FEDERAL REPORTERS, INC.

Official Reporters  
444 North Capitol Street  
Washington, D.C. 20001  
(202) 347-3700

8502250075 850214  
PDR ACRS  
T-1377 PDR

05000447

NATIONWIDE COVERAGE

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION  
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
4 SUBCOMMITTEE ON GESSAR II AND  
5 RELIABILITY AND PROBABILISTIC ASSESSMENT

6 Belmont Room  
7 Airport Park Hotel  
8 600 Prairie Avenue  
9 Inglewood, California

10 Thursday, February 14, 1985

11 The meeting of the subcommittee on GESSAR II  
12 and Reliability and Probabilistic Assessment was convened,  
13 in open session, at the hour of 8:30 a.m.

14 PRESENT FOR THE ACRS:

15 D. OKRENT, Chairman  
16 J. EBERSOLE  
17 H. ETHERINGTON  
18 C. SIESS  
19 D. WARD  
20 M. BOHN, Consultant  
21 R. SAVIO, ACRS Staff

22 NRC STAFF PRESENT:

23 D. SCALETTI  
24 M. RUBIN

25 ALSO PRESENT:

K. SHIU  
N. CHOKSHI  
R. BARI  
J. REED  
R. HARDIN  
B. IBRAHIM

PRESENT FOR G.E.:

K. HOLTZCLAW  
D. HANKINS  
D. FOREMAN  
J. QUIRK  
R. VILLA

P R O C E E D I N G S

8:35 a.m.

CHAIRMAN OKRENT: The meeting will now come to order. This is a combined meeting of the Advisory Committee on Reactor Safeguards Subcommittees on GESSAR II and Reliability and Probabilistic Assessment.

I am David Okrent, Chairman of the Subcommittee. The other ACRS members present today are Mr. Ebersole, Mr. Etherington, Mr. Siess, Mr. Ward. Also present is ACRS consultant, Mr. Bohn; Mr. Savio, raising his hand, is the ACRS Staff member for this meeting.

The purpose of this meeting will be to continue to review the application of the General Electric Company for a final design approval that can be applied to future plans referencing the GESSAR II concept the BWR/6 Mark III Nuclear Island.

This will be the third in a current series of subcommittee meetings to review the General Electric Standard Safety Analysis Report to extend the final design approval so that it will be applicable to future plans.

The principal topic of discussion at this subcommittee meeting will be seismic risk evaluation.

Portions of the meeting may be closed due to the proprietary nature of some of the material covered. I ask General Electric to alert me to those portions of

1 the meeting which they believe will involve proprietary  
2 materials.

3 A transcript of the meeting is being kept  
4 and it is requested that each speaker first identify himself  
5 or herself and speak with sufficient clarity and volume  
6 so that he or she can be readily heard.

7 We have not received any requests to make  
8 oral statements nor have we received any written comments  
9 from members of the public.

10 First, let me note that it is planned for  
11 the meeting to run to some quitting time today but that,  
12 tomorrow, I expect we will adjourn no later than noon so  
13 that, if we seem to be running more slowly than the agenda  
14 estimated today, I expect to run a little late today.

15 Let me, if I may, start the meeting with a  
16 few thoughts and questions and these are partly for the  
17 subcommittee to think on and partly for the NRC and General  
18 Electric to think on.

19 If one looks at the SFER number 3, that the  
20 staff issued and, if one looks at the reports prepared for  
21 the staff by their consultants in the seismic part of the  
22 review, one sees that there are quite a few technical  
23 questions which are not being resolved at this time and  
24 that, in one way or another, the staff is proposing that  
25 what you might call a more thorough seismic review be done

1 in connection with any construction permit application that  
2 references the GESSAR II to FDA.

3 A reasonably large part of the GESSAR II plant  
4 itself would have to be looked at in connection with such  
5 a new seismic PRA, since there are these technical questions  
6 and, also, it is not clear, at the moment, whether the  
7 approach that would be taken at an actual plant, the seismic  
8 hazard, for example, including uncertainties, et cetera,  
9 would correspond enough to what GE has done that one could  
10 just take what GE has done. There are questions about the  
11 fragilities General Electric has used and so forth, as well  
12 as some of the methodology.

13 So, it seems to me, one of the questions that  
14 the ACRS has to think about is: What does it mean if we  
15 agree to the issuance of an FDA under these circumstances  
16 and are we satisfied with issuance of an FDA under the  
17 approach that the staff outlines in their SFER-3?

18 Then, it seems to me, that there is a second  
19 kind of question. In the absence of what I will define  
20 as a seismic PRA which the staff accepts, including the  
21 entire plant but, also, dealing with all aspects of the  
22 portions of the plant covered by the FDA, how does one  
23 decide that GESSAR II is adequate in what it proposes to  
24 do in the areas which it covers? More specifically, how  
25 does one decide that its shutdown heat removal is adequate

1 if one has not fully analyzed shutdown heat removal for  
2 seismic? How does one decide that the measures proposed for  
3 containment are adequate if there is not a full evaluation  
4 of seismic? How does one decide that the evaluation of  
5 possible improvements, which GE did in its study, in terms  
6 of the PRA it presented, how does one decide that those  
7 will be valid when one has a more thorough seismic PRA?

8           How does one know that they will, in fact,  
9 not, in a sense, leave one in a, let's say, possibly,  
10 unhappy sort of awkward position in certain aspects where  
11 he wished he had something different, but accepted the FDA,  
12 after he looks at what is supposed to be the PRA for the  
13 actual plant? In fact, how does one know that the seemingly  
14 negative cross-benefit results on various features won't  
15 look differently, given what I will call a staff-accepted  
16 PRA with the full treatment of uncertainties, et cetera,  
17 plus some engineering detriments, in view of the  
18 uncertainties of the bounds.

19           In fact, if we just think of the containment  
20 aspect, we do not, at the moment, have containment  
21 performance criteria by the staff. Hence, we have no  
22 measure, in a sense, of when a containment is performing  
23 adequately, including the seismic part.

24           It is conceivable that new bypass paths will  
25 arise out of a more thorough seismic PRA. I don't know.

1 But, with no containment performance to measure overall  
2 behavior, where will one stand and so forth?

3 So I, for one, at the moment, do not find  
4 myself in a good position to just move and agree with the  
5 approach that the staff seems to be proposing in this  
6 regard. I am interested in learning more in this area to  
7 see why and if what is being proposed makes sense or, in  
8 fact, whether it does make sense to issue an FDA under these  
9 conditions.

10 Anyway, I wonder if the subcommittee members  
11 have any comments in this sort of basic kind of issue as  
12 distinct from the specific technical issue that we will  
13 get into, of course.

14 MR. EBERSOLE: Dave, I would like to make  
15 a comment. I am a little bothered by what, I guess, I call  
16 the methodology of approaching this seismic problem. I  
17 just came from a rather intense meeting on fire protection  
18 in Wilkes-Barre (phonetic), which is a Westinghouse plant  
19 and here is my problem.

20 I see, in here, a lot of shots, fragilities,  
21 on pieces of equipment but I don't see a coordinated plan  
22 that says, "What do I need to shut down to get the shutdown  
23 heat removal process to work?" "What are the detailed  
24 elements of the plant that I need, down to the last gear  
25 and cotter key?" "Don't give me generalities, I want to

1 know where the pieces are."

2           And then I want to know that they will work  
3 and then I want to know that, beyond those pieces, what  
4 pieces which I don't need but which might fail in some  
5 disorderly way will inhibit the functions of the organized  
6 set that I need for shutdown. And then, having identified  
7 this, along the lines of a Q-list, display these  
8 individually and grind to a conclusion what the fragilities  
9 are, what the margins of competence are to do their jobs,  
10 what the margins to failure are under seismic influence.

11           Instead of that, what I see is a succession  
12 of shots in the dark at a variety of things like valves-  
13 at-large, hangers-at-large, et cetera, et cetera. I think  
14 that the GESSAR II is intended to be delineated in such  
15 sharp detail that we can close on it and cease to worry  
16 about the generalized aspects of its competence because  
17 we know the detailed aspects of it. I hope that is going to  
18 be the case. It may be I am overly optimistic.

19           There is another thing. There is expressed in  
20 here a continued dependence on complex chains of systems  
21 on which you are dependent to get the heat out, as a case in  
22 point. GE has, as its capacity to do so, a highly  
23 simplified way of doing this which diminish the target size  
24 for seismic influence. If we are not confident, in the  
25 end, that these complex and interdependent chains of



1 equipment will work under these queer challenges which we  
2 can never, of course, put our thumb right tight on. I think  
3 it is important to invoke such simplifications as are  
4 possible in this unique design which so different from the  
5 PWR's.

6 CHAIRMAN OKRENT: Any other comments?

7 Mr. Siess?

8 MR. SIESS: I think this is general, Dave.

9 In the Brookhaven report, reviewing the GESSAR  
10 PRA, there are frequent references to something not being  
11 conservative. Now, I do not find the same kind of language  
12 in the SER but I do find it in the Brookhaven report.

13 And it is not clear to me whether it really  
14 means not being conservative or not being correct. I thought  
15 PRA's were supposed to be done on a best-estimate basis  
16 and not using conservative-type licensing of functions.

17 I do not know if anybody can address that  
18 or not. The staff does not use that language but the  
19 Brookhaven does.

20 CHAIRMAN OKRENT: I will ask the staff to  
21 reflect on your comment and, at an appropriate time, respond  
22 to it.

23 Any other substantive comments now?

24 (No response.)

25 CHAIRMAN OKRENT: All right. In that case, we

1 will move into the next agenda item in which the NRC staff  
2 is to give an introduction of assessments and a summary  
3 of conclusion.

4 Who is the spokesman for the staff?

5 MR. SCALETTI: Good morning.

6 My name is Dino Scaletti. I am with the U.S.  
7 Nuclear Regulatory Commission, Division of Licensing. I  
8 am the project manager for the staff for GESSAR II.

9 With me today I have Mr. Mark Rubin from the  
10 Division of Safety Technology, Mr. Ibrahim formerly from  
11 the Defense Originary (phonetic), Mr. Robert Bari from  
12 Brookhaven National Laboratories, Mr. Calvin Shiu from  
13 Brookhaven National Laboratories, Mr. Hardin from the Divi-  
14 sion of Safety Integration from the NRC staff, Louis Chokshi  
15 from the Division of Engineering and, also, Mr. John Reed  
16 from Benkem (phonetic) and Associates.

17 Just briefly, well, firstly, the staff will  
18 be requesting that, under item 4 this afternoon, parts B and  
19 C, be closed because they do discuss General Electric  
20 proprietary information. Up until that time, we have nothing  
21 that would be of proprietary nature, in order to close the  
22 meeting.

23 I will, briefly, fill you in on the status  
24 of the unsolved safety issues and the conservatory issues  
25 indentified in supplement 3 to the GESSAR II Safety

1 Evaluation Report. The containment construction analysis  
2 has been one portion which is demonstration of compliance  
3 to the CPML rule is complete and will be reported in  
4 supplement 4.

5 The dry well analysis and containment failure  
6 modes is still undergoing discussion but, I also believe,  
7 that will be completed and also reported in supplement 4.

8 The staff has completed the evaluation of  
9 they hydrogen control measures that were under discussion  
10 previously, a combination of compliance with the new  
11 hydrogen rule of 75 percent metal/water reaction and a  
12 combination of the plant protection system to comply with  
13 the hundred percent required by the CPML rule.

14 The potential design modifications, the staff,  
15 at the request of the ACRS, has met with and will meet again  
16 with IDA and General Electric to discuss the differences  
17 between the constant benefits that were developed by GE  
18 and by IDA.

19 The safety parameter display system, again,  
20 is still under review. We have identified our concerns  
21 to General Electric in the form of draft safety evaluation  
22 report which, I believe, you people have. They have  
23 responded to a couple of the concerns. We are still talking  
24 about those. I plan to publish the majority of their  
25 evaluation of the safety parameter display system in

1 supplement 4.

2           The USI's and GSI's that remain outstanding,  
3 again, are still being reviewed and, hopefully, they will  
4 be resolved by supplement 4.

5           The external events which are under discussion  
6 today have three outstanding issues identified, the relay  
7 chatter, consequence analysis and full bypass.

8           From the standpoint of relay chatter, the  
9 staff has identified or has talked to GE and identified  
10 concerns we have with regard to relay chatter. I guess  
11 three possible options to resolve this issue for GESSAR  
12 II, one of them would be for GE to complete an analysis  
13 that we would request, and give it to us before the review  
14 is complete. Another alternative would be a final design  
15 approval condition requiring it be done prior to issuing  
16 a construction permit or prior to filing an application  
17 for a construction permit by a utility applicant or as an  
18 interface issue which would be, then, left -- the burden  
19 would be placed upon the utility applicant to resolve it  
20 to the staff's satisfaction prior to issuing a construction  
21 permit.

22           The confirmatory issues are identified, are  
23 the ones that are remaining, are identified in supplement 3.

24           The sliding issues, the staff will report  
25 on that at supplement 4. The other issues, the station

1 blackout, shutdown decay heat removal, will be resolved  
2 in conjunction with completion of final design of the UPPS.  
3 The combustible gas control is still under review and it  
4 may be a while before it is resolved.

5           The optical isolators required the staff to  
6 visit San Jose -- excuse me, the software engineering manual  
7 required the staff to visit San Jose and I see no plans  
8 in the immediate future to do that to resolve that  
9 conservatory issue.

10           The optical isolators may be resolved in  
11 supplement 4.

12           The interfaces information has been ident-  
13 ified, the additional interface information, in table 2  
14 of the SER, supplement 3. This table is not all-inclusive.  
15 The interface information identified both the other two  
16 supplements and, also, in the SER. All this information  
17 will be reviewed again, at the time an application is filed,  
18 that references GESSAR II. And, at that time, the subcom-  
19 mittee and the ACRS will have an opportunity to rereview  
20 this information or to review it for the first time.

21           CHAIRMAN OKRENT: All right. May I ask a  
22 question?

23           MR. SCALETTI: Surely.

24           CHAIRMAN OKRENT: You were sent a copy of  
25 the comments prepared by our consultants at Sandia with

1 regard to, I guess, what one would call internal events  
2 for the PRA and there was interest in some additional infor-  
3 mation.

4 Has that been prepared or where does that  
5 stand? Could you remind me?

6 MR. SCALETTI: Dr. Savio and I talked about  
7 that the other day and I was unaware of a request for us  
8 to comment or to respond to additional information in the  
9 ACRS's consultant report.

10 When I get back to the office, I will, again,  
11 talk to Dr. Savio and see what can be resolved in that.

12 CHAIRMAN OKRENT: Well, I am sorry you mis-  
13 understood. I thought it was clear that we were interested  
14 in having our consultants get the information that they  
15 were interested in. In mean, I don't know why we would  
16 get them as consultants if we did not try to see that they  
17 can get information in the same way that you have your con-  
18 sultants get information.

19 What is the problem?

20 MR. SCALETTI: The request to the staff, Dr.  
21 Okrent, as far as I know now, and Dr. Savio can correct  
22 me if I am wrong, was: Could the ACRS consultants confront  
23 freely with the Brookhaven consultants over the telephone  
24 and the staff felt it would be better if -- certainly, we  
25 did not object to them conferring with Brookhaven, at all,

1 however, we did want to be aware of what was going on.

2 All effort should be made, whenever a conver-  
3 sation of this nature took place, that one staff personnel  
4 was there to understand the resolution of the problems or  
5 what the problems were. And, to my knowledge, no attempt  
6 has been made.

7 CHAIRMAN OKRENT: Mr. Savio?

8 MR. SAVIO: It is my understanding that Sandia  
9 has had some conversations with Brookhaven regarding, not  
10 necessarily their report, they are getting some additional  
11 information.

12 Is that correct?

13 MR. BOHN: I don't know. I do know that,  
14 right now, they are short on information. They feel they  
15 need to evaluate the parts that they are studying right  
16 now.

17 CHAIRMAN OKRENT: Well, let me advise the  
18 staff that we will want to be sure that our Sandia consul-  
19 tants have that information that they consider to be signif-  
20 icant. So, I will leave it at that for now.

21 Go ahead.

22 MR. SCALETTI: I believe that completes all  
23 that I have to say with regard to issue number A under item  
24 2. Mr. Rubin, now, will --

25 CHAIRMAN OKRENT: Excuse me. You just men-

1 tioned the schedule of the SFER?

2 MR. SCALETTI: Oh, I am sorry.

3 Presently, the schedule would call for another  
4 supplement 4 to be issued in March.

5 CHAIRMAN OKRENT: Beginning or end?

6 MR. SCALETTI: I wish I could be that  
7 definite.

8 CHAIRMAN OKRENT: All right.

9 MR. SCALETTI: Probably the middle or towards  
10 the end.

11 CHAIRMAN OKRENT: Thank you.

12 MR. SCALETTI: Mr. Rubin will discuss the  
13 bypass sequences.

14 MR. RUBIN: The seismic evaluation is not  
15 complete in the areas of the back end water. The consequence  
16 analysis still remains to be done. And, as part of that,  
17 two full bypass sequences are still being considered by  
18 the staff and our consultants, Brookhaven National Labor-  
19 atories.

20 Preliminary results indicate that there were  
21 two additional bypass sequences that were not considered  
22 in the General Electric seismic risk assessments. The two  
23 sequences identified involve a massive structural failure  
24 involving reactor pressure vessel, the drywall containment  
25 and the shield buildings as one sequence and, also, a



1 possible bypass sequence involving the RHR heat exchanger.

2 Both of these would involve potential loss  
3 of the suppression pool and the release of unscrubbed  
4 material following a core melt.

5 As indicated, the work is not complete. Pre-  
6 liminarily, it appears that the massive structural failure  
7 is quite unlikely but consequences are being considered  
8 by the staff and we will be reporting that in a supplement.

9 The RHR heat exchanger failure is still under  
10 evaluation and we are not yet confident on quantification  
11 of the sequence that is being worked on currently.

12 Wfhen we complete this work, we will report  
13 it to you.

14 MR. EBERSOLE: Could you tell me a little  
15 bit more about the RHR bypass being in the heat exchangers?

16 MR. RUBIN: Yes, the RHR bypass sequence in-  
17 volves the failure to the heat exchanger, most probably  
18 the support rupture of the heat exchanger shelf tubes, the  
19 draining of the suppression pool, potentially, below the  
20 level where you get effective scrubbing of the fission pro-  
21 ducts. And the increased consequences would be beyond what  
22 was originally anticipated and analyzed before in those  
23 releases.

24 MR. EBERSOLE: So, you bypass the suppression  
25 pool through loss of water, through the heat exchangers?

1 MR. RUBIN: Yes, into the RHR heat exchanger  
2 rooms and possibly for right now, outside the rooms.

3 MR. EBERSOLE: And then you subject the con-  
4 tainment, then, to an unsuppressed pressurized --

5 MR. RUBIN: That would also --

6 MR. EBERSOLE: What I am trying to get at:  
7 They have got this space where the containment site is it-  
8 self, more than it ceases to hold fission products, it also  
9 contributes to making the accident worse?

10 You were taling to post-core melt phenomenon,  
11 aren't you?

12 MR. RUBIN: Yes.

13 MR. EBERSOLE: You are not taling about bypass  
14 in the context of a bypass initiating the event that caused  
15 the core melt?

16 MR. RUBIN: That is correct. It was not  
17 initiation event.

18 MR. EBERSOLE: Right.

19 The reason I asked, it is important all con-  
20 tainments carry a penalty. If you don't get the heat out,  
21 they can, then, lead to core damage.

22 Then the GE design has the, as a feature,  
23 however, has scrubbing and it would be, at least in my view,  
24 to select a second bypass because of core melt without the  
25 privilege of opening the secondary side of the suppression

1 system.

2 Now, I really don't know what is in place  
3 now, in the logic, once you get a bypass, but you still  
4 have an undamaged core. Whether we vigorously permit dis-  
5 charge from the back side of the suppression pools or not  
6 to prevent core damage, is there any generic practice in  
7 that respect?

8 MR. RUBIN: There is protection against, say,  
9 failure of the heat exchanger into the rooms and for un-  
10 mitigated loss of fluid from the system. You have room  
11 alarms; you have procedures for terminating, isolation  
12 valves --

13 MR. EBERSOLE: It is -- involve a --

14 MR. RUBIN: Yes.

15 MR. EBERSOLE: I see.

16 Well, the effect which I said -- core damage,  
17 would, then, containment failure occur and you would inherit  
18 core damage from that?

19 MR. RUBIN: Just a moment.

20 MR. EBERSOLE: The reason I ask that, I don't  
21 think that should be the case.

22 MR. SHIU: Calvin Shiu from Brookhaven.

23 The statement that we have looked at involves  
24 only of the core damage. The possibility of failure is  
25 that, should there be a tragic event, the heat exchanger

1 failed and, as a result of its failure, leading to a po-  
2 tential drainage of the suppression pools.

3 MR. EBERSOLE: But, up to this point, there  
4 is no core damage?

5 MR. SHIU: Up to this point, there is no core  
6 damage.

7 MR. EBERSOLE: All right.

8 MR. SHIU: And, in the meantime, if an assump-  
9 tion is made, because I have lost by -- heat exchanger,  
10 that there would be no containment heat removal capability  
11 and, eventually, there will be core damage.

12 MR. EBERSOLE: But they are still have to  
13 use a loss of special process, but you haven't damaged the  
14 core?

15 MR. SHIU: Right.

16 MR. EBERSOLE: There is the privilege you  
17 have with this plant, I guess, with a degree of suppression  
18 to relieve the containment on the back side and, thus, pre-  
19 vent it from causing core damage.

20 MR. SHIU: There is possibility with their  
21 avenues, given you have lost your RHR heat exchanger, to  
22 continue to maintain some sort of venting and keep --

23 MR. EBERSOLE: I am inviting --

24 MR. SHIU: The UPPS system, for instance,  
25 would mitigate this particular scenario.

1 MR. EBERSOLE: If it were designed to cope  
2 with it.

3 MR. SHIU: That is right.

4 MR. EBERSOLE: Which it is not now.

5 MR. SHIU: We have not examined that particu-  
6 lar --

7 MR. EBERSOLE: No, it is designed as an --  
8 perspective of recovering the loss of power, I believe.

9 MR. SHIU: Well, I believe that, if we assume  
10 that UPPS will survive the initiating event, the earthquake,  
11 that, potentially, it can be considered.

12 MR. EBERSOLE: This was the point I was get-  
13 ting around to. Have you exhausted your avenues of escape?

14 MR. SHIU: In the BNL (phonetic) evaluation,  
15 we did not include a UPPS as part of the consideration.

16 MR. EBERSOLE: Thank you.

17 MR. SCALETTI: Dr. Chokshi will address the  
18 seismic monitorings from the standpoint of the staff.

19 MR. CHOKSHI: This is a detailed presentation  
20 planned this afternoon on the fragility aspects and there  
21 are a lot of fragility issues that will be discussed during  
22 the presentation.

23 This morning, I am just going to briefly  
24 summarize what is the oral stop findings (phonetic), and  
25 comments from the GESSAR PRA review as it addresses the

1 margin issue.

2 One thing that most specific seismic margin  
3 study comes of which has been characterized as a high-prob-  
4 ability consequence of failure. That nature (phonetic)  
5 was conducted for the -- by staff and I am, also, not aware  
6 of what -- has done but --

7 CHAIRMAN OKRENT: I am sorry. I can't hear.  
8 Would you speak a little more slowly, please.

9 MR. CHOKSHI: The staff did not conduct a  
10 specific margin study in terms of high-probability, low --  
11 high-confidence, low-probability -- values of 95 percent  
12 confidence, five percent failure. It was presented in  
13 limited meeting.

14 The reasons for that this study is almost  
15 precluded by the very nature of GESSAR II that it not an  
16 active plant or actual site and the details are not available  
17 to conduct that kind of study in any meaningful fashion.

18 As we will discuss this afternoon, there are  
19 -- aspects which help -- and site specific -- and are not  
20 addressing -- generates the other.

21 Manual fragilities are based on segment and  
22 from the previous CRA's and which will, also, require a  
23 detailed evaluation and as to a particular site to assess  
24 some margins.

25 So, in terms of high-confidence, low-probab-

1    ility of failure, that kind of margins we do not have in  
2    quantative sums.    However, based on PRA review and both  
3    FDA review, we have some feelings for the margins in general  
4    and I would like to briefly say what we think of.

5                   Structures and component levels, I think it  
6    is already strong feeling that for structures whose capacity  
7    is governed by seismitic environment, and I am excluding  
8    in these the structural capacity based on the soil in neg-  
9    ative failure modes, those stuctures, I think, in looking  
10   at the GESSAR fragility values, although we have some doubts  
11   and some questions about it, I am enthused that -- it is  
12   still believed that those values indicate that those struct-  
13   ures have a high capacity as you would expect from an  
14   element of design.

15                   For confidence and for site -- aspect, we  
16   do not have enough information at this time to conclude --  
17   For an example, SLC tank, the fragility and -- are limited  
18   value without regard to the location of that particular  
19   component in the building -- for consideration.

20                   Looking at actual plans, the fragilities are  
21   quite different.    A lot of -- for Limerick.    However, on  
22   the structure of designs, also, are more complete and I  
23   think there is more confidence the structures exhibit  
24   margins of similar -- plans.    And I will cite an example  
25   where the capacity will go on structure design will be a

1 shield building where the shields and structurals are pri-  
2 marily -- from seismic consideration and you will see  
3 that these have more capacity than for a plant-specific  
4 design.

5 CHAIRMAN OKRENT: Excuse me. If I understood  
6 correctly, all of these points are going to be covered in  
7 more detail?

8 MR. CHOKSHI: Yes.

9 Yes, these plans just give brief summary of  
10 what we think about margin at this time.

11 I wanted to point out that the GESSAR II  
12 design is done to the current stock requirement and it con-  
13 tains the conventional conservatism such as -- drills versus  
14 the -- drills, the radioconductor analysis, response comb-  
15 ination which are very similar to the --

16 And additional margin comes and these come  
17 as applicable back to, again, structural capacity, is from  
18 developing design department. So, at some sites with lower  
19 SSE, you will see some margin -- in design for those com-  
20 ponents.

21 However, I would like to conclude on this  
22 particular topic that all this needs to be demonstrated  
23 in a more detailed fashion, on a plant-specific basis, to  
24 really evaluate margins in more quantitative terms, particu-  
25 larly with components and site-specific aspects which I



1 want to discuss in the next few minutes, which I need some  
2 more -- by way of information.

3 You are aware of the fact that margin panel  
4 is looking at some -- PRA's to come up with generic, high-  
5 confidence, low-probability values and I believe that that  
6 is going to be presented to you the next few weeks.

7 CHAIRMAN OKRENT: Excuse me. I am not quite  
8 sure what the interpretation is of the remark that you made  
9 that there needs to be more evaluation of margins.

10 When? By whom and so forth? Could you help  
11 me on that?

12 MR. CHOKSHI: Yes, I think we have indicated  
13 that on site-specific basis, the needs to demonstrate that  
14 the fragilities are -- to those that are found in GESSAR  
15 or equivalent to what was assumed in the staff analysis,  
16 sensitivity analysis.

17 The condition, too, at the --

18 CHAIRMAN OKRENT: I am not quite sure what  
19 you mean when you say assumed in a sensitivity analysis.

20 Usually, in a sensitivity analysis, one takes  
21 a variation in things. What does it mean to say, "...the  
22 same as assumed in a sensitivity analysis"?

23 MR. CHOKSHI: The BNL conducted the studies  
24 of alternate fragility of the components which were not  
25 included in GESSAR, to get an idea of the margins of --

1 CHAIRMAN OKRENT: But what --

2 MR. CHOKSHI: Those fragilities were based  
3 on the past PRA's.

4 CHAIRMAN OKRENT: But what does it mean to  
5 say, ..."the same as the staff assumed in its fragility  
6 analyses"? I am trying to understand the sentence, at the  
7 moment.

8 MR. CHOKSHI: Those are representative of  
9 fragilities in the sense that those represent, in past PRA's  
10 of -- plants.

11 CHAIRMAN OKRENT: It is vague. You are  
12 answering a different question.

13 MR. RUBIN: Dr. Okrent, staff and our con-  
14 sultancy now felt that the critical components list was  
15 not complete for the plant and proposed what they thought  
16 were likely representative fragility values for missing  
17 components, structures.

18 As a starting point, we have presented those  
19 in a requantification as part of the sensitivity analysis  
20 to come up what we feel are better values for seismic cont-  
21 ribution to core melt. And, when an application is made  
22 referencing GESSAR, the site is selected, the full scope  
23 of the plant is available, we feel that the fragilities  
24 have to be reassessed and they should be compared to the  
25 value that has been postulated in our evaluation where

1 deviations are identified, a more complete risk assessment  
2 needs to be conducted to determine whether the fragility  
3 values in the as-built plant will be sufficient.

4 CHAIRMAN OKRENT: Now, presumably, you  
5 specified some value with an uncertainty distribution around  
6 it or --

7 MR. RUBIN: That is correct. Well, yes, the  
8 table in the SER and the BNL report indicates the beta  
9 values around the component structural facilities.

10 CHAIRMAN OKRENT: And when General Electric  
11 compares something with that, they are also comparing some  
12 kind of subjective estimate with some subjective estimate  
13 of an uncertainty distribution or what?

14 MR. CHOKSHI: I would make a general comment  
15 and then ask Dr. John Villa some comment on this.

16 At this point, I would think that when the  
17 fragility analysis is being carried out, the assumptions  
18 and some of the values would be very similar to what we  
19 have seen in past PRA's or, at least based on some kind  
20 of judgment which we can -- look at the -- on those values  
21 and to the process similar to which is being carried out  
22 for their PRA's in computing total distribution.

23 CHAIRMAN OKRENT: By the way, I want to make  
24 an observation here. It is true that we have a family,  
25 now, of seismic PRA's but there is a commonality in the

1 estimation of fragility. And there could easily be a common  
2 mode error here. I think it is somewhat dangerous to assume  
3 that having three or four PRA's gives you much additional  
4 information. And I don't know how to factor that in but  
5 I can look back in history and think of times when there  
6 was one person who took one point of view against the rest  
7 of the scientific community and won out. So, one has to  
8 be a little cautious.

9           Here, you don't even have what I would con-  
10 sider to be the benefit of many different independent ex-  
11 perts. A second thing is, what you find acceptable for  
12 existing plants in the PRA's may or may not be what should  
13 be acceptable for a new FDA. It is not clear to me that  
14 the same standards should be used, for example, with regard  
15 to knowledge of fragility. It is not clear to me at all.

16           In fact, I would like the staff to think on  
17 this question. I am not looking for an off-the-top-of-head  
18 answer. This is just: What do you think should be accept-  
19 able in regard to this kind of uncertainty in our knowledge  
20 as well as other aspects of the plant that have similar  
21 questions or a new plant, for a new FDA.

22           Now, you may come back and say the same.  
23 I want to know why the same, if that is your position.

24           MR. CHOKSHI: If the actual mechanics of that,  
25 the intent of that requirement has to be, as you say, to

1 part out and monitor.

2 CHAIRMAN OKRENT: Well, we are trying to raise  
3 broader considerations today, since this is our first  
4 attempt to go through an FDA or a standard plant approval  
5 under what may be the Commission policy.

6 All right. Go ahead.

7 MR. CHOKSHI: If there are no more questions  
8 on the margin issue then, I would like to talk about the  
9 next item, about how the fragility analysis encompass  
10 various site conditions.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1                   CHAIRMAN OKRENT: All right. Before you do  
2 that, you, sort of, left out liquifaction.

3                   MR. CHOKSHI: I am going to address it.

4                   CHAIRMAN OKRENT: You are going to address it?

5                   MR. CHOKSHI: Yes.

6                   CHAIRMAN OKRENT: All right.

7                   MR. CHOKSHI: Again, I am going to, similar  
8 to my previous comment, is going to be very brief and just  
9 a summary of what will be discussed in considerable details  
10 this afternoon.

11                   But, I am going to highlight -- value. We  
12 think there are -- fragility analysis compared with all  
13 sites. Most often, BNL review identified sole structures  
14 and compnents and failure modes which are quite dependent  
15 and have not been considered in GNR's explicitly at this  
16 time.

17                   For example, of structures and components not  
18 included in GESSAR II fragility evaluation are some of the  
19 things that are found on the other PRA's such as retaining  
20 walls and -- piping.

21                   Of course, these are outside the scope of  
22 GESSAR II design, Nuclear Island, and these are the DOP-type  
23 of structures.

24                   But, before I go into more detail, I would  
25 like to mention that, for the deterministic design review,

1 GESSAR did design plans for plant 2G (phonetic) with various  
2 site conditions, ranging from a relatively soft site to a  
3 rough site. And many parameters which include the -- such  
4 as imbedment will, also, consider the parameters estab-  
5 lished from the deterministic design point of view to  
6 address various sites.

7 The same -- or same degree of -- is not in  
8 the PRA calculations. PRA calculations are more general  
9 and, therefore, I think it is not clear to us that they are  
10 bounding (phonetic) when you consider various sites or  
11 conditions.

12 Going back to the failure modes, and such  
13 which you have not -- not have an exclusive address of the  
14 liquifaction and settlement and slope failure, for an  
15 example.

16 The deterministic design addresses this issue  
17 of the relative levels. However, the SSC (phonetic) -- I  
18 think this issue, they have to be dealt on site-specific  
19 basis.

20 CHAIRMAN OKRENT: How?

21 MR. CHOKSHI: What was the question?

22 CHAIRMAN OKRENT: How?

23 MR. CHOKSHI: How they should be dealt on the  
24 site-specific basis?

25 CHAIRMAN OKRENT: Yes.

1 MR. CHOKSHI: I would, again, point to the  
2 PRA's done on other plants which held this phenomena.

3 For example, on the -- is currently looking  
4 at this deception potential which might -- that issue has  
5 been based -- that they should look at the liquifaction but  
6 that the index structure is not -- but --

7 CHAIRMAN OKRENT: What criteria will you use  
8 in judging whether or not something is acceptable with  
9 regard to liquifaction, if they meet the standard review  
10 plan?

11 MR. CHOKSHI: I don't have a specific answer  
12 to this question. I would think that a lot of system con-  
13 sideration will go into that, deciding whether liquifaction  
14 is that extent which leads to a certain kind of unacceptable  
15 consequences.

16 I don't have any specific --

17 CHAIRMAN OKRENT: I must confess that is not  
18 a very well-defined approach for how one would deal with  
19 the issue at the site-specific review and I suspect, if I  
20 ask a similar question concerning components and structures  
21 as to how you will judge adequacy, if they meet the SRP,  
22 it is going to be a similar answer and it sort of leaves  
23 me not knowing quite where this all is.

24 MR. CHOKSHI: Maybe I don't understand your  
25 question, but --



1                   CHAIRMAN OKRENT: Well, let's get back to  
2     liquifaction. Now, when one looks at how this has been  
3     approached for sites where it was an issue, the safety  
4     factors provided have varied considerably from plant to  
5     plant, always meeting the SRP.

6                   Are you going to ask for a safety factor of  
7     five? Four? Well, you could say, "Put it on rock." or  
8     whatever. But it is, right now, very elusive, in my mind,  
9     what the basis is that the staff would use in judging beyond  
10    what is required in the SRP.

11                  MR. CHOKSHI: I think I agree with you that  
12    the -- will come. They will come, for example, factors of  
13    safety are used for -- stability of structures and R-1 will  
14    build -- is a question which I don't have answers for. And  
15    I doubt if anyone can address, from the quality point of  
16    view --

17                  MR. SIESS: But liquifaction is in a different  
18    category than slide and overturning. It is possible to select  
19    a site or to so modify the soil that liquifaction is  
20    impossible. The same is not true for sliding and I believe  
21    that a prudent licensee, a prudent applicant, in the future,  
22    would not even consider a site where he had to make an  
23    argument for a factor of safety on liquifaction. He could,  
24    probably, save three months of review time by either putting  
25    in a fill or picking a proper site. But that is not true

1 for the other things.

2 CHAIRMAN OKRENT: Well, let me throw a little  
3 curve into what Mr. Siess has said in that there have been  
4 some cases where applicants have tried to do, let's say,  
5 what he said, namely to, at least, reduce the likelihood  
6 of liquifaction to small numbers but the quality of the work  
7 now becomes important, the quality of achieving what you  
8 set out to do on paper.

9 And I believe it is not clear, in the past,  
10 plants met the original design intent. In fact, I am sure  
11 we can find some examples.

12 So, I still find this an elusive area, among  
13 others.

14 MR. CHOKSHI: What I understand the comment,  
15 on liquifaction potential, it is, probably, possible to  
16 look at preventing this liquifaction by adopting certain  
17 measures, other than not relying on specific analysis, which  
18 is very uncertain.

19 I am understanding correctly the question?

20 CHAIRMAN OKRENT: Well, we are trying to  
21 understand, at the moment, just what it is the staff is  
22 proposing in connection with this proposed FDA, how  
23 questions of this sort are to be addressed and we are exam-  
24 ining one specific issue, although there are others of the  
25 same type.

1           MR. SCALETTI: You are asking us to define  
2 our acceptance criteria for ten years down the road or five  
3 years down the road? It may change, at that time, when the  
4 site is identified and application is submitted that ref-  
5 erences GESSAR II. The siting information would have to  
6 be reviewed; it would have to be evaluated against -- the  
7 current PRA against all the interface items would have to  
8 be resolved. At this time, the staff will deal with that  
9 issue and, also, you gentlemen will have the opportunity  
10 to revisit that, based upon the current acceptance criteria.

11           CHAIRMAN OKRENT: Some of these gentlemen may;  
12 others will not.

13           MR. EBERSOLE: That really bothers me because  
14 of the open-endedness of the whole problem, which is the  
15 basis for failure of the whole process, at the moment.

16           MR. SCALETTI: Well, the Commission allows  
17 for the definition of scope and it does not require, at this  
18 time, a complete plan. Right now we have the 4-S GESSAR  
19 which is the most complete plant, standard plant we have  
20 had under review. We have more information here. We are  
21 trying to deal with this information as best we can but we  
22 realize there is going to be, when an application is filed,  
23 much work that has to be done.

24           The process will be shortened, I am sure but  
25 there will still be a great deal of review that will have

1 to take place.

2 CHAIRMAN OKRENT: You mentioned criteria?

3 MR. SIESS: All your review for margins will  
4 be based on a PRA, then?

5 MR. EBERSOLE: The standard review plan calls  
6 for SSE with nominal margins. If you are looking at much  
7 larger seismic shaking, then your criterion will be only  
8 in the PRA. You will look and see on that basis; is that  
9 what I am hearing?

10 MR. SCALETTI: The only high class criteria  
11 are those that are specified in our standard review plan,  
12 in our regulations.

13 I will let Mr. Rubin address the PRA context  
14 here but we don't even have any hard facts criteria or im-  
15 plied margins within the probabilistic risk factor.

16 CHAIRMAN OKRENT: By the way, before he goes  
17 on, I should note, only last week I heard it said that the  
18 SRP are really not hardfast regulations.

19 MR. SCALETTI: Well, complying with the SRP  
20 is required by, or by regulations. 5034-G, I believe, re-  
21 quires that you can document deviations but these deviations  
22 have to be acceptable to the staff. But it is a regulation,  
23 5034-G.

24 MR. RUBIN: Mr. Scaletti already mentioned  
25 most of the points. Let me just reiterate that.

1           We have no margin requirement in the PRA or  
2 attempt -- what to obtain a more accurate, to the extent  
3 possible, more representative assessments of the plants  
4 seismic risk. To the extent that site-specific factors might  
5 invalidate our assessment, or reassessment of the General  
6 Electric work, we feel that should be revisited when that  
7 information is available, to provide assurance at that point  
8 that the -- I don't know if this is really correct to use  
9 the word "margin" in this context, but to validate the  
10 quantification on the site-specific basis.

11           If the site -- the parameters identify that  
12 you might have rocking or sliding or liquifaction or other  
13 factors that would impinge on the plant response that would  
14 cause an increase in risk, core melt contribution, we think  
15 that should be identified at the time the plant is sited,  
16 appropriate action should be taken.

17           At this point in time, that information is  
18 not available to allow the process to go forward. And that  
19 is why we ask that it be revisited at a later date.

20           CHAIRMAN OKRENT: Mr. Bohn has a question.

21           MR. BOHN: Well, this is really more of a  
22 comment in regards to the liquifaction in general.

23           The relative displacement problems between  
24 buildings, and that is what these really address, these have  
25 turned up in past PRA's as being important.

1           One recognizes that the failures that are pre-  
2 dicted are based on a relative displacement of, say, two  
3 inches or something, between buildings. And it is the rel-  
4 ative displacement stresses that are causing the failure.  
5 They are not inertia stresses, at all.

6           I would think that one could define limits  
7 or GE could postulate limits on relative densities of sands  
8 of various sites which is the critical parameter in liqui-  
9 faction, as well as water densities, and do a series of  
10 studies, very limited, simple studies, I should add, that  
11 would enable them to estimate for a given distance between  
12 foundations and given relative densities of sands, what type  
13 of potential there really was for causing pipe breakage.

14           And they could, in defining their GESSAR  
15 design, define relative anchorages between the two buildings  
16 or relative spacings between the two buildings as a function  
17 of potential for relative motion, such that you wouldn't  
18 get into this problem.

19           And, I think, they could do that with  
20 sufficient margin so that it would not be a problem in the  
21 future. I think the same sort of approach could be taken  
22 for components, as Neil (phonetic) had mentioned --

23           I suspect the types of components that are  
24 being used are relatively standard. We recently computed  
25 a walkdown of seven power plants that are operating in this

1 country and, typically, we find, as others have found in  
2 the past, that it is anchorage that causes problems. And  
3 I would think that, in their design, the anchorage could  
4 be specified as part of the GESSAR design in such a fashion  
5 that these problems would not constitute an important part  
6 of the risk due to seismic.

7 In general, we find, if there is reasonable  
8 anchorage, they don't contribute to seismic risk. If there  
9 is not reasonable anchorage, if there is just tack-welds  
10 or very small bolts holding, say, switch gear down, then  
11 it really doesn't matter what size they are, they do con-  
12 tribute to the risk. And I would think that these could  
13 be addressed in the context of a generic design such as  
14 GESSAR.

15 MR. CHOKSHI: I guess only one more item con-  
16 cerns fragility with respect to siting hazard, evolution  
17 itself. And parameters such as expected manipulations, a  
18 -- will also affect fragility. And the local site condi-  
19 tions will go on those parameters. So, that, also, has to  
20 be looked at along with hazard evaluation.

21 I think that, sort of, in conclusion, I would  
22 like to say that fragilistic design has considerable affect  
23 on conditions and, as we have discussed in our previous  
24 GER's, we don't feel that in PRA context, that has been --  
25 that all site conditions as to fragility statements are

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

representative for all site conditions.



1                   CHAIRMAN OKRENT: All right.

2                   Why don't we take up item E and then we will  
3 have some general discussion -- or more general discussion  
4 -- or additional general discussion.

5                   MR. EBERSOLE: Mr. Chairman, may I ask a  
6 question?

7                   CHAIRMAN OKRENT: Surely.

8                   MR. EBERSOLE: I have come to look on this,  
9 really, as no more than sort of a sampling of the method-  
10 ology that GE intends to use for GESSAR II. It is,  
11 certainly, by no means, polished to include all those points  
12 I mentioned earlier. It is just, perhaps, a small sampling  
13 of the intent to go forward on a really detailed specific.

14                   And, whatever we do here is not more than an  
15 approval of that process that they are going to use on a  
16 far more detailed basis.

17                   Am I correct?

18                   MR. SCALETTI: In part you are correct, yes.  
19 I think there is a lot more effort that has to take place  
20 when a site is chosen.

21                   MR. EBERSOLE: Therefore, we need not really  
22 look, as I questioned, the fact that this is -- we are  
23 closing on this in high detail, which we are not by any  
24 means. We are just closing on the generalized methodology  
25 which will be used in high detail later on. Is that the

1 way I --

2 MR. SCALETTI: Well, there is a lot of effort  
3 that has taken place which is valid and it can be used.  
4 We require that certain things be done at the site-specific  
5 stage and all this information will have to be reviewed and  
6 evaluated against -- to see whether it does fall within the  
7 site hazard curve, to see if everything fits in place.

8 And to say that everything will have to be  
9 done again, I wouldn't go quite that far. I do believe  
10 there is a great deal of effort that will have to be done.

11 MR. EBERSOLE: Well, you know there is only  
12 a small sampling of the horrendous detail that goes into  
13 a plant.

14 MR. SCALETTI: Certainly but I don't -- all  
15 of our SER's is, in most cases, it is a sampling of infor-  
16 mation, never a complete review process or all the detail  
17 that goes into the design that is written up in the SER.

18 CHAIRMAN OKRENT: Jesse, I would be a little  
19 hesitant to arrive at the conclusion you were suggesting,  
20 at least quite yet.

21 We will leave it at that for the moment.

22 MR. EBERSOLE: Yes, all right.

23 CHAIRMAN OKRENT: And we will see what devel-  
24 ops.

25 MR. EBERSOLE: When you get into relay chatter

1 where you invite some consideration to -- I think they are  
2 available, chatter-free relays, if you look for them.

3 And there is a related problem which came out  
4 recently in some reports that transducing equipment, operat-  
5 ing near the setpoint of trip, which is not tested in the  
6 seismic mode, tends to, in effect, cross over the sensing  
7 point and become, in essence, a chattering transducer.

8 Do you follow me?

9 CHAIRMAN OKRENT: Why don't we hear what they  
10 are going to do to resolve relay chatter and, now, trans-  
11 ducer chattering issues.

12 MR. SCALETTI: We didn't plan on trying to  
13 resolve relay chatter right now. We had indicated, earlier  
14 on, that -- I had indicated that it was a new problem. The  
15 staff has not totally identified this problem. We have dis-  
16 cussed it with GE. We do have the three options that I had  
17 previously discussed. We are willing to entertain any  
18 questions you have. It is an outstanding issue; the staff  
19 hasn't completed its review and I don't know what we can  
20 tell you.

21 But, if you have some questions, we have some  
22 people here that will try to answer them for you.

23 CHAIRMAN OKRENT: Does the staff review now  
24 include or will it include, or does GE's analysis include  
25 what I would call a system behavior analysis in the face

1 of postulated relay chatter?

2 MR. RUBIN: I think that is exactly what we  
3 would want to be looking for. The problem is fairly  
4 recently identified. We think it potentially could be  
5 serious but we are not convinced of that.

6 We need to obtain a full understanding of the  
7 plant, responsibly -- we don't have it at this point.

8 CHAIRMAN OKRENT: Is this something, again,  
9 that is left for the CP stage, in your mind, or what?

10 MR. RUBIN: We have alternatives on approach-  
11 ing it. We have identified various information that we feel  
12 we need to go forward on a full assessment of the plant  
13 response. And it is not yet determined if we will get all  
14 that information at this time or that some of it will have  
15 to be provided later.

16 CHAIRMAN OKRENT: Excuse me, but I think the  
17 staff wants to come into the ACRS to get the committee  
18 opinion. Where will this matter stand at that time?

19 Unresolved; is that what you are saying? Or  
20 you don't know?

21 MR. SCALETTI: It will probably be still un-  
22 resolved; correct.

23 CHAIRMAN OKRENT: And it is okay for it to  
24 be unresolved?

25 MR. SCALETTI: It would have to be resolved

1 prior to a construction permit being issued.

2 Again, Doctor, we have only a piece of the  
3 design. We don't have the complete design; we have a large  
4 part of it.

5 CHAIRMAN OKRENT: But before the final design  
6 approval, this is what I am trying to -- maybe it is a pre-  
7 liminary design approval.

8 MR. SCALETTI: Well, I don't think so. We  
9 mentioned earlier that the Commission allows for partial  
10 designs to be approved. The final design review is for  
11 partial design.

12 CHAIRMAN OKRENT: All right.

13 Are you going, again, to give a list of those  
14 parts of the design which are approved and those parts which  
15 are not?

16 MR. SCALETTI: Those are identified in the  
17 SER's as far as the interface items; they are identified  
18 in GESSAR in section 1.9, I believe it is. There is a great  
19 long list of items that have to be completed and this would  
20 be part of the construction permit review, is to resolve  
21 all of these interface issues.

22 MR. EBERSOLE: Well, Dave, that is what I was  
23 trying to say earlier. This is a final design of a small  
24 part of the plant, the final design approval, but, by no  
25 means, comprehensive.

1 MR. SCALETTI: Well, clearly, it is a large  
2 part of the plant. It is not just the NSSS.

3 MR. EBERSOLE: I guess I am just down in the  
4 component level, now, when I am talking about small percent-  
5 age of parts.

6 CHAIRMAN OKRENT: Mr. Siess?

7 MR. SIESS: I got the impression that the  
8 staff said they don't know whether relay chatter is a prob-  
9 lem; is that right?

10 MR. RUBIN: That is correct. It has been --

11 MR. SIESS: All right.

12 And does that mean that you expect to use  
13 GESSAR II as a basis for finding out whether relay chatter  
14 is a problem?

15 I mean, if it is a problem on GESSAR II, it  
16 is, probably, a problem on a lot of other plants.

17 Is there available either a digital computer  
18 program or an analog computer that would represent the  
19 control and protection system where you could introduce  
20 random relay chatter into it and see what it does in the  
21 way of C & N's or complications, or does somebody have to  
22 sit down with a line diagram and make a lot of assumptions?

23 CHAIRMAN OKRENT: I think you would want the  
24 power system in there, too.

25 MR. SIESS: Power system. Anything that has

1 relays in it.

2 MR. RUBIN: I think we would, certainly, like  
3 to have available to us that first option and I don't be-  
4 lieve it is available.

5 MR. SIESS: You mean the other alternative  
6 is to wait until the earthquake occurs and find out what  
7 happens. But that is really not the way we --

8 MR. RUBIN: That is not --

9 MR. SIESS: We have done this in the past but  
10 let's -- I thought we were trying to get away from that.

11 MR. RUBIN: Well, we definitely are. This  
12 is a developing problem, recently identified. I think first  
13 referenced on the Limerick PRA as a potential impacting --

14 MR. SIESS: What, relay chatter?

15 MR. RUBIN: Recently, on Limerick.

16 MR. SIESS: How recent? It has been around  
17 for at least three years that I know about.

18 CHAIRMAN OKRENT: It is not that new but go  
19 ahead.

20 MR. SIESS: I have been hearing about it for  
21 a long time.

22 MR. RUBIN: Well, we don't have a complete  
23 modeling of the effect. I think that is what we are looking  
24 for. And it is a fairly large effort which we haven't been  
25 able to go forward and complete, at this point in time.

1           And what we have done in the PRA reassessment  
2 is to attempt to model, as part of the scoping analysis,  
3 how serious the potential impact of relay chatter would be.  
4 Those results have indicated to us that it is non-trivial  
5 and we are going forward. We hope to eliminate relay  
6 chatter as a serious contribution.

7           MR. WARD: What do you mean, you hope to  
8 eliminate it? Do you mean that you hope that the study  
9 is going to tell you it is not a serious contributor; is  
10 that it?

11           MR. RUBIN: We will complete the study to  
12 determine if actions have to be taken such as chatterless  
13 relays or other system modifications to reduce its potential  
14 impact.

15           MR. SIESS: Does your analysis look at whether  
16 the consequences of relay chatter are easily known to the  
17 operator?

18           It seems to me there are two categories, the  
19 relay chatter concealing something or actuate something and  
20 the operator would know it. And then he would have some  
21 probability of being able to correct it.

22           And the other possibility is that something  
23 will happen as a result of relay chatter and the operator  
24 will not know it has happened. Now, we had an incident  
25 recently where somebody opened the wrong DC breaker, DC



1 switch, and it took the plant about 30 minutes to figure  
2 out what happened. Something had happened wrong and they  
3 didn't know it was wrong. And there is a big difference  
4 between knowing that a breaker is open and it should be shut  
5 -- going over and hitting the button, and having oddball  
6 things going on in the plant and not knowing it.

7 Is that something you are looking at?

8 MR. RUBIN: The second part is -- a major part  
9 of our concern but we have yet to develop a detailed process  
10 for completing it. What we have done is convinced ourselves  
11 that it is potentially serious and indicated we wish to go  
12 forward in a great amount of detail.

13 MR. SIESS: Are plant simulators sufficiently  
14 sophisticated to introduce random-type things like this?

15 I mean, a simulator has all the -- of a lot  
16 of computers sitting behind there to represent things.

17 Are any of those sophisticated enough to pro-  
18 duce random --

19 MR. RUBIN: I have no way of knowing.

20 MR. WARD: I don't think they are  
21 designed to model electric surges.

22 MR. RUBIN: They are not.

23 MR. WARD: Well, you would have to put it in  
24 as a fault or a -- whether they have a -- I mean, I guess  
25 the interesting aspect -- where you can put in a transient

1 fault which might be characteristic of this.

2 MR. SIESS: A computer that puts them in with-  
3 out -- I was just wondering if --

4 MR. WARD: You say the staff sees this as a  
5 serious problem but --

6 MR. RUBIN: Potentially serious.

7 MR. WARD: Oh, okay. Right.

8 But is there a program -- what sort of a pro-  
9 gram is it? Where is it addressed -- generic modeling or  
10 something? A tool for making this analysis, what sort of  
11 a program to you have underway?

12 MR. BOHN: I can comment on that.

13 There is a small effort with Future Resources  
14 Associates; Howard Lambert is the principal investigator  
15 on that, looking at the possibility of locking circuits and  
16 relay chatter.

17 These first came up, I think, in conjunction  
18 with an early PRA effort and there certain locking circuits  
19 were identified into load sequences following and it was  
20 identified that it was possible that there were self-ener-  
21 gizing circuits that could preclude bringing some loads up  
22 on after you went on your on-side AC power and that was the  
23 source of the interest in this problem.

24 If one puts relay chatter into a PRA blindly  
25 and just assigns relay chatter to all the electrical

1 components, one finds that it dominates the seismic PRA.

2 Now, it was mentioned that, perhaps, a code  
3 might be available that one could randomly input relay  
4 chatter and, during an earthquake, you would not have to  
5 put it in randomly because all the relays chatter that are  
6 not solid-state or otherwise protected.

7 So, the real problem is whether or not there  
8 are locking circuits, that is, circuits that, if the relay  
9 temporarily closes, they self-energize into a state that  
10 one didn't plan.

11 There is a potential tool available for ana-  
12 lyzing this. There is a computer code that I am aware of,  
13 anyway, and exactly what complete state it is in, I don't  
14 know but there is a code that will take line diagrams of  
15 electrical circuits and search out for locking, that is  
16 feedback effects. And this is exactly what one is looking  
17 for.

18 MR. WARD: Well, is this similar to the old  
19 sneak circuit analysis?

20 MR. BOHN: That is part of it, yes.

21 MR. EBERSOLE: You said all relays chatter.  
22 Well --

23 MR. BOHN: I am sorry. I said all except,  
24 you know, solid-state or protected relays.

25 MR. EBERSOLE: I am talking about the mech-

1    anical, electromagnetic types.

2                   MR. BOHN: In general that is --

3                   MR. EBERSOLE: Well, we have to have relays  
4 in airplanes and we have got to have them in submarines and  
5 ships and other things. And, when this problem is  
6 encountered, the typical approach to it is to put them on  
7 a lug mount or something out the high frequencies to cause  
8 this sympathetic vibration and to pay some attention to the  
9 masses and spring constance of the relays themselves.

10                   You are telling us, really, that we haven't  
11 done any of that.

12                   MR. BOHN: Well, I know that a number of plant  
13 include time-delay circuits related to their relays.

14                   MR. EBERSOLE: That is compensatory to relay  
15 problems.

16                   MR. BOHN: Pardon?

17                   MR. EBERSOLE: That is compensatory to the  
18 relay problem itself?

19                   MR. BOHN: Yes, that is one way around it.  
20 There are various ways --

21                   MR. EBERSOLE: The other way is to protect  
22 the relay against the inputs, which is put them on the --  
23 he says it is --

24                   MR. BOHN: I would think the effort involved  
25 in that would be so much in terms of identifying what type

1 of isolation mounts you would have to have that would be  
2 much easier to have relays that were not susceptible.

3 MR. EBERSOLE: But is it generally true that  
4 the sum constants in masses of the relays structures makes  
5 them, virtually, all susceptible to chatter?

6 MR. BOHN: I can't answer that but I do know  
7 that relay chatter has been a common experience in earth-  
8 quakes to date.

9 MR. EBERSOLE: Okay.

10 MR. WARD: Let me ask, does General Electric  
11 see this as a potentially important problem and, if so, do  
12 you have a program to address the sort of analysis that  
13 might be required to --

14 MR. HOLTZCLAW: Dr. Ward, we --.Kevin  
15 Holtzclaw from General Electric.

16 When the staff and their consultants brought  
17 up the concern with relay chatter they requested GE to look  
18 into the problem in, I could say, maybe, an overview fasion  
19 and try and get some kind of a handle on what it might mean  
20 relative to GESSAR. And it is, probably, less of a problem  
21 on GESSAR for a couple of reasons, both of which, I think,  
22 have been mentioned by members of the ACRS this morning.  
23 One being that a good deal of the electronics are solid-  
24 state so that, I think, the point that Mr. Ebersole is  
25 making, that most of that equipment is not susceptible to

1 this type of a problem.

2           There are, however, switch gear protective  
3 relays that are included in the plant design, obviously,  
4 and so we did look at -- tried to track down those on line  
5 diagrams and whatnot to see what would be the potential  
6 impact and what we could divulge just from a quick look  
7 through of the plant elementaries and whatnot.

8           And we did identify a number of relays in,  
9 probably, the two key systems, the HPCS system and the RCIC  
10 system, which are, probably, the first lines of defense  
11 against a seismic event that could, ultimately, lead to core  
12 damage.

13           In looking at the relays that could be impact-  
14 ed, again, we found, in a number of instances, I think,  
15 again, another point that Mr. Ebersole was making, that the  
16 relays that we are dealing with here are fairly substantial.  
17 They are not the type, the small relays that might be in-  
18 volved with a component. And, although we are still looking  
19 at some of that to try and identify what the test basis is  
20 on some of those relays themselves to see what kind of  
21 seismic performance you might expect from them, but we,  
22 also, noted, I think, another point that Mr. Ebersole is  
23 making that there have been some attempts made with regard  
24 to isolating some of the frequencies coming from a large  
25 earthquake which would actually protect the relay against

1 the chattering phenomenon.

2           Although, again, this is a fairly cursory  
3 review and we have not, really, completed the look-see that  
4 we started.

5           We, also, noted with regards to the RCIC, a  
6 turbent (phonetic) trip may occur due to the chatter of the  
7 agastat (phonetic) relays. However, you, also, have the  
8 capability to receipt the relay from the control room. It  
9 is a fairly routine operation. It takes about five minutes  
10 for the operator to do. In the time window that you have  
11 got available to perform that function, is on the order of  
12 30 to 45 minutes.

13           With regards to the HPCS system, protective  
14 relays for that system may need to be reset. And they would  
15 have to be reset at 69kv switch gear. That has some kind --  
16 it is unlimited access and it would take, probably, about  
17 15 minutes to reset. Again, you have got about a 30 to 45-  
18 minute time window available, assuming the failure of the  
19 RCIC system. You would have several hours time window if  
20 the RCIC system is operable.

21           So, those are the two key areas that we looked  
22 at. We don't have any generic program in-house to consider  
23 this in a lot more detail. I know that it is being con-  
24 sidered as part of some of the overall fragility work in  
25 some of the Lawrence Livermore programs and GE is providing

1 some input to those programs and, I believe, we be, at least  
2 trying to give them the information that we found as part  
3 of our review on the GESSAR.

4 MR. EBERSOLE: May I ask a question, sir?

5 If you know the problem in advance, it is no  
6 big deal to escape the consequence; is it? You just design  
7 to it; am I correct?

8 MR. HOLTZCLAW: That is correct.

9 MR. EBERSOLE: So, whatever it may be, the  
10 front line of the problem is in the old plants that are  
11 running today and need not be in the new ones.

12 CHAIRMAN OKRENT: Jesse, that may be so in  
13 principle but, I guess, what we are trying to ascertain is  
14 whether it is true for the proposed FDA?

15 MR. EBERSOLE: Well, then I get down to the  
16 generalities of the -- with FDA and say that we don't have  
17 sufficient prime structure in it to determine.

18 CHAIRMAN OKRENT: Well, we could write a man-  
19 date in it that we won't have it when we get through.

20 Well, I wonder if I could raise a few general  
21 questions to the staff.

22 If I recall correctly, you raised the question  
23 to General Electric: Why haven't you included design and  
24 construction errors in your seismic PRA and, if I remember  
25 correctly, they said, "We don't think it is possible to do



1 that in a PRA." Correct me if I am wrong.

2 But where does that leave us? Is it the  
3 staff's conclusion that design and construction errors have  
4 not been important in prior plants or, if they have been  
5 important in prior plants, they have a basis for knowing  
6 they will not be important in future plants? And, if they  
7 don't have a basis for knowing they will not be important  
8 in future plants, how they are factoring design and con-  
9 struction errors into their own judgment.

10 MR. RUBIN: I don't believe I have a formal  
11 response for you and, I think, we would like to give it more  
12 thought preparing detail. I will say, though, that the PRA  
13 does not exist in a vacuum. We have tried to present what  
14 is generally accepted practice in presenting a PRA. We are  
15 definitely not saying that design and construction errors  
16 are unimportant. They, generally, have not been modeled  
17 and -- to date and we weren't developing new methodology  
18 to support the GE submittal.

19 However, hopefully, some of it is captured  
20 during the process of evaluating operating experience and  
21 we will learn from that. But we will, if you wish, we will  
22 try to provide you a more complete answer.

23 CHAIRMAN OKRENT: Well, I, in fact, would like  
24 to hear what the staff's answer is, at some future time and  
25 that time being before the ACRS completes its review of the

1 GESSAR II FDA. I don't think you can draw solice from the  
2 past, let me put it that way. And I see no reason to assume  
3 you will be able to draw solice from operating experience.

4 MR. SIESS: If so, that is very unfortunate  
5 because that is the only basis you are ever going to have  
6 for knowing what design and construction errors can do.

7 You only know the areas you find.

8 CHAIRMAN OKRENT: Well, let me, for the  
9 moment, leave that personal opinion --

10 MR. SIESS: You can postulate a design and  
11 construction error to affect anything in the plant. And,  
12 if you do that, you can just go on and on and on. So, I  
13 don't really know how you get at it.

14 In design of structures, we have attacked this  
15 problem for a period of about 15 and 20 years on a probab-  
16 ilistic -- using probabilistic-based design. We take care  
17 of design construction errors by simply calibrating our  
18 overall probabilities to past experience. That may be a  
19 hundred years of experience in building, most things have  
20 failed that can fail; all the possible things have happened,  
21 we think. And we believe that, let's say, factors of safety  
22 that will yield the same result now will adequately take  
23 care of design and construction errors, that most of them  
24 have occurred.

25 But there is no way of putting them in expli-

1     citly.

2                     CHAIRMAN OKRENT:  It depends on how you define  
3     adequately.  I think you accept a failure now and then, like  
4     at Kansas City and so forth, benefactically.

5                     MR. SIESS:  Well, its failure rate has been  
6     acceptable to society and --

7                     CHAIRMAN OKRENT:  All right.

8                     MR. SIESS:  But nuclear plants have the same  
9     thing.  We have failures that occur all the time but they  
10    don't lead to serious consequences.

11                    But whether we have got a large-enough data  
12    base, I don't know.

13                    CHAIRMAN OKRENT:  Well, again, the staff is --  
14    you are talking about remarkably low frequency of adverse  
15    consequences occurring for GESSAR II and the, I would say,  
16    the lower you are down the scale, the more vulnerable you  
17    are to design and construction errors in general and in the  
18    seismic area, certainly.

19                    Could I ask a different question of the staff.

20                    If I recall correctly, when the SSNRP study  
21    of the Zion plant was performed, they arrived at a rather  
22    different estimate of the uncertainties in the analysis than  
23    was presented in the PRA done for Zion by the licensee and,  
24    I think, although I am not sure, that larger uncertainties  
25    probably, than in any succeeding PRA that tried to do a

1 thoughtful job on the seismic part.

2           What does this all mean? Were they wrong at  
3 Livermore? If they were wrong, how do you know they were  
4 wrong, assuming my original recollection is correct. If  
5 they weren't wrong, how do you input this into your evalua-  
6 tion and the decision making?

7           MR. CHOKSHI: I guess that the question is  
8 that all subjective judgment, in answer to this, assigned  
9 to a particular components or structures and the question  
10 of which one is correct is -- I am not quite -- I don't  
11 quite understand.

12           The question you are asking is: How we deal  
13 with the differences? Is that it?

14           CHAIRMAN OKRENT: Why don't I recommend that  
15 you read the transcript at your leisure and develop a  
16 response at a future time. There are several questions of  
17 this sort, including questions I raised in my introductory  
18 remarks. But you are not going to address them today.

19           Again, we would like to hear your considered  
20 and, hopefully, reasons, meaning justified opinions, at some  
21 future time.

22           Let's see, we are almost at the point, or a  
23 little beyond the point for a break.

24           Are there any further points the staff wants  
25 to make at this point in their presentation?

1 MR. SCALETTI: No.

2 CHAIRMAN OKRENT: I think we might as well  
3 follow the agenda, then, and take a ten-minute break and  
4 then we will hear from GE.

5 (Whereupon, a short recess was taken.)

6 CHAIRMAN OKRENT: We will reconvene.

7 MR. HOLTZCLAW: Dr. Okrent, you had asked us  
8 to identify the portions of our presentation when we do have  
9 some proprietary information. We do have some charts in  
10 this presentation that were taken directly from the study  
11 that have been identified as proprietary.

12 What I would propose to do, though, is to go  
13 through as much of the presentation as we can until we come  
14 to those specific charts and then I will alert you at that  
15 time.

16 CHAIRMAN OKRENT: Thank you.

17 MR. HOLTZCLAW: Originally, on the agenda,  
18 we had planned a short presentation on the deterministic  
19 portion of the seismic analysis that has been done for the  
20 GESSAR standard plant design. A good deal of the analysis  
21 work was done at the ACRS review and is part of the original  
22 FDA. Consequently, we decided that it would be fairly  
23 repetitious and, probably, not worthy of time here and we  
24 want to progress with what has been done post-FDA, if you  
25 will.

1           So, we will dispense with that presentation.  
2 But we should point out that a good deal of some of the  
3 basis, deterministic engineering work that was done in sup-  
4 port of that analysis was utilized in the seismic event  
5 analysis that deals, also, with the probabilistics.

6           This is important, primarily, in a couple of  
7 areas, one being the envelope approach used in the determin-  
8 istic analysis and secondly, in defining the peak ground  
9 acceleration for the design -- for the design up to the SSE  
10 capability.

11           (Slide.)

12           Let me just tell you, briefly, what we plan  
13 on covering this morning. I will go through a discussion  
14 of the seismic hazard analysis, the structural fragility  
15 and component fragility work that was done in support of  
16 this study.

17           Dr. Deborah Hankins will pick up at that point  
18 and illustrate how we used the information in analyzing core  
19 damage frequency and in doing the risk portion of the eval-  
20 uation. She will, also, cover some work that we did in  
21 something of an interactive mode with the staff and its  
22 consultants in the course of our review. What we did do,  
23 some sensitivity studies, specifically with regard to the  
24 fragility factors and the uncertainties in the fragility  
25 factors to assess the importance in the bottom-line results

1 of core-damage probability and consequences.

2 MR. EBERSOLE: I think that the things you  
3 call components include those sometimes called equipment,  
4 as well.

5 MR. HOLTZCLAW: That is right.

6 (Slide.)

7 I would like to give you a little bit of back-  
8 ground, not for the purposes of giving you the normal  
9 licensing fluff, but to give you some kind of perspective  
10 on how we ended up with the study, primarily, because, I  
11 think, in reading the SSER's, there seems to be more of a  
12 discrepancy between the applicant's material and the staff  
13 review, if you will, than, at least, I am familiar in seeing  
14 in other SSER's.

15 And, I think, it deals with a lot of the  
16 evolution of the requirement for this type of analyses as  
17 part of the severe-accident policy statement.

18 Do you recall back when the policy statement  
19 was first issued, it went through a number of revisions and,  
20 I believe, it was part of this SECY paper, 82-1(b), where  
21 there was more focus put on the external event analyses  
22 leading to and having an impact on severe accidents, spec-  
23 ifically in section 9 of that draft of the SECY document,  
24 was the, I guess, the primary focus on looking at seismic  
25 in more detail.

1           At that time, GE, in doing the analyses rela-  
2           ting to severe accident issues, had not performed any kind  
3           of additional seismic evaluation. The prime focus was on  
4           the internal event PRA. And, consequently, we are trying  
5           to deal -- work with the staff, actually, at how we are  
6           going to address this requirement in the severe-accident  
7           policy statement. In fact, at the time, GE considered a  
8           number of different approaches. In fact, we had talked to  
9           other consultants, including Jack Benjamin Associates and  
10          other -- in looking at what could, possibly, be done in this  
11          area, ultimately making a decision that we would do the  
12          analysis in-house.

13                 The staff, at the time, was to try and get  
14                 some kind of a perspective on what the impact of seismic  
15                 is on severe accidents. It wasn't -- at least, it wasn't  
16                 GE's intent, at the outset, to do a study that would be  
17                 typical in the resource expenditure and level of detail of  
18                 the internal event PRA.

19                 In retrospect, that might have led to some  
20                 of the problems that we have seen today with the differences  
21                 of opinion between the SSER and the GE analyses. However,  
22                 that was the approach that was taken after a good deal of  
23                 discussion with the staff and staff management.

24                 The principal tasks of the study were to look  
25                 at the seismic hazards and establish a seismic hazard curve



1 for use in the study, look at the structures and components  
2 and hardware to assess their fragility, evaluate the core  
3 damage frequency and then get some kind of an estimate of  
4 off-site consequences.

5 At the outset, we knew that there would have  
6 to be additional work done on a specific plan application,  
7 primarily, because we were, specifically, in the seismic  
8 hazard area, not defining any specific site nor the geolo-  
9 logical implications of any specific site.

10 (Slide.)

11 I am going to be discussing that aspect of  
12 the hazard curve in more detail because, at the outset,  
13 simplistically assume that that would be one of the key  
14 parameters that would have to be considered on a site-  
15 specific application.

16 Since that time, I think, we would agree with  
17 the staff that, based, maybe even more, on the amount of  
18 work that is being done in fragility analyses, that, at the  
19 time of a specific plant application, it would be appro-  
20 priate to review all the assumptions in the seismic study  
21 that GE performed against the available new information that  
22 might come up prior to a specific site application.

23 This flow chart shows, simplistically, what  
24 we attempted to do in our seismic analysis. We wanted to  
25 identify the systems that were important to core damage,

1 identify the components in the system and what their impor-  
2 tant functions were.

3 Looking at the plant configuration, and in  
4 the first two blocks it was a lot of the information coming  
5 out at the internal event PRA figured very strongly into  
6 the work relative to seismic. We have done extensive  
7 systems analyses as part of the internal plant PRA. Consider  
8 that -- has been looking at the systems under seismic  
9 conditions.

10 We looked at a plant configuration primarily  
11 to review the layout drawings assessing, basically, any  
12 spacial commonalities or leading commong mode failure effect  
13 associated with a seismic and the shear.

14 Also, look at the structures that contain  
15 thosse components and then assess what the implications were  
16 of individual structural failures on the systems themselves.

17 I think the rest of the flow chart is fairly  
18 self-explanatory in assessing the components --

19 MR. EBERSOLE: I have a comment on the chart,  
20 just a moment.

21 Where it says "identify structure that con-  
22 tains the component", doesn't that too sharply dileneate?  
23 Don't you mean identify structures whose malperformance may  
24 influence the performance of the components?

25 MR. HOLTZCLAW: That is correct.

1                   And you will, with an assumption that we made,  
2 really a simplifying assumption in the analysis that, if  
3 we assume the structure failure, we made the assumption that  
4 any of the components within that structure would also be  
5 failed.

6                   MR. EBERSOLE: I know, but it doesn't need  
7 to be inside. For instance, we have numerous high stacks  
8 that are 150 feet away from diesel buildings that influence  
9 the performance of the critical structures.

10                   And this specification that it contains is  
11 too narrow in scope.

12                   MR. HOLTZCLAW: That is a good point. I guess  
13 there were a number of staff comments related to that one  
14 aspect, specifically with regards to the stack and what the  
15 implications are.

16                   MR. EBERSOLE: That is only one case.

17                   MR. HOLTZCLAW: That is definitely only one  
18 case.

19                   In some of these areas we would hope to be  
20 able to recover conditions for those kinds of structures  
21 that -- some kind of an interface requirement.

22                   MR. EBERSOLE: Yes.

23                   MR. HOLTZCLAW: Because that can vary.

24                   MR. EBERSOLE: It is an interactive propos-  
25 ition, no matter whether it contains it or not.

1 MR. HOLTZCLAW: That is right.

2 MR. WARD: I didn't get what the answer was,  
3 though.

4 Does your analysis accommodate these inter-  
5 actions or not?

6 MR. HOLTZCLAW: In some cases it does and in  
7 some cases it doesn't. I think we tried to readdress this  
8 in, primarily, response to specific staff questions on  
9 individual structure, typically, that were outside the scope  
10 of the GESSAR Nuclear Island, the stack being one of them.

11 But, I think, in the -- you will be hearing  
12 the staff consultant analyses and I think they considered  
13 further structures that GE did not, in the GE study.

14 MR. EBERSOLE: I suggest you have a look at  
15 Diablo Canyon, it has a few thousand --

16 (Slide.)

17 MR. HOLTZCLAW: I would like to talk a little  
18 about the seismic hazard analysis that was performed as one  
19 element of the seismic analysis.

20 This was, maybe, one of the first problems  
21 that was faced by GE in performing the analysis for a  
22 standard plant design, as to what kind of approach do you  
23 take on characterizing what is basically a site-specific  
24 parameter for use in an envelope design that is intended  
25 for numerous sites.

1                   This was actually a very difficult proposition  
2 and involved a number of meetings between GE and the staff  
3 as for an appropriate approach. We ended up using published  
4 data from some very specific PRA's as well as some USGS  
5 information to try and characterize what we term a repre-  
6 sentative curve. I guess the terminology has been somewhat  
7 diluted because we have called it a number of things in the  
8 course of this review.

9                   We tried to stay away from an actual bounding  
10 curve because we thought that would be inappropriate for  
11 a number of reasons, I think, that were elicited earlier  
12 this morning on trying to stay away from a safety analysis  
13 review, as far as definitely bounding things.

14                   But, on the other hand, it proved to be some-  
15 what difficult to get what you might consider as best esti-  
16 mate hazard curve. However, that was the approach we  
17 ultimately took.

18                   The staff did have a number of comments and  
19 recommendations during the course of this decision process.  
20 I guess it was a suggestion that is really, ultimately been  
21 utilized by the staff consultants is to try and take a  
22 number of different sites and look at the implications of  
23 a number of different sites with a standard plant design.

24                   We evaluated that at the outset of doing the  
25 hazard analysis and felt, at the time, that it was inconsis-

1 tent with the timing and the schedule we were trying to com-  
2 plete the analysis on. And it seemed like we had a fairly  
3 large matrix of both soil conditions and situations so it  
4 seemed like it might be -- it actually seemed like there  
5 was a resource-intensive effort that we weren't in a posi-  
6 tion to support. So we ended up going with the approach  
7 of characterizing a single hazard curve.

8 We limited the probability of exceedence to  
9  $10^{-8}$ . I think there is a misconception in the SSER III re-  
10 ports that the staff has issued with regards to the cut-off  
11 value that we used on the seismic hazard curve. It wasn't  
12 specifically set at any specific (g) level for any reason;  
13 it was really -- what we ended up doing was characterizing  
14 the hazard curve and then limiting the probability value  
15 consistent with the probability values that we utilized in  
16 the internal event PRA.

17 So we didn't cut it off relative (g) level,  
18 we cut it off relative to  $10^{-8}$  probability level. We felt  
19 that that was important in getting, maybe, a more consistent  
20 representation between seismic hazard core damage probab-  
21 ilities and risk of the external event versus the internal  
22 event.

23 CHAIRMAN OKRENT: Whose  $10^{-8}$  earthquake do  
24 you have in mind when you say you are limiting something  
25 to  $10^{-8}$ ?

1 MR. HOLTZCLAW: None in particular, Doctor,  
2 I think we only wanted to show the hazard curve which is  
3 the next chart. I think I can try and explain, looking at  
4 the hazard curve.

5 (Slide.)

6 CHAIRMAN OKRENT: Excuse me, I will repeat  
7 the question.

8 Whose  $10^{-8}$  value do you have in mind? I mean,  
9 I have seen that curve and it is not clear to me on what  
10 basis you are planning to establish that, going up to a  
11  $10^{-8}$  seismic event.

12 MR. HOLTZCLAW: I think the basis was just  
13 consistency with the internal event.

14 There is no basis relative to the hazard curve  
15 itself.

16 CHAIRMAN OKRENT: Again, in calculating inter-  
17 nal events, somebody gets some data and puts some judgment  
18 in and tries to develop a suitable -- and so forth and com-  
19 putes, then, different frequencies for different sequences,  
20 including some operation actions and so forth. And I have  
21 little doubt that, given four people trying to do this in  
22 isolation, that they wouldn't all come out with the same  
23 list of events that met the  $10^{-8}$  criterion or not.

24 In the seismic area, if we took experts and  
25 put them in a room, separately, at the  $10^{-8}$  level, I would

1 anticipate a very considerable diversity of opinion unless  
2 you preselected your experts not to achieve it.

3 So, I am trying to understand what you mean  
4 when you say you are taking a hazard curve that takes you  
5 out to the  $10^{-8}$  frequency.

6 Even if we have a site selected, let's say,  
7 and the licensee tries to generate a hazard curve for the  
8 site, again, if he were to take a broad spectrum of opinion  
9 from seismologists and geologists in the country instead  
10 of going only to those who have, in the past, afforded  
11 license applications, I think he would get a very broad  
12 spectrum of opinion as to what was the (g) level that  
13 corresponded to  $10^{-8}$ .

14 That is why I am asking: Whose?

15 MR. HOLTZCLAW: Aren't you really asking, Dr.  
16 Okrent, really the basis for the hazard curve, itself, be-  
17 cause --

18 CHAIRMAN OKRENT: GE was the one who said,  
19 "We are going to take something out to  $10^{-8}$  and I am just  
20 trying to understand --

21 MR. BOHN: Dr. Okrent, by cutting it off at  
22  $10^{-8}$  it is basically saying that there is going to be --  
23 we are going to neglect in contributions below  $10^{-8}$ . It  
24 is equivalent to saying in the internal event analysis and  
25 I don't know what you mean.



1 CHAIRMAN OKRENT: Oh, no, no. Excuse me.

2 I understand very much what they mean by  
3 deciding to go off at  $10^{-8}$ . That is not my question.

4 But trying to decide what the (g) value is at  
5  $10^{-8}$ . Whose (g) value? That is what I am asking.

6 MR. HOLTZCLAW: Okay. I think that really  
7 comes from the explanation of the curve itself because it  
8 is a simple exercise to identify what the (g) value is given  
9 a probability number.

10 CHAIRMAN OKRENT: I am sorry, I missed some-  
11 thng. Something is simple?

12 MR. WARD: Well, you have got the curve; you  
13 just have to look at it.

14 MR. HOLTZCLAW: That is right. But I want  
15 to make sure that is what Dr. Okrent's question is.

16 MR. WARD: I don't know what you are asking  
17 either, Dave. I think what you are asking is: Where do  
18 they get the curve? Is that what you mean?

19 CHAIRMAN OKRENT: No. I know where they got  
20 their curve but it is proposed, the GE approach, that some-  
21 how acceleration whose frequency is larger than  $10^{-8}$  will  
22 be considered and I am asking: In whose judgment will it  
23 be that the accelerations are such that they have a frequen-  
24 cy of  $10^{-8}$  or greater? And what I am suggesting is, at  
25 least in my own experience both a decade ago and this year,

1 I can get a rather wide spectrum of opinion at frequencies  
2 which are substantially larger than  $10^{-8}$  per year and, at  
3  $10^{-8}$  per year, it seems to me, opinion will vary markedly.

4 MR. HOLTZCLAW: Well, we tried to get, I guess,  
5 at what your point is by doing a sensitivity study on chang-  
6 ing the shape of the curve so that we ended up picking up  
7 a different (g) value at the  $10^{-8}$  frequency. But, I think,  
8 what Dr. Bohn was saying was exactly how we actually did  
9 the analysis, that is, you really neglect the implication  
10 of anything at a lower frequency.

11 CHAIRMAN OKRENT: Again, that is not the ques-  
12 tion, though.

13 All right. Let it go on, for now, but not  
14 forever.

15 MR. WARD: Well, could I ask you: Are you  
16 going to tell us if you have come to any conclusion about  
17 whether it makes any difference what detail is like?

18 MR. HOLTZCLAW: Yes.

19 MR. WARD: Okay.

20 MR. HOLTZCLAW: This --

21 MR. WARD: I have to wait, though?

22 MR. HOLTZCLAW: No, not too long.

23 MR. WARD: Okay.

24 MR. EBERSOLE: May I ask, when I see the  
25 red line down there: What is the bend width of professional

1 opinion that I should see instead of that small line --

2 MR. HOLTZCLAW: Let me show you the next  
3 curve, let me show that professional opinion.

4 I did want to say something, though, about  
5 the preceding curve.

6 At the time we did this study, there was a  
7 fairly limited basis of hazard curves available. And this  
8 is probably one of the problems in the staff's viewpoint  
9 as how we can characterize seismic hazards with one simple  
10 curve.

11 So, we did look at existing PRA's and those  
12 are the curves that you see plotted on this figure. We were  
13 not intentionally trying to bracket all of them, although  
14 we effectively did with, at least of these three or four  
15 studies.

16 (Slide.)

17 MR. HOLTZCLAW: The next curve, though, shows  
18 some information that was made available through the SSMRP  
19 program, shortly after GE submitted their report to the  
20 staff, and does show a much higher variability in seismic  
21 hazard curves.

22 And you see the green curve is the GESSAR  
23 curve that was used in the study originally with the tail  
24 dropping off at the lower portion of the curve.

25 Now, prior to the sensitivity analysis that

1 we did, we used the Limerick, or the tail of the Limerick  
2 curve, as shown by the upper portion of the green line,  
3 here, where it splits off, and then assessed the impact on  
4 core damage frequency associated with using that portion  
5 of the tail of the curve, as shown there.

6 Dr. Hankins will be covering that in a discus-  
7 sion of core damage frequency.

8 MR. WARD: I guess I don't understand. The  
9 curve labeled number 1, there, is not the same as your  
10 GESSAR curve on the previous one?

11 MR. HOLTZCLAW: I think the difference being  
12 in whether it is effective peak ground acceleration or peak  
13 ground acceleration and there is a 1.25 factor in there.

14 MR. BOHN: That looks much more than a factor  
15 of 1.25.

16 MR. HOLTZCLAW: I will have to admit this  
17 isn't the GE curve; this is the curve that was in one of  
18 the staff consultant reports.

19 CHAIRMAN OKRENT: May I ask a question.

20 Number 14, for example, which says, "Watts  
21 Bar-Livermore National Laboratories", is that supposed to  
22 be a mean, a median, roughly, or 95 percent confidence curve  
23 or what?

24 MR. HOLTZCLAW: I can't say with a hundred  
25 percent assurance, Doctor, but I believe these are inter-

1 po.ated to be mean curves.

2 CHAIRMAN OKRENT: I think so. They did a  
3 sampling of expert opinion.

4 So, there is some spread and I would guess  
5 it could be a fairly substantial spread, depending, again,  
6 on who you go to for your experts and how many experts you  
7 have.

8 Around curve number 14, for example, lower  
9 and higher. Okay. So, the departure from the green curve  
10 can be even greater among expert opinion than shown here  
11 but for, well, an eastern site.

12 MR. HOLTZCLAW: In fact, we did do a limited  
13 uncertainty analysis associated with the seismic analysis  
14 where we did try and put some kind of bounds on the seismic  
15 curve that we utilized.

16 I think we, also, received some criticism for  
17 the bases on which we --

18 CHAIRMAN OKRENT: Bad reference.

19 MR. HOLTZCLAW: On which we based our spread  
20 and it was probably legitimate. I think there was some  
21 additional, newer information, not necessarily better infor-  
22 mation but newer information that might have been referenced.

23 MR. WARD: Well, if I look at this, the Watts-  
24 Bar curve, number 14 there, and, if I go off to once in a  
25 hundred years at which there is some historical evidence,

1 I mean, that just doesn't -- who is number 14? I mean, is  
2 there any -- do these people attempt to tie into historical  
3 records or is it -- well, I am probably asking more than  
4 is fair to ask you.

5 MR. HOLTZCLAW: More than fair to ask me  
6 because I have limited experience in this area.

7 But I really can't answer your question, Dr.  
8 Okrent.

9 MR. BOHN: Well, I am not totally familiar  
10 with exactly where this curve came from. I believe it is  
11 out of the eastern seismic hazard characterization -- and  
12 I don't recall the numbers, myself. I am assuming this is  
13 a median curve over all experts.

14 But, the point I did want to make is: Yes,  
15 they use the earthquake catalog for the particular region  
16 in trying to construct these. But they, also, use a wide  
17 variety of expert opinion and that tends to increase the  
18 uncertainty and push the curves higher.

19 But, the basic answer is: Yes, they attempt  
20 to correlate with the earthquake occurrence record. The  
21 problem is, they, typically, had just one or two large  
22 events, maybe a hundred years ago or 200 years ago like New

23 (phonetic) and small, more frequent earthquakes at  
24 a much smaller range. So there is the presence of one large  
25 earthquake, several years ago, can influence these curves

1 quite a bit.

2 MR. WARD: Well, there is no reactor at New  
3 Madrid at Watts Bar. I mean, there is an historical record,  
4 just for example, at Watts Bar back a couple hundred years,  
5 probably.

6 CHAIRMAN OKRENT: You think they had strong  
7 motion?

8 MR. WARD: No, but I think they had people  
9 who would have observed .2(g) in earthquake. I think that  
10 would have been a noteworthy thing in letters and diaries.

11 MR. SIESS: I imagine it was probably felt  
12 there but I doubt if it was felt at .2(g)'s.

13 MR. SCALETTI: May I interject something here?

14 John Reed will be using this same slide in  
15 his presentation this afternoon. If questions arise this  
16 time about the origin of the curves or -- maybe we could  
17 address them then?

18 MR. HOLTZCLAW: The only other significance  
19 is, again, that most of this information did come out after  
20 we completed our study. And, in light of that information,  
21 we might have chosen a different curve for representation  
22 of GESSAR. I kind of look at it from the standpoint of a  
23 zealous simplistic engineering viewpoint. You kind of  
24 squint your eyes and look at these curves; the green curve  
25 does not look that bad as a representative curve for -- it

1 is kind of the approach that the --

2 MR. WARD: Except the tail, which is what --

3 MR. HOLTZCLAW: I am sorry -- with the tail  
4 that we used in the sensitivity study; that is a good point.

5 And that was kind of the approach that we were  
6 attempting to utilize in this study.

7 If I could have the preceeding chart on the  
8 discussion of seismic hazard analysis?

9 (Previous slide.)

10 MR. HOLTZCLAW: After a number of meetings  
11 with the staff that I mentioned earlier, we decided on this  
12 approach to consider a representative curve with the impli-  
13 cit understanding that the NRC was going to involve some  
14 additional subcontractor analyses which would look at very  
15 specific PRA curves and try and assess what the differences  
16 might be associated with using curves that could be better  
17 or worse than the curve that was chosen by GE to use in this  
18 study.

19 At that time, I think there were some very  
20 specific PRA's in mind that -- wherein the information has  
21 not been released but the staff was privy to, that they could  
22 use in their analyses. It turns out that the Livermore  
23 report came out very shortly thereafter, which provided a  
24 compendium of curves that could be used in these kinds of  
25 sensitivity studies.



1           At that time, maybe we looked at this rather  
2           simplistically, as it, again, was the consideration of the  
3           site specific application and, at least with regards to the  
4           seismic hazard curve, it was expected that this might become  
5           an interface requirement, if you will, relative to severe  
6           accidents and the seismic analysis, wherein an applicant  
7           that would be utilizing this study to address the seismic  
8           issues in severe accidents, would, then, have to look at  
9           their site specific hazard curve and see what the implica-  
10          tions were, the site specific curve relative to the curve  
11          that GE used. And that was always our intent at the outset  
12          and I think it has been expanded a little bit to include  
13          some of the fragility information, as well.

14                   MR. ETHERINGTON: Do you assume some statis-  
15                   tical crack distribution when you estimate your structural  
16                   capacity capability?

17                   MR. HOLTZCLAW: I am sorry; I didn't catch  
18                   the first part of that, Dr. Etherington.

19                   MR. ETHERINGTON: As part of it?

20                   MR. HOLTZCLAW: Do you assume?

21                   MR. ETHERINGTON: A statistical crack distri-  
22                   bution.

23                   MR. HOLTZCLAW: I don't believe so. I really  
24                   shouldn't answer that question. I really don't know but I  
25                   can find out for you.

1 MR. ETHERINGTON: Most structures fail, when  
2 they do fail, as a result of a defect; isn't that true?

3 MR. HOLTZCLAW: That's right.

4 I believe Dr. Galry (phonetic) in the struc-  
5 tural area, did take that into account because that would  
6 have been consistent with what we did do in the internal  
7 event study when we looked -- specific, when we looked at  
8 the containment structure. But I will have to verify that  
9 for you.

10 (Slide.)

11 MR. HOLTZCLAW: What I would do is talk a  
12 little bit now about the structural fragility evaluations.

13 This was a fairly standard approach that has  
14 been used in past PRA's to develop fragility curves to  
15 assess the capability of the structures as a function of  
16 peak effective ground acceleration. And you may not recall,  
17 but it was at the ACRS full committee meeting, I believe  
18 it was in about April of 1983, with Dr. EdChitz (phonetic)  
19 from General Electric made a short presentation to try --  
20 and I guess, at that time, it was looking at seismic margins  
21 and he put a long equation on the board, trying to identify  
22 specific elements of the design wherein we believe seismic  
23 margin exists. And it was really, I guess, the work that  
24 we did, relative to structures, is really based on, kind  
25 of, Dr. Chitz' work, at that time, or, maybe, his perception

1 at that time, where we went through and did identify speci-  
2 fic parameters where we believed that the design had capa-  
3 bility in excess of the normal design kinds of calculations  
4 relative deflections.

5 And that is really the approach that we took  
6 that we will be talking about on our next few charts, here,  
7 was to go in in each individual area, try and identify  
8 factors which contribute to an overall factor of safety,  
9 if you will.

10 I think this is fairly consistent with what's  
11 been done in previous PRA's, although I think some of the  
12 numbers that GE came up with have been -- are a little bit  
13 different than what you may have seen in previous studies.

14 Part of this, we, also, wanted to look at the  
15 critical structures, define their capacity factor of safety  
16 and, then, convert that into a structural capacity in terms  
17 of acceleration capability. And, from that, develop a  
18 fragility curve for the structures.

19 (Slide.)

20 MR. HOLTZCLAW: The next chart just shows an  
21 overview of the key structures that were considered. It  
22 is the RPV pedestal, the containment drywell wall, the con-  
23 tainment vessel, itself, shield building, the auxiliary  
24 building, some other seismic category 1 structures that I  
25 will talk about and some limited work on non-seismic cat-

1 egory 1 structures.

2 (Slide.)

3 MR. HOLTZCLAW: This chart that I have marked  
4 up a little bit, in comparison with what you have got in  
5 your handouts, identifies the factors that we did consider.

6 The overall capacity factor of safety is  
7 really a combination of two factors. I have an inherent  
8 strength factor that is inherent with the structure itself,  
9 and then, what we call a structural response factor which  
10 has to do with the response and the interaction-types of  
11 factors.

12 What I would like to do is, just, go through  
13 each of these and give you some perception on the bases that  
14 we utilized. This is indicated more thoroughly in the re-  
15 port which, also, points out the references that we used  
16 in defining the individual factors themselves.

17 The first factor is the load margin factor.  
18 The GESSAR II seismic analysis, the deterministic seismic  
19 analysis, is contained in appendix 3(a) of the GESSAR docu-  
20 mentation. This appendix was generated prior to the stand-  
21 ard review plan 3.7.1, the seismic design parameter, the  
22 standard review plan.

23 In subsequent analyses that GE has performed  
24 have shown margins that are in excess of those that were  
25 identified in the original appendix 3(a) values. That is

1 load capabilities beyond those that are normally included  
2 or defined as the design load. So we calculated this load  
3 margin and that value typically falls between the value of  
4 one and the value -- as high as 4.5 for the structures that  
5 we looked at.

6 Now, this is looking at different potential  
7 failure modes, too, so we were looking at the loads and  
8 tension and compression and shear load. I give you that  
9 range just to give you some kind of a ballpark idea on the  
10 value can be -- or what the range of the values are.

11 MR. WARD: What was the range, again, I am  
12 sorry.

13 MR. HOLTZCLAW: As values from as low as one  
14 or no margin, to as high as the value of 4.5.

15 MR. WARD: Okay, fine.

16 MR. HOLTZCLAW: In the seismic event analysis  
17 has a series of tables in section 3 of the report that con-  
18 siders all of the structures in the potential failure mode  
19 and then shows you what those values are. It lists all the  
20 values in those tables.

21 The next value is the strength margin. And,  
22 typically, what we are dealing with here, the structures  
23 that we are dealing with are concrete and some steel struc-  
24 tures. And there are some effects, particularly concrete  
25 compressive strength ratios and the capability of increasing

1 concrete strength with age and then allowing for the  
2 reinforcing steel strength and capability of the design  
3 beyond the normal yield strength capability that was used  
4 as part of the bases of the original analyses.

5 And, so, there is this margin and, again, there  
6 are some very broad ranges on what this margin can be,  
7 values as low as ten percent above the yield stress up to  
8 factors as high eight above the yield stress -- I am sorry,  
9 above the allowable stress.

10 And account for the capability of materials  
11 to deform past their yield without ultimate failure.

12 I have only touched on pieces of this one  
13 factor. There has been a lot more discussion in the report  
14 talking about the bases and the justification for the values  
15 that GE used.

16 MR. BOHN: May I ask a question?

17 MR. HOLTZCLAW: Surely.

18 MR. BOHN: Mike Bohn.

19 On your structural factor, normally one sub-  
20 tracts off the normal loads prior to evaluating that factor.

21 Was this systematically done in developing  
22 the structural fragilities or the fragilities in general?

23 In other words, you have certain normal --

24 MR. HOLTZCLAW: I understand that what --

25 MR. BOHN: -- temperatures that are there,

1 regardless of the level of earthquake and that removes a  
2 certain capacity -- a certain portion of the strength, if  
3 you will, and then the remaining margin is that margin which  
4 can properly be scaled with earthquake size.

5 MR. HOLTZCLAW: I know what your question is,  
6 Mark, I don't recall the answer, but I can find that out  
7 and let you know this afternoon.

8 MR. BOHN: The second question has to do with  
9 the ductility factor. You have used effective damage accel-  
10 eration in scaling your hazard curve and this had to do with  
11 -- it is really sort of derived from the idea that the  
12 damage that an earthquake does to a structure, it depends  
13 on the number of large-motion cycles. If you just have one  
14 large motion cycle, not much happens; if you have eight to  
15 twelve, like a typical damaging earthquake, then you do have  
16 damage.

17 Have you used that idea in defining effective  
18 hazards -- effective hazard curve acceleration and here we  
19 partly use the same idea in defining another factor on the  
20 strength. It would seem that there was double counting  
21 involved, here, if you will.

22 MR. HOLTZCLAW: I understand your question  
23 because the staff and their consultants, also, defined a  
24 potential for double counting here. And I really don't know  
25 the answer to your question.

1           A third factor would be the inelastic energy  
2 absorption factor. And that accounts for the fact that the  
3 earthquake represents a limited energy source. And  
4 structural components are capable of absorbing energy beyond  
5 the elastic limit without harm for the function.  
6 We have been consistent with previous document PRA's in  
7 using a typical value of 2.0 or 2.5, depending on the  
8 structure here. And I believe that the staff, in their  
9 evaluation, identifies it as one area where we were very  
10 consistent with what's been done in the past.

11           MR. EBERSOLE: In relation to what he ask,  
12 the old-style, super-conservative model was to combine the  
13 accident load and the seismic load. I think you are shying  
14 off from that here and there but not everywhere.

15           For instance, you take a containment at its  
16 load, I guess; do you not? A containment is considered  
17 loaded?

18           MR. HOLTZCLAW: That is correct.

19           MR. EBERSOLE: As though there had been a  
20 prior accident; is that correct?

21           MR. HOLTZCLAW: You mean pressurize it?

22           MR. EBERSOLE: Yes.

23           MR. HOLTZCLAW: I think that is getting to  
24 the same question that Dr. Bohn asked and I am not sure --

25           MR. EBERSOLE: Well, not quite because he is



1 taking about --

2 MR. HOLTZCLAW: I understand what you are say-  
3 ing but he is talking about, really, the combination of  
4 either a steady-state load or, even, an accident load with  
5 the seismic --

6 MR. EBERSOLE: I am talking about the latter  
7 kind of load.

8 MR. VILLA: Rudy Villa, General Electric.

9 In the design calculations that we do, we  
10 actually do combine all accident and normal loads to calcu-  
11 late whether or not we meet allowable stress limits and  
12 allowable load factors on the containment.

13 Our calculations also show that we have margin  
14 even with the comparison to the design loads.

15 I don't know if that answers your question.

16 MR. EBERSOLE: Well, I think we are coming  
17 around, aren't we, to conclude that we don't need, for  
18 instance, to combine local loads with seismic loads.

19 MR. VILLA: That is correct, however --

20 MR. EBERSOLE: On the other hand, for a con-  
21 tainment, you do it anyway.

22 MR. VILLA: That is right, and for equipment  
23 and piping and other structures.

24 MR. EBERSOLE: Yes.

25 MR. SIESS: I thought I understood but I

1 don't. I think the question was, and if it wasn't, I will  
2 ask it this way: When you express a margin for the seismic  
3 load, does that margin represent the multiple of the design  
4 seismic load that you can carry before it fails, in combin-  
5 ation with the other loads?

6 MR. VILLA: I believe that it does because --

7 MR. SIESS: I makes a big difference whether  
8 the seismic is ten percent of the design load or a hundred  
9 percent of the design load.

10 MR. VILLA: I believe that it does because,  
11 when we calculate a load for any given component, we combine  
12 all of the loads to ensure that the calculated stress is  
13 below the allowable design stress. And so, any margin that  
14 would be measured would be measured beyond the design load.

15 MR. BOHN: But the issue here is that, if 50  
16 percent of your capacity is taken up in a normal loading  
17 situation, then that needs to be subtracted out and divided  
18 by the seismic load to have the proper multiple to scale  
19 for higher earthquakes.

20 MR. VILLA: That is correct but I believe you  
21 would measure, when you measure the capacity, you measure  
22 it in reference to the design load.

23 The design load gives you an allowable stress,  
24 given the condition, and, when you measure margin, you  
25 measure it based on the design load which has already

1 included normal loads and accident loads and seismic loads.

2 MR. SIESS: But only the seismic is being sub-  
3 jected to this multiplier that you are calling a factor of  
4 safety.

5 MR. VILLA: Okay, now you are out of my realm  
6 of --

7 MR. SIESS: If I have got a 90 percent fixed  
8 load and ten percent seismic which adds up to a hundred and  
9 it turns out that the capacity is 200, that gives me a  
10 factor of ten on seismic. The seismic was only ten percent  
11 of it. I can multiply it by 11 and still not exceed the  
12 capacity.

13 MR. VILLA: I think that is correct.

14 MR. SIESS: But, if I have got 50 percent  
15 seismic and the total capacity is 200, I have only got a  
16 factor of three. This is an issue that has been kicking  
17 around for five years; I thought it was settled somewhere.

18 MR. VILLA: Well, I think that is correct but,  
19 although I don't understand exactly how these values were  
20 generated, if you are measuring the margin that you have  
21 as a factor, a capacity factor that you have, related to  
22 the design load, then you have to do a little more research  
23 to determine what factor that is on the seismic load because  
24 the seismic load is less than the load that is calculated  
25 for the design.

1 MR. SIESS: Well, this is confusing because  
2 the first three items on the list are, essentially,  
3 increases in resistance due to the various margins that are  
4 built into the thing and the remaining items on the list  
5 are decreases in forces due to various conservatisms and  
6 so forth in the analysis.

7 There really ought to be a numerator/demoni-  
8 nator-type thing there. And they all sort of multiply to-  
9 gether.

10 MR. VILLA: They are all correct if you want  
11 to understand the direct influence on the seismic load; that  
12 is correct.

13 CHAIRMAN OKRENT: Mr. Reed?

14 MR. REED: I am John Reed. Let me make one  
15 comment.

16 What Mike said is correct. The proper way  
17 of doing this is in the numerator, there, you, of course,  
18 would subtract out the normal load. But what GE did is,  
19 also -- you have to look at the denominator, too. That  
20 calculated stress was not just the SSE stress; they, also,  
21 had their normal loads in the denominator, too.

22 And so, that will actually -- I am not sure,  
23 overall, the possible combinations; you are always conser-  
24 vative that way. But the few cases that I looked at looked  
25 like they were conservative. In other words, the proper

1 way is: You subtract the normal load out of the numerator  
2 and you subtract the normal out of the denominator. What  
3 they did was, in the actual calculation, there, of the load  
4 margin, was they left the normal load in both the numerator  
5 and the denominator.

6 It, certainly, would be very non-conservative  
7 to put a total design load in the numerator and then just  
8 use the earthquake load in the denominator. And that is,  
9 kind of, what I sense your conversation was really revolving  
10 around. You were not focusing on the denominator, too.

11 MR. BOHN: Well, we are agreed, then, that,  
12 in principle, one subtracts out normal loads in figuring  
13 this ratio because we wish to scale the higher earthquakes.

14 MR. REED: Absolutely.

15 MR. BOHN: So, it gets back to Chas' comment  
16 that it depends very much on the relative proportion of  
17 normal to seismic and, probably, then, these factors could  
18 vary for different pieces of equipment and we don't know  
19 exactly what the right factors are.

20 MR. REED: That is right. And my comment is:  
21 In my review, usually, they were on the conservative. But  
22 I don't think that is universal; I think you can, probably,  
23 invent some combination of numbers where it would be uncon-  
24 servative.

25 MR. BOHN: I guess, given the information that

1 went into this, though, it would be a very easy thing to  
2 re-evaluate those ratios, the information must be there in  
3 this appendix 3(a)?

4 MR. VILLA: Sure.

5 MR. BOHN: It would be a trivial exercise for  
6 this, the ten structures involved, in components.

7 MR. WARD: Well, let's see, just so I under-  
8 stand.

9 You quoted as an example the fact that the  
10 load margins might vary from the different structures from  
11 1.0 to 4.5. And by this different definition, those numbers  
12 would be a little bit different at this point. Do you know  
13 what we are talking about?

14 MR. SIESS: It could be a lot different.

15 MR. WARD: Well, I don't know; one to 4.5,  
16 that is a lot different right there.

17 MR. SIESS: I think what they are doing is  
18 conservative; but I am not sure.

19 The next question is --

20 MR. WARD: It depends on what you do with the  
21 numbers. We have not heard what they are going to do with  
22 the numbers yet.

23 MR. BOHN: Well, for structures, though, many  
24 of them are often -- the seismic load is the controlling  
25 load, so, in those cases, it would not be conservative.

For piping, where the seismic loads are, typically, 15 to 20 percent of your maximum allowable, it would be conservative. But, for structures, which is what this approach is primarily useful for, it would not, necessarily, be so.

MR. SIESS: Allowable load.

MR. BOHN: Yes.

MR. HOLTZCLAW: I think that was indicated in the Brookhaven report, if not in SSER III for the check calculations that were done with the factors that GE derived. They were found to be conservative, albeit they were not done for -- I don't believe they were done for every structure.

There is an additional factor having to do with -- there is a factor to account for the response spectra that has been used in design compared with the a more median spectra, if you will. The time history that has been used in seismic analysis was generated for GESSAR in the design calculations to envelope the NRC design response spectra. So there was a factor to account for a, maybe, more realistic spectral condition, if you will. And so, that factor was included in the  $F_{TH}$  and there is about a 40 percent affect on that one multiplier. That is a typical value, is on the order of 1.4.

There is, also, a factor to account for the damping values. Normal design practice is to use REG guide

1 1.61 and these values have been considered to be quite con-  
2 servative, particularly at response levels typical of struc-  
3 tural failure levels. And so, we utilized some reports by  
4 NUMARK to identify what the impact of this factor is. And  
5 it, typically, ranges from about a 20 to 30 percent factor.  
6 So, the typical value is 1.2 to 1.3.

7           There were three additional factors in the  
8 response portion of this overall factor, if you will. There  
9 is one that was to account for earthquake duration and it  
10 was, again, based on more or less historical data on how  
11 long a damaging earthquake would actually last.

12           The first is the time history that was used  
13 in the seismic analysis. And it turned out to be a smaller  
14 factor on the order of about 1.2, 1.25 in length.

15           MR. WARD: Can that fact -- double counting  
16 with your inelastic energy absorption --

17           MR. HOLTZCLAW: No, I believe one is the dura-  
18 tion effect on the input and one is an effect of the  
19 material -- a more of a material property effect.

20           MR. BOHN: Well, but the factor on -- as de-  
21 rived by NUMARK and its compatriots, took a simple one de-  
22 gree -- system with lack of plastic properties for time  
23 histories, put 28 different time histories through it, pro-  
24 pagated 12 cycles of strong motion and computed ductility.

25           That means, duration definitely was used in



1 the definition of the ductility factor and the NUMARK Rudel  
2 (phonetic) thesis contains all the details of that. So,  
3 it is clear to me that there has been some double counting.

4 MR. HOLTZCLAW: Well, we did evaluate the  
5 impact of changing these factors, too, and found --  
6 Especially for this one, it was a relatively small effect  
7 because the factor, itself, was relatively small.

8 MR. BOHN: My concern is not in its use here,  
9 but in its use in the effective damage acceleration which  
10 has shifted your hazard curve over by a factor of, roughly,  
11 a quarter.

12 MR. SIESS: Let me as a more general question.  
13 It seems to me, what you have done, is to  
14 start off with what John Stevenson (phonetic) calls as code  
15 margins, the normal margin that is built into a nominal re-  
16 sistance divided by a nominal load. And then you modify  
17 that with a series of factors, some of the applying to the  
18 resistance, some of them applying to the load. And, at no  
19 time, have you actually tried to compute the actual resis-  
20 tance as modified by all the conservative assumptions in  
21 design or the actual load as modified.

22 You simply put these factors on top of a nom-  
23 inal factor.

24 MR. HOLTZCLAW: I think that is a very valid  
25 point and I think it was made by the NRC subcontractors and

1 it really had to do with the analysis approach that we had  
2 available to start with.

3 In fact, I believe John Reed made some point  
4 to this in his evaluation, that there may be more specific  
5 alternative approaches to get at the same problem in a  
6 different fashion which GE utilized. And the thing is, what  
7 we did do is we utilized the design analyses that we had  
8 at hand, based on our seismic analysis, deterministically,  
9 and tried to utilize that as best we could in this study.

10 MR. SIESS: Well, I think the advantage to  
11 the other method is not only that it is -- I think it is  
12 clearly superior to get at an answer but it is one heck of  
13 a lot more transparent. I am not sure whether that is good  
14 or bad; it depends on which side of the fence you are on,  
15 I guess. But it certainly is a desirable feature.

16 I have problems with this, a question of  
17 double counting, a question of just what the ratio means.  
18 If there is some ratio of earthquake capacity to design  
19 earthquake level, and this is an awful difficult way of  
20 understanding how you get to it --

21 MR. HOLTZCLAW: There were two additional  
22 factors that were indicated here on the chart, some factors  
23 associated with structural modeling which is really not  
24 relevant to the GESSAR design but takes into account dif-  
25 ferences in, primarily, relative to earlier plant designs,

1 looking at SRSS versus other types of modeling.

2 In the GESSAR analysis, the  $F_M$  value was  
3 always utilized as 1.0, as well as the factor to account  
4 for soil-structure interaction value utilized in the GESSAR  
5 analysis was 1.0.

6 MR. BOHN: The last factor, the soil structure  
7 -- I am sorry, Mike Bohn.

8 The structure interaction factor is often used  
9 to partially account for soil amplification, soil column  
10 amplification under the plant. So, if you have a site that  
11 has 80 to 100 feet of consolidated stiff soil, that in-  
12 creases the load into your structure.

13 Now, about a third of the plant locations in  
14 the country have that situation and I would thought, for  
15 a generic design, one would have included an approximation  
16 to that local site amplification in that particular factor.

17 MR. HOLTZCLAW: What we did here was really  
18 was the soil-structure interaction factor that we referred  
19 to here is more relevant to the analyses that we did deter-  
20 ministically in our envelope portion, where we did look at  
21 different soil-structure interactions and found that a range  
22 of different potential values, so, if you used, for a spe-  
23 cific site, there may some margin just based on whatever  
24 that site is relative to the site that we envelope the  
25 design for.

1 I think we accounted for it in that fact so  
2 that the deterministic analysis and we were not trying to  
3 take any additional credit in this portion of the analysis.

4 MR. BOHN: That would be an acceptable way  
5 of doing it. Did you, in your load determination, did you  
6 look at sort of a worse case which is I described, 80 to  
7 100 feet of fairly stiff soil?

8 MR. HOLTZCLAW: Yes, that is correct.

9 MR. BOHN: And that is what you used to amp-  
10 lify the soil motion over bedrock motion?

11 MR. HOLTZCLAW: Yes.

12 MR. BOHN: Okay. That is appropriate, then.

13 CHAIRMAN OKRENT: I am a little bit unclear  
14 about the full import of the last discussion.

15 You started with some kind of free seal  
16 (phonetic) acceleration; did you?

17 MR. VILLA: Yes.

18 CHAIRMAN OKRENT: And then you worked your  
19 way down to an assumed bedrock?

20 MR. VILLA: Yes.

21 CHAIRMAN OKRENT: All right.

22 In the end, I am not sure which comes first,  
23 free sealed or the bedrock, in ones thinking. I don't know  
24 what this curve means when you look at a mixture of sites,  
25 but I am going to believe it is an observation.

1 MR. BOHN: The key question here, I think,  
2 is where -- you said this plant is keyed on a .3 GSSE.

3 Where is that .3 GSSE? Is that bedrock accel-  
4 eration, surface-ground acceleration or what?

5 MR. VILLA: What we have, in describing GESSAR  
6 and I believe in the staff's safety evaluation report on  
7 the deterministic review, is a range, a total of eight con-  
8 ditions that describe the range of the seismic envelope  
9 which would allow us to put this plant at something like  
10 90 percent of the sites in the United States. And that 90  
11 percent is a number out of the air. Each site would have  
12 to satisfy these particular conditions that are defined.

13 And the range of bedrock is defined by velo-  
14 cities and, right now, I can't remember the shear velocities.  
15 I believe something like 600 to 3,000 or so, something like  
16 that.

17 But I can look up that answer instead giving  
18 you the answer.

19 MR. BOHN: Well, my question really was: How  
20 does one interpret this .3 (g)? Does it interpret it as  
21 a rock outcrop acceleration gotten from the entire data base  
22 of mixed rock and soil sites which is typically used in  
23 defining the acceleration of the site or does --

24 MR. VILLA: I think that answer to that is  
25 yes.

1 MR. BOHN: -- it include the amplification  
2 of the soil which considerably amplifies the surface PGA  
3 under these conditions of a moderate soil site --

4 MR. VILLA: I think the answer to that is  
5 both.

6 MR. QUIRK: Joe Quirk from GE.

7 Mike, in the early phases of our review on  
8 the GESSAR PDA, we assumed the horizontal ground accelera-  
9 tion was inputted at the base mat, or .3 (g) was inputted  
10 at the base mat. As we went into the final design phase  
11 of the review, the staff came out with some additional guid-  
12 ance, NSRP's, that allowed the input motion to be at free  
13 field and we used that in the final design.

14 So, we have .3 (g) in the free field. So it  
15 is less certain.

16 MR. HOLTZCLAW: I would like to skip the next  
17 curve in the handout, for now. Then we can consider it in  
18 detail.

19 (Slide.)

20 MR. HOLTZCLAW: This is one of the tables from  
21 the report, just to give you a feeling for values. In this  
22 case, it is for the drywell under concrete compression and  
23 what the values used for the individual factors were.

24 I would like to go through a discussion of  
25 as much non-proprietary information as we can. And, I think,

1 the only thing that I have got here is just a couple of  
2 tables that are right out of the report that you have, show-  
3 ing examples.

4 The next chart, generally, what we did to de-  
5 velop the structural fragility curve, based on the indivi-  
6 dual factors that we have discussed in the previous chart.

7 We defined the median value for capacity and  
8 then the median ground acceleration level corresponding to  
9 failure can be determined for each individual structure.

10 In this case, we assume that failure of struc-  
11 ture would be defined as that situation that the inelastic  
12 deformation of the structure increases such that the func-  
13 tion of the operability of safety related equipment cannot  
14 be assured. And we have made the assumption of the  
15 lognormal distribution and tried to assess, simplistically,  
16 the statistical variations and selected a coefficient of  
17 variation.

18 And the next curve gives you the eight indivi-  
19 dual structures and the values that we utilized in the  
20 study. Again, that is just out of the report.

21 (Slide.)

22 MR. HOLTZCLAW: What I would like to do now  
23 is just talk very briefly on the component fragility because  
24 that is -- and then that leads into discussions of the use  
25 of both the component structural fragilities in juxtapo-

1 sition with the seismic hazard to then assess core damage  
2 probability that Dr. Hankins will be reporting on.

3 The objective of the analysis of the component  
4 fragility was to develop the fragility data for use in our  
5 evaluation. This, again, makes use of a number of PRA  
6 studies that were already available where we could lump  
7 things in terms of very generic components.

8 MR. EBERSOLE: May I ask a question.

9 What do you do with the somewhat complicated  
10 case where you lose the containment function, per se, but  
11 then you find you didn't need it anyhow? It looks like you  
12 didn't have a core-damage accident.

13 How do you handle that?

14 MR. HOLTZCLAW: I guess, for purposes of this  
15 seismic analysis, I believe that containment failure went  
16 directly to core melt and that is somewhat inconsistent with  
17 what we did do in the internal event study where containment  
18 failure did not have that one to one correlation, obviously.

19 We analyzed a number of sequences.

20 MR. EBERSOLE: Well, you can easily lose the  
21 containment function as a containment function without  
22 having full melt.

23 MR. HOLTZCLAW: I understand.

24 CHAIRMAN OKRENT: What was the median capacity  
25 acceleration for the weakest link in your containment? It



1 was pretty large; wasn't it?

2 MR. HOLTZCLAW: Yes, it was, Doctor.

3 CHAIRMAN OKRENT: So, it is sort of an aca-  
4 demic question, I think.

5 MR. HOLTZCLAW: In doing the assessment of  
6 the component fragility, we made use of -- a good deal of  
7 use of the internal event study to look at critical compo-  
8 nents as part of our systems analysis. And we identified  
9 a factor of safety for the components in a somewhat similar  
10 fashion that we did for the structures and then identified  
11 their fragility curves consistent with the approaches that  
12 have been used in previous PRA's.

13 (Slide.)

14 MR. HOLTZCLAW: In the next two slides, just  
15 provide an example for the pipe rupture as well as a com-  
16 pilation of the median capacities for the components used  
17 in our analysis.

18 MR. BOHN: Could you go back to that last  
19 slide. I am sure this point has been made in the staff  
20 review.

21 (Previous slide.)

22 MR. BOHN: This ratio is appropriate to com-  
23 ponent failure where the failure is, primarily, anchorage  
24 failure and I am sure John Reed and -- the parts have been  
25 brought out.

1 Anchorage failure is a form of component fail-  
2 ure and they are estimating the anchorage load and scaling  
3 them by ductility, et cetera, is an appropriate way to go.  
4 It, certainly, is not appropriate for components whose fail-  
5 ure is functional, that is, relay chatter, circuit breaker  
6 trip.

7 In particular, you have identified stem binding  
8 on pumps as being your dominant failure and I don't think  
9 that this approach with its scaling factor is appropriate  
10 for stem binding a pump because that is a functional failure;  
11 there is no ductility involved in that, for example.

12 Same problem with coder-operated valves and  
13 stem bindings there.

14 In addition, a second comment that I am sure  
15 has been made somewhere is that the use of effective ground  
16 acceleration which is scaled on ten to twelve cycles of  
17 damages done in motion is not appropriate for components  
18 whose failure is functional. So, in evaluating these compo-  
19 nents with function failure, one should not use the proba-  
20 bilities off the scale effective hazard curve, but rather  
21 use the full hazard curve with this extra factor of 25 per-  
22 cent removed.

23 MR. HOLTZCLAW: I believe that comment was  
24 made in -- part of the reason why we did go back and look  
25 at sensitivity on that component values that we used in the

1 study.

2 CHAIRMAN OKRENT: Could I ask a question con-  
3 cerning anchorage.

4 It is my impression that it is not uncommon  
5 for there to be defects in the fabrication that is involved  
6 in anchorage in particular, for example, the welding. But  
7 there are other kinds of defects.

8 In other words, if one looks at prior exper-  
9 ience, this is not a low probability event. Furthermore,  
10 it is of the nature that, in fact, it could drastically  
11 change your estimate of fragility.

12 Is it reasonable to ignore prior empirical  
13 knowledge and assume perfection? If so, why? And, if not,  
14 why should I assume some rather arbitrary subjective modifi-  
15 cation of fragility in a purported sensitivity analysis is  
16 adequate to cover this particular deficiency that, as I say,  
17 has been observed not as a rare event?

18 MR. HOLTZCLAW: In answer, I think, to the  
19 question. We did not assume any specific affect on the  
20 fragility curve other than what, I guess, what has been the  
21 past practice in PRA's and that is, probably, a deficiency  
22 in that regard.

23 I, personally, don't have a good deal of know-  
24 ledge in how we might -- or what might be the appropriate  
25 factor to use there.

1 CHAIRMAN OKRENT: Well, let's see.

2 How do we figure out what the likelihood of  
3 a valve failing or a pump failing? You go back and look  
4 at data.

5 MR. HOLTZCLAW: Right.

6 CHAIRMAN OKRENT: It is not obvious to me why  
7 one doesn't go back and look at data of this sort. And,  
8 unless you have some valid reason for saying that the data  
9 would be different --

10 MR. HOLTZCLAW: I know what you are getting  
11 at, Doctor, because we tried to do this a little bit when  
12 we were looking at our fire analysis because we got with  
13 the staff and, really, as part of addressing the design  
14 deficiencies or problems associated -- the construction  
15 error problem.

16 I think that what you are really identifying  
17 is a classic in that area.

18 We did address it -- I mean, we didn't address  
19 it, we did consider it and we were trying to figure out a  
20 way to factor that into the study in a couple of different  
21 areas. The problems that we were running up against was  
22 that you could have some things like LAR reports and some  
23 kinds of reports that identified the failures or identified  
24 the problems in specific construction errors. I was think-  
25 ing more in the fire area and the installation of dampers

1 in the wrong place or lack of installation of dampers.

2 But it hard to come to grips with what the  
3 total data base might be on how many successes you had, how  
4 many times you are able to do it right to, maybe, put this  
5 into some kind of a little -- or eventuary (phonetic), if  
6 you will, to put some level of confidence on what an esti-  
7 mate might be in the affect to fragility.

8 That is, probably, a very simplistic answer  
9 to your question which, basically, says that we did not con-  
10 sider that aspect in the analysis.

11 MR. ETHERINGTON: Now, I would like to pursue  
12 that a litte, if I may, Mr. Chairman.

13 There has been a tremendous amount of work  
14 by NRC and others in the integrity of reactor vessels,  
15 particularly in connection with PWR's and there has been  
16 a tremendous amount of development of fracture mechanics in  
17 placing the integrity of the vessels.

18 In all of this work, there is an asumption  
19 that cracks will be present on some statistical or other  
20 distribution. It seems to me, here, you are taking advan-  
21 tage of a statistical spread in physical properties, tensile  
22 strength and so on and not taking any debit against the fact  
23 that you, surely, have defects in structural materials.

24 I think, in this area, you are far behind the  
25 approach that is being applied to reactor vessels using

1 fracture mechanics. In fact, fracture mechanics doesn't  
2 seem to have entered into the vocabulary, even, in anything  
3 I have heard today.

4 I think there is a weakness there.

5 MR. HOLTZCLAW: I think that just from the  
6 standpoint, though, that were there is data available to  
7 back up the component or structural fragility, and I think  
8 you more hear about component fragility, there are fragility  
9 curves that have been based on some test work and I would  
10 expect that those components would be as amenable to having  
11 a crack initiated or as any other component that might be  
12 used in GESSAR, from the standpoint that the fragility curve  
13 was based on some data that would evidence that kind of a  
14 problem and, okay, maybe, second order, you are considering  
15 the affect.

16 But it is not being highlighted as a separate  
17 affect of its own. And I think that is what you are kind  
18 of getting at, Dr. Etherington.

19 MR. ETHERINGTON: But I still repeat that I  
20 think the great majority of industrial failures have been  
21 due to defects in materials.

22 CHAIRMAN OKRENT: By the way, there are, at  
23 least, I guess, two classes of defects. One might be flaws,  
24 if you will and there is another class where you don't have  
25 the material you thought you ought to. I mean, it might

1 even have the right chemical composition but had been heat-  
2 treated differently, making it, again, the wrong material.

3 MR. BOHN: May I make a comment on that.

4 When we are dealing with supports, certainly  
5 what test data there was, primarily from the safeguard, U.S.  
6 Army Corps of Engineer program, they could only test a  
7 limited number like four pumps and 27 relays, for example,  
8 is what the data base is, as I recall.

9 But the other side of the question, as far  
10 as fracture and flaws in supports is that most of these  
11 pieces of equipment are anchored in a very redundant fasion.  
12 That is, a pump has four supports or four bolting places  
13 or else it is, typically, welded along one side, so the  
14 presence of a flaw, you have to hypothesize a flaw in more  
15 than one support in order for it to become significant.

16 And that is -- one could, probably, go through  
17 statistical arguments showing that it is not likely that,  
18 in four lugs used simultaneously. But that is something  
19 that could be looked at, I suppose.

20 CHAIRMAN OKRENT: Unless there was bad welding  
21 practice and so it was not random. And that, in fact, is  
22 what you find in prior experience.

23 MR. HOLTZCLAW: The common mode failure of  
24 that kind of a practice.

25 CHAIRMAN OKRENT: Or a bad seet of bolts.

1 MR. HOLTZCLAW: And universally heat-treated  
2 incorrectly and you get all four of them fasten this com-  
3 ponent.

4 One point of information here and, I guess,  
5 this is, primarily, brought out in the interaction with John  
6 Reed and some of our consultant people at GE. I think, in  
7 doing this study, it kind of opened our eyes up to an area  
8 that we had only been limitedly involved with, that is  
9 really, the extension of the seismic analyses beyond what  
10 we normally had done in the past on a deterministic design  
11 basis standpoint.

12 And we, in-house, had looked into getting more  
13 information on components that GE, typically, deals with  
14 on our reactors and; because of the interaction with some  
15 of the people at Lawrence Livermore, our working with them  
16 and trying to provide additional data on the components that  
17 we are using in our design.

18 I guess it was a little bit of an item of  
19 interest to me, personally, and to the team that worked on  
20 this report, to discover that the data base is extremely  
21 limited. But it, also, is -- there are extensive ongoing  
22 programs to better characterize that data base and we have  
23 some input to some of those programs.

24 What we would to do now, Dr. Okrent, is to  
25 shift into some more of the systems analysis area, if you



1 will, and --

2 CHAIRMAN OKRENT: Could ask a question.

3 According to the agenda, we were going to  
4 break for lunch about noon. Is this a good breaking point?

5 MR. HOLTZCLAW: Yes.  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

1                   CHAIRMAN OKRENT: Why don't we, if everyone  
2 is agreeable and, even, if they are not, recess for lunch  
3 and try to be back in one hour.

4                   I don't know what the capability, the capacity  
5 factor is, for the existing dining facilities. They usually  
6 have two and they have lost one since we were last here.

7                   But, anyway, let us try to be back in an hour.

8                   (Whereupon, at 11:55 o'clock a.m., the open  
9 session was adjourned, to be reconvened in closed session  
10 at the hour of 1:00 o'clock p.m.)

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

## AFTERNOON OPEN SESSION

3:30 p.m.

CHAIRMAN OKRENT: The meeting will reconvene.

It occurs to me -- I am not sure if we heard what was the risk contribution of utility supply systems during the prior discussion.

Did we hear that?

Maybe the NRC has answers to this. We can ask GE when they get back. In any event, why don't we start with the next agenda item.

MR. BARI: My name is Robert Bari from Brookhaven National Laboratories and I will provide some opening remarks on the general approach to the Brookhaven review of the GESSAR seismic PRA.

(Slide.)

MR. BARI: Just as general background, Brookhaven has been under contract to the Nuclear Regulatory Commission for some years now, on various aspects of the review of the GESSAR PRA, which includes the internal event part of the PRA which was submitted to the staff at least a year ago, the external events which include the seismic analysis that you are going to hear about today and, also, a fire analysis. And, in addition, we have an ongoing review of the core and containment analysis including core degradation, fission product behavior and containment and

1 eventual release from containment.

2           These studies have been carried out in an  
3 integrated fashion. Several people, over several years,  
4 participating in the effort.

5           (Slide.)

6           MR. BARI: In terms of the scope of our review  
7 has several elements. First of all, we have evaluated the  
8 overall GE methodology for loss of components and structures  
9 due to seismic events.

10           One of the key elements that you will hear  
11 about was the comparison with state-of-the-art PRA's. We  
12 touched base with the various PRA's that have been produced  
13 in recent years for purposes of comparison and contrasting  
14 the approaches.

15           We performed, in this analysis, limited,  
16 simplified calculations of event leading to core meltdown.  
17 I want to emphasize here that what you are going to hear  
18 today are analyses of events leading up to core meltdown.  
19 We are not presenting the results, the consequence-type  
20 analysis, the core meltdown-type of analysis associated with  
21 the seismic events. That would be forthcoming at a later  
22 meeting, I understand.

23           We have, basically --

24           CHAIRMAN OKRENT: Excuse me.

25           MR. BARI: Surely.

1                   CHAIRMAN OKRENT: I need to understand what  
2 it is you just said.

3                   There is some additional information that we  
4 should expect to learn about in the future concerning core  
5 meltdowns for seismic?

6                   MR. BARI: The consequences, the behavior of  
7 fission products in containment and the behavior of fission  
8 products as they leave containment. That analysis is not  
9 presented here today.

10                  CHAIRMAN OKRENT: As it relates to seismic?

11                  MR. BARI: As it relates to seismic.

12                  CHAIRMAN OKRENT: Thank you.

13                  MR. BARI: We are just presenting core melt-  
14 down frequencies as a bottom-line risk indicator, here,  
15 today.

16                  The types of things we have been doing -- we  
17 have been identifying alternative models, for example,  
18 hazard curves. You have seen some of those already. The  
19 BNL analyses was actually presented earlier by GE and you  
20 will hear more about it in a little while.

21                  We have examined the study for completeness.  
22 For example, we have augmented the critical components list  
23 for -- in connection with fragility analysis. We have re-  
24 viewed the model assumptions in the GE seismic PRA. In fact,  
25 you will hear, specifically, about what we regard as the

1 system dependencies in the PRA, our alternative approaches.

2 We have carried out sensitivity analysis and,  
3 finally, we have done some importance ranking assistance.

4 (Slide.)

5 MR. BARI: Some of the bookkeeping connecting  
6 with the nuts and bolts of the approach, the hazard and  
7 fragility analyses have been reviewed by Jack Benjamin  
8 Associates under contract to BNL and you will be hearing  
9 from John Reed, shortly, on the details of that review.

10 The systems analyses were performed at Brook-  
11 haven, mostly by Kelvin Shiu who is here right now and will  
12 follow John Reed in his presentation.

13 There have been close interfacing of these  
14 tasks between John and Kelvin over the the period of the  
15 review. We have, also, had several meetings with General  
16 Electric. I think that was evidence from the previous talk.

17 The study was initiated at Brookhaven in Sep-  
18 tember of '83 when we received the first submittal from GE  
19 which did not include uncertainty analysis. We received  
20 a supplementary document in December of '83 which did  
21 include uncertainty analysis.

22 We submitted our draft report to NRR in Sep-  
23 tember of '84 and I believe you have that report. And, as  
24 I said, these results will be input to our containment  
25 analysis that we have handled on a separate contract, NRR.

1 CHAIRMAN OKRENT: May I ask a couple of ques-  
2 tions.

3 MR. BARI: Sure.

4 CHAIRMAN OKRENT: Are we going to hear from  
5 Brookhaven concerning the risk contribution of utility  
6 supply systems or is that something you did not look at?

7 MR. BARI: Utility supply system?

8 CHAIRMAN OKRENT: As this thing from Watson --

9 MR. SHIU: Kelvin Shiu.

10 We did not include, to any great extent,  
11 designs of plant.

12 CHAIRMAN OKRENT: Okay.

13 Different question. It says that the BNL  
14 draft report was in 9/84. I notice that the acknowledgement  
15 thanks members of the NRC for helping improve earlier  
16 versions.

17 What I wonder is: Is there any technical in-  
18 formation that was an earlier version that we missed in the  
19 final one? Are there any opinions in the report of 9/84  
20 that not all members of the BNL staff agree with?

21 Anything more we ought to know about the draft  
22 that is dated 9/84?

23 MR. BARI: As far as I am concerned, no. I  
24 am not aware of any information that -- in addition to what  
25 we have in the 9/84 draft that would be useful at this point.

1 Kelvin, do you have anything?

2 MR. SHIU: There are no differing opinions  
3 at Brookhaven, let me put it that way.

4 MR. BARI: At Brookhaven, no.

5 MR. SCALETTI: Dr. Okrent, you do have, I  
6 believe, copies of earlier Brookhaven correspondence with  
7 the staff. Are you implying that you don't have earlier  
8 copies?

9 Because, everything that was discovered, that  
10 went out for the FOIA discovery that we had, was turned over  
11 to the ACRS with the exception of the GE information, sub-  
12 mittals to us which you people get routinely.

13 CHAIRMAN OKRENT: What I looked at in my most  
14 recent review of documents included something dated 9/84  
15 and something else dated 10/84. If I had earlier things  
16 from Brookhaven, they weren't in my two-foot file at home,  
17 I am sorry to say. And I was just trying to see whether  
18 there was anything that I missed by only looking at these,  
19 okay?

20 Let me just, as an aside, ask if GE, at some  
21 point during this meeting, is able to add to this question  
22 that was on the last GE agenda item, on this contribution,  
23 of utility-supplied systems. You did show some fragility  
24 numbers. I wondered if you had, actually, ground them out  
25 and decided what the contribution to risk was. Was it



1 negligible or whatever, if you meant the numbers included  
2 there.

3 But we don't have to do that now.

4 Are there anyother questions of Mr. Bari?

5 MR. BARI: I have one final comment on the  
6 opening remark by Dr. Siess on the word conservatism used  
7 in the BNL report.

8 It was not our intention, as apparently there  
9 was an inference, that, perhaps, we were advocating doing  
10 a conservative PRA. If that was what was inferred, then  
11 we have misled you.

12 It is true that the word conscervative has been  
13 used in various places in the report. For example, it was  
14 mentioned, aspects of the GE analysis that we felt not to  
15 be conservative. What we meant there was, optimistic.  
16 Perhaps that is an easieer way to say it and we will go  
17 back --

18 MR. SIESS: What is wrong with "correct"?

19 Or you don't use the word "correct" in terms  
20 of probability?

21 There is a place, for example, where it said,  
22 "In this sense, the ultimate value of the representative  
23 and may or may not be conservative in all cases."

24 MR. BARI: Which section is that in?

25 MR. SIESS: Page 5-1 of the September, 1984

1 draft.

2 On the other hand, the values developed by  
3 GE are on the non-conservative side. So, you know --

4 MR. BARI: I think it is a question of the  
5 wording by the author. I think we will go back and look  
6 at that and try to present a less ambiguous --

7 MR. SIESS: There is a statement -- this is  
8 under sensitivity analysis and it says, "The analyses are  
9 definitely not bounding conservative analyses and will not  
10 be realistic or representative for all potential plants which  
11 may be located at different sites."

12 And that one really confused me because it  
13 says they are not bounding conservative analyses and are  
14 not realistic or representative and I didn't know whether  
15 that was two thoughts in one sentence or whether they are  
16 not realistic because they are not bounding. Do you see  
17 what I am --

18 MR. BARI: Yes, sure.

19 MR. SIESS: -- apparently didn't get as much  
20 help from the staff --

21 MR. BARI: Yes, I believe this is going to  
22 come out with John Reed's presentation. If it is not, I  
23 hope we will make that more clear.

24 CHAIRMAN OKRENT: By the way, just as -- by  
25 today's GRS level --

1                   Just so Mr. Scaletti doesn't think that I was  
2 born yesterday, I don't assume that, because we, let's say,  
3 if we sent copies of what you call letter reports as well  
4 as draft reports, that we are necessarily exposed to all  
5 of the technical interchange that may have taken place be-  
6 cause there is a period before a letter report is allowed  
7 to be written.

8                   Let me just leave it at that.

9                   MR. BARI: I am through.

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1                   MR. REED: Dr. Okrent, most of my material,  
2 a good deal of my material has proprietary information in  
3 it, so I think, for the sake of implicity, you should  
4 consider my whole talk being under the propietary side of  
5 the recording.

6                   CHAIRMAN OKRENT: All right.

7                   We will go off the record.

8                   (Whereupon, at 3:45 o'clock p.m., the open  
9 session was adjourned and the subcommittee reconvened in  
10 closed session.)

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE OF OFFICIAL REPORTER

This is to certify that the attached proceedings  
before the UNITED STATES NUCLEAR REGULATORY COMMISSION in  
the matter of:

NAME OF PROCEEDING:


COMBINED GESSAR II RELIABILITY AND  
PROBABILITY ASSESSMENT

DOCKET NO.: NONE

PLACE: LOS ANGELES, CALIFORNIA

DATE: FEBRUARY 14, 1985

were held as herein appears, and that this is the original  
transcript thereof for the file of the United States  
Nuclear Regulatory Commission.

  
MICHAEL CONNOLLY  
Official Reporter

Reporter's Affiliation  
Jim Higgins and Associates

GESSAR II - SEISMIC MARGIN

NO SPECIFIC SEISMIC MARGIN STUDY WAS CONDUCTED OF GESSAR II IN TERMS OF HIGH CONFIDENCE LOW PROBABILITY EVALUATION. SOME MARGIN INSIGHT OBTAINED BASED ON PRA RESULTS.

BASED ON THE REVIEW OF PRA FRAGILITIES, THE STAFF BELIEVES THAT GESSAR II DESIGN, IN GENERAL, WILL POSSESS MARGINS SIMILAR TO [REDACTED] THOSE FOR OTHER RECENT PLANTS.

THIS IS MORE EVIDENT FOR STRUCTURES BASED ON LIMITED FRAGILITY EVALUATION IN GESSAR II. FOR COMPONENTS, MORE DETAILED EVALUATIONS ARE NEEDED.

HOWEVER, TO ESTABLISH MEANINGFUL MARGINS, SITE SPECIFIC INVESTIGATIONS ARE NEEDED.

GESSAR II MARGINS ARISE NOT ONLY FROM THE CONSERVATISMS USED IN DESIGN PROCESS (E.G. USE OF SPECIFIED STRENGTH VS. ACTUAL STRENGTH) BUT ALSO DUE TO ENVELOPING DESIGN OF GESSAR II FOR VARIOUS CONDITIONS.



THE STAFF IS ACTIVELY INVESTIGATING THE SEISMIC MARGIN ISSUE GENERALLY. EFFORTS ARE UNDERWAY TO REVIEW RECENT PRAS TO ESTABLISH HIGH CONFIDENCE LOW PROBABILITY DATA FOR SEVERAL COMPONENTS AND STRUCTURES.

GESSAR II - SEISMIC MARGIN

NO SPECIFIC SEISMIC MARGIN STUDY WAS CONDUCTED OF GESSAR II IN TERMS OF HIGH CONFIDENCE LOW PROBABILITY EVALUATION. SOME MARGIN INSIGHT OBTAINED BASED ON PRA RESULTS.

BASED ON THE REVIEW OF PRA FRAGILITIES, THE STAFF BELIEVES THAT GESSAR II DESIGN, IN GENERAL, WILL POSSESS MARGINS SIMILAR TO [REDACTED] THOSE FOR OTHER RECENT PLANTS.

THIS IS MORE EVIDENT FOR STRUCTURES BASED ON LIMITED FRAGILITY EVALUATION IN GESSAR II. FOR COMPONENTS, MORE DETAILED EVALUATIONS ARE NEEDED.

HOWEVER, TO ESTABLISH MEANINGFUL MARGINS, SITE SPECIFIC INVESTIGATIONS ARE NEEDED.

GESSAR II MARGINS ARISE NOT ONLY FROM THE CONSERVATISMS USED IN DESIGN PROCESS (E.G. USE OF SPECIFIED STRENGTH VS. ACTUAL STREIGHT) BUT ALSO DUE TO ENVELOPING DESIGN OF GESSAR II FOR VARIOUS CONDITIONS.

THE STAFF IS ACTIVELY INVESTIGATING THE SEISMIC MARGIN ISSUE GENERALLY,  
EFFORTS ARE UNDERWAY TO REVIEW RECENT PRAS TO ESTABLISH HIGH CONFIDENCE  
LOW PROBABILITY DATA FOR SEVERAL COMPONENTS AND STRUCTURES.

GESSAR II SEISMIC EVENT ANALYSIS  
AGENDA

- o INTRODUCTION J. F. QUIRK
- o BACKGROUND K. W. HOLTZCLAW
- o SEISMIC HAZARD ANALYSIS
- o STRUCTURAL FRAGILITY EVALUATION
- o COMPONENT FRAGILITY
- o SEISMIC IMPACT ON CORE DAMAGE FREQUENCY D. A. HANKINS
- o SEISMIC ANALYSIS SENSITIVITY STUDY
- o COMPONENTS & STRUCTURES IMPORTANT TO SEISMIC RISK
- o RISK EVALUATION
- o CONCLUSIONS

## INTRODUCTION

### o BACKGROUND


STUDY PERFORMED TO MEET THE REQUIREMENT IN THE DRAFT  
SEVERE ACCIDENT POLICY STATEMENT

### o PRINCIPAL TASKS

- ESTABLISH SEISMIC HAZARD CURVE
- DETERMINE SEISMIC CAPABILITY OF CRITICAL STRUCTURES  
AND COMPONENTS
- EVALUATE CORE DAMAGE FREQUENCY
- ESTIMATE OFFSITE CONSEQUENCES

### o APPLICATION TO SPECIFIC PLANT SITE

GESSAR II SEISMIC EVENT ANALYSIS





## SEISMIC HAZARD ANALYSIS

### 0 OBJECTIVE


- 0 CHARACTERIZE SEISMIC HAZARD FOR GESSAR II SITES

### 0 APPROACH

- 0 PUBLISHED DATA USED FOR ESTABLISHING BASE SEISMIC HAZARD CURVE FOR GESSAR APPLICATION
  - SITE SPECIFIC ANALYSES
    - ZION
    - LIMERICK
    - OYSTER CREEK
  - WASH-1400 (NUREG-75/014) 1975
  - USGS OPEN FILE REPORT 82-1033, 1982
- 0 DEVELOPED CHARACTERISTIC SEISMIC HAZARD CURVE
- 0 LIMIT PROBABILITY OF EXCEEDENCE TO  $10^{-8}$  CONSISTENT WITH INTERNAL EVENT PRA (NO INITIATING EVENT FREQUENCIES LESS THAN  $10^{-8}$ )

## DISCUSSION ON SEISMIC HAZARD ANALYSIS

- 0 NUMEROUS DISCUSSIONS WITH STAFF ON HAZARD ANALYSIS APPROACH
  - 0 SUGGESTIONS ON CONSIDERING MULTIPLE HAZARD LEVELS COUPLED WITH MULTIPLE SITE CONDITIONS
  - 0 MEETING WITH STAFF - ALTERNATIVE APPROACH OF USING HIGH AND LOW SEISMIC SITES
    - USE AVAILABLE SITE SPECIFIC INFORMATION
  
- 0 DECIDE ON PRESENT APPROACH
  - 0 GE CONSIDER A "REPRESENTATIVE" CURVE
  - 0 NRC SUBCONTRACTOR WOULD LOOK AT RESULTS BASED ON HAZARD INFORMATION FROM EXISTING PRAS
  
- 0 RECOGNIZED NEED TO CONSIDER SITE SPECIFIC APPLICATION
  - 0 INTENT: APPLICANT DEFINE SITE SPECIFIC HAZARD CURVE AND COMPARE TO CURVE USED SEISMIC EVENT ANALYSIS



GESSAR II Seismic Hazard Curve Compared to Hazard Curves from other Studies.




Figure 2-2. Comparison of the GESSAR II best-estimate hazard curve to the results of other seismic hazard studies.



## STRUCTURAL FRAGILITY EVALUATION

o OBJECTIVE: DEVELOP FRAGILITY CURVES TO ASSESS PROBABILITY OF STRUCTURAL FAILURE AS A FUNCTION OF PEAK EFFECTIVE GROUND ACCELERATION

o APPROACH

- DEFINE STRUCTURAL FAILURE:

STRUCTURE LOSES ITS FUNCTION WHEN LARGE INELASTIC DEFORMATIONS OF STRUCTURE INTERFERE WITH THE OPERABILITY/FUNCTION OF SAFETY RELATED SYSTEM OR EQUIPMENT

- IDENTIFY CRITICAL STRUCTURES

- ESTIMATE "CAPACITY FACTOR OF SAFETY" (F):

$$F = \frac{\text{INHERENT ULTIMATE STRUCTURAL CAPACITY}}{\text{IN TERMS OF ACCELERATION}}$$

DESIGN CAPACITY (OBE/SSE),

- CONVERT F TO MEDIAN STRUCTURAL CAPACITY IN TERMS OF ACCELERATION

- DEVELOP FRAGILITY CURVE FOR STRUCTURES

## STRUCTURES CONSIDERED

- RPV PEDESTAL
- DRYWELL WALL
- CONTAINMENT VESSEL
- SHIELD BUILDING
- AUXILIARY BUILDING
- OTHER SEISMIC CATEGORY 1 STRUCTURES
- NON-SEISMIC CATEGORY 1 STRUCTURES

## CALCULATION OF CAPACITY FACTOR OF SAFETY (F)

$$FFS = F_{\ell} \cdot F_{ST} \cdot F_{\nu} \cdot F_{TH} \cdot F_D \cdot F_{ED} \cdot F_M \cdot F_{SSI}$$

WHERE  $F_{\ell} = \frac{\text{DESIGN LOAD}}{\text{CALCULATED LOAD}}$

$$F_{ST} = \frac{\text{YIELD STRESS}}{\text{ALLOWABLE STRESS}}$$

$F_{\nu} =$  FACTOR TO ACCOUNT FOR THE FACT THAT AN EARTHQUAKE REPRESENTS A LIMITED ENERGY SOURCE AND STRUCTURAL COMPONENTS ARE CAPABLE OF ABSORBING ENERGY BEYOND ELASTIC LIMIT WITHOUT LOSS OF FUNCTION.

$$F_{TH} = \frac{\text{SPECTRAL ACCELERATION AT CRITICAL DAMPING NEAR FAILURE}}{\text{SPECTRAL ACCELERATION AT CRITICAL DAMPING FOR DESIGN}}$$

$F_D =$  FACTOR TO ACCOUNT FOR CONSERVATIVE DAMPING VALUES SPECIFIED IN REGULATORY GUIDE 1.61.

$F_{ED} =$  FACTOR TO ACCOUNT FOR EARTHQUAKE DURATION

$F_M =$  FACTOR TO ACCOUNT FOR STRUCTURAL MODELING

$F_{SSI} =$  FACTOR TO ACCOUNT FOR SOIL-STRUCTURE INTERACTION

## DEVELOPMENT OF FRAGILITY CURVE

o MEDIAN GROUND ACCELERATION (A)

$$= F * (\text{OBE OR SSE})$$

o LOGNORMAL DISTRIBUTION IS ASSUMED

- STATISTICAL VARIATION OF MATERIAL PROPERTIES
- SEISMIC RESPONSE VARIABLES ARE BEST REPRESENTED BY THIS DISTRIBUTION

o SELECT COEFFICIENT OF VARIATION

$$P_F \sim 0. \text{ AT DESIGN VALUE.}$$



## COMPONENT FRAGILITY

### OBJECTIVE

DEVELOP COMPONENT FRAGILITY DATA FOR USE IN GESSAR EVALUATION

### APPROACH

- o SELECT CRITICAL COMPONENTS
- o ESTABLISH FAILURE CRITERIA OF COMPONENTS AS IT RELATES TO SYSTEM FUNCTION

- o ESTIMATE COMPONENT FACTORS OF SAFETY (F)

$$F = \frac{\text{ULTIMATE CAPABILITY OF COMPONENT}}{\text{DESIGN CAPABILITY}}$$

- o DETERMINE MEDIAN CAPACITY OF COMPONENT IN TERMS OF PEAK GROUND ACCELERATION (PGA)

$$\text{MEDIAN CAPACITY} = F \cdot (\text{DESIGN PGA})$$

- o ESTIMATE COMPONENT FAILURE PROBABILITY AS A FUNCTION OF PGA

- LOG NORMAL PROBABILITY DISTRIBUTION WITH ESTIMATED COEFFICIENT OF VARIATION

#1

09/11

BNL SEISMIC RISK ANALYSIS  
SUMMARY OF GENERAL APPROACH

PRESENTED TO  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
INGLEWOOD, CA

FEBRUARY 14-15, 1985

BACKGROUND

BNL IS UNDER CONTRACT TO NRC/NRR TO PROVIDE  
A REVIEW OF THE GESSAR-II PRA, INCLUDING:

- INTERNAL EVENTS
- EXTERNAL EVENTS
- CORE AND CONTAINMENT BEHAVIOR

## SCOPE OF SEISMIC REVIEW

- EVALUATED GE METHODOLOGY FOR LOSS OF COMPONENTS AND STRUCTURES DUE TO SEISMIC EVENTS.
- COMPARED WITH STATE-OF-THE-ART.
- PERFORMED LIMITED, SIMPLIFIED INDEPENDENT CALCULATIONS OF EVENTS LEADING TO CORE MELTDOWN.
- IDENTIFIED ALTERNATIVE MODELS (E.G., HAZARD CURVES).
- EXAMINED COMPLETENESS (E.G., CRITICAL COMPONENTS FOR FRAGILITY ANALYSIS).
- REVIEWED MODEL ASSUMPTIONS (E.G., SYSTEM DEPENDENCES).
- PERFORMED SENSITIVITY ANALYSIS.
- DEVELOPED IMPORTANCE RANKING.

APPROACH TO REVIEW

- HAZARD ANALYSIS
  - FRAGILITY ANALYSIS
  - SYSTEMS ANALYSIS (PERFORMED BY BNL)
  - CLOSE INTERFACING OF TASKS
  - SEVERAL MEETINGS WITH GE
  - STUDY INITIATED IN 9/83; RECEIVED GE UNCERTAINTY ANALYSIS IN 12/83
  - BNL DRAFT REPORT TO NRR IN 9/84
  - INPUT TO CONTAINMENT ANALYSIS
- } PERFORMED BY  
J. BENJAMIN, INC.  
} UNDER CONTRACT TO BNL