

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

April 15, 1996

WO 96-0063


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: March, 1996, Monthly
Operating Report

Gentlemen:

Attached is the March, 1996, Monthly Operating Report for Wolf Creek
Generating Station. This submittal is being made in accordance with the
requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a
W. D. Johnson (NRC), w/a
J. F. Ringwald (NRC), w/a
J. C. Stone (NRC), w/a

190010

9604190078 960331
PDR ADOCK 05000482
R PDR

JE24

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: March YEAR: 1996

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 133

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of March, 1996. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit remained in outage conditions throughout the month of March, 1996, as activities associated with Refuel VIII continued. The unit completed reloading fuel on March 16, 1996 in Mode 6. The unit entered Mode 5 at 1343 on March 20, 1996, and entered Mode 4 at 0313 on March 29, 1996.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

Reactor Coolant System check valve repair
"B" Residual Heat Removal System
"B" Train Essential Service Water System
"B" Component Cooling Water System
Check Valve Flow and Testing
Safety Injection Pump Testing
"B" Diesel Generator Maintenance and Testing
"B" Train NK Battery Replacement
Accumulator Safety Injection System Maintenance
ASME 10-Year Inservice Inspection
"B" Centrifugal Charging Pump Maintenance

OPERATING STATUS

1. Reporting Period: March, 1996 Gross Hours in Reporting Period: 744
2. Currently Authorized Power Level (MWT): 3565 Max. Depend. Capacity (MWe-Net): 1167
 Design Electrical Rating (MWe-Net): 1170
3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|-------------|------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>0.0</u> | <u>699.6</u> | <u>75,316.4</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>0.0</u> | <u>699.6</u> | <u>74,479.3</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWh) | <u>0.0</u> | <u>2,481,700</u> | <u>247,823,370</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>0.0</u> | <u>863,196</u> | <u>86,122,116</u> |
| 11. Net Electrical Energy Generated (MWh) | <u>0.0</u> | <u>799,354</u> | <u>82,236,205</u> |
| 12. Reactor Service Factor | <u>0.0%</u> | <u>32.0%</u> | <u>81.2%</u> |
| 13. Reactor Availability Factor | <u>0.0%</u> | <u>32.0%</u> | <u>81.6%</u> |
| 14. Unit Service Factor | <u>0.0%</u> | <u>32.0%</u> | <u>80.3%</u> |
| 15. Unit Availability Factor | <u>0.0%</u> | <u>32.0%</u> | <u>80.3%</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>0.0%</u> | <u>31.4%</u> | <u>78.0%</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>0.0%</u> | <u>31.3%</u> | <u>75.8%</u> |
| 18. Unit Forced Outage Rate | <u>0.0%</u> | <u>13.6%</u> | <u>4.8%</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):
Wolf Creek Generating Station returned on-line April 7, 1996, after Refuel VIII outage, a total of 65 days.
20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 4-9-96
TELEPHONE 316-364-8831

MONTH March, 1996

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0

17	0
18	0
19	0
20	0
21	0
22	0
23	0
24	0
25	0
26	0
27	0
28	0
29	0
30	0
31	0

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH March, 1996

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
3/1/96	0000	The unit remained in outage conditions throughout the month of March, 1996, as activities associated with Refuel VIII continued. The unit completed reloading fuel on March 16, 1996 in Mode 6. The unit entered Mode 5 at 1343 on March 20, 1996, and entered Mode 4 at 0313 on March 29, 1996.