

739 50

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE---PNO-V-85-09 Date: February 13, 1985

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Pacific Gas & Electric Co.
Diablo Canyon Unit 1
Docket No. 50-275
San Luis Obispo County, California

Licensee Emergency Classification
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: SAFETY INJECTION AND REACTOR TRIP

At 12:43 am (PDT) on February 13, 1985, a safety injection and associated reactor trip occurred, apparently due to a spurious high steam line differential pressure indication. The reactor was at 75% power for startup testing at the time of the event (incore flux mapping was in progress). Plant conditions were stabilized within 30 minutes. The reactor is currently being maintained in hot standby pending evaluation of the event and its cause. The licensee did declare this to be an "Unusual Event" at 12:50 am and terminated it at 1:18 am.

The licensee intends to issue a press release this morning. Region V does not, but will respond to any inquiries.

This information is current as of 10:00 am (PDT) on February 13, 1985.

CONTACT: R. T. Dodds
FTS 463-3720

M. Mendonca
(805) 595-2353

DISTRIBUTION

| | | | | | | |
|--------------------|------------------|----------------------|-----------------|---------------------|------------------|-----------|
| H St. <u>3:00</u> | MNBB <u>2:01</u> | Phillips <u>3:28</u> | E/W <u>2:02</u> | Willste <u>2:04</u> | Air Rights _____ | Mail: |
| Chairman Pallidino | EDO | NRR | IE | NMSS | | ADM:DMB |
| Comm. Zech | PA | | OIA | RES | | DOT:Trans |
| Comm. Bernthal | MPA | | AEOD | | | Only |
| Comm. Roberts | ELD | | | | | |
| Comm. Asselstine | | | | | | |
| SECY | | | | | | |
| ACRS | | | | | | |
| CA | | | | | | |
| PDR | | | | | | |

Regions: RI-3:49, RII-3:40, RIII-3:41, RIV-8:05
 INPO 11:23 NSAC 9:40
 Licensee: 11:21
 (Reactor Licensees)
 Resident Inspector 10:42

REGION V: FORM 211
(Revised 3/14/83)

8502250380 850213
PDR I&E
PNO-V-85-009 PDR

IE-34

011