



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 ■ PERRY, OHIO 44081 ■ TELEPHONE (216) 259-3737 ■ ADDRESS-10 CENTER ROAD

*Serving The Best Location in the Nation*  
PERRY NUCLEAR POWER PLANT

February 18, 1985  
PY-CEI/NRR-0150L

Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Additional Information  
on Containment Pressure  
Boundary Fracture Prevention  
(Confirmatory Issue 58)

Dear Mr. Youngblood:

This letter and its attachments are provided to address Confirmatory Issue 58 in Perry SSER/5 (Section 6.2.8), and to confirm that the lowest service metal temperatures of the reactor containment pressure boundary satisfy GDC 51.

Attachment 1 to this letter summarizes permissible lowest service metal temperatures for limiting components of the containment boundary. Material certifications are provided for limiting materials discussed. It is concluded that the permissible temperatures are satisfied under all conditions.

If you have any questions, please feel free to call me.

Very truly yours,

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:jj

DW94/M/1

Attachments

cc: Jay Silberg, Esq.  
John Stefano  
J. Grobe

8502250481 850218  
PDR ADUCK 05000440  
E PDR

Boo!  
1/1

TECHNICAL BASIS FOR PNPP  
COMPLIANCE WITH GENERAL DESIGN CRITERION (GDC) 51

Limiting ferritic materials in the Perry containment pressure boundary have been identified for compliance with GDC 51. Section 6.2.7 of the Standard Review Plan (NUREG-0800) provides the basis for making this determination. Two methods are described: (1) fracture toughness test in accordance with the ASME Code, or for materials not so tested, (2) correlate material properties to NUREG-0577 and determine lowest service temperature in accordance with referenced code provisions. Perry containment materials satisfy ASME Code criteria for impact testing. In addition, the more conservative method of correlation to NUREG-0577 yields acceptable results per Table 1.1.

The permissible temperatures in Table 1.1 have been determined for this evaluation in a manner not directly comparable to some values reported in the FSAR which are based on ASME required toughness tests.

The metallurgical characterization of these materials, when correlated with the data presented in NUREG-0577 and the Summer 1977 Addenda of the ASME Code Section III, provides the technical basis for the following determination of compliance.

Definition of Lowest Service Metal Temperature

Within the context of GDC-51 "lowest service metal temperature" is the limiting temperature which will be experienced by the materials of the containment pressure boundary when they are providing a pressure boundary during the performance of the containment function under operating, maintenance, testing and postulated accident conditions.

PLSMT = permissible lowest service metal temperature under conditions cited by GDC-51.

LSMT = Lowest service metal temperature postulated by design under conditions cited by GDC-51.

a. Containment Vessel/Equipment Hatch/Personnel Locks

(1) Containment Vessel; PLSMT = 50°F

SA 516 GR 70 4" thick shell inserts at penetrations is applied in the containment vessel. FSAR 3.8.2.6.1.2 presently identifies 50°F as the lowest service metal temperature anticipated. A more recent calculation is in close agreement (55°F). CMTR identifies the 4" material to have been normalized and tempered. S'77 Addenda Class 2 rules assign a Tndt of 0°F and a PLSMT of +50°F.

(2) Equipment Hatch/Personnel Air Locks; PLSMT = 55°F

The limiting material is identified as SA 516 GR 70 quenched and tempered, 6½" thick in the equipment hatch door flange. S'77 Addenda Class 2 rules assign a Tndt of -10°F and a PLSMT of +55°F to the material.

b. Penetrations

(1) Sleeves; PLSMT = +25°F (SA 333 GR 6); +30°F (SA 155 KCF 70)

SA 333 GR 6 normalized, 12-3/4" x 1" NW in Penetration #104 is identified as limiting. NUREG-0577 would categorize the material as C-Mn to which Table 4.4 would assign a (NDT + 1.3 σ) NDT of -5°F. S'77 Addenda Class 2 rules assign a PLSMT of +25°F.

SA 155 KCF 70 applying SA 516 GR 70, normalized, 1" NW, is identified (TYP) as applied in main steam penetration guard pipe. S'77 Addenda Class 2 rules assign a Tndt of 0°F and a +30°F PLSMT to the material.

(2) Process Pipe; PLSMT = 70°F

SA 106 GR B, 20" x S80 (1.031)" NW, normalized, applied in feedwater penetrations (P121 TYP) is identified as a limiting material. NUREG-0577, Table 4.4, via Fig. B-7, would assign a Tndt at or below the NDT of +40°F. Given a Tndt of 40°F, S'77 Addenda Class 2 rules assign a PLSMT of +70°F.

HPCS(E22) pressure boundary piping, SA 106 GR B:

12-3/4"x0.688" NW, N1698: NUREG-0577, Table 4.4 would assign a Tndt at or below the +40°F NDT. Assuming a +40°F Tndt, S'77 Addenda Class 2 rules assign a PLSMT of +70°F.

90° Ell, N1222 and N948: Ladish normalizes, and Crane mill practice discharges pipe to cooling, at 1650°F. Both materials are assumed normalized. NUREG-0577, Table 4.4, would assign a Tndt at or below the +40°F NDT. Assuming a +40°F Tndt, S'77 Addenda Class 2 rules assign a PLSMT of +70°F.

Sch 100 pipe, N1032: Phoenix Steel pipe mill practice discharges pipe to cooling beds above the A<sub>3</sub> temperature. The material is assumed normalized. NUREG-0577, Table 4.4, would assign a Tndt at or below the 40°F NDT. Assuming a +40°F Tndt, S'77 Addenda Class 2 rules assign a PLSMT of +70°F.

Sch 80 penetration process pipe, SA 106 B: see N1698 above.

(3) Flued Head Closure; PLSMT = +35°F

Limiting material applied in flued head closures is identified as SA 105, normalized, 3" design axial thickness, of feedwater penetrations (P121 TYP). NUREG-0577, Table 4.4, assigns a (NDT + 1.3σ) NDT of -5°F. Assuming a Tndt of -5°F, S'77 Addenda Class 2 rules would assign a PLSMT of +35°F to the material.

(4) Flat Plate Closure; PLSMT = +30°F

The limiting material applied in flat plate closures is identified as SA 516 GR 70, 3/4" thick, normalized, to which S'77 Addenda Class 2 rules assign a Tndt of 0°F and a PLSMT of +30°F.

c. Main Steam/Main Feedwater System Piping

The main steam/main feedwater system piping between containment penetrations and isolation valves are pipe spool pieces, including no fittings, procured to SA 106 GR B as addressed in Item b (2) above.

d. Isolation Valves

(1) Main Steam Isolation Valves (26" SN 5-560 TYP);

Body: SA 216 GR WCB normalized and tempered, 1-15/16" min. design wall. NUREG-0577, Table 4.4, assigns a PLSMT=65°F (NDT + 1.3 σ) NDT of +57°F and a NDT of +35°F to the material as identified for 2½"-5" thick. material. Given its 1-15/16" thickness, the Tndt of the material should lie in that population below the 35°F NDT. Assuming a Tndt of +35°F, S'77 Addenda Class 2 rules would assign a PLSMT of 65°F to the material.

Poppet: SA 350 GR LF 2, quenched and tempered, 6-1/8" min. design wall. NUREG-0577 would categorize the material as C-Mn, comparable to SA 105. NUREG-0577, Table 4.4, assigns a NDT of -28°F to normalized material. The Tndt of quenched and tempered material can be expected to lie in the population below -28°F. Assuming a Tndt of -28°F, S'77 Addenda Class 2 rules would assign a PLSMT of +34°F to the material.

Cover: SA 105, quenched and tempered, 5-15/16" min. design thickness. The analysis applied for the poppet would assign a PLSMT of +32°F to the material.

Bolting: Studs: SA 540 GR B23 Class 5  
Nuts: SA 540 GR B23 Class 5  
NUREG-0577, Table 4.6 categorizes this material as having least susceptibility to brittle failure.

(2) Main Feedwater Isolation Valve (Borg-Warner SN 51691);

Body: SA 216 GR WCB (Pacific Metals) annealed (5 hrs. @ 900°C + F.C.): 3.11" min. wall.  
PLSMT=120°F NUREG-0577, Table 4.4, assigns a (NDT + 1.3 σ) NDT of +57°F to 2½"-5" A 216, normalized and tempered. Since, however, the material in question was annealed its Tndt would be expected to be higher. Steel Castings Handbook data indicate an approximate 40% difference in Cv energy between normalized and annealed A 216 WCB. Assuming a comparable degradation in Tndt and a (NDT + 1.3 σ) NDT of +57°F (from NUREG-0577, Table 4.4) an estimated Tndt of +80°F is assigned to the annealed SA 216 GR WCB. On this basis, S'77 Addenda Class 2 rules would assign a PLSMT of +120°F to the material.

Retainer: SA 105, normalized 2" thick. NUREG-0577, Table 4.4, assigns a (NDT + 1.3 σ) NDT of -5°F. S'77 Addenda Class 2 rules assign a PLSMT of 25°F.  
PLSMT=25°F

Bonnet: SA 216 GR WCB (Pacific Metals) annealed (5 hrs. @ 900°C + F.C.): 3.083" min. wall. A PLSMT of +120°F is assigned to the material on the basis of the analysis for the body.  
PLSMT=120°F

(3) Main Feedwater Isolation Check Valve (1B21-F032B);

Body: SA 216 GR WCC, normalized, 1.89" min. design wall. NUREG-0577, Table 4.4, based on Fig. B-2 data, would assign a Tndt in the population at or below the NDT of +35°F for 2½"-5" thick material. Given a Tndt of +35°F, S'77 Addenda Class 2 rules would assign a PLSMT of +65°F.  
PLSMT=65°F

Cover: SA 105, normalized and tempered, 3.23" thick. NUREG-0577, Table 4.4, assigns a (NDT + 1.3 σ) NDT of -5°F. S'77 Addenda Class 2 rules assign a PLSMT of +35°F.  
PLSMT=35°F

Disc: Not containment pressure boundary.

---

\* Steel Castings Handbook, Fourth Edition, Steel Founders' Society of America, p. 489.

(4) HPCS Isolation Valve (1E22-F004);

Body: SA 216 WCB by Vulcan Steel Foundry: normalized, .97" min. design wall. NUREG-0577, Table 4.4, would assign a -6°F Tndt for 1" material. Given a Tndt of -6°F, S'77 Addenda Class 2 rules would assign a PLSMT of +24°F.  
PLSMT=24°F

Bonnet: SA 216 WCB by Vulcan: normalized, 2" min. design thickness. NUREG 0577, Table 4.4, would assign a 35°F Tndt. S'77 Addenda Class 2 rules would assign a PLSMT of +65°F.  
PLSMT=65°F

Disc: SA 216 WCB: normalized, 1-3/8" min. design thickness. Analysis for bonnet applies.

Bolting: A 193 B7 studs, SA 194-2H nuts: NUREG-0577, Table 4.6, categorizes these materials as having least susceptibility to brittle fracture.

CMTR's are attached for items discussed above; page numbers in the lower right hand corner are keyed to section numbers above:

	<u>Pages</u>
Containment vessel shell inserts	a(1)-1,2
Equipment hatch door flange	a(2)-1,2,3
Penetration sleeves: P104	b(1)-1,2,3
P122	b(1)-4,5,6
Process pipe: feedwater	b(2)-1,2
HPCS	b(2)-3,4,5,6
Flued head closure	b(3)-1,2
Flat plate closure	b(4)-1,2
MSIV	d(1)-1 through 11
Feedwater isolation valve (SN 51691)	d(2)-1 through 6
Feedwater isolation valve (1B21-F032B)	d(3)-1,2,3
HPCS isolation valve (1E22-F004)	d(4)-1 through 9

DW94/M/7/kaw

TABLE 1.1 - SERVICE TEMPERATURE VS LOWEST PERMISSIBLE TEMPERATURE

<u>Containment Vessel</u>	<u>PLSMT</u> <sup>(1)</sup>	<u>LSMT</u>	<u>Remarks</u>
1. Containment vessel (FSAR 3.8.2.6.1.2)	50°F	55°F	Minimum calculated annulus temperature.
2. Equip. Hatch/Pers. Air Locks (FSAR 3.8.2.6.1.2e)	55°F	55°F	
<u>Penetrations</u>			
1. Penetration sleeves (FSAR 3.8.2.6.1.2c)	30°F 25°F	55°F	
2. Feedwater pipe HPCS pipe	70°F 70°F	(2) 82°F	(3)
3. Flued head closures	35°F	55°F	
4. Flat plate closures	30°F	55°F	
<u>Isolation Valves</u>			
1. Main Steam Isolation Valves	65°F 34°F 32°F	100°F	System hydrotest
Feedwater Isolation Valves:			
2. 1B21F065A&B (gate)	120°F	130°F	All operating conditions(4)
3. 1B21F032A&B (check)	65°F 35°F	130°F	All operating conditions; 10 year hydro @ 120°F
4. High Press. Core Spray	65°F 24°F	82°F	(3) (3)

(1) PLSMT = permissible lowest service metal temperature. LSMT = design minimum service metal temperature.

(2) 100°F inboard of maintenance isolation valves 1N27F560A&B, 130°F outboard excepting 10 year hydros at 120°F.

(3) FSAR Table 3.11-3, minimum under pressurized conditions in Zone AB-8.

(4) At or above 130°F before valve is subjected to 20% of hydro test pressure per Figure 3.4.6.1-1 in technical specifications. Valves will be ASME XI hydro tested at or above 120°F.





ITEM NO.	QTY REQD	PART NO.	DESCRIPTION	MATERIAL	GRADE / TYPE	HEAT NO.	SLAB NO.	LOT NO.	BATCH NO.	INSTRUMENT
1	6	33368-1	7x9x60° COLLAR SEGMENTS	SA-516	GR70	D3078	1	A20948-3		338
2	8	33368-2	PLATE - SEGMENT-45°	SA-516	GR70	D3062	3	A20948-2		338
3	1	33368-3	DOLLAR PLATE	SA-516	GR70	D3062	3	A20948-1		338
5	2	33368-5	R 12"x1"x2'-0"	SA-516	GR70	53219	7-2	A22658-2		338
6	2	33368-6	R 8"x2 1/4"x1'-7 1/8"	SA-516	GR70	A5034	2	A20952-5		338
7	2	33368-7	R 8"x2"x2'-3 1/2"	SA-516	GR70	A5034	2	A20952-5		338
9	4	33368-9	R 12"x1"x1'-0"	SA-516	GR70	D3062	3	A20952-4		338
10	1	33368-10	R 10"x1/2"x0'-11"	SA-516	GR70	B0999	3A	A22978-5		338
11	4	33368-11	R 8"x3/4"x0'-9 1/4"	A-36	—	12773		A18822-3		338
12	2	33368-12	R 9 1/4"x3/4"x0'-9 1/4"	A-36	—	12773		A18822-3		338

MURDOCK, INC.  
DRAWING CONTROL  
DIVISION II  
COPY NO. 3  
DATE 5-9-78

EFFECTIVITY  
3-1671-03  
J/S WOL

NUCLEAR

COMPLETED DRAWING REVIEWED  
AND ACCEPTED BY: Woolley 5478  
QUALITY ENGR

THIS DWG FORMS PART OF THE AS CONSTRUCTED DRAWING

DRAWN: D. Woolley DATE: 5-4-78  
NEXT: ASBY  
UNLESS OTHERWISE SPECIFIED  
DIMENSIONS APPLY AFTER PLATING  
REMOVE ALL BURRS  
BREAK ALL SHARP EDGES 50S-010  
TOLERANCES: DECIMALS ± .005  
                  DECIMALS XX ± .002  
                  DECIMALS XXX ± .001  
                  ANGLES ± .5

MURDOCK, INC.

15000 So. Avalon Compton, California 90220 Phone 376-022 (213)

NAME: BILL OF MATL, HATCH COVER  
S/N 33366  
CUSTOMER: WOOLLEY NUMBER: ACD-33368 REV: N/C  
JOB NO: 3-1671 SCALE: NONE SHEET 1 OF 1

ACD-33368

0(2)-1

KAISER STEEL CORP.  
FABR. DIV., PUR. AGENT  
P.O. BOX 95  
FONTANA, CALIF. 92335

CONSUMER SERVICE DEPARTMENT

COASTVILLE, PA. 15302  
**TEST CERTIFICATE**

DATE: **6-7-76** FILE # **4205-02-01**  
CONDITIONS  
KAISER STEEL CORP.  
PLANT #1  
13032 SLOVER AVE.  
KAISER, CALIF.

WILL ORDER NO.  
70666-1

CUSTOMER P.O.  
45131201

MP 6376 DD  
1/14

*A. J. Gilmore*

ALL TESTS WERE MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATIONS

Revised Copy 3-29-77

SA-516 GR. 70 ASME CODE SECT. II & III SUB. NE 1974 EDITION THRU SUMMER 1974 ADDENDUM 1 & 1977  
N-1160 8/4/78

WELD TEST O.K. HOMOGENEITY TEST

**CHEMICAL ANALYSIS**

WELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	XXR	XXR	GRAIN	BASIC PROC.	
														SIZE		
03078	26	1.14	.012	.005		.22								VIP STEEL	7-8	ELEC

Please destroy other test report previously sent.  
This is a revised copy.  
Reason: Added decimal points and mercury clause per customer request.

**MURDOCK INC.**  
LOT # A20948-3  
JOB # 4191 2-1671-01  
DATE 3-9-77

**PHYSICAL PROPERTIES**

WELT NO.	SLAB NO.	YIELD STRENGTH	TENSILE STRENGTH	% ELONG. IN 2"	% RA	ENH	IMPACTS			FRACTURE APPEARANCE & SHEAR	DESCRIPTION
							V 0°F.				
03078	1	590 595	815 805	30 29			T 43	42	42	40-40-40	1- 7" x 102 x 132
							L110	108	110	90-90-90	
							LATERAL EXPANSION IN INCHES				
							T.038	.037	.038		
							L.086	.088	.087		

Mercury or mercury compounds are not used in the manufacture of Luken's products.

PLATE AND TESTS HEATED TO 1625°F./1675°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED, THEN TEMPERED 1200°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED.

TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100°F. PER HR. TO 1100°F./1150°F., HELD 30 HRS. AND FURNACE COOLED WITHIN A RATE OF 100°F. PER HR. TO 800°F.

**NUCLEAR**  
M.I.R. REVIEWED AND ACCEPTED  
4-12-77

1312  
224

*A. J. Gilmore*

**KAISER  
STEEL**

METAL PRODUCTS DIVISION  
P O BOX 65 © FONTANA CALIFORNIA 92331  
TELEPHONE 825 3350

CERTIFICATE OF COMPLIANCE

December 22, 1976

Job 1312, Murdock, Inc. M-14453.

We hereby certify that all heat treating performed by KAISER STEEL CORP. on above work order was in accordance with ASME Code, Section III, 1974 Edition, Summer 1974 Addenda, Class IIC, Subsection NE and Job 1312 Normalizing Procedure - revised 8-18-76.

KAISER STEEL CORP.  
Metal Products Division

*Gregory Shepherd*  
Gregory Shepherd, Inspector  
Fontana Plate Fabricating.

2-10-77

INTEGRAL EAR

MURDOCK INC.	
LOT #	<u>A20940-3</u>
JOB #	<u>WOL 3-1671-01</u>
DATE	<u>2-9-77</u> (M/8)

EC 324 6 PCS  
D.3078-1 Part I  
a(2)-3

12/11/69

P104



Newport News Industrial Corporation  
Subsidiary of Newport News Shipbuilding  
Atlantic City

SHIP-01  
INSPEC.  
REPORT

DATE INSPECTION OF MATERIAL LISTED COMPLETED AND RECEIVED FOR SHIPMENT				<input checked="" type="checkbox"/> COMPANY FURN. MAT'L.	Q. NO. 5025-A	INSPECTION DATE 11-30-77	11-30-77
CR. NO.	PRG. ITEM	MAT. ITEM	QTY	DESCRIPTION	<input type="checkbox"/> CUSTOMER FURN. MAT'L.		
					<input type="checkbox"/> OTHER		
				<b>Assy 99-1 Six Sleeve Penetration Assy Special - Unit #1 Containment Vessel</b>			
				<b>249752 Rev. A-3</b>			
				<b>16 NNI 359</b>			
			1	2 Sleeve Steel See Assy 90 Dwg. 249703			
				<b>6 NNI 310</b>			
			2	2 Sleeve Steel See Assy 88 Dwg. 249703			
				<b>6 NNI 240</b>			
			3	1 Sleeve Steel See Assy 95 Dwg. 249703			
				<b>16 NNI 326</b>			
			4	1 Insert Plate 1 1/2"			
				<b>6 NNI 396</b>			
			5	1 Reinf Penetration Assy. see assy Dwgs. 249721 Rev. A-3 see assy 92 Dwg. 249703 Rev. B-3			
			16	6 Half Couplings			
				<b>249703 Rev. B-3 I 537</b>			

RECEIVED CENTER  
FILE COPY

MANUFACTURE CERTIFICATION

MANUFACTURE CERT.

INSPECTION RECORDS

EQUIPMENT HISTORY

OTHER IDENTIFYING INFORMATION

APPLICABLE SPECIFICATIONS

INSPECTOR: *CLARENCE HARRIS*

DATE: *11-30-77*

BY: *W.D. Long*

DATE: *1-2-78*

APPROVED INSPECTOR: *N/A*

SHIP. NO. 5025-A-2  
SHEET 2 OF 9

6(1)-1

# INFORMATION ONLY




## Capitol

PIPE & STEEL PRODUCTS CO.

DIVISION OF FAS INTERNATIONAL, INC.

301 CITY LINE AVENUE • AREA CODE 215 • TE 9-4300  
BALA-CYNWYD, PENNSYLVANIA 19004



### CAPITOL PIPE CERTIFICATE OF COMPLIANCE

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS) NUMBER N-936

EXPIRATION DATE: JANUARY 6, 1978

MATERIAL: 12-3/4" OD X SCH 120 ASME SA-333 GR-6.

HEAT NO: 65326

MANUFACTURER: PHOENIX STEEL CORP.

76NDW1310  
OK TO SPEC  
8/17/76  
DO NOT ACCEPT  
SHEET 1 OF 3

This Certification affirms that the content of the attached report (s) is correct and accurate and that all test results and operations performed are in compliance with the below listed Specifications:

- 1) ASME Code Section II 1974 Edition including addenda through Summer 1974.
- 2) ASME Code Section III 1974 Edition including addenda through Summer 1974 for Class MC Materials.

REFERENCE:  
NEWPORT NEWS P.O.# 50256A-64  
CAPITOL S.O.# PN-2477-A  
ITEM# 1

23 July 77  
Murray Herbert Feldman

N. N. I. C. 356  
RECORD CENTER  
FILE COPY

QUALITY ASSURANCE

QUALITY ASSURANCE

Newport News Ind.  
P.O. 5025-A-64  
S.O.# PN-2477-A  
Ch# N-00943

Item# 1

PHOENIX STEEL CORPORATION

INFORMATION ONLY

TUBE DIVISION  
PHOENIXVILLE, PENNA.

CERTIFICATE OF INSPECTION AND TESTS

12" 5/120 SA 6

DATE: 6-14-75	DATE SHIPPED: 6-10-76	MILL ORDER NO. T-8986-C (54D)
S O L D T O	Capitol Pipe & Steel Prod., Inc. Div. of FAS International, Inc. P. O. Box 471 Bala Cynwyd, Pa. 19004	CUSTOMER ORDER NO. 77653-00
		CAR NO. RDG 38869
		MATERIAL: SEAMLESS <input type="checkbox"/> PIPE <input type="checkbox"/> TUBE, HOT FINISHED
S H I P T O	7ENN1310	N. N. I. C. 286
	ASTM A-333-75 Gr. 6, ASME SA-333 Gr. 6 (O.H.)	

RECORD CENTER  
FILE COPY

NO. PCS. 00	WALL THICKNESS 12.750" x 1.000"	LENGTH	TOTAL FT.	TOTAL WT.	HEAT NO. 65326
-------------	---------------------------------	--------	-----------	-----------	----------------

Longitudinal Vee Notch Charpy at minus 50°F. (10mm x 10mm)  
 Foot lbs. 100-46-28  
 Lateral Expansion .096 - .040 - .030  
 Percent Shear 50-30-20

HEAT NO.	C	Mn.	P.	S.	Si.	Cu.	Ni.	Cr.	Mo.	V.
65326	.11	1.00	.011	.027	.18					
65326	.14	.98	.011	.028	.19					
65326	.11	.98	.012	.029	.18					

Ladle Analysis  
Product Analysis  
Product Analysis

OK TO  
SIGN  
Handwritten signature and date 8-17-76

SHEET 3 OF 3

HEAT NO.	TENSILE (KSI)	YIELD (KSI)	% ELONG. IN 2"	% RA	ROCKWELL HARDNESS	BRINELL	GRAIN SIZE
65326	62.5	46.0	36.00				

Normalized. Equalized at 1650°F. plus 25°F. minus 0°F. Held for 1 hour and air cooled. (.505" Test Specimen)

SWORN TO AND SUBSCRIBED BEFORE ME THIS 14TH DAY OF JUNE 1976.

MAURICE V. LEWIS, Notary Public  
PHOENIXVILLE BOROUGH, CHESTER COUNTY  
MY COMMISSION EXPIRES OCT. 29, 1979

JOINT DISTANCE - 16TH		ROCKWELL C		FLATTLING		HYDROSTATIC PSI	
1	2	4	6	8	10	12	14
						OK	
							2800

THE PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY'S RECORDS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PRESCRIBED BY SAID SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. BASED UPON SUCH INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATION.

Handwritten signature  
ENGINEER OF TESTS



**Newport News Industrial Corporation**  
 Subsidiary of Newport News Shipbuilding  
 A Tenneco Company

P122

**SHIP-OUT  
 INSPECTION  
 REPORT**

FINAL INSPECTION OF MATERIAL LISTET HAS BEEN COMPLETED AND IS RELEASED FOR SHIPMENT				<input checked="" type="checkbox"/> COMPANY FURN. MAT'L <input type="checkbox"/> CUSTOMER FURN. MAT'L <input type="checkbox"/> OTHER	I.D. NO. <b>5025-A</b>	P.O. NO. <b>212-20</b>
DES. NO.	QTY	DESCRIPTION	INSPECTION DATE	DATE		
<b>24975Y</b>	1	<b>AB499-1 Gasket Penetration Assy. Course #7</b>				
<b>REV. B-2</b>	1	<b>Notes: CONTAINMENT HOSELINE consisting of</b>				
<b>75WJ5E7</b>	2	<b>Shell Plate</b>				
<b>76WJ242</b>	4	<b>Sleeves on Day 24975 Rev. B-2 Gasket</b>				
<b>DRL</b>						
<b>249703</b>	16	<b>HMF COUPLING</b>				
<b>REV. B-3</b>						
<b>77WJ577</b>						

AUG 29 1977

**N. N. I. C.  
 RECORD CENTER  
 FILE COPY**

THIS COMPLETES (PARTIALLY COMPLETES) \_\_\_\_\_ REV. \_\_\_\_\_  
 THIS CLEARS (PARTIALLY CLEARS) NR \_\_\_\_\_ DATED \_\_\_\_\_

APPLICABLE INSPECTIONS	APPLICABLE DATA
EACH CHECKED INSPECTION HAS BEEN PERFORMED ON EACH ITEM LISTED ABOVE <b>VISUAL INSPECTION</b> <input type="checkbox"/> MARKING <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> CLEANLINESS <input type="checkbox"/> GRADE _____ <input type="checkbox"/> AS REC'D FOR SHIP/OUT <input type="checkbox"/> PRM. CLEAN TAG. <input type="checkbox"/> PLUG WARNING TAG <b>DIMENSIONAL INSP.</b> <input checked="" type="checkbox"/> WELD PREP <input checked="" type="checkbox"/> OVERALL	<b>DOCUMENTATION</b> <input type="checkbox"/> MANUFACTURE CERT. <input type="checkbox"/> SHIPPING PAPERS <input type="checkbox"/> EQUIPMENT HISTORY OTHER (SPECIFY) _____ <b>SHIPPING TRANSPORTATION</b> <input type="checkbox"/> _____ <input type="checkbox"/> _____
	<b>ENGINEERING INSTRUCTION</b> <b>REV.</b> <b>QA INSPECTOR</b> <b>CUSTOMER INSPECTOR</b> <b>AUTHORIZED INSPECTOR</b>
	<b>SHIPPED TO</b> <b>ENGINEERING INSTRUCTION</b> <b>REV.</b> <b>DATE</b>
	<b>DATE</b> <b>DATE</b> <b>DATE</b>

**DISTRIBUTION:**  
 1. Record Center NNF  
 1. J.H. Brown #10



# INFORMATION ONLY

**PURCHASER:**

3 • NEWPORT NEWS INDUSTRIAL CORP.  
 QUALITY ASSURANCE MANAGER  
 12388 WARWICK BLVD.  
 NEWPORT NEWS, VA. 23606

**LUKENS STEEL COMPANY**

COATESVILLE, PA. 19320

**TEST CERTIFICATE**

DATE: 7-16-76

FILE NO 7791-04-01

CONSIGNEE:

MILL ORDER NO.

70941-2

CUSTOMER P.O.

5025-A-63

MP 71076 DM  
5/21

THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATIONS

SA-516 GR. 70 S5 ASME CODE SECT. II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA  
 N-1160 8/4/78 MOD. FOR IMPACTS

BEND TEST O.K. HOMOGENEITY TEST

SHEET #1 OF 2

**CHEMICAL ANALYSIS**

MELT NO.	C	MN	P	S	CU	SI	N	CR	MO	V	Ti	AL	B	GRAIN SIZE
C6894	22	93	012	018		21								7-8
D2977	21	1.07	012	017		25								7-8
A4859	24	1.04	004	021		25								7-8
D3161	22	1.00	009	020		23								7-8
C913	21	1.04	012	020		21								7-8
D3163	22	1.04	007	020		24								7-8

RECORD CENTER  
 N. N. I. C.  
 FILE COPY

CK TO REC.  
 [Signature]  
 8-4-76  
 SHEET 1 OF 2

**PHYSICAL PROPERTIES**

MELT NO.	SLAB NO.	YIELD PSI @100	TENSILE PSI @100	% ELONG. IN 8"	% R.A.	BHN	IMPACTS LV OFF.	FRACTURE APPEARANCE	DESCRIPTION	ITEM #
C6894	11B	450	743	27			71 70 72	70-70-70	1- 1-1/2" X 90 X 205 76NNI238	2
D2977	7U	452	755	30			.069 .066 .068	70-70-70	1- 1-1/4" X 60 X 188 76NNI239	3
A4859	3T	456	780	28			.066 .067 .064	50-50-50	1- 1-1/8" X 60 X 225 76NNI240	4
D3161	7A	515	736	29			58 60 56	70-70-70	1- 1" X 90 X 366 76NNI241	5
							.052 .055 .051			
							70 70 66			
							.062 .066 .065			

We hereby certify the above information is correct.

SUPERVISOR TESTING

[Signature]

b(1)-5

# INFORMATION ONLY

PURCHASER:  
 NEWPORT NEWS INDUSTRIAL CORP.  
 NEWPORT NEWS, VA. 23606

## LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

### TEST CERTIFICATE

DATE: 7-16-76

FILE NO: 7791-04-01

CONSIGNEE:

MILL ORDER NO.  
70941-2

CUSTOMER P.O.  
5025-A-63

5/22

THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S):

SAME

BEND TEST O.K. HOMOGENEITY TEST

SHEET #2 OF 2

### CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	TI	A	B
<div style="border: 1px solid black; padding: 10px; display: inline-block;"> <p style="margin: 0;">N. N. I. C. 269                      RECORD CENTER                      FILE COPY</p> </div> <div style="border: 1px solid black; padding: 10px; display: inline-block; margin-left: 20px;"> <p style="margin: 0; text-align: center;">OK TO SPEC  <i>Handwritten Signature</i> 8-4-76                      NOT ACCEPTED                      SHEET 2 OF 2</p> </div>													

### PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 8"	% R.A.	BHN	IMPACTS LV 0°F.			FRACTURE APPEARANCE	DESCRIPTION	ITEM #
C6894	13T	493	732	26			71	70	70	70-70-70	1- 1" x 60 x 341 76NN1242	6
							LATERAL EXPANSION IN INCHES .066 .057 .066					
C6913	16B	521	768	27			80	78	80	80-80-80	1- 1" x 92 x 247 - 76NN1243	7
							LATERAL EXPANSION IN INCHES .076 .075 .077					
D3168	3F	500	755	24			86	88	88	90-90-90	1- 3/4" x 90 x 240 76NN1244	8
							LATERAL EXPANSION IN INCHES .086 .085 .084					
PLATES AND TESTS NORM. 1625-1675°F., HELD 1/2 HR. PER INCH MIN. AND AIR COOLED.												

We hereby certify the above information is correct.

SUPERVISOR TESTING

*F. St. Line*



CERTIFICATE OF TEST ON PIPE MATERIAL

SUPPLEMENTARY REPORT

3/10/77

*Cameron*

IRON WORKS, INC.

P. O. BOX 1212  
HOUSTON, TEXAS 77001

PULLMAN KELLOGG  
POWER PIPING  
P. O. BOX 1007  
WILLIAMSPORT, PA 17701

Date 24 May 1977

C. I. W. Order No. 8405-163 C. I. W. Order No. F-9053 Specification ASME SA106 Gr. B Sec. III Class I with Kellogg Spec. IV-18; IV-33 & VIII-1 W/ Impacts at +30°F.

Description of Material O.D. 20" I.D. \_\_\_\_\_ WALL SCH. 80

C. I. W. Part No. 86-9053-200-180

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS)  
NO. N-1261 EXPIRES 10-27-78.

Heat No.	Location of Serial No.	CHEMICAL ANALYSIS							
		C	MN	P	S	SI	CR	NI	MO
<u>L 3768</u>		.24	.89	.025	.025	.27			

PULLMAN KELLOGG  
QUALITY ASSURANCE  
CMTR APPROVED  
6/1/77 BY JM  
6/8/77 BY JTB

THIS MATERIAL CERTIFIED TO  
1974 ASME CODE,  
6/75 ADDENDA,  
SECTION II  
PULLMAN KELLOGG  
QUALITY ASSURANCE DEPARTMENT  
BY: JM DATE: 6/1/77

Quantity or Serial No.	Heat No.	Test Loc.	MECHANICAL PROPERTIES							V-Notch Impact +30° Ft.Lbs. Lat.Exp. %D/
			Tensile PSI	.2 % Offset Yield PSI	% Elong. 2 in.	% Red. Area	Test Lot#	Flaw Detection Test		
3	<u>L 3768</u>	rans.	74,900	41,700	28.1	53.3	* 957	OK	65.0 ✓ 59 ✓ 71LS 72% 64.0 ✓ 54 ✓ 58 56.0 ✓ 50 ✓ 58	

Tensile specimen size:  
.505

Each length of pipe 100% ultrasonically inspected in accordance with CIW PU-41 W/Add. #9053 and found acceptable. Report attached.

\* IMPACT SPECIMENS WERE REMOVED AXIALLY WITH CENTER AXIS 1/4 T FROM O.D. & NOTCHED RADially.

Forging Ser. #	Test Lot#
22387	957
28583	957
28590	957

Hydrostatic Test: Each length of pipe hydrostatically tested at 1900 psi f. - 5 sec. and found acceptable

Heat Treatment: 1550°F. held 1 hr. at temp. Air cooled.


Heat Treat Charts attached.

Subscribed and sworn to before me this  
24th Day of May 1977

Notary Public

I certify these tests to be correct as contained in the records of the company.

Metallurgical Representative H. D. WRIGHT, Int



02-NT677

CERTIFICATE OF INSPECTION AND TESTS

\*\*SUPPLEMENTARY COPY 11-18-77

DATE: 11-7-77	DATE SHIPPED: 11-7-77	MILL ORDER NO. T-3876-A2	SHIPPING LIST # 19
Standard Pipe & Supply Co., Inc.		CUSTOMER ORDER NO. 307 ADD#1	
		CAR NO.	
Pullman-Power Products		MATERIAL: SEAMLESS <input checked="" type="checkbox"/> PIPE <input type="checkbox"/> TUBE, NOT FINISHED	
		SPECIFICATION: ASME SA-106-B F.G. (O.H.) NORM.	

NO.	PCS.	OD	WALL	LENGTH	TOTAL FT.	TOTAL WT.	HEAT NO.
		12.750"	x .688"				57016
Longitudinal Vee Notch Charpy at Plus 30°F. (10mm x 10mm)							35-37-49 ft.lbs.
**LATERAL EXPANSION				**PERCENT SHEAR			
.037-.037-.046				30-30-40			

HEAT NO.	C	Mn.	P.	S.	Si.	Cu.	Ni.	Ca.	Mo.	V.
57016	.22	.75	.012	.025	.23					
57016	.23	.81	.012	.025	.24					
57016	.23	.79	.012	.026	.23					

INFORMATION ONLY

CEI  
PNPP  
1 OF 2  
P-1314L

HEAT NO.	TENSILE (KSI)	YIELD (KSI)	% ELONG. IN 2"	% RA	ROCKWELL	HARDNESS BRINELL	GRAIN SIZE
57016	71.6	43.0	48.00			Normalized at 1650°F	

THIS MATERIAL CERTIFIED TO  
 1974 ASME CODE  
 6/75 ADDENDA SECTION II  
 PULLMAN POWER PRODUCTS  
 QUALITY ASSURANCE DEPARTMENT

PULLMAN POWER PRODUCTS  
 QUALITY ASSURANCE  
 CNTR APPROVED  
 11/21/77 BY [Signature]  
 11/21/77 BY [Signature]

DOCUMENT REVIEWED  
 BY 8202  
 PNPP  
 GAI/QA

JOURNEY DISTANCE	1631	FLATTENING	OK	HYDROSTATIC PSI	2300							
1	2	4	6	8	10	12	14	16	20	24	28	32

THE PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY'S RECORDS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PRESCRIBED BY SAID SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. BASED UPON SUCH INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATION.

*A. W. Beckwith*  
 ENGINEER IN CHARGE

# LADISH CO.

CUDAHY • WISCONSIN • 53110

Pullman Kellogg  
Tower Piping  
P.O. Box 1007  
Williamsport, PA 17701

CE N1209

## METALLURGICAL MATERIAL ANALYSIS REPORT

CUSTOMER ORDER NO. **34-N1222** LADISH ORDER NO. LADISH INVOICE NO.  
 \*SHIP TO CUSTOMER'S ADDRESS AND ORDER WILL BE IN C.M.A. ET.  
**REVISED REPORT 8-18-77**  
 DATE SHIPPED **6-23-77** DATE OF REPORT **8-29-77**

ITEM	PCS.	SPECIFICATION	DESCRIPTION	CODE	HEAT NO.
5	2	ASME SA234 WPB Per*	12 X 6 S/100 90 LR RED EL	YK31G	168652
C	.27	Mn 1.50 P .008 S .010 Si .16 Ni Cr Mo Cu V N	YIELD KSI 48.4	ULTIMATE KSI 71.5	% EL. 36 % RED.

ASME Section III Class 2 1974 Edition thru Winter 1975 Addenda in addition PK IV 26 Rev. 8-12-76 and PK IV-33 Rev. 11-16-76. Ser. #'s 884 & 885.

CE N1213

ITEM	PCS.	SPECIFICATION	DESCRIPTION	CODE	HEAT NO.
5	1	ASME SA234 WPB Per*	24 X 16 STD RED TEE	VL3GT	168652
C	.23	Mn .89 P .005 S .019 Si .18 Ni Cr Mo Cu V N	YIELD KSI 45.4	ULTIMATE KSI 69.9	% EL. 33 % RED. 54

ASME Section III Class 2 1974 Edition thru Winter 1975 Addenda in addition PK IV-26 Rev. 8-12-76 and PK IV-33 Rev. 11-16-76. Ser. #882.

CE N1222

ITEM	PCS.	SPECIFICATION	DESCRIPTION	CODE	HEAT NO.
8	9	ASME SA234 WPB Per*	12 S/60 90 LR EL	YK31G	168725
C	.24	Mn .87 P .008 S .014 Si .19 Ni Cr Mo Cu V N	YIELD KSI 45.7	ULTIMATE KSI 70.2	% EL. 33 % RED. 87

ASME Section III Class 1 1974 Edition thru Winter 1975 Addenda in addition PK IV-20 Rev. 8-12-76 and PK IV-33 Rev. 11-16-76. Ser. #'s 887 thru 895.

### INFORMATION ONLY

ITEM	CHARPY (SIZE)	V NOTCH	TEMP. °F	FOOT POUNDS	% SHEAR	LATERAL EXPANSION
8	10 X 10 X 8		+30	86 - 84 - 98	72 - 55 - 72	.074 .070 .050

PULLMAN POWER PRODUCTS  
QUALITY ASSURANCE  
CMTR APPROVED  
7/16/77  
7/28/77 BY *JO*

ALL STARTING MATERIAL CONFORMS TO CHEMICAL ANALYSIS REQUIREMENTS OF ASME SA106 Gr. B Pipe.  
 ALL FITTINGS HAVE A MAXIMUM HARDNESS OF 71281/77 BY *JO*  
 FITTINGS CONFORM TO THE REQUIREMENTS OF MSS-SP-75

ITEM	TENSILE SPECIMEN
6043	STD. RD.
	FULL SEC.
5	STRIP
ITEM	HEAT TREATMENT
5	NOT REQUIRED
	STRESS RELIEVE
6048	NORM 1650 °F
	NORM 1750 °F
	TEMPER 1300 °F
	WATER QUENCH 1650 °F
	TEMPER
	WATER QUENCH 1650 °F
	TEMPER 1200 °F

THIS MATERIAL CERTIFIED TO ACCEPTED PER  
 WELDING RADIOGRAPHICALLY INSPECTED  
 1974 ASME CODE  
 FITTINGS CAPABLE OF CONFORMING TO HYDROSTATIC TEST REQUIREMENTS  
 SECTION II  
 PULLMAN POWER PRODUCTS  
QUALITY ASSURANCE DEPARTMENT  
 BY *jm* DATE 7/16/77

DOCUMENT REVIEWED  
BY 8202 PNPB GAI/QA

NOTES: I hereby certify that to the best of my knowledge and belief this material analysis report is true and correct.



# MIDWEST FITTINGS

# CERTIFIED MATERIAL TEST REPORT

450 SO. SECOND STREET (R.O. BOX 433) Customer FULLMAN POWER PRODUCTS Customer's Order No. 8405-108  
 T. LOUIS. MO. 63104. (63188) TELEPHONE (314) 621-8300 CMF Order No. 13468307 Date 6-23-77 Page 1 of 1


Product Specifications		Quantity	Description Of Item																
A223 SA223 ASME Section III Class 1 157- Ed. Winter 75 Add. & MK IV-20, IV-33 and VIII-1		6	12" SCH 80 (SA223 WPB) LR 90 Deg. Ell. (C-431A) X1, X2, X3, X4, X5, X6 (Item 1-248)																
Materials Conform to Specifications		Heat Number or Symbol	Tensile Strength PSI	Yield Strength PSI	Elong. in 2"	Red of Area %	CHEMICAL ANALYSIS												
							C	Mn	P	S	SI	Cr	Ni	Mo	Cu				
A223 Grade B		(237351) (CVAL)	72,900	38,100	42.0		.21	.88	.009	.014	.190								

PULLY KILLING  
 CENTER APPROVED  
 7/5/77 BY [Signature]  
 11-1-77

Ultrasonic Test - Pipe was ultrasonic tested per Crane procedure UF-3 Rev. 2 (MK) and found acceptable.  
 Heat Treatment - Not required final forming operation completed at a temperature above 1150 Deg. F. & below 1800 Deg. F. (SA223 Para. 6.1.1.)  
 Magnetic Particle - 100% of the fitting was magnetic particles tested per Crane procedure MF-3 Rev. 3 and found acceptable.  
 Ultrasonic Test - Fitting was ultrasonic tested per Crane procedure UF-3 Rev. 2 (MK) and found acceptable.  
 Impact Test - Charpy "V" Notch, Full Size at plus 30 Deg. F. - Longitudinal

Ft. Lbs.	Shear	Lat. Exp.
110	90%	78 Mills
110	90%	81 Mills
122	90%	

THE 78 MILS AL CERTIFIED TO  
 12/14 ASME CODE.  
 2/75 ASME SECTION II  
 WITH HELLOTT  
 QUALITY CONTROL DEPARTMENT



BRINELL HARDNESS  
 This is to certify that the brinell hardness of fittings described above does not exceed HB197.

8405-108  
 13468307

12221032

20. 11022  
8-105-12.7

DATE: 4-25-77	DATE SHIPPED: 4-22-77	MILL ORDER NO. T-3072-A2-10-20	SHIPPING LIST NO. 115C
Standard Pipe & Supply Co., Inc.		CUSTOMER ORDER NO. 9716	
		CAR NO. PC 525801	
		MATERIAL: SEAMLESS <input checked="" type="checkbox"/> PIPE <input type="checkbox"/> TUBE, HOT FINISHED	
Pullman Kellogg Co.		SPECIFICATION: ASME SA-106-B (O.H.)	

NO. PCS.	OD	WALL	LENGTH	TOTAL WT.	TOTAL LBS.	NET WT.
	12.750"	x .844"				

CEI  
 PNPP  
 1 OR 2  
 P-1314L

57529

INFORMATION ONLY

MEAT. NO. 57529	C .25	Mn .74	P .011	S .022	Si .21	Cu.	Ni.	Cr.	Mo.
-----------------	-------	--------	--------	--------	--------	-----	-----	-----	-----

DOCUMENT REVIEWED  
 BY 8202  
 PNPP  
 GA/QA

THIS MATERIAL CERTIFIED TO  
 1974 ASME CODE.  
 W/25 ADDENDA.  
 SECTION II  
 PULLMAN KELLOGG  
 QUALITY ASSURANCE DEPARTMENT  
 BY: [Signature] DATE: 5/16/77

HEAT NO.	TENSILE (KSI)	YIELD (KSI)	% ELONG. IN 2"	% RA	ROCKWELL	HARDNESS BRINELL	GRAIN SIZE
57529	75.0	41.5	29.00				

(.505" Test Specimen)

PULLMAN KELLOGG  
 QUALITY ASSURANCE  
 CMTR APPROVED  
 5/6/77 BY [Signature]  
 7/5/77 BY [Signature]

RECEIVED  
 MAY 6 1977  
 QUALITY CONTR.

JOINTY DISTANCE - 16TH			ROCKWELL C			FLATTENING OK			HYDROSTATIC PSI 2800			
1	2	4	6	8	10	12	14	16	20	24	28	32

PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY RECORDS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PRESCRIBED SAID SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. BASED UPON SUCH INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATIONS.

A. W. Pickens

402/1399

APPROVED FOR PRODUCTION

PENE. N<sup>o</sup> 1 P121 P414  
Unit # 2 P410 P112

Code see 1748, Subseries 8E-2341 and 8E-2319 at  
Summer 1976 Address, and Appendix 1, Tables 1, 10,  
and 113.3 of Standard 8977 Address apply as permitted  
by SP-125 and Paragraph 8E-1140771

ASSEMBLY DWG NO. 70195Y-D35.1  
SIZE CAT NO DWG TREATMENT

# TUBE TURNS

## BELLOWS EXPANSION JOINT

FOR USE IN NUCLEAR POWER PLANT - C.E.I.

PLANT ORDER TO 195Y  
ITEM NO. 17734

ITEM NO.	QUANTITY	DETAIL (PART NO.)	UNIT	FINISHED DIMENSIONS	REMARKS	ITEM NO.	FINISHED DIMENSIONS	REMARKS	ITEM NO.	FINISHED DIMENSIONS	REMARKS
1	3	SA 205	3	SEE DWG	SEE DWG	SA 205	SEE DWG	SEE DWG	SA 205	SEE DWG	SEE DWG
2	3	SA 206	3	SEE DWG	SEE DWG	SA 206	SEE DWG	SEE DWG	SA 206	SEE DWG	SEE DWG
3	1	SA 207	1	SEE DWG	SEE DWG	SA 207	SEE DWG	SEE DWG	SA 207	SEE DWG	SEE DWG
4	1	SA 208	1	SEE DWG	SEE DWG	SA 208	SEE DWG	SEE DWG	SA 208	SEE DWG	SEE DWG
5	1	SA 209	1	SEE DWG	SEE DWG	SA 209	SEE DWG	SEE DWG	SA 209	SEE DWG	SEE DWG
6	1	SA 210	1	SEE DWG	SEE DWG	SA 210	SEE DWG	SEE DWG	SA 210	SEE DWG	SEE DWG
7	1	SA 211	1	SEE DWG	SEE DWG	SA 211	SEE DWG	SEE DWG	SA 211	SEE DWG	SEE DWG
8	1	SA 212	1	SEE DWG	SEE DWG	SA 212	SEE DWG	SEE DWG	SA 212	SEE DWG	SEE DWG
9	1	SA 213	1	SEE DWG	SEE DWG	SA 213	SEE DWG	SEE DWG	SA 213	SEE DWG	SEE DWG
10	1	SA 214	1	SEE DWG	SEE DWG	SA 214	SEE DWG	SEE DWG	SA 214	SEE DWG	SEE DWG
11	1	SA 215	1	SEE DWG	SEE DWG	SA 215	SEE DWG	SEE DWG	SA 215	SEE DWG	SEE DWG
12	1	SA 216	1	SEE DWG	SEE DWG	SA 216	SEE DWG	SEE DWG	SA 216	SEE DWG	SEE DWG
13	1	SA 217	1	SEE DWG	SEE DWG	SA 217	SEE DWG	SEE DWG	SA 217	SEE DWG	SEE DWG
14	1	SA 218	1	SEE DWG	SEE DWG	SA 218	SEE DWG	SEE DWG	SA 218	SEE DWG	SEE DWG
15	1	SA 219	1	SEE DWG	SEE DWG	SA 219	SEE DWG	SEE DWG	SA 219	SEE DWG	SEE DWG
16	1	SA 220	1	SEE DWG	SEE DWG	SA 220	SEE DWG	SEE DWG	SA 220	SEE DWG	SEE DWG
17	1	SA 221	1	SEE DWG	SEE DWG	SA 221	SEE DWG	SEE DWG	SA 221	SEE DWG	SEE DWG
18	1	SA 222	1	SEE DWG	SEE DWG	SA 222	SEE DWG	SEE DWG	SA 222	SEE DWG	SEE DWG
19	1	SA 223	1	SEE DWG	SEE DWG	SA 223	SEE DWG	SEE DWG	SA 223	SEE DWG	SEE DWG
20	1	SA 224	1	SEE DWG	SEE DWG	SA 224	SEE DWG	SEE DWG	SA 224	SEE DWG	SEE DWG
21	1	SA 225	1	SEE DWG	SEE DWG	SA 225	SEE DWG	SEE DWG	SA 225	SEE DWG	SEE DWG
22	1	SA 226	1	SEE DWG	SEE DWG	SA 226	SEE DWG	SEE DWG	SA 226	SEE DWG	SEE DWG
23	1	SA 227	1	SEE DWG	SEE DWG	SA 227	SEE DWG	SEE DWG	SA 227	SEE DWG	SEE DWG
24	1	SA 228	1	SEE DWG	SEE DWG	SA 228	SEE DWG	SEE DWG	SA 228	SEE DWG	SEE DWG
25	1	SA 229	1	SEE DWG	SEE DWG	SA 229	SEE DWG	SEE DWG	SA 229	SEE DWG	SEE DWG
26	1	SA 230	1	SEE DWG	SEE DWG	SA 230	SEE DWG	SEE DWG	SA 230	SEE DWG	SEE DWG
27	1	SA 231	1	SEE DWG	SEE DWG	SA 231	SEE DWG	SEE DWG	SA 231	SEE DWG	SEE DWG
28	1	SA 232	1	SEE DWG	SEE DWG	SA 232	SEE DWG	SEE DWG	SA 232	SEE DWG	SEE DWG
29	1	SA 233	1	SEE DWG	SEE DWG	SA 233	SEE DWG	SEE DWG	SA 233	SEE DWG	SEE DWG
30	1	SA 234	1	SEE DWG	SEE DWG	SA 234	SEE DWG	SEE DWG	SA 234	SEE DWG	SEE DWG
31	1	SA 235	1	SEE DWG	SEE DWG	SA 235	SEE DWG	SEE DWG	SA 235	SEE DWG	SEE DWG
32	1	SA 236	1	SEE DWG	SEE DWG	SA 236	SEE DWG	SEE DWG	SA 236	SEE DWG	SEE DWG
33	1	SA 237	1	SEE DWG	SEE DWG	SA 237	SEE DWG	SEE DWG	SA 237	SEE DWG	SEE DWG
34	1	SA 238	1	SEE DWG	SEE DWG	SA 238	SEE DWG	SEE DWG	SA 238	SEE DWG	SEE DWG
35	1	SA 239	1	SEE DWG	SEE DWG	SA 239	SEE DWG	SEE DWG	SA 239	SEE DWG	SEE DWG
36	1	SA 240	1	SEE DWG	SEE DWG	SA 240	SEE DWG	SEE DWG	SA 240	SEE DWG	SEE DWG
37	1	SA 241	1	SEE DWG	SEE DWG	SA 241	SEE DWG	SEE DWG	SA 241	SEE DWG	SEE DWG
38	1	SA 242	1	SEE DWG	SEE DWG	SA 242	SEE DWG	SEE DWG	SA 242	SEE DWG	SEE DWG
39	1	SA 243	1	SEE DWG	SEE DWG	SA 243	SEE DWG	SEE DWG	SA 243	SEE DWG	SEE DWG
40	1	SA 244	1	SEE DWG	SEE DWG	SA 244	SEE DWG	SEE DWG	SA 244	SEE DWG	SEE DWG
41	1	SA 245	1	SEE DWG	SEE DWG	SA 245	SEE DWG	SEE DWG	SA 245	SEE DWG	SEE DWG
42	1	SA 246	1	SEE DWG	SEE DWG	SA 246	SEE DWG	SEE DWG	SA 246	SEE DWG	SEE DWG
43	1	SA 247	1	SEE DWG	SEE DWG	SA 247	SEE DWG	SEE DWG	SA 247	SEE DWG	SEE DWG
44	1	SA 248	1	SEE DWG	SEE DWG	SA 248	SEE DWG	SEE DWG	SA 248	SEE DWG	SEE DWG
45	1	SA 249	1	SEE DWG	SEE DWG	SA 249	SEE DWG	SEE DWG	SA 249	SEE DWG	SEE DWG
46	1	SA 250	1	SEE DWG	SEE DWG	SA 250	SEE DWG	SEE DWG	SA 250	SEE DWG	SEE DWG
47	1	SA 251	1	SEE DWG	SEE DWG	SA 251	SEE DWG	SEE DWG	SA 251	SEE DWG	SEE DWG
48	1	SA 252	1	SEE DWG	SEE DWG	SA 252	SEE DWG	SEE DWG	SA 252	SEE DWG	SEE DWG
49	1	SA 253	1	SEE DWG	SEE DWG	SA 253	SEE DWG	SEE DWG	SA 253	SEE DWG	SEE DWG
50	1	SA 254	1	SEE DWG	SEE DWG	SA 254	SEE DWG	SEE DWG	SA 254	SEE DWG	SEE DWG
51	1	SA 255	1	SEE DWG	SEE DWG	SA 255	SEE DWG	SEE DWG	SA 255	SEE DWG	SEE DWG
52	1	SA 256	1	SEE DWG	SEE DWG	SA 256	SEE DWG	SEE DWG	SA 256	SEE DWG	SEE DWG
53	1	SA 257	1	SEE DWG	SEE DWG	SA 257	SEE DWG	SEE DWG	SA 257	SEE DWG	SEE DWG
54	1	SA 258	1	SEE DWG	SEE DWG	SA 258	SEE DWG	SEE DWG	SA 258	SEE DWG	SEE DWG
55	1	SA 259	1	SEE DWG	SEE DWG	SA 259	SEE DWG	SEE DWG	SA 259	SEE DWG	SEE DWG
56	1	SA 260	1	SEE DWG	SEE DWG	SA 260	SEE DWG	SEE DWG	SA 260	SEE DWG	SEE DWG
57	1	SA 261	1	SEE DWG	SEE DWG	SA 261	SEE DWG	SEE DWG	SA 261	SEE DWG	SEE DWG
58	1	SA 262	1	SEE DWG	SEE DWG	SA 262	SEE DWG	SEE DWG	SA 262	SEE DWG	SEE DWG
59	1	SA 263	1	SEE DWG	SEE DWG	SA 263	SEE DWG	SEE DWG	SA 263	SEE DWG	SEE DWG
60	1	SA 264	1	SEE DWG	SEE DWG	SA 264	SEE DWG	SEE DWG	SA 264	SEE DWG	SEE DWG
61	1	SA 265	1	SEE DWG	SEE DWG	SA 265	SEE DWG	SEE DWG	SA 265	SEE DWG	SEE DWG
62	1	SA 266	1	SEE DWG	SEE DWG	SA 266	SEE DWG	SEE DWG	SA 266	SEE DWG	SEE DWG
63	1	SA 267	1	SEE DWG	SEE DWG	SA 267	SEE DWG	SEE DWG	SA 267	SEE DWG	SEE DWG
64	1	SA 268	1	SEE DWG	SEE DWG	SA 268	SEE DWG	SEE DWG	SA 268	SEE DWG	SEE DWG
65	1	SA 269	1	SEE DWG	SEE DWG	SA 269	SEE DWG	SEE DWG	SA 269	SEE DWG	SEE DWG
66	1	SA 270	1	SEE DWG	SEE DWG	SA 270	SEE DWG	SEE DWG	SA 270	SEE DWG	SEE DWG
67	1	SA 271	1	SEE DWG	SEE DWG	SA 271	SEE DWG	SEE DWG	SA 271	SEE DWG	SEE DWG
68	1	SA 272	1	SEE DWG	SEE DWG	SA 272	SEE DWG	SEE DWG	SA 272	SEE DWG	SEE DWG
69	1	SA 273	1	SEE DWG	SEE DWG	SA 273	SEE DWG	SEE DWG	SA 273	SEE DWG	SEE DWG
70	1	SA 274	1	SEE DWG	SEE DWG	SA 274	SEE DWG	SEE DWG	SA 274	SEE DWG	SEE DWG
71	1	SA 275	1	SEE DWG	SEE DWG	SA 275	SEE DWG	SEE DWG	SA 275	SEE DWG	SEE DWG
72	1	SA 276	1	SEE DWG	SEE DWG	SA 276	SEE DWG	SEE DWG	SA 276	SEE DWG	SEE DWG
73	1	SA 277	1	SEE DWG	SEE DWG	SA 277	SEE DWG	SEE DWG	SA 277	SEE DWG	SEE DWG
74	1	SA 278	1	SEE DWG	SEE DWG	SA 278	SEE DWG	SEE DWG	SA 278	SEE DWG	SEE DWG
75	1	SA 279	1	SEE DWG	SEE DWG	SA 279	SEE DWG	SEE DWG	SA 279	SEE DWG	SEE DWG
76	1	SA 280	1	SEE DWG	SEE DWG	SA 280	SEE DWG	SEE DWG	SA 280	SEE DWG	SEE DWG
77	1	SA 281	1	SEE DWG	SEE DWG	SA 281	SEE DWG	SEE DWG	SA 281	SEE DWG	SEE DWG
78	1	SA 282	1	SEE DWG	SEE DWG	SA 282	SEE DWG	SEE DWG	SA 282	SEE DWG	SEE DWG
79	1	SA 283	1	SEE DWG	SEE DWG	SA 283	SEE DWG	SEE DWG	SA 283	SEE DWG	SEE DWG
80	1	SA 284	1	SEE DWG	SEE DWG	SA 284	SEE DWG	SEE DWG	SA 284	SEE DWG	SEE DWG
81	1	SA 285	1	SEE DWG	SEE DWG	SA 285	SEE DWG	SEE DWG	SA 285	SEE DWG	SEE DWG
82	1	SA 286	1	SEE DWG	SEE DWG	SA 286	SEE DWG	SEE DWG	SA 286	SEE DWG	SEE DWG
83	1	SA 287	1	SEE DWG	SEE DWG	SA 287	SEE DWG	SEE DWG	SA 287	SEE DWG	SEE DWG
84	1	SA 288	1	SEE DWG	SEE DWG	SA 288	SEE DWG	SEE DWG	SA 288	SEE DWG	SEE DWG
85	1	SA 289	1	SEE DWG	SEE DWG	SA 289	SEE DWG	SEE DWG	SA 289	SEE DWG	SEE DWG
86	1	SA 290	1	SEE DWG	SEE DWG	SA 290	SEE DWG	SEE DWG	SA 290	SEE DWG	SEE DWG
87	1	SA 291	1	SEE DWG	SEE DWG	SA 291	SEE DWG	SEE DWG	SA 291	SEE DWG	SEE DWG
88	1	SA 292	1	SEE DWG	SEE DWG	SA 292	SEE DWG	SEE DWG	SA 292	SEE DWG	SEE DWG
89	1	SA 293	1	SEE DWG	SEE DWG	SA 293	SEE DWG	SEE DWG	SA 293	SEE DWG	SEE DWG
90	1	SA 294	1	SEE DWG	SEE DWG	SA 294	SEE DWG	SEE DWG	SA 294	SEE DWG	SEE DWG
91	1	SA 295	1	SEE DWG	SEE DWG	SA 295	SEE DWG	SEE DWG	SA 295	SEE DWG	SEE DWG
92	1	SA 296	1	SEE DWG	SEE DWG	SA 296	SEE DWG	SEE DWG	SA 296	SEE DWG	SEE DWG
93	1	SA 297	1	SEE DWG	SEE DWG	SA 297	SEE DWG	SEE DWG	SA 297	SEE DWG	SEE DWG
94	1	SA 298	1	SEE DWG	SEE DWG	SA 298	SEE DWG	SEE DWG	SA 298	SEE DWG	SEE DWG
95	1	SA 299	1	SEE DWG	SEE DWG	SA 299	SEE DWG	SEE DWG	SA 299	SEE DWG	SEE DWG
96	1	SA 300	1	SEE DWG	SEE DWG	SA 300	SEE DWG	SEE DWG	SA 300	SEE DWG	SEE DWG
97	1	SA 301	1	SEE DWG	SEE DWG	SA 301	SEE DWG	SEE DWG	SA 301	SEE DWG	SEE DWG
98	1	SA 302	1	SEE DWG	SEE DWG	SA 302	SEE DWG	SEE DWG	SA 302	SEE DWG	SEE DWG
99	1	SA 303	1	SEE DWG	SEE DWG	SA 303	SEE DWG	SEE DWG	SA 303	SEE DWG	SEE DWG
100	1	SA 304	1	SEE DWG	SEE DWG	SA 304	SEE DWG	SEE DWG	SA 304	SEE DWG	SEE DWG
101	1	SA 305	1	SEE DWG	SEE DWG	SA 305	SEE DWG	SEE DWG	SA 305	SEE DWG	SEE DWG</

INDEX TO SECTION I

405/380

- A) ITT Grinnell Reports on Main Steam - pages E1 thru E41
- B) Bolting Materials Test Reports - pages E42 thru E55, E-109, E-110

<u>Control Number</u>	<u>Page</u>
LV	E56, E57
FK680	E58
FK778	E59
F1288	E60
F1290	E61
F1292	E62
F1293	E63
L6753	E64, E65
A63426	E66 thru E85
59102	E86, E87
92174	E88
6010319	E89, E90
6058246	E91, E92
6066765	E93
6076104	E89, E94, E95, E96
6076106	E97, E98
L6777	E99
L6773	E100, E100A
L6780	E101
F1313	E102
F1314	E102
842253	E103
76784	E104
Merriman Lubrite	E105, E106, E107, E-108
F1316	E111
71496	E112
70512	E113



D Louisville, Kentucky 40201  
 Tube Turns  
 718 South 28th St.  
 Gate #1  
 Louisville, Kentucky 40211

TUBE TURNS ORDER NO. HMF 4 94487

CUSTOMER ORDER NO. 94487

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO.	SPECIFIC TON IN MATERIAL FROM WHICH MADE	
	3/8 HEAT TREATMENT	WELD POINT PER SQUARE INCH	TENSILE STRENGTH PER SQUARE INCH	YIELD STRENGTH PER SQUARE INCH	ELONGATION PER INCH	C	MN	P	S	SI	CR	NI	MO			CB
Item 001 2 Pieces 12.25 Max. 21.686 Min. 32.062 Min. O.D. x 21.814 Max. x 7.600 - .062" Flued Heads Complete per Dwg. 70195Y-D33.1 Rev. 1	3	48,700	74,800	32.7	63.2	.25	.70	.011	.022	.18	.04				6010319	SA-105
						Charpy "V" Notch @ -0°F. 82-102-64 Ft. Lbs./59-72-50 Mile L.E./60-60-60% Shear										
						Ultrasonic Inspection tested per TT 04-037 Rev. 1 Add. 2										
						TAG: 1 Pc. P.O. 70195Y Item 33, Code L										
						1 Pc. P.O. 70195Y Item 37, Code L										
Item 002 2 Pieces 32.25 Max. 21.686 Min. 32.062 Min. O.D. x 21.814 Max. x 7.600 - .062" Lg. Flued Heads complete per Dwg. 70195Y-D33.1 Rev. 1	3	50,900	84,900	29.6	60.1	.29	.96	.008	.032	.18					6076104	SA-105
						Charpy "V" Notch @ -0°F. 154-82-170 Ft. Lbs./62-56-79 Mile L.E./100-80-100% Shear										
						Ultrasonic Inspection tested per TT 04-037 Rev. 1 Add. 2										
						TAG: 1 Pc. P.O. 70195Y Item 41, Code L										
						1 Pc. P.O. 70195Y Item 45, Code L										



THIS MATERIAL RECEIVED AS COMPLYING WITH THE SPECIFICATION  
 COMPLIANCE WITH ASTM A300 IS BASED ON UICSC REPORT OF 7-31-77  
 THIS DOCUMENT IS NOT TO BE USED FOR ANY OTHER PURPOSE  
 TUBE TURNS  
 BY *[Signature]* DATE 20-31-77

\* STANDARD ROUND TEST SPECIMEN: 1 NORMALIZED 2 ANNEALED 3 HEAT TREATED PER ORDER SPECIFICATION  
 SUBSCRIBED AND SWORN TO BEFORE ME THIS 28th DAY OF October 19 77

I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

*[Signature]*  
 NOTARY PUBLIC

Metrow Tube Turn  
 My Commission Expires...

*[Signature]*  
 R. Avera, Quality Control Engt.



b(3)-1



Louisville, Kentucky 40201  
 Tube Name  
 718 South 28th St.  
 Gate #1  
 Louisville, Kentucky 40211

B  
 N  
 T  
 I  
 O  
 P

Replaces DAR dated 10/13/77

ORDER NO. 21/2 bh  
 TUBE TURNS ORDER NO. #MF 4 93173  
 CUSTOMER'S ORDER NO. 93178

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS										HEAT OR LOT NO.	SPECIFY TYPE OF MATERIAL FROM WHICH MADE
	STANDARD TREATMENT	YIELD POINT PER SQUARE INCH	TENSILE STRENGTH PER SQUARE INCH	PERCENT ELONGATION IN 2"	PERCENT REDUCTION IN AREA	C	MN	P	S	SI	CR	NI	MO	CB			
Item 001 2 Pieces 32.25 Max. +031 32.125 Min. I.D. x 2.250 -062	3	51,700	78,400	29.0		.22	1.01	.010	.017	.22						59102	SA516 Gr. 70
x 48.187 Max. Anchor Plates		TAG:	1 Pc.	P.O. 70195	Item 33, Code M												
Machine Complete per Tube			1 Pc.	P.O. 70195	Item 37, Code M												
Turns Diag. #70195-D33.1, Rev.																	
1 Spec. CS-P-106 Rev. 1																	
Item 002 2 Pieces 32.25 Max. +031 32.125 Min. I.D. x 2.250 -062	3	51,700	78,400	29.0		.22	1.01	.010	.017	.22						59102	SA516 Gr. 70
x 48.187 Max. Anchor Plates		TAG:	1 Pc.	P.O. 70195	Item 41, Code M												
Machine Complete per Tube			1 Pc.	P.O. 70195	Item 45, Code M												
Turns Diag. #70195-D33.1, Rev.																	
1 Component Spec. CS-P-106 Rev. 1																	
			Charpy "V" Notch @ 0°F.														
			78-104-85 Ft. lbs./61-71-68 Mils L. E. 170-100-80% Shear														



THIS MATERIAL ACCEPTED AS COMPLYING WITH THE SPECIFICATION  
 COMPLIANCE IS BASED ON  
 [ ] TEST REPORT OF 1-25-77  
 NONE OF THE ABOVE APPLIES  
**TUBE TURNS**  
 BY SRV DATE 10-31-77

\* STANDARD ROUND TEST SPECIMEN \*\* 1 - NORMALIZED 2 - ANNEALED 3 HEAT TREATED PER ORDER SPECIFICATION.  
 SUBSCRIBED AND SWORN TO BEFORE ME THIS  
 23rd DAY OF November 19 77  
 I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT  
 ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

*[Signature]*  
 NOTARY PUBLIC

VICKI DIVIN  
 Notary Public in and for Harris County, Texas  
 My Commission Expires November 8, 1978

*[Signature]*  
 R. C. Campbell, U. C. Rep.



1-(7)

L O J. BOX 34100  
 D Andersonville, Kentucky 48232

8 Tube Turns  
 H T 718 South 28th St., Gate #1  
 I O Louisville, Kentucky 40211  
 P

Replaces DAR dated 10/7/77

PROCESSED, TRADE MARK  
 TUBE TURNS  
 ORDER NO. 4 93182  
 CUSTOMER'S  
 ORDER NO. 92182

DESCRIPTION	PHYSICALS		CHEMICAL ANALYSIS										MATERIAL FROM WHICH MADE	MAY OR LOT NO.	MATERIAL FROM WHICH MADE			
	Q & Q	Q & Q	C	MN	P	S	SI	CR	NI	MO	CB							
Item 001 2 Pieces 32.250 Max 32.175 Min. I.D. x 2.000 +0.031 -0.062 x 40.000 + .125 O.D.	3	51,700	78,400	29.0	.22	1.01	.010	.017	.22								59102	SA516 Gr. 70
Anchor Plates Machine com- plete per Tube Turns Diag.																		
70195Y-D49.1 Rev. 1																		
Cherry 'V' Notch @ 0 F. 78-104-85 Ft. lbs. 761-71-68 Mills L.E. 70-100-80% Shear																		

THIS MATERIAL ACCEPTED AS COMPLYING WITH THE SPECIFICATION  
 COMPLIANCE Y... .. IS BASED ON [ ] C/A T AULT OF 1-35-77  
 REFERENCE TO 2410 IN 2410S  
 BY *Shirley* DATE 10-1-78



STANDARD ROUND TEST SPECIMEN # 1 NORMALIZED 2-ANNEALED 3-HEAT TREATED PER ORDER SPECIFICATION.  
 I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT  
 ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION



R. C. Campbell, Q. C. Notary

VICKI L...  
 Notary Public in and for Harris County, Texas  
 My Commission Expires November 8, 1978

23rd DAY OF November 19 77

*W. C. ...*  
 NOTARY PUBLIC

FORM NP-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES\*

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Atwood & Morrill Co. Inc., Salem, Mass. 01970 Order No. 13560-01  
(Name & Address of Manufacturer)
2. Manufactured for General Electric Co., San Jose, California Order No. 205-AF774  
(Name and Address)
3. Owner Cleveland Electric Illuminating Co.
4. Location of Plant North Perry, Ohio
5. Pump or Valve Identification Valve S/N 5-560 26" 575# Main Steam Isolation Valve  
For Service in Main Steam Piping System  
(Brief description of service for which equipment was designed)

(a) Drawing No. 13560-01-H Rev. 3 Prepared by Robert J. Knox

(b) National Board No. N/A

6. Design Conditions 1375 psi 586 °F  
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III. Class 1

Edition 1974, Addenda Date N/A, Case No. 1622

Mark No.	Material Spec. No.	Manufacturer	Remarks
<b>(a) Castings</b>			
Body RT# N2128	SA216 WCB	Quaker Alloy	S/N 5-560
<b>(b) Forgings</b>			
Poppet	SA350 Gr. LF-2	Cann & Saul	S/N 1-560
Cover	SA105 (QT)	Cann. & Saul	S/N 1-560

\*Supplemental sheets in form of lists, sketches, drawings may be used provided (1) size is 8 1/2" x 11", (2) information is: Items, 1, 2, 5a and

677/593

dcu

FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Cover Studs (18)	SA540 Gr. B23 Class 5	Jos. Dyson & Sons	Heat# 114188
Cover Nuts (18)	SA540 Gr. B23 Class 5	Jos. Dyson & Sons	Heat# 134951
(d) Other Parts			
* 3/4" - Nipples (2)	SA106 Gr. B	U.S. Steel	S/N 1-560
* 45° Elbow	SA105	Vogt Mach. Co.	S/N 9-560
* Note: These items comply with the CODE for Material Construction and workmanship, but are not included as far as design is concerned.			

8. Hydrostatic test Body Poppet  
2175 1450 psi.

CERTIFICATION OF DESIGN

Design information on file at General Electric Co., San Jose, California  
 Stress analysis report on file at Atwood & Morrill Co., Inc., Salem, Mass.  
 Design specifications certified by Ranjit Ranjan Ghosh (I) Prof. Eng. State Calif. Reg. No. 16371  
 Stress analysis report certified by Herbert Cook (I) Prof. Eng. State Mass. Reg. No. 10981  
 (I) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 2-23 19 76 Signed Atwood & Morrill Co. Inc. By *F. J. Prater*  
 (Manufacturer) Quality Control Manager  
 Certificate of Authorization No. N812 expires May 7, 1977

CERTIFICATE OF SIOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of Massachusetts and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, Conn. have inspected the equipment described in this Data Report on 2-23 19 76, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.  
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-23 19 76

*V. J. Smith*  
 (Inspector) V. J. Smith

Commissions Mass. 946  
 (National Board, State, Province and No.)

Cust.: General Electric Company

Cust. P.O.# : 205-AF774

A&M S.O., No. : 13560 Item No. 01 Dwg. No. : 13560-01-H Rev. 3

Valve Serial No. : 5-560 ASME Section III Class : 1 (1974)

Valve Description : 26" Main Steam Isolation Valve

Addenda : N/A

Plant Name : Perry I. Location : North Perry, Ohio

Record Title	A&M Ident. No.	RT. No.	Heat No.	Date Rec'd.	In Pkg
<b>GENERAL</b>					
G.E. Product Quality Certification Manufacturers Data Report (NPV-1) Vendors Cert. for Qualified NDE & Weld Personnel A&M Cert. for Qualified NDE & Weld Personnel Customer Certified Design Spec. A&M Certified Stress Report Certified "As Constructed" Dwg. Approved DDR's	N/A				x x x x No No No No
<b>BODY</b>					
CMTR with Heat Treat Charpy Data R.T. Reader Sheets w/shooting sketch M.T. as cast at foundry Repair Data (Charts, P.W.H.T. etc.) M.T. Finished Mach. Surfaces & Cert. P.T. Seat Overlay w/Weld Record & Cert. P.T. Riba Overlay, w/Weld Record & Cert. P.T. Weld Ends after Final Mach. Min. Wall Dimensional Report Weld Rod CMTR Visual Examination (See Final Insp. Data Sheet)	5-560	N2128	F6944		x x x x x x x x x x x
POPPET	1-560	N/A	632225		x x x x x
CMTR with Heat Treat & Charpy Data Ultrasonic Test Report M.T. Final Mach. Surfaces & Cert. P.T. Overlays w/Weld Record & Cert. Min. Wall Dimensional Report Weld Rod CMTR					x x x x x

CEI QUALITY ASSURANCE  
 REVIEWED HGB  
 DATE 11-18-76  
 PNPP

Retained A&M Eng. Files  
Retained A&M Eng. Files  
Retained A&M Q.C. Files

*Wade 6/76*

Reviewed By: J. F. Boehm Date: 6-3-76  
 N. W. Gen. Quality Control Specialist  
 General Electric Co. - BWR Projects Dept.  
 J. F. Boehm Quality Control Records Specialist  
 General Electric Co. - BWR Projects Dept.

Record Title	Ident. #	RL No.	Plant No.	Date	REC'D
<u>COVER</u> CMTR with Heat Treat & Charpy Data Ultrasonic Test Report M.T. Final Mach. Surfaces & Cert. P.T. Backseat Overlay w/Weld Record & Cert. P.T. 3/4" Nipple to Cover Weld w/Weld Record Min. Wall Dimensional Report Weld Rod CMTR	1-560	N/A	632202		
<u>STEM (NPR)</u> CMTR with Heat Treat & Charpy Data Ultrasonic Test Report P.T. Final Mach. prior & post threading Min. Wall Dimensional Report	2-560	N/A	71780		
<u>STUDS &amp; NUTS</u> CMTR with Heat Treat & Charpy Data M.T. all surfaces (Subvendor)	N/A	N/A	114188 (Studs) 134951 (Nuts)		
<u>3/4" PIPE</u> Mfgs. Certificate of Compliance P.T. All Accessible Surfaces & Cert. <u>45° ELBOW</u>	1-560		64L349		
Mfgs. Certificate of Compliance P.T. of elbow to pipe weld w/weld record Weld Rod CMTR P.T. All Accessible Surfaces & Cert.	9-560	N/A	N/A		
<u>FINAL REPORTS</u> Hydro & Operational Test Report Final Dimensional Record Final Inspection Data Sheet					
<u>OPERATOR</u> Subvendor Test Report	668268	N/A	N/A		

A&M *[Signature]* 2/23/76 Auth. Insp. *[Signature]* 2-23-76 Cust. Rep. *[Signature]* 2-24-76





**QUAKER ALLOY CASTING CO.**  
A DIVISION OF HARSCO CORP.  
MYERTOWN, PENNA. 17067

S/N 5-560

13560  
BODY 26"

**MATERIAL TEST REPORT**

205AF774

CUSTOMER ORDER NO	PATTERN NO	QUAKER ALLOY DESIGNATION	SPECIFICATION	SHOP ORDER NUMBER	DATE SHIPPED
AM25336	16731-30147-102	Q70	ASME SA216 GR.WCB (74)		1-16-76

CUSTOMER

Atwood and Morrill

**APPROVED**  
BY *R. J. ...*  
DATE *1/23/76*  
ATWOOD & MORRILL CO. INC.

HEAT NO	C	Mn	Si	P	S	Cr	Ni	Mo	YIELD P.S.I.	TENSILE P.S.I.	ELONG. %	RED. of AREA %	CSTG. SER.#	F.#	PC SHIP	
F6944	.25	.68	.47	.013	.018				46,000	84,000	32.0	50.7	F6944-3	12128		
			Charpy Impact V Notch Plus 60°F						34-37-37		foot.pounds					
									34-36-37		lateral expansion					
									30-30-30		% Ductile Fracture					

REMARKS

Reviewed By: *REC* Date: *1/23/76*  
R. E. Ciampa, Quality Control Representative  
General Electric Co. - BWR Projects Dept.

CHEMICAL & PHYSICAL  
REPORT CHECKED



*1-14-76*

BY: *M. Franco*  
DATE: *1-21-76*  
ATWOOD & MORRILL CO. INC.



*R. 1-15-76*

STATE OF PENNSYLVANIA, COUNTY OF LEBANON, S.S.  
SWORN TO AND SUBSCRIBED BEFORE ME

"I CERTIFY THE ABOVE INFORMATION IS CORRECT"

QUAKER ALLOY CASTING CO.

THIS

DAY OF

19

*1-23-76*

5-11P



# CANN & SAUL STEEL CO.

*AM S/N 1 Thru 4-5*

ROYERSFORD PA. 19468

Report of Physical Tests and/or Chemical Compositions

12/3/75

Corrected copy for report dated 11/26/75

Customer's Order No.

Cann & Saul Order No.

Customer Atwood & Morrill Co.  
 Address 2 85 Canal St.  
 Salem, Mass. 01970

AM-25353  
 Ref. #13560-01 COVER 34062

Attention Purchasing Dept.

## CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
632202	.26	.94	.023	.015	.20				

## PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	34062 1	.505	9,600	48,000	16,000	80,000	32.0	.061	69.5	
Charpy Impacts "V" Notch			67 68 61	Mils Lateral expansion @ +60°F						
			89 92 82	Ft. Lbs.						
			30 30 25	percent shear						

CHEMICAL & PHYSICAL REPORT CHECKED

## OTHER TESTS

Brinell: 143/149

Sonic C&S A388, Rev. 20(4/11/75) Acceptable

Mag. Part. B&PV #12, Rev. 1(5/7/75) Acceptable for A&M Info

Heat Treat. to C&S Proc. #5B(10/25/74)

We certify that the contents of this report are correct and accurate and that all operations performed by our company or subcontractors are in compliance with the requirements of materials specification and the ASME Code Sec. III

Customer's Specifications:

ASME SA-105 (QT)

XX 36,000 YS .2% 1974 Ed.

Charpy "V" Impacts 25 Mils lat. exp. @ +60°F

T. 70,000

E. 22%

B.H.N. 187 Max.

R. 30%

DATE 12/1/76  
 ATWOOD & MORRILL CO. INC.

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

- 4 - Cover Forgings per Dwg. 30861-405-D, Rev. 0 for Code 30861-405-2974 Forgings serialized #2 thru 5

G.E.

Reviewed By: [Signature] In-charge of [Signature]  
 R. E. Ciampa, Quality Control Representative  
 General Electric Co. - BWR Projects Dept.

Inspector



CANN & SAUL STEEL CO.

[Signature]  
 Eng. of Tests

JOE. DYSON AND SONS, INC. CERTIFIED TEST REPORT

January 12, 1976  
P.O. AM-25931  
S.O. N-572  
Brisch Code 34285-290  
327  
Heat No. 114188 Code A

Atwood and Morrill Co.  
285 Canal Street  
Salem, Massachusetts 01970

STUDS

1-13-76

123 Pcs.

Studs for 26" and 28" Main Steam Isolation Valves  
2-1/4" - 8 UN3A x 13-1/4" Long S.E. 3-1/2" N.E.  
3-1/2" per Sketch 3730

SPECIFICATIONS: Alloy Steel Bolting Material for Special Application  
ASME SA-540 Gr. B-23, Class 5

HEAT NUMBER 114188  
CODE A-88

LADLE ANALYSIS: C-.42 Mn-.81 Phos-.009 Sul-.008 Sil-.34 Cr-.81 Ni-1.75 Mo-.28

CHECK ANALYSIS: C-.42 Mn-.81 Phos-.014 Sul-.006 Sil-.27 Cr-.82 Ni-1.74 Mo-.26

MECHANICAL TESTS:	TENSILE	YIELD	ELONG	RED	RC
	146,300	130,450	18	55	30.5
	141,350	122,400	17	54.5	31.5

CHARPY V-NOTCH Impact Test per SA-370 Specification At +60°F  
45 Ft/Lbs.

	FT/LBS.	% SHEAR	LATERAL EXPANSION (IN.)	
	69	50	.048	CHEMICAL & PHYSICAL REPORT CHECKED
	68	50	.048	
	68	50	.048	
Ave.	68			
	74	60	.052	BY <u>St. Sharp</u> DATE <u>1/16/76</u> ATWOOD & MORRILL CO. INC.
	75	60	.053	
	74	60	.053	
Ave.	74			

HEAT TREAT DATA: Heated to 1550°F 2-1/2 Hrs. at Heat - Oil Quenched  
Tempered 1180°F 3 Hr. at Heat - Air Cooled  
Per Procedure HTN-572 Rev. 2, dated 6-12-75

-CONTINUED-

REC Date: 1/20/76  
R. E. Clampa, Quality Control Representative  
General Electric Co. - DWR Projects Dept.

AI 1-16-76  
for 123 studs

APPROVED  
BY R. E. Clampa  
DATE 1/16/76  
ATWOOD & MORRILL CO. INC.

STUDS

Atwood and Morrill Co.  
285 Canal Street  
Salem, Massachusetts 01970

ULTRASONIC INSPECTION:

All items referenced in this report have been inspected in accordance with Atwood and Morrill approved Procedure UL-4, Supplement Rev. 1, dated 6-12-75 and per ASME Code 1974, Sec. III, Para 2584/2585.

RESULTS OF INSPECTION:

All items acceptable.

MAGNETIC PARTICLE INSPECTION:

All items referenced in this report have been inspected in accordance with Atwood and Morrill approved Procedures UL-6, Supplement Rev. 1, dated 6-12-75.

RESULTS OF INSPECTION

All items acceptable.

We hereby certify that the contents of this report are correct and accurate and that all operations performed by this company or our sub-contractors are in compliance with the material specification and appropriate material requirements of the ASME Code Sec. II 1974, as stipulated in the procurement documents.

JOS. DYSON & SONS, INC.

Ralph McKinney  
Art Mazzearella-Q.A. Manager or/  
Ralph McKinney

Reviewed By: REC Date: 1/20/76  
R. E. Ciampa, Quality Control Representative  
General Electric Co. - BWR Projects Dept.

CORRECTED TEST REPORTS 1-16-76

Atwood and Morrill Co.  
 285 Canal Street  
 Salem, Massachusetts 01970

ITEM 2

197 Pcs. Hex Nuts for 26" and 28" Main Steam Isolation Valves  
 1-13-76 2-1/4" - 8 ANSI Standard Heavy

SPECIFICATIONS: SA-540 B-23, Class 5

HEAT NO. 134951 CODE A-13

LADLE ANALYSIS: C-.42 Mn-.75 Phos-.013 Sul-.011 Sil-.25 Ni-1.70 Cr-.77 Mo-.26

CHECK ANALYSIS: C-.43 Mn-.67 Phos-.016 Sul-.012 Sil-.24 Ni-1.56 Cr-.79 Mo-.27

MECHANICAL TESTS:

TENSILE	YIELD	ELONG	RED	RC HARDNESS
142,150	122,300	17	57.5	31.8
146,750	130,350	15	42	32.8

CHARPY IMPACT TESTED AT +60°F PER SA-370 45 Ft/Lbs.

FT/LBS.	% SHEAR	LAT. EXPANSION (IN.)
74	60	.051
66	50	.047
<u>73</u>	60	.051
Ave. 71		
54	40	.037
45	30	.030
<u>46</u>	30	.031
Ave. 48		

Meets Mechanical requirements of ASME SA-540 Gr. B-23, Class 5, and ASME Section III, Sub-Section NB-2333

HEAT TREAT DATA: Heated to 1550°F 2 Hrs. at Heat - Oil Quenched  
 Tempered 1160°F 2-1/2 Hrs. at Heat - Air Cooled  
 PER PROCEDURE HTN-573, Rev. 2, dated 6-12-75

Reviewed By: REC Date: 1/20/76  
 R. E. Ciampa, Quality Control Representative  
 General Electric Co. - EWR Projects Dept.

-CONTINUED-

APPROVED  
 BY: *[Signature]*  
 DATE: 1-20-76  
 ATWOOD & MORRILL CO. INC.

D - 1-20-76

A.I. for 197 pieces  
 for 13560-01102.

JOS. DYSON AND SONS, INC. CERTIFIED TEST REPORT

January 12, 1976  
P.O. AM-25931  
S.O. N-573  
Heat No. 134951  
CODE A-13  
Brisch Code 21838-78

Atwood and Morrill Co.  
285 Canal Street  
Salem, Massachusetts 01970

CORRECTED TEST REPORTS 1-16-76

ULTRASONIC INSPECTION:

All items referenced in this report have been inspected in accordance with Atwood and Morrill approved Procedure UL-4, Supplement 42, Rev. 1, dated 6-12-75, and ASME Code 1974, Section III, Para. NB-2584/2585

RESULTS OF INSPECTION:

All items acceptable.

MAGNETIC PARTICLE INSPECTION:

All items referenced in this report have been inspected in accordance with Atwood and Morrill approved Procedures UL-6, Supplement 19, Rev. 1, dated 6-12-75, and ASME Code 1974, Sec. III, Para. NB-2580

RESULTS OF INSPECTION:

All items acceptable.

Material referenced in this report has been tested and inspected per the requirements of the specifications and as stated herein and are acceptable.

-----  
We hereby certify that the contents of this report are correct and accurate and that all operations performed by this company or our sub-contractors are in compliance with the material specification and appropriate material requirements of ASME Code Sec. III, 1974 as stipulated in the procurement documents.

JOS. DYSON & SONS, INC.

*Ralph McKinney*  
Art Mazarella  
Quality Assurance Manager/  
Ralph McKinney

Reviewed By: *REC* Date: *1/20/76*  
R. E. Ciarra, Quality Control Representative  
General Electric Co. - DWR Projects Dept.

1717/2101

**FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES\***  
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Nuclear Valve Div., Borg Warner, 7500 Tyrone Ave., Van Nuys, Calif.  
(Name and Address of N Certificate Holder)
2. Manufactured for Cleveland Electric Illuminating Co., P.O. Box 5000, Cleveland, Ohio  
(Name and Address of Purchaser or Owner)
3. Location of Installation Perry Nuclear Power Plant, North Perry, Ohio  
(Name and Address)
4. Pump or Valve Gate Valve . Nominal Inlet Size 20 (inch) Outlet Size 20 (inch)

	(a) Model No., Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1)	900#	(51691)	N/A	81160-1	2	N/A	1979
(2)							
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. The valves are designed to handle a fluid media which includes steam, water condensate, borated water, etc., associated with a PWR and BWR. The temperature pressure rating of the media is stated below.  
(Brief description of service for which equipment was designed)

6. Design Conditions 2160 (Pressure) psi 100 (Temperature) °F or Valve Pressure Class N/A (1)

7. Cold Working Pressure 2160 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
<b>(a) Castings</b>			
Body-Code 3V02	SA 216 WCB	Pacific Metals	
Bonnet-Code 3V12	SA 216 WCB	Pacific Metals	
Gate-Code 3V14	SA 216 WCB	Pacific Metals	
<b>(b) Forgings</b>			
Retainer-Code 3L50	SA 105	Compton Forge	



(1) For manually operated valves only.

\* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

d(2)-1

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
Drain Pipe-Code 3T42	SA 106 GR B	Tubesales	
Pipe Plug-Code 1A85	SA 105 Gr. II	Compton Forge	



8. Hydrostatic test 3250 psi. Disk Differential test pressure 2160 psi.

**CERTIFICATE OF COMPLIANCE**

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.  
 Addenda Winter 1975 (Date), Code Case No. N/A, Date 10-8-77.  
 Signed Nuclear Valve Div., Borg Warner by [Signature]  
(N Certificate Holder)  
 Our ASME Certificate of Authorization No. N-1254 to use the N symbol expires 10/27/81.  
(N) (Date)

**CERTIFICATION OF DESIGN**

Design information on file at NYD of Borg Warner, 7500 Tyrone Ave., Van Nuys, Ca. 91409  
 Stress analysis report (Class 1 only) on file at N/A  
 Design specifications certified by (1) Jeffrey Lee Fink  
 PE State PA Reg. No. 25626  
 Stress analysis certified by (1) N/A  
 PE State \_\_\_\_\_ Reg. No. \_\_\_\_\_  
 (1) Signature not required. List name only.

**CERTIFICATE OF SHOP INSPECTION**

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of California and employed by Lumbermen's Mutual Casualty of Long Grove, Illinois have inspected the pump, or valve, described in this Data Report on 10/9 1979, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10/9 1979 Commissions 1275-CA. OHIO 1/25/78  
(Inspector) (Nat'l Bd., State, Prov. and No.)



# PACIFIC METALS CO., LTD.

Nuclear Valve Division  
MESSRS BORG - WARNER CORPORATION

HEAD OFFICE NO.1, 8-1 Chome Otomachi Chiyoda-ku Tokyo Japan.  
NAOETSU WORKS Minato-Che Jutsu Higata Pref, Japan.

# N

HEAT NO. 85134  
N CODE NO. 3V02  
S/O \_\_\_\_\_  
P.O. \_\_\_\_\_  
QTY. 1  
INSP (8V 122) DATE 3-15-79  
VENDOR Geo CHIALG

Gate Valve Body  
NAME OF ARTICLES Gate Valve Bonnet

DRAWING No. \_\_\_\_\_

SPECIFICATION ASME SA216 Gr. WCB

## INSPECTION CERTIFICATE

Date Dec. 8, 1978

Inspection No. 78 - 196

Order No. \_\_\_\_\_

Heat Charge No.	Quantity		Tensile Test				Hardness Test	Bond Test	Impact Test	Chemical Compositions in %								Sulfides V	
			Yield Strength	Tensile Strength	Elongation	Reduction				C	Si	Mn	P	S	Ni	Cr	Mo		Cu
			kg/mm <sup>2</sup> Psi	kg/mm <sup>2</sup> Psi	%	%													
Standard			min. 36,000	70,000	min. 22	min. 35			Chargy (notch)	0.30	0.60	1.00	0.040	0.045	0.50	0.50	0.25	0.50	0.03
85134	1		44,950	72,560	30.8	57.0	140			0.25	0.50	0.78	0.012	0.011	0.08	0.11	0.01	0.16	tr.
85135	1		47,790	81,070	24.8	39.8	152			0.24	0.48	0.72	0.009	0.017	0.11	0.17	0.02	0.16	tr.
85132	6		46,510	79,080	26.8	46.3	152			0.24	0.54	0.76	0.011	0.016	0.08	0.14	0.04	0.14	tr.

HEAT No.	PART No.	ARTICLE	FURNACE LOAD	Impact Test	85134-1	85134-2	85134-3
85134	79558	20"x900lb Gate V. Body	018 - 172	Test Temperature(°F)	39.2	39.2	39.2
85135	79558	20"x900lb Gate V. Body	018 - 160	Lateral Expansion(mil)	31.50	30.31	30.31
85132	79565	20"x900lb Gate V. Bonnet	018 - 168	Absorbed Energy(ft-lb)	35.94	29.49	28.84

Impact Test	85135-1	85135-2	85135-3	85132-1	85132-2	85132-3
Test Temperature(°F)	39.2	39.2	39.2	39.2	39.2	39.2
Lateral Expansion(mil)	29.92	34.65	33.07	29.13	29.92	28.35
Absorbed Energy(ft-lb)	29.49	33.19	29.86	23.62	26.88	24.93

PACIFIC METALS CO., LTD. NAOETSU WORKS.

Surveyor \_\_\_\_\_

REVIEWED BY  
AUTHORIZED  
INSPECTOR



*K. Nishiyama*  
Manager of Quality Assurance

DATE 3/14/79

d(2)-3



# PACIFIC METALS CO., LTD.

Nuclear Valve Division  
SSRS IORIG - WARNER CORPORATION

HEAD OFFICE NO. 1, 8-1 Chome Otomachi Chiyoda-ku Tokyo Japan.  
MAETSU WORKS Minato-Che Joetsu Niigata Pref, Japan.

HEAT NO. 85135  
N CODE NO. 3Y12  
S/O \_\_\_\_\_  
P.O. 14103  
QTY. 6  
INSP DATE 3-16-79  
VENDOR GEO CHIANG

Gate Valve Body  
ME OF ARTICLES Gate Valve Bonnet

Date Dec. 8, 1978

AWING No. \_\_\_\_\_  
**INSPECTION CERTIFICATE**

Inspection No. 78 - 196

ECIFICATION ASME SA216 Gr. WCB

Order No. \_\_\_\_\_

Lot No.	Quantity		Tensile Test				Hardness Test	Red Test	Impact Test	Chemical Composition in %								Sulphur V	
	Number	Weight in lbs	Tensile Strength	Tensile Strength	Elongation	Reduction				C	Si	Mn	P	S	Ni	Cr	Mo		Cu
			kg/cm <sup>2</sup> Psi	kg/cm <sup>2</sup> Psi	%	%													
			min. 36,000	70,000	min. 22	min. 35				MAX. 0.30	MAX. 0.60	MAX. 1.00	MAX. 0.040	MAX. 0.045	MAX. 0.50	MAX. 0.50	MAX. 0.25	MAX. 0.50	MAX. 0.03
134	1		44,950	72,560	30.8	57.0	140			0.25	0.50	0.78	0.012	0.011	0.08	0.11	0.01	0.16	tr.
135	1		47,790	81,070	24.8	39.8	152			0.24	0.48	0.72	0.009	0.017	0.11	0.17	0.02	0.16	tr.
132	6		46,510	79,000	26.8	46.3	152			0.24	0.54	0.76	0.011	0.016	0.08	0.14	0.04	0.14	tr.

HEAT No.	PART No.	ARTICLE	FURNACE LOAD	Impact Test	85134-1	85134-2	85134-3
85134	79558	20"x900lb Gate V. Body	018 - 172	Test Temperature(°F)	39.2	39.2	39.2
85135	79558	20"x900lb Gate V. Body	018 - 168	Lateral Expansion(mil)	31.50	30.31	30.31
85132	79565	20"x900lb Gate V. Bonnet	018 - 168	Absorbed Energy(ft-lb)	35.94	29.49	28.84

Impact Test	85135-1	85135-2	85135-3	85132-1	85132-2	85132-3
Temperature (F)	39.2	39.2	39.2	39.2	39.2	39.2
Lateral Expansion(mil)	29.92	34.65	33.07	29.13	29.92	28.35
Absorbed Energy(ft-lb)	29.49	33.19	29.86	23.62	26.88	24.93

PACIFIC METALS CO., LTD. MAETSU WORKS.

4(2)-4

Surveyor

REVIEWED BY  
AUTHORIZED  
INSPECTOR



*K. Nishiyama*  
Manager of Quality Assurance

DATE 3/19/79



# PACIFIC METALS CO., LTD.

Nuclear Valve Division  
MESSRS. DORC - WARNER CORPORATION

HEAD OFFICE NO1, 8-1 Chome Otomachi Chiyoda-ku Tokyo Japan.  
NAOETSU WORKS Minato-Che Joetsu Niigata Pref, Japan.

# N

HEAT NO. 85131  
N CODE NO. 3V14  
S/O \_\_\_\_\_  
P.O. \_\_\_\_\_  
QTY. 5  
DATE 3-16-78  
VENDOR Geo CHIANG

NAME OF ARTICLES Gate Valve Gate

DRAWING No. \_\_\_\_\_

SPECIFICATION ASME SA216 Gr. WCB

## INSPECTION CERTIFICATE

Date Dec. 8, 1978

Inspection No. 78-197

Order No. \_\_\_\_\_

Heat Charge No.	Quantity		Tensile Test				Hardness Test	Bond Test	Impact Test	Chemical Composition in %								Observation	
			Yield Strength	Tensile Strength	Elongation	Reduction				C	Si	Mn	P	S	Ni	Cr	Mo		Cu
			kg./mm <sup>2</sup> Psi	kg./mm <sup>2</sup> Psi	%	%													
Standard			min. 36,000	70,000	min. 22	min. 35			kg./mm <sup>2</sup> (notch)	MAX. 0.30	MAX. 0.60	MAX. 1.00	MAX. 0.040	MAX. 0.045	MAX. 0.50	MAX. 0.50	MAX. 0.25	MAX. 0.25	MAX. 0.03
85130	1		49,640	80,220	25.6	46.3	156			0.24	0.51	0.74	0.013	0.013	0.20	0.16	0.03	0.17	tr.
85131	5		43,670	75,950	31.6	54.4	144			0.26	0.46	0.71	0.005	0.013	0.10	0.21	0.02	0.15	tr.

HEAT No.	PART No.	ARTICLE	FURNACE LOAD
85130	79569	20"x900lb Gate V. Gate	018 - 168
Remarks 85131	79569	20"x900lb Gate V. Gate	018 - 168

REVIEWED BY  
AUTHORIZED  
INSPECTOR

DATE \_\_\_\_\_

Impact Test	85130-1	85130-2	85130-3	85131-1	85131-2	85131-3
Test Temperature(°F)	39.2	39.2	39.2	39.2	39.2	39.2
Lateral Expansion(mil)	42.91	32.28	33.86	33.07	29.53	32.28
Absorbed Energy(ft-lb)	40.14	30.14	32.17	33.55	28.19	27.54

PACIFIC METALS CO., LTD. NAOETSU WORKS.

Surveyor \_\_\_\_\_



*K. Nishiyama*  
Manager of Quality Assurance

d(2)-5

# COMPTON FORGE, INC.

No 7913

## REPORT OF CHEMICAL AND PHYSICAL TESTS

**SOLD TO:** NUCLEAR VALVE DIVISION  
P.O. BOX 2185  
VAN NUYS, CA 91409

**SHIPPED TO:**  
7500 TYRONE AVE.  
VAN NUYS, CA 91409

**CUST. ORDER NO.** 16805      **SHIPPER NO.** 7913      **SPECIFICATION NO.** ASME SA-105 1029 NORMALIZED, CLEANED, & SONIC

**ITEM NO.** 1      **DESCRIPTION** 14 PC'S P/N: 26 'OD 18 1/2 ID' HEAT: 217160 W/O: FD-1763  
NUCLEAR CODE: 3L50 1 TEST BAR

REVIEWED BY  
AUTHORIZED  
INSPECTOR

*[Signature]*

DATE 07-3-78

MAT'L SA-105 SIZE 12" RCS

MILL SHARON

HEAT NO. 217160  
N CODE NO. 3L50  
S/O \_\_\_\_\_  
P.O. 16805  
QTY. 14  
INSP DATE 9-26-78  
VENDOR Compton Forge

**N**

### MECHANICAL PROPERTIES

HEAT NO.	YIELD POINT P.S.I.	TENSILE STRENGTH P.S.I.	% ELONG 2"	% RED. AREA	BRINELL	ROCI WEL
217160	58,400	83,900	27.5	60.6		

COMPTON FORGE, INC. CERTIFIES THAT THE ABOVE FORGINGS WERE MANUFACTURED AND PROCESSED IN ACCORDANCE WITH AND MEET THE REQUIREMENTS OF: NMS 70478 NUCLEAR VALVE P.O. #16805 REV. D

*[Signature: Daniel Paul McGary]*

DANIEL PAUL MCGARY

09-14-78  
Date:

### CHEMICALS

HEAT NO.	C	MN	P	S	SI	NI	CR	CU	AL	MO	TI		
217160	.31	.81	.013	.018	.23								

SUBSCRIBED AND SWORN TO BEFORE ME THIS 14 DAY OF SEPTEMBER 19 78

I CERTIFY THAT THESE ARE CORRECT COPIES OF REPORTS NOW ON FILE AT COMPTON FORGE, INC.

*[Signature: Daniel Paul McGary]*



NUCLEAR

d(2)-6

FORM NPV-1 N CERTIFICATE HOLDERS DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code, Section III, Div. 1

MP 19065 11


1. Manufactured by Rockwell International Corp., 1900 S. Saunders St., Raleigh, NC 27603  
(Name and Address of N Certificate Holder)  
 2. Manufactured for Cleveland Elec. Ill. Company, P.O. Box 500, Cleveland, Ohio 44101  
(Name and Address of Purchaser or Owner)  
 3. Location of installation Perry Nuclear Power Plant, Units 1 & 2, North Perry, Ohio  
(Name and Address)  
 4. Pump or Valve Valve Nominal Inlet Size 20 Outlet Size 20  
(inch) (inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1) 7592(WCC)	QC-51	N/A	D81-24401-15	1	670	1982
(2) JNQTY			Rev. A			
(3)						
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

5. Controlled Closure Check Valve  
(Brief description of service for which equipment was designed)  
Heat No. 4810433-120 Rockwell S.O. 36-24401

6. Design Conditions 1510 psi 420 °F or Valve Pressure Class N/A (1)  
(Pressure) (Temperature)  
 7. Cold Working Pressure 2250 psi at 100°F.  
 8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
<b>(a) Castings</b>			
4810433	SA 216 Gr. WCC	Rockwell Int'l (Metal Casting Div.)	Body
<b>(b) Forgings</b>			
116447	SA 105	Charles E. Larson	Cover
10502	SA 105	Charles E. Larson	Disk
36996	SA 638 Gr. 660T2	Charles E. Larson	Gasket Retainer
126376	SA 105	Charles E. Larson	Drain Cap (2)
116792	SA 105	Charles E. Larson	Test Fitting





(1) For manually operated valves only.  
 \* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

1811 F0032B

+2107 1210/926

HEAT NO.	PART. NO.	MO. PCS.	SRL NO.	ORDER NO.	SPEC.	YS PH	TS PH	ELONG IN %	RED AREA %	MIN	CHEST IMPACT		ANALYSIS														
											FT LBS	INCHES	C	Mn	P	S	Si	C	Ni	Mo	Co	Al	B	Ti	V	Zr	Co
4810433	126	1	120	70847	ASME SA-216 BCC MPC 01025	55000 SECTION 11/111 1974 EDITION WINTER 975 ADDENDUM, CODE 1	80000	25.0	55.5		50.0	43.0	.19	1.20	0.08	.010	.54	.11	.15	.12	.16	.05	.0005	.0021	.005	.0006	.010
NOTE: TEST SPECIMEN RECEIVED & SOLVED TEST WELDS HEAT TREATMENT AT 1100°F FOR 16 HOURS. HEAT TREAT INFORMATION: 1300°F for 6 hours - Normalize 1250°F for 6 hours - Temper ALL WELDS STRESS RELIEVED A MINIMUM OF ONE HOUR PER INCH OF THICKNESS WELD DEPOSIT - 50-100°F BELOW THE TEMPERING TEMPERATURE. OPERATIONS NOT PERFORMED: T AND A Final N.T. Inspection B Final Stress Rel. etc											THIS MATERIAL WAS MANUFACTURED IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION III, PARAGRAPH WQ.3.10.0. WE HEREBY CERTIFY THAT THE HEAT TREAT AND METALLURGICAL DATA RELATIVE TO THE ANALYSIS AND PHYSICAL PROPERTIES OF THE MATERIAL DESCRIBED ARE TRUE AND ACCURATE. MICHAEL J. WEAVER CHIEF OF METALLURGICAL SERVICES																

LOCATION AND ORIENTATION OF IMPACT SPECIMENS



ROCKWELL INTERNATIONAL  
 Customer: Cleveland Electric Illuminating Co  
 Rockwell S. O. No. 36-24401  
 Component: Body  
 Inspectability Code  
 APPROVED BY: P.C.  
 Q. A. Representative  
 Authorized Inspector  
 Date: 10-7-81  
 Date: 12-8-81



TO

Rockwell Int.  
Raleigh, North Carolina 27603

Attn: John Gramack

ROCKWELL INTERNATIONAL  
Customer: Cleveland Electric Illuminating Co.  
Rockwell S. O. No. 312-24401  
Component: Case Traceability Code: NA  
APPROVED BY: P.C. [Signature] Date: 10-8-81  
Q. A. Representative: [Signature] Date: 10-8-81  
Authorized Inspector: [Signature] Date: 10-8-81

CUSTOMER ORDER NO.	DATE SHIPPED	HEAT NO.	SPECIFICATION-GRADE
36-72242-C	9-30-81	116447	EMC-01112 ASME SA-105 C-1029
ITEM	QUANTITY	DESCRIPTION	

8 ✓ 00196516-24401-01 Pancake forging made, normalized and tempered as per Drg. No. A-196516 Rev. 0  
17-3/4" Dia. x 7-1/8" Thick

✓ The forgings were heated to 1700°F., held at temp for one hour and air cooled. The forgings were re-heated to 1250°F., held at temp for 8 hours and air cooled. The test specimen received an additional tempering, at 1125°F., for 16 hours and air cooled.

✓ Forgings comply with B & PV Code Sections II & III Cl. 1 1974 Edition thru Winter 1975 Addenda, Sec. III Para. WCA-3800 & Per Larson QC Manual Rev. 4 Dated 9-1-81.

Charpy Impact Test @ = +33°F

Ft. Lbs.	Mils Lateral Expn.	% Shear
76	57	50
85	62	50
89	70	50



REPORTED LADLE ANALYSIS												
C	Mn	P	S	Si	Ni	Cr	Mo	V	Cu	Co	Cl	Cl
.27	1.05	.010	.011	.21						.01		
Ta	Al	Sn	Fe	Ti	B	Pb	W					

MECHANICAL PROPERTIES					ULTRASONIC TEST RESULTS											
HARDNESS	TENSILE (PSI)	YIELD (PSI)	%ELONG. IN 2"	%RED. IN AREA												
BHN 156	75,000	49,500	38%	68%												
GRAIN SIZE	JOMINY HARDENABILITY BY 1/16"															
	1	2	3	4	5	6	7	8	9	10	12	14	16	20	24	28

SUBSCRIBED AND SWORN TO BEFORE ME

THIS 30th DAY OF September, 1981

[Signature]  
NOTARY PUBLIC

CHARLES E. LARSON & SONS, INC.

[Signature]

FORGERS OF CARBON, ALLOY, STAINLESS & TOOL STEELS, COPPER, MONEL, INCONEL,  
MY COMMISSION EXPIRES OCTOBER 10, 1981 HIGH TEMPERATURE & EXOTIC METALS

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES\*

As Required by the Provisions of the ASME Code Rules

676/1078

1. Manufactured by ANCHOR/DARLING VALVE CO., HAYWARD, CA. Order No. 5220-02  
(Name & Address of Manufacturer) NPL #22-P004
2. Manufactured for GENERAL ELECTRIC, SAN JOSE, CA. Order No. 205-AG-103  
(Name and Address) ITEM 03
3. Owner CLEVELAND ELECTRIC ILLUMINATING COMPANY
4. Location of Plant PERRY NUCLEAR POWER PLANT, NORTH PERRY, OHIO
5. Pump or Valve Identification SERIAL # 1N176 12" 655# GATE

ASME SECTION III

(Brief description of service for which equipment was designed)

STEAM AND WATER SERVICE IN A COMMERCIAL NUCLEAR POWER PLANT

- (a) Drawing No. 2997-3 Prepared by E.O. HOOK
- (b) National Board No. NA  
1575 100
6. Design Conditions 1512 psi 700 °F or Pressure Class 655# (1)  
(Pressure) (Temperature)
7. The material, design, construction, and workmanship complies with ASME Code Section III, Class X
- Edition 1971, Addenda Date Winter '73, Case No. 1567, 1637

Mark No.	Material Spec. No.	Manufacturer	Remarks
<b>(a) Castings</b>			
BODY HT. 6381E SH 2	SA216 WCB	ANCHOR/DARLING	VULCAN
BONNET HT. 6667E SH 2	SA216 WCB	ANCHOR/DARLING	VULCAN
DISC HT. 6595E SH 1G	SA216 WCB	ANCHOR/DARLING	VULCAN
<b>(b) Forgings</b>			
BACKSEAT HT. 213319	SA105	ANCHOR/DARLING	AIRCO VIKING
DRAIN. COIN. BODY HT. 213981	SA105	ANCHOR/DARLING	AIRCO VIKING
DRAIN. COIN. BONN. HT. 213981	SA105	ANCHOR/DARLING	AIRCO VIKING

(1) For manually operated valves only

\*Supplemental sheets in form of lists, sketches or drawings may be used provided: (1) size is 8 1/2" x 11", (2) information in items 1, 2, 5a and 5b on this data report is included on supplemental sheets and (3) each sheet is numbered and number of sheets is recorded at top of this form.

This form (E 6061), may be obtained from the Order Dept., ASME, 345 E. 47 St., New York, N.Y. 10017.

d(4)-1

FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
<b>(c) Bolting</b>			
BONNET STUDS CODE 6C	A193 B7	ANCHOR/DARLING	RALPH KNUDTSEN
BONNET NUTS CODE A9	SA194-2H	ANCHOR/DARLING	VITCO
<b>(d) Other Parts</b>			
SEAT RING HT. 10379-11-1	SA515 GR. 70	ANCHOR/DARLING	KAYSER
PIPE HT. JA2405	SA106	ANCHOR/DARLING	GULF STATES TUBE

B. Hydrostatic test 2460 psi.

**CERTIFICATION OF DESIGN**

Design information on file at CLEVELAND ELECTRIC  
 Stress analysis report on file at NA  
 Design specifications certified by CLYDE T. NYE (I) Prof. Eng. State CA Reg. No. 15587  
 Stress analysis report certified by S.T. YAMAHARA (I) Prof. Eng. State CA Reg. No. 23521  
 (I) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date July 19 19 76 Signed ANCHOR/DARLING CO. (Manufacturer) by [Signature]  
 Certificate of Authorization No. N-781 expires March 4, 1977

**CERTIFICATE OF SHOP INSPECTION**

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of CALIFORNIA and employed by LUMBERMENS MUTUAL of LONG GROVE, ILLINOIS have inspected the equipment described in this Data Report on 7-19 19 76, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 7-19 19 76  
John J. Conall (Inspector) CA 1309  
 (National Board, State, Province and No.)

# VULCAN STEEL FOUNDRY CO.

Carbon and Alloy Steel Castings

2809 CHAPMAN STREET • OAKLAND, CALIF. 94601  
PHONE (415) 261-5305

## MATERIAL TEST REPORT

DATE 6-1-75

ANCHOR VALVE CO.  
24747 CLAWITER RD.  
HAYWARD, CALIFORNIA 94545

MATERIAL SPECIFICATION: ASME SA-216 WCB

ASME Section III  
Winter 1973 Addenda

HEAT NUMBER: 6381 E

PO/JOB NUMBER 4076-5221-02 PATTERN NUMBER 1192-5-1 SERIAL NUMBER 1-2

MATERIAL MARKED BY: Heat and Serial Numbers (Metal Stamp)

NORMALIZED @ 1700 °F 2 HRS 30 MIN - AQ - DATE 6-1-75 CH5175A  
STRESS RELIEVED @ °F HRS MIN - AQ - DATE  
SOLUTION ANNEALED @ °F HRS MIN - WQ - DATE  
OTHER TREATMENT 1150 7 DATE 9-11-75 OWT

PROC 1822-1 REVE

Chemical Properties	Mechanical Properties	Charpy Impact Test (V-Notch)
<u>.20</u> Carbon ✓	<u>83,600</u> Tensile Strength, psi	Temperature <u>+10</u> °F
<u>.96</u> Manganese ✓	<u>62,500</u> Yield Point, psi	<u>1</u>
<u>.16</u> Silicon ✓	<u>31</u> Elongation (%)	<u>53.1</u> Ft Lbs
<u>.018</u> Phosphorus ✓	<u>62.1</u> Reduction of Area (%)	<u>95</u> Shear
<u>.020</u> Sulfur ✓		<u>.053</u> Expansion
Nickel		
Chromium		
Molybdenum		<u>2</u>
Columbium		<u>59.9</u> Ft Lbs
Copper		<u>95</u> Shear
		<u>.050</u> Expansion
		<u>3</u>
		<u>53.6</u> Ft Lbs
		<u>95</u> Shear
		<u>.050</u> Expansion



We hereby certify that this material meets all requirements of the material specification and all applicable special requirements of (Article 17A of the ASME Pump and Valve Code [Draft]) or (Article NB-2000 of the ASME Section III, Boiler and Pressure Vessel Code).

Temper Performed on Test Bars only.

10-21-75  
(DATE)

Daniel K. [Signature]  
QUALITY CONTROL MANAGER

# VULCAN STEEL FOUNDRY CO.

Carbon and Alloy Steel Castings

2909 CHAPMAN STREET • OAKLAND, CALIF. 94601

PHONE (415) 261-5305

## MATERIAL TEST REPORT

DATE: 10-2-75

ANCHOR VALVE CO.  
24747 CLAWITER RD.  
HAYWARD, CALIFORNIA 94545

MATERIAL SPECIFICATION: ASME SA-216 ✓

ASME Section III  
Winter 1973 Addenda

HEAT NUMBER: 6657 E

PO. JOB NUMBER: 4076-5221-02 PATTERN NUMBER: 5174-1-5-2 SERIAL NUMBER: 1-2

MATERIAL MARKED BY: Heat and Serial Numbers (Metal Stamp)

NORMALIZED @ 1700 °F 2 HRS. MIN - AQ - DATE 10-6-75 CHIC675A

STRESS RELIEVED @ °F HRS. MIN - AQ - DATE

SOLUTION ANNEALED @ °F HRS. MIN - WQ - DATE

OTHER TEMPLER 1150 6 30 DATE 10-30-75 CRT

### PROC 1322-1 REV E

Chemical Properties	Mechanical Properties	Charpy Impact Test (V-Notch)
<u>.22</u> Carbon ✓	<u>75,800</u> Tensile Strength, psi	Temperature: <u>10</u> °F
<u>.85</u> Manganese ✓	<u>17,400</u> Yield Point, psi	<u>87.1</u> Ft Lbs
<u>.16</u> Silicon ✓	<u>29.5</u> Elongation (%)	<u>80</u> Shear
<u>.019</u> Phosphorus ✓	<u>51.4</u> Reduction of Area (%)	<u>.076</u> Expansion
<u>.027</u> Sulfur ✓		
Nickel		
Chromium		
Molybdenum		
Columbium		
Copper		
		<u>2</u>
		<u>72.6</u> Ft Lbs
		<u>80</u> Shear
		<u>.076</u> Expansion
		<u>3</u>
		<u>93.4</u> Ft Lbs
		<u>80</u> Shear
		<u>.082</u> Expansion



We hereby certify that this material meets all requirements of the material specification and all applicable special requirements of (Article 1000 of the ASME Part 1 and Code (Draft)) or (Article 113.2000 of the ASME Section III, Boiler and Pressure Vessel Code)

Test bars were tested post weld heat treatment performed on test bars only.

10-2-75 (DATE) *K. Douglas Eason*  
QUALITY CONTROL MANAGER

d(4)-4

# VULCAN STEEL FOUNDRY CO.

*Carbon and Alloy Steel Castings*

2909 CHAPMAN STREET • OAKLAND, CALIF. 94601  
PHONE (415) 261-5305

## MATERIAL TEST REPORT

DATE: 9-22-75

ANCHOR VALVE CO.  
24747 CLAWITER RD.  
HAYWARD, CALIFORNIA 94545

MATERIAL SPECIFICATION: ASME SA-216 WCB

ASME Section III  
Winter 1973 Addenda

HEAT NUMBER: 6595 E

PO/JOB NUMBER L076-5221-02 PATTERN NUMBER 1182-5-4 SERIAL NUMBER 15-16

MATERIAL MARKED BY: Heat and Serial Numbers (Metal Stamp)

NORMALIZED @ 1600 °F 2 HRS MIN - AQ - DATE 9-23-75 CH92375A  
STRESS RELIEVED @ °F HRS MIN - AQ - DATE  
SOLUTION ANNEALED @ °F HRS MIN - WQ - DATE  
OTHER TEMPER 1150 6 DATE 9-25-75 . Q/T

1322-1 REV E

### Chemical Properties

.19 Carbon  
.39 Manganese  
.42 Silicon  
.018 Phosphorus  
.027 Sulfur  
Nickel  
Chromium  
Molybdenum  
Columbium  
Copper

### Mechanical Properties

70,800 Tensile Strength, psi  
45,500 Yield Point, psi  
33 Elongation (%)  
63.5 Reduction of Area (%)

### Charpy Impact Test (V-Notch)

Temperature +110 °F  
1  
42.2 Ft Lbs  
15 Shear  
250 Expansion  
2  
40.5 Ft Lbs  
45 Shear  
21.7 Expansion  
3  
41.4 Ft Lbs  
45 Shear  
21.9 Expansion



Due to the none requirement of a PWHT of the disc, new mechanical and impact tests were performed on a specimen that was heat treated similarly to the disc itself. See attachments for proper test results.

We hereby certify that this material meets all requirements of the material specification and all applicable special requirements of (Article 1.7 of the ASME Pump and Valve Code (Draft)) or (Article 2000 of the ASME Section III, Boiler and Pressure Vessel Code)

Temper Performed on Test Bars Only.

10-20-75  
(DATE)

*Donald L. Gilman*  
QUALITY CONTROL MANAGER

d(4)-5



RALPH  NUDTSEN CORP.

45805 WARM SPRINGS BLVD.

FREMONT, CA. 94538

(415) 651-1363

ANCHOR/DARLING VALVE COMPANY  
24747 Clawiter Road  
Hayward, California 94545

Gentlemen: We hereby certify the bolting manufactured by us  
meets the following specifications:

ASTM - SA 193 B-7

CODE # - 6C

HEAT NUMBER - 51981

MILL - TIMKEN

CODE # 6C IS TRACEABLE TO MILL HEAT # 51981

IDENTIFICATION - STUDS ARE STAMPED ON ONE END WITH B7 AND  
TRACEABILITY CODE 6C.



SIGNED:

**STEEL DIVISION  
CERTIFICATE OF TEST**

DATE **March 21, 1971**

SOLD TO:

Coulter Steel and Forge Company  
Box 8005  
Emeryville, California 94662  
Attn: Tom O'Connor

TIMKEN ORDER **25113**

CUSTOMER ORDER **04520-2.4**

SHIP TO:

Coulter Steel & Forge Company  
1494 - 67th St.  
Emeryville, California 94608

NOTARIZE

ENCLOSURES

SIZE **1.250" RD**

DESCRIPTION OF MATERIAL **4140 - Hot Rolled - Quenched - Tempered - Straightened - Stress Relieved**  
Spec: ASTM-A-193 Grade B-7

HEAT	SPECIMEN SIZE	MECHANICAL PROPERTIES					Brinell HARDNESS	IMPACT
		YIELD Strength P.S.I.	TENSILE P.S.I.	% ELONG. 2 IN.	% RED. AREA			
51981	.505" RD	123,250	135,000	20.5	60.8	293		
	" "	124,000	137,000	19.0	58.3			

**CODE - 6C**

Quenched at 1550°F for 2 hours  
Tempered at 1100°F for 8 hours  
Stress Relieved at 1060°F for 7 hours



HEAT	CHEMICAL ANALYSIS									
	C.	MN.	P.	S.	SI.	CR.	NI.	MO.	VA.	CU.
51981	.42	.55	.015	.012	.30	.56	.18	.20		.11

HEAT	101	FORGED HARDENABILITY DATA															
		1	2	3	4	5	6	7	8	10	12	14	16	20	24	28	32
51981	101	58	53	57	56	56	55	55	55	53	51	48	46	41	39	36	37
	108	57	57	57	56	56	55	55	55	54	52	49	47	43	40	38	37

The Timken Company hereby certifies that the above materials have been inspected and tested in accordance with the methods prescribed in the governing specifications and the results of such inspection and tests conform with the applicable requirements. For properties or characteristics for which no methods of inspecting or testing are prescribed by said specifications, the standard mill inspection and testing practices of the Timken Company have been applied.

WHEN SHIPPING NOTICE IS ATTACHED, IT BECOMES PART OF THIS CERTIFICATE.

**THE TIMKEN COMPANY  
STEEL DIVISION**

*John J. ...*  
Authorized Signature

of Ohio  
County of Stark

who being duly sworn according to the law, say that the facts contained foregoing Certificate are true and correct according to the best of his knowledge, information and belief.

Notary Public

d(4)-7



ANCHOR/DARLING VALVE COMPANY 24747 CLAWITER ROAD • HAYWARD, CALIFORNIA 94545 • (415) 72  
CABLE: ANCORCO • TELEX: :


"CERTIFICATION"

Subject: PRESSURE BOUNDRY BOLTING MATERIAL

HT 57853256

CODE A9

We hereby certify that this material meets all the requirements of the material specification and applicable special requirements of NB-2000, ASME Section III, Nuclear Power Plant Components, Winter Addenda 73.

  
J.W. Smith, Jr.  
Quality Assurance Engineer

5/21/76



# CERTIFIED TEST REPORT

VITCO NUCLEAR PRODUCTS INC. 13801 360TH EAST AVE., (PH) 44091  
PHONE AREA CODE 216 946 9550

TO: ANCHOR/DARLING VALVE COMPANY  
24747 Clawiter Road  
Hayward, CA 94545

DATE SHIPPED	VITCO ORDER NUMBER	CUSTOMER ORDER NUMBER
6-15-76	1489	1810

ITEM 24 Pcs. 1-1/4" -8 Hvy Hex Nuts (Trace. A9)  
Tag: 5220-02

SPECIFICATION ASME SA 194, Grade 2H, ASME Section III, Class 1, W-73

### CHEMICAL COMPOSITION

HEAT NO	C	Mn	P	S	Si	Cr	Mo	Ni	Cu	Fe	Al	Ti
578S3256	.42	.87	.019	.019	.28	1.00	.18					
	✓	✓	✓	✓	✓							

### PHYSICAL COMPOSITION

TENSILE STRENGTH PSI	YIELD PSI	ELONG. % IN 2"	RED. AREA %	HARDNESS	GRAIN SIZE	BEND TEST	MIN. TEMP.
Hardness	Per ASME SA 194, Para.	8.A		30-32 RC			1175° F
Hardness	Per ASME SA 194, Para.	8.B		248 BHN			

### ADDITIONAL SPECIFICATION REQUIREMENTS OR SPECIAL TESTS

CONE STRIPPING PROOF LOAD ( 109,350 Lbs. ) SATISFACTORY



### ATTACHMENTS

WESTERN COLD DRAWN STEEL CO. MILL TEST REPORT FOR HEAT # 578S3256.  
ULTRA LABS., INC. MAGNETIC PARTICLE INSPECTION.

IMPACT STRENGTH V-NOTCH  
CHARPY BARS @+40°F.  
(FT. LBS)

LATERAL EXPANSION  
(IN.)

DUCTILE FRACTURE AREA  
(%)

72.0  
75.0  
72.5  
Average 73.0

.046  
.048  
.044

100  
100  
100



I CERTIFY THAT THE ABOVE MATERIAL IS COMMERCIALY FREE FROM MERCURY CONTAMINATION AND MEETS THE REQUIREMENTS OF SPECIFICATION ASME SA 194, GRADE 2 H, ASME SECTION III, CLASS 1, S-74, AND YOUR ORDER # 1810.

THE ABOVE TESTS CONFORM TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE AND DESCRIBED BEFORE ME.  
ON \_\_\_\_\_ DAY OF \_\_\_\_\_ BY A DULY  
QUALIFIED AGENT OF VITCO NUCLEAR PRODUCTS INC.

WE HEREBY CERTIFY THAT THE ABOVE DATA IS A TRUE COPY OF THE DATA FURNISHED US BY THE PRODUCING MILL OR SUPPLIER OF THE DATA RESULTING FROM TESTS PERFORMED IN ACCORDANCE WITH CODES AND ALL THE REQUIREMENTS OF THE SPECIFICATION LISTED.

VITCO NUCLEAR PRODUCTS INC

BY [Signature]

d(4)-9