

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

WILLIAM R. McCOLLUM, JR.
Vice President
(803)831-3200 Office
(803)831-3426 Fax



DUKE POWER

April 2, 1996

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Subject: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414
Proposed Technical Specifications Change (Tables 3.6-1 and 3.6-2a)

By Duke Power Company letter to your staff, dated January 11, 1996, it was requested that your staff consider proposed changes to Catawba's Technical Specifications which would delete reference to process penetration M308 (Nuclear Service Water To Upper Containment Ventilation Units Out) in Technical Specifications Table 3.6-1 (Secondary Containment Bypass Leakage Paths), and delete reference to the associated containment isolation valves RN-429A (Return from Upper Containment Ventilation Units Containment Isolation - Inside) and RN-432B (Return from Upper Containment Ventilation Units Containment Isolation - Outside) listed in Technical Specifications Table 3.6-2a (Unit 1 Containment Isolation Valves) and Table 3.6-2b (Unit 2 Containment Isolation Valves).

It was recently discovered that the reference to containment isolation valve RN-429A in Technical Specifications Tables 3.6-2a and 3.6-2b is incorrectly listed in these tables as RN-429B. This discrepancy is in direct conflict with the design designation of the valve, physical labeling of the valve, and all associated referencing of this valve in Catawba's Final Safety Analysis Report (FSAR), drawings, procedures, and directives. Accordingly, it is requested that the correct designation to this valve in these tables be considered in conjunction with the proposed changes described earlier. Attached are revised marked-up revisions to Tables 3.6-2a and 3.6-2b as they should appear in Catawba's Technical Specifications.

Should there be any questions or should additional information be required, please contact Jeff Lowery at (803) 831-3414.

Sincerely,

W. R. McCollum, Site Vice-President
Catawba Nuclear Station

190073

Attachment

9604190272 960402
PDR ADDCK 05000413
P PDR

ADD 1/1

U. S. Nuclear Regulatory Commission

April 2, 1996

Page 2

xc: S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission - Region II
101 Marietta Street, NW - Suite 2900
Atlanta, Georgia 30323

R. J. Freudenburger
Senior Resident Inspector
Catawba Nuclear Station

R. E. Martin, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop 14H25, OWFN
Washington, D. C. 20555

bxc: ELL
L. B. Jones EC050
J. L. Lowery CN01RC
NCMPA-1
NCEMC
PMPA
SREC
Document Control File CN-801.01
Group File CN-801.01