

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Sequoyah, Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 3 2 7	PAGE (3) 1 OF 0 2
---------------------------------------	--------------------------------------	----------------------

TITLE (4)
Fire Doors A-92 and DE-3 Inoperable Greater Than Seven (7) Days

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 9	2 6	8 4	8 4	0 0 6	0 0	1 0	2 3	8 4	Sequoyah, Unit 2		0 5 0 0 0 3 2 8
											0 5 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §. (Check one or more of the following) (11)

OPERATING MODE (9) 1	20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 1 0 0	20.406(a)(1)(i)	50.36(c)(1)	50.73(a)(2)(v)	73.71(c)
	20.406(a)(1)(ii)	50.36(c)(2)	50.73(a)(2)(vi)	X OTHER (Specify in Abstract below and in Text, NRC Form 366A)
	20.406(a)(1)(iii)	50.73(a)(2)(i)	50.73(a)(2)(viii)(A)	
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(vii)(B)	
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME Michael R. Cooper, Compliance Section Engineer	TELEPHONE NUMBER 6 1 5 8 7 0 - 6 1 4 6
AREA CODE	

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

The following Special Report 84-06 contains details on the breaching of two fire doors for greater than seven days. This report is required per Action 'a' of Technical Specification 3.7.12. The two incidents are not related and will be described separately in the report. Both doors have been returned to operable status.

8411030667 841023
PDR ADOCK 05000328
S PDR

IEZZ 1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Sequoyah, Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 3 2 7 8 4 -	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		0 0 6	- 0 0	0 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

Event Description Door DE-3

On 09/24/84 at 2140 CST the penetration fire barrier breach permit (PFBBP) for door DE-3 expired. The door had been breached to allow ventilation to the CDWE building since the air conditioning unit was inoperable. A fire watch had been established and remained in effect throughout the door breach. On 09/26/84 at 1030 CST an audit of Breach Permit Book by an ASE revealed the permit had expired. The door was immediately closed.

Corrective Actions

- 1) Each fire watch was issued a training letter that states requirement for monitoring breach permit expiration dates.
- 2) A night order was issued by Operations supervisor that requires the ASE, assigned to supervise Shift Engineers office activities, to verify that the PFBBP book is reviewed every midnight shift.

Event Description Door A-92

Door A-92 was found to be inoperable by a firewatch on 10/07/84. Penetration fire barrier breach permit No. 1830 was written and the controls of Technical Specification 3.7.12 were placed in effect. Maintenance Request (MR) No. A121506 was written and sent to be loaded into the MR tracking system. The MR was not loaded into the system and no work was performed on door during the seven days that Breach Permit No. 1830 was in effect. On 10/14/84 Permit No. 1830 expired and a second permit, No. 1907, was written along with a new MR, No. A121508. The craftsmen received the MR on 10/15/84 and the door was repaired the same day. A post-maintenance surveillance was performed to verify operability of the door and Breaching Permit No. 1907 was closed out.

Corrective Actions

Door was repaired and returned to service on 10/15/84.

TENNESSEE VALLEY AUTHORITY

Sequoyah Nuclear Plant
Post Office Box 2000
Soddy Daisy, Tennessee 37379

October 23, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555


Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2 - DOCKET
NO. 50-327/50-328 - FACILITY OPERATING LICENSE DPR-77/79 - SPECIAL REPORT 84-06

The enclosed licensee special report provides details concerning fire
door A-92 and fire door DE-3 inoperable greater than seven days. This
event is reported in accordance with Special Report requirements per
Technical Specification 3.7.12.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



P. R. Wallace
Plant Manager

Enclosure
cc (Enclosure):

James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30323

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, NUC PR, Sequoyah