


Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111



April 29, 1975

Mr. Paul R. Nelson, Chief
Radiological and Environmental Protection Branch
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Nelson:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
IE Inspection Report No. 50-219/75-08

Two violations were noted in Mr. Bores' inspection of March 18-20, 1975 (No. 75-08). These involved the failure to analyze some surface and well water samples in accordance with the time intervals specified in the Oyster Creek Nuclear Generating Station's Technical Specifications. This was caused by an apparent change in the procedures of the radio-analytical vendor contracted by Jersey Central Power & Light Company for the sample analyses. Mr. Bores was informed that such occurrences had prompted a change in vendors in the past.

To insure that similar occurrences do not occur in the future, a program is being initiated immediately to send to the vendor with each sample shipment, a listing of all of the analyses required by the Technical Specifications. As the analyses are completed, the sheet is checked off and any remaining sample is retained. Upon completion of all the analyses for a particular sampling period, the check-off sheet is returned to Jersey Central Power & Light Company where it is reviewed to assure all analyses have been completed. The vendor is then informed as to whether the samples may be disposed.

Very truly yours,

Donald A. Ross, Manager
Generating Stations-Nuclear

CS