

February 14, 1985

DPR 016

Docket Nos. 50-317  
and 50-318

DISTRIBUTION:

Docket File	HRDenton
NRC PDR	LTremper
L PDR	RDiggs
SECY	DBrinkman
ORB#3 Rdg	OPA, CMiles
DEisenhut	TBarnhart-8
PMKreutzer-3	EJordan
DJaffe	JNGrace
OELD	LJHarmon
ACRS-10	Gray File

Mr. A. E. Lundvall, Jr.  
Vice President - Supply  
Baltimore Gas & Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203

Dear Mr. Lundvall:

The Commission has issued the enclosed Amendment Nos. 98 and 80 to Facility Operating License Nos. DPR-53 and DPR-69 for Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications in response to your application dated October 11, 1984.

The amendments revise the Technical Specifications to allow completion of the third containment Integrated Leak Rate Test prior to the 10-year Inservice Inspection outage. This change provides for a "one time only" schedule change for the third (10-year service interval) Integrated Leak Rate Test.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next monthly Federal Register notice.

The Commission has also issued the enclosed Exemption to 10 CFR Part 50, Appendix J, which was necessary in that the schedular requirements of TS 4.6.1.2a are also included in Section III.D.1(a) of Appendix J. This Exemption is in response to your application dated September 14, 1984. A copy of the Exemption is being filed with the Office of the Federal Register for publication.

Sincerely,

/S/

David H. Jaffe, Project Manager  
Operating Reactors Branch #3  
Division of Licensing

Enclosures:

1. Amendment No. to DPR-53
2. Amendment No. to DPR-69
3. Safety Evaluation
4. Exemption

cc w/enclosures:  
See next page

B502250822	B50214
PDR	ADOCK 05000317
P	PDR

\*\*See previous concurrences : reran do to machine error

ORB#3:DL	ORB#3:DL	ORB#3:DL	OELD	AD:OR:DL
PMKreutzer	DJaffe	JRMiller	CWoodward	GCLainas
1/28/85	1/28/85	1/28/85	1/29/85	2/09/85

February 14, 1985

Docket Nos. 50-317  
and 50-318

DISTRIBUTION:

<u>Docket File</u>	HRDenton
NRC PDR	LTremper
L PDR	RDiggs
SECY	DBrinkman
ORB#3 Rdg	OPA, CMiles
DEisenhut	TBarnhart-8
PMKreutzer-3	EJordan
DJaffe	JNGrace
OELD	LJHarmon
ACRS-10	Gray File

Mr. A. E. Lundvall, Jr.  
Vice President - Supply  
Baltimore Gas & Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203

Dear Mr. Lundvall:

The amendments revise the Technical Specifications to allow completion of the third containment Integrated Leak Rate Test prior to the 10-year Inservice Inspection outage. This change provides for a "one time only" schedule change for the third (10-year service interval) Integrated Leak Rate Test.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next monthly Federal Register notice.

The Commission has also issued the enclosed Exemption to 10 CFR Part 50, Appendix J, which was necessary in that the scheduler requirements of TS 4.6.1.2a are also included in Section III.D.1(a) of Appendix J. This Exemption is in response to your application dated September 14, 1984. A copy of the Exemption is being filed with the Office of the Federal Register for publication.

Sincerely,

David H. Jaffe, Project Manager  
Operating Reactors Branch #3  
Division of Licensing

Enclosures:

1. Amendment No. to DPR-53
2. Amendment No. to DPR-69
3. Safety Evaluation
4. Exemption

cc w/enclosures:  
See next page

ORB#3:DL  
PMKreutzer  
1/26/85

ORB#3:DL  
DJaffe  
1/28/85

ORB#3:DL  
OEHillier  
1/28/85

OELD  
1/29/85

AD:OR:DL  
GCL:mas  
2/9/85

*Review of No  
Significant Impact  
Exemption*

Baltimore Gas and Electric Company

cc:

D. A. Brune, Esquire  
General Counsel  
Baltimore Gas and Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203

George F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, NW  
Washington, DC 20036

Mr. R. C. L. Olson, Principal Engineer  
Nuclear Licensing Analysis Unit  
Baltimore Gas and Electric Company  
Room 922 - G&E Building  
P. O. Box 1475  
Baltimore, Maryland 21203

Mr. Leon B. Russell  
Plant Superintendent  
Calvert Cliffs Nuclear Power Plant  
Maryland Routes 2 and 4  
Lusby, Maryland 20657

Bechtel Power Corporation  
ATTN: Mr. J. C. Ventur  
Calvert Cliffs Project  
Engineer  
15740 Shady Grove Road  
Gaithersburg, Maryland 20760

Combustion Engineering, Inc.  
ATTN: Mr. R. R. Mills, Manager  
Engineering Services  
P. O. Box 500  
Windsor, Connecticut 06095

Mr. R. M. Douglass, Manager  
Quality Assurance Department  
Baltimore Gas and Electric Company  
Fort Smallwood Road Complex  
P. O. Box 1475  
Baltimore, Maryland 21203

Mr. S. M. Davis, General Supervisor  
Operations Quality Assurance  
Calvert Cliffs Nuclear Power Plant  
Maryland Routes 2 and 4  
Lusby, Maryland 20657

Regional Administrator  
Nuclear Regulatory Commission, Region I  
Office of Executive Director for Operations  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Mr. William T. Bowen, President  
Calvert County Board of County  
Commissioners  
Prince Frederick, Maryland 20768

U.S. Environmental Protection Agency  
Region III Office  
ATTN: Reg. Radiation Representative  
Curtis Building (Sixth Floor)  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106

Mr. T. Foley  
Resident Reactor Inspector  
NRC Inspector and Enforcement  
P. O. Box 437  
Lusby, Maryland 20657

Mr. Charles B. Brinkman  
Manager - Washington Nuclear Operations  
Combustion Engineering, Inc.  
7910 Woodmont Avenue  
Bethesda, Maryland 20014

Mr. J. A. Tiernan, Manager  
Nuclear Power Department  
Calvert Cliffs Nuclear Power Plant  
Maryland Routes 2 and 4  
Lusby, Maryland 20657

Mr. M. E. Bowman, Principal Engineer  
In-Core Fuel Management  
Baltimore Gas & Electric Company  
Calvert Cliffs Nuclear Power Plant  
P. O. Box 1475  
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor  
Training & Technical Services  
Calvert Cliffs Nuclear Power Plant  
Maryland Routes 2 and 4  
Lusby, Maryland 20657

Administrator, Power Plant Siting Program  
Energy and Coastal Zone Administration  
Department of Natural Resources  
Tawes State Office Building  
Annapolis, Maryland 21204