


Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111



August 1, 1975

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement, Region 1
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Status Report for IE Bulletins No. 75-04 and No. 75-04A

Reference: My letters to you of May 27 and June 30, 1975

This reports the status of incomplete activities that were initiated in response to IE Bulletins No. 75-04 and No. 75-04A.

Since the June 30, 1975, status report regarding the addition of a fire detection and suppression system at the Oyster Creek Nuclear Generating Station, the following activities have taken place:

1. Completed the engineering evaluation of available sealing materials for penetrating seals.
2. Vendors' recommendations for the fire protection are being formalized in an engineering evaluation to determine the optimal fire detection and suppression system.

It is anticipated that during the next 30-day period, we will accomplish the following:

1. Review and approval of recommended sealing material.
2. Submit a modification proposal to the Plant Operations Review Committee (PORC) and the General Office Review Board.
3. Determine, if necessary, whether the following are required:
 - (a) Area structural changes.
 - (b) Additional area ventilation dampers.

9604220220 960213
PDR FOIA PDR
DEKOK95-258

6/778

Mr. O'Reilly

-2-

August 1, 1975

The Shutdown Procedure and Emergency Procedures are currently being reviewed by subcommittees of PORC. Following this subcommittee review, they will be presented to PORC for approval of any revisions or modifications.

Very truly yours,

A handwritten signature in cursive script that reads "Donald A. Ross". The signature is written in dark ink and extends across the width of the typed name below it.

Donald A. Ross, Manager
Generating Stations-Nuclear

CS