

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

October 29, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Serial No. 285
E&C/PEC:klh:2007N
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2
RESOLUTION OF SER'S FOR ENVIRONMENTAL QUALIFICATION
OF SAFETY-RELATED ELECTRICAL EQUIPMENT

On March 24, 1983, Vepco received the NRC Safety Evaluation Report (SER) for the Environmental Qualification of Safety-Related Electrical Equipment at North Anna Power Station Units 1 and 2. The SER contained a Technical Evaluation Report (TER) which noted a number of environmental qualification deficiencies for safety-related electrical equipment at North Anna. Vepco formally responded to the TER deficiencies on April 29, 1983 (Serial No. 110B). On March 19, 1984, Vepco met with members of the NRC Staff to further discuss our method of resolution for each of the deficiencies noted in the North Anna TER. The TER deficiencies identified and the status of their resolutions are contained in Attachment 1 which is Vepco's "Status of Environmental Qualification of Electrical Equipment" for the North Anna Power Station. This attachment also contains the list of equipment at North Anna within the scope of 10CFR50.49. Appropriate notations have been added to the list which indicate whether equipment 1) is qualified, 2) will be qualified and on what schedule, or 3) deleted from the list. The Justification for Continued Operation (JCO) listed in Attachment 2 is the only currently applicable JCO. Several JCO's previously provided to the NRC are no longer applicable since either the equipment referenced by the JCO has been qualified or replaced with qualified equipment during the current refueling outages.

At the March 19, 1984 meeting, the Staff also requested confirmation that the Design Basis Events at North Anna Power Station which could result in a potentially harsh environment, including flooding outside containment, were addressed in identifying the safety-related electrical equipment required to be environmentally qualified. The flooding and environmental effects resulting from postulated Design Basis Events are documented in the North Anna Final Safety Analysis Report (FSAP). The effects of flooding and the environmental effects resulting from High-Energy Line Breaks (HELB) outside containment are documented in our response to the initial Safety Evaluation Report for Unit 1

8411050403 841029
PDR ADOCK 05C00338
P PDR

AOAG
11

dated August 24, 1981 (Serial No. 330). Approval of this response is documented in Section 4.3.5 of the TER. Therefore, the Design Basis Events which could potentially result in a harsh environment at North Anna Power Station were considered in the identification of electrical equipment within the scope of Paragraph(b)(1) of 10CFR50.49.

Additionally it was requested at the March 19, 1984 NRC/Vepco meeting that Vepco provide its general methodology for the identification of equipment within the scope of 10CFR50.49, paragraph (b).

(A) Safety-Related Electric Equipment - 10CFR50.49(b)(1)

Vepco prepared its initial list of safety-related electric equipment in response to IEB 79-01B and NUREG-0588 by determining what safety-related plant electrical equipment is required to function to obtain safe hot shutdown. This list was based on reviews of the Final Safety Analysis Report (FSAR), Technical Specifications, Emergency and Abnormal Operating Procedures and flow and electrical diagrams for safety systems. Mechanical and auxiliary systems necessary to support the operation of equipment on the Environmental Qualification Master List (EQML) (e.g., cooling water or lubricating systems) were also considered. The electrical equipment identified is incorporated into the EQML, which was reviewed and accepted by the NRC on May 20, 1981 (Unit 1) and June 3, 1981 (Unit 2). Subsequent to that time, electrical items which were installed due to TMI requirements and are located in a harsh environment have been added and items to be qualified under Regulatory Guide 1.97 have been identified on the EQML. With the issuance of the EQ Rule (10CFR50.49), those EQML items identified as located in a mild environment were deleted. Subsequent reviews and/or local refinements of the Environmental Zone Descriptions have identified a few additional mild environment items, which have also been deleted.

(B) Non-Safety Related Equipment - 10CFR50.49(b)(2)

The methodology for the "(b)(2)" review was submitted to the NRC by our letter dated December 1, 1983 (Serial No. 668A). In summary, paragraph (b)(2) of 10CFR50.49 requires that licensees identify "Nonsafety-related electric equipment whose failure under postulated environmental conditions could prevent satisfactory accomplishment of safety functions ...". The methodology that was used to identify such equipment is summarized below:

1. A list of safety-related electrical equipment (as defined in paragraph (b)(1) of 10CFR50.49) required to remain functional during or following design-basis Loss of Coolant Accident (LOCA) or High Energy Line Break (HELB) Accidents was generated. The LOCA/HELB accidents are the only design-basis accidents which result in significantly adverse environments to electrical equipment which is required for safe shutdown or accident mitigation. This list was based on reviews of the Final Safety Analysis Report (FSAR), Technical Specifications, Emergency and

Abnormal Operating Procedures, and flow and electrical diagrams for safety systems.

2. The elementary wiring diagrams of the safety-related electrical equipment identified in Step 1 have been reviewed to identify any auxiliary devices electrically connected directly into the control or power circuitry of the safety-related equipment (e.g., automatic trips) whose failure due to postulated environmental conditions could prevent the required operation of the safety-related equipment.
3. The operation of safety-related systems and equipment was reviewed to identify any directly mechanically connected auxiliary systems with electrical components which are necessary for the required operation of the safety-related equipment (e.g., cooling water or lubricating systems). This involved the review of electrical and flow diagrams, component technical manuals, and/or system descriptions in the FSAR.
4. Nonsafety-related electrical circuits indirectly associated with the electrical equipment identified in Step 1 by common power supply or in physical proximity were considered by a review of the original North Anna Power Station electrical design including the use of applicable industry standards (e.g., IEEE, NEMA, ANSI, UL, and NEC) and the use of properly coordinated protective relays, circuit breakers, and fuses for electrical circuit fault protection.

The failure due to environmental effects on systems and equipment identified by the process delineated in Steps 2, 3 or 4 above was reviewed for potential impact on the EQML equipment. No additional EQML equipment was identified by this review. However, the review did identify that a short circuit on certain non-safety branch circuits fed from the 120 VAC Vital Bus System could potentially degrade the voltage on the Vital Bus. Even though the likelihood of such an occurrence is low, Vepco is proceeding to install in-line fuses to protect the Vital Bus from faults on the non-safety branch circuits on Unit 2. Unit 1 modifications are complete.

(C) Post-Accident Monitoring Equipment - 10CFR50.49(b)(3)

The Post-Accident monitoring instrumentation is presently derived from Regulatory Guide 1.97, Revision 3 by comparing, on a point-by-point basis, the list of generic points in Regulatory Guide 1.97 Revision 3 with existing plant parameters. The resultant list, including the equipment to be added, was transmitted to the NRC for review on January 31, 1984 (Serial No. 054). Upon completion of the NRC review, the Category 1 and 2 variables will be added to the EQML. Certain of these items have been identified in Attachment 1 and will be qualified under the Regulatory Guide 1.97 implementation schedule.

During the March 19, 1984 meeting, the NRC staff inquired about the Vepco plans for long-term maintenance of environmentally qualified electrical equipment. We recognize this to be an important aspect of the environmental qualification program. Accordingly, we have been taking steps to integrate an effective EQ maintenance program into existing station programs. Upon complete implementation, Vepco's surveillance/maintenance program will ensure continued qualification of equipment on the EQML and will consist of the following basic components:

- Documentation of the maintenance/surveillance program and responsibilities
- Documentation of maintenance/surveillance requirements
- Control of maintenance/surveillance practices
- Maintenance/surveillance training
- Control of replacement parts
- Routine preventive maintenance, including replacement of aged parts at the end of their design life
- Failure trend analysis
- Control of maintenance/surveillance records

The continued maintenance of "qualified" electrical equipment will also depend on the incorporation of pertinent information disseminated to the industry. Such information is available from several sources, such as equipment vendors, INPO and the NRC (primarily via I&E Notices and Bulletins). Proper review of this information for applicability is performed by Vepco at both the corporate and station level and is documented. If such industry information affects the qualification status of any electrical equipment, the information will be evaluated for inclusion into the surveillance/maintenance program as discussed previously.

In order to ensure that design modifications will not adversely affect the continued environmental qualification program, the Engineering procedures will be revised to ensure EQ requirements are incorporated in Design Change Packages (DCPs) and that control of the EQML and qualification documents are addressed in future DCPs.


Vepco's aging evaluation program, which will be incorporated into the surveillance/maintenance programs as discussed above, was submitted to the NRC in the response to the initial SEI's for North Anna in mid-1981. Approval of Vepco's aging evaluation program, subject to implementation, is documented in section 4.3.6 to the TER.

With the equipment identified and qualified, or scheduled for modification or replacement, Vepco's environmental qualification program, in response to the requirements of 10CFR50.49, is in place. The essence of this program as described in this letter includes the following: (1) identification of equipment covered by the EQ rule, (2) replacement of unqualified equipment in Unit 1 and plans for replacement of unqualified equipment in Unit 2 as identified in Attachment 1, (3) the establishment of the supporting equipment qualification files and (4) the submittal of one necessary exemption request (Attachment 2) for the Hydrogen Recombiner (Vepco letter June 18, 1984 s/n 298).

The complimentary maintenance and surveillance programs are being developed and implemented based on the most recent upgrade of EQML equipment during the refueling outages. These programs will include the provisions for aging and failure trending to empirically validate and monitor service life for this equipment. The aging and failure trending analysis programs will be implemented by January 31, 1985.

Accordingly, it is requested that a supplemental SER be issued to indicate that Vepco's environmental qualification program, with the exceptions noted herein, has been implemented and that the March 24, 1983 SER deficiencies have been resolved.

Very truly yours,


W. L. Stewart

Attachments (2)

cc: Mr. James P. O'Reilly (w/attachments)
Regional Administrator
Region II
USNRC

Mr. M. W. Branch (w/attachments)
NRC Resident Inspector
North Anna Power Station

ATTACHMENT 1
STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT
NORTH ANNA POWER STATION

NOTE & CATEGORY GUIDE

NORTH ANNA

- Note 1: Qualified equipment will be installed by the second refueling outage after March 31, 1982. These outage end dates are presently scheduled for completion by 09/28/84 and 10/28/84 for Units 1 and 2 respectively.
- Note 2: Will be upgraded to Regulatory Guide 1.97 requirements and added to the Master List in accordance with our NUREG-0737 Supplement 1 response by the third refueling after March 31, 1982. These outage end dates are presently scheduled for completion by 04/07/86 and 04/21/86 for Units 1 and 2 respectively.
- Note 3: Will be upgraded to Regulatory Guide 1.97 requirements and added to the Master List in accordance with our NUREG-0737 Supplement 1 response during the 1987 refueling outages.

<u>NRC</u> <u>CATEGORY</u>	<u>CATEGORY</u> <u>DESCRIPTION</u>
I.A.	EQUIPMENT QUALIFIED
I.B	EQUIPMENT QUALIFICATION PENDING MODIFICATION REVIEW WAS NOT PERFORMED ON EQUIPMENT IDENTIFIED AS BEING REPLACED PRIOR TO COMMENCEMENT OF FAC REVIEW
II.A	EQUIPMENT QUALIFICATION NOT ESTABLISHED
II.B	EQUIPMENT NOT QUALIFIED
II.C	EQUIPMENT SATISFIES ALL REQUIREMENTS EXCEPT QUALIFIED LIFE OR REPLACEMENT SCHEDULE JUSTIFIED
III.A	EQUIPMENT EXEMPT FROM QUALIFICATION
III.B	EQUIPMENT NOT IN THE SCOPE OF THE REVIEW
IV.	DOCUMENTATION NOT MADE AVAILABLE

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
1.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
	MOV-RS-100A Casing Cooling to Outside Recirculation Spray Pump	Additional	Documentation in QDR	Qualified
	MOV-RS-155A Outside Recirculation Spray Suction	Additional	Documentation in QDR	Qualified
	MOV-RS-155B Outside Recirculation Spray Suction	Additional	Documentation in QDR	Qualified
	MOV-RS-156A Outside Recirculation Spray Discharge	Additional	Documentation in QDR	Qualified
	MOV-RS-156B Outside Recirculation Spray Discharge	Additional	Documentation in QDR	Qualified
	MOV-QS-100A Quench Spray Pump Suction	Additional	Documentation in QDR	Qualified
	MOV-QS-100B Quench Spray Pump Suction	Additional	Documentation in QDR	Qualified
	MOV-QS-101A Quench Spray Pump Discharge	Additional	Documentation in QDR	Qualified
	MOV-QS-101B Quench Spray Pump Discharge	Additional	Documentation in QDR	Qualified
9.	MOV-QS-201A Quench Spray Pump Discharge	Additional	Documentation in QDR	Qualified
9.	MOV-QS-201B Quench Spray Pump Discharge	Additional	Documentation in QDR	Qualified
9.	MOV-RS-255A Outside Recirculation Spray Suction	Additional	Documentation in QDR	Qualified
9.	MOV-RS-255B Outside Recirculation Spray Suction	Additional	Documentation in QDR	Qualified
9.	MOV-RS-256A Outside Recirculation Spray Discharge	Additional	Documentation in QDR	Qualified
9.	MOV-RS-256B Outside Recirculation Spray Discharge	Additional	Documentation in QDR	Qualified
9.	MOV-RS-200A Casing Cooling to Outside Recirculation Spray Pump	Additional	Documentation in QDR	Qualified
9.	MOV-QS-200A Quench Spray Pump Suction	Additional	Documentation in QDR	Qualified
9.	MOV-QS-200B Quench Spray Pump Suction	Additional	Documentation in QDR	Qualified
2.	LIMITORQUE MOTOR OPERATED VALVES	I.B	AGING QUALIFIED LIFE RADIATION	
9.	MOV-1890C Low Head Safety Injection Line Stop Valve	Removed	Unqualified Brake Assemblies	Qualified
	MOV-2890C Low Head Safety Injection Line Stop Valve	Removed	Unqualified Brake Assemblies	Qualified
3.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
	MOV-RS-100B Casing Cooling to Outside Recirculation Spray Pump	Additional	Documentation in QDR	Qualified
	MOV-RS-101A Casing Cooling to Outside Recirculation Spray Pump	Additional	Documentation in QDR	Qualified
9.	MOV-RS-200B Casing Cooling to Outside Recirculation Spray Pump	Additional	Documentation in QDR	Qualified
9.	MOV-RS-201A Casing Cooling to Outside Recirculation Spray Pump	Additional	Documentation in QDR	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
4.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
	MOV-1864A Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified		
	MOV-1864B Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified		
15.	MOV-2864A Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified		
15.	MOV-2864B Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified		
5.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
	MOV-1860A Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
	MOV-1860B Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
	MOV-1885A Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
	MOV-1885B Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
116.	MOV-2860A Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
116.	MOV-2860B Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
116.	MOV-2885A Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
116.	MOV-2885B Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
6.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
	MOV-1862A Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
	MOV-1862B Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
	MOV-1885C Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
	MOV-1885D Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
15.	MOV-2885C Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
15.	MOV-2885D Low Head Safety Injection Recirculation Valve	Additional	Documentation in QDR	Qualified		
15.	MOV-2862A Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		
15.	MOV-2862B Low Head Safety Injection Suction Valve	Additional	Documentation in QDR	Qualified		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
7.	LIMITORQUE MOTOR OPERATED VALVES	I.B	SIMILARITY AGING QUALIFIED LIFE	
9.	MOV-RS-101B Casing Cooling to Outside Recirculation Spray Pump MOV-RS-201B Casing Cooling to Outside Recirculation Spray Pump	Replaced Unqualified Parts Replaced Unqualified Parts		Qualified Qualified
8.	LIMITORQUE MOTOR OPERATED VALVES	I.B	AGING QUALIFIED LIFE RADIATION	
	MOV-1890A Low Head Safety Injection Line Stop Valve	Replaced Unqualified Parts		Qualified
	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
12.	MOV-2890A Low Head Safety Injection Line Stop Valve	Additional Documentation in QDR		Qualified
9.	LIMITORQUE MOTOR OPERATED VALVES	I.B	AGING QUALIFIED LIFE RADIATION	
	MOV-1890B Low Head Safety Injection Line Stop Valve	Replaced Unqualified Parts		Qualified
	MOV-1890D Low Head Safety Injection Line Stop Valve	Replaced Unqualified Parts		Qualified
9.	MOV-2890D Low Head Safety Injection Line Stop Valve	Replaced Unqualified Parts		Qualified
12.	MOV-2890B Low Head Safety Injection Line Stop Valve	Replaced Unqualified Parts		Qualified
10.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
	MOV-1867C Boron Injection Tank Outlet Valve	Additional Documentation in QDR		Qualified
16.	MOV-2867C Boron Injection Tank Outlet Valve	Additional Documentation in QDR		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT					
ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
11.		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
		MOV-1373 Charging Pump Recirculation Stop Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2373 Charging Pump Recirculation Stop Valve	Additional	Documentation in QDR	Qualified
12.		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
		MOV-1381 Seal Water Return Service	Additional	Documentation in QDR	Qualified
		MOV-1869B Charging Pump Safety Injection Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1869A Charging Pump Safety Injection Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1863B Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified
		MOV-1863A Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified
		MOV-1836 High Head Cold Leg PA Circulation Isolation Valve	Additional	Documentation in QDR	Qualified
		MOV-1270B Low Head and Volume Control Tank Discharge to Charging Pump	Additional	Documentation in QDR	Qualified
		MOV-1269B Low Head and Volume Control Tank Discharge to Charging Pump	Additional	Documentation in QDR	Qualified
		MOV-1267B Low Head Safety Injection to Charging Pump	Additional	Documentation in QDR	Qualified
		MOV-1370 Charging Pump to Seal Water Recirculation Stop Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2863A Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2863B Low Head Safety Injection Discharge Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2267B Low Head Safety Injection Charging Pump	Additional	Documentation in QDR	Qualified
6.		MOV-2269B Low Head and Volume Control Tank Discharge to Charging Pump	Additional	Documentation in QDR	Qualified
6.		MOV-2270B Low Head and Volume Control Tank Discharge to Charging Pump	Additional	Documentation in QDR	Qualified
6.		MOV-2370 Charging Pump to Seal Water Recirculation Stop Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2869A Charging Pump Safety Injection Stop Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2869B Charging Pump Safety Injection Stop Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2836 Cold Leg Circulation Valve	Additional	Documentation in QDR	Qualified
6.		MOV-2381 Seal Water Return Service	Additional	Documentation in QDR	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

13.		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
		MOV-1275C Charging Pump Recirculation Stop Valve		Additional Documentation in QDR	Qualified
		MOV-1275B Charging Pump Recirculation Stop Valve		Additional Documentation in QDR	Qualified
		MOV-1275A Charging Pump Recirculation Stop Valve		Additional Documentation in QDR	Qualified
6.		MOV-2275A Charging Pump Recirculation Stop Valve		Additional Documentation in QDR	Qualified
6.		MOV-2275C Charging Pump Recirculation Stop Valve		Additional Documentation in QDR	Qualified
		LIMITORQUE MOTOR OPERATED VALVES	I.B	DOCUMENTATION	
3.		MOV-2275B Charging Pump Recirculation Stop Valve		Replaced Unqualified Parts	Qualified
14.		LIMITORQUE MOTOR OPERATED VALVES	I.B	AGING QUALIFIED LIFE RADIATION	
		MOV-1115D Charging Pump Suction From Refueling Water Storage Tank		Replaced Unqualified Parts	Qualified
		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
5.		MOV-2115D Charging Pump Suction from Refueling Water Storage Tank		Additional Documentation in QDR	Qualified
15.		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
		MOV-1286B Charging Pump Discharge Valve		Additional Documentation in QDR	Qualified
7.		MOV-2286B Charging Pump Discharge Valve		Additional Documentation in QDR	Qualified
16.		LIMITORQUE MOTOR OPERATED VALVES	I.B	SIMILARITY AGING QUALIFIED LIFE	
		MOV-1269A Low Head Safety Injection and Volume Control Tank Discharge Valve		Replaced Unqualified Parts	Qualified
		MOV-1115B Charging Pump Suction From Refueling Water Storage Tank Valve		Replaced Unqualified Parts	Qualified
7A.		MOV-2269A Low Head Safety Injection and Volume Control Tank Discharge Valve		Replaced Unqualified Parts	Qualified
7A.		MOV-2115B Charging Pump Suction From Refueling Water Storage Tank Valve		Replaced Unqualified Parts	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
17.		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
		MOV-1270A Low Head Safety Injection and Volume Control Tank Discharge Valve	Additional	Documentation in QDR	Qualified
		MOV-1267A Low Head Safety Injection to Charging Pump	Additional	Documentation in QDR	Qualified
		MOV-1867D Boron Injection Tank Outlet Valve	Additional	Documentation in QDR	Qualified
		MOV-1867B Boron Injection Tank Inlet Valve	Additional	Documentation in QDR	Qualified
		MOV-1867A Boron Injection Tank Inlet Valve	Additional	Documentation in QDR	Qualified
		MOV-1287C Charging Pump Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1287B Charging Pump Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1287A Charging Pump Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1289B Charging Pump Discharge Line Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1289A Charging Pump Discharge Line Stop Valve	Additional	Documentation in QDR	Qualified
		MOV-1286C Charging Pump Discharge Valve	Additional	Documentation in QDR	Qualified
		MOV-1286A Charging Pump Discharge Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2286A Charging Pump Discharge Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2286C Charging Pump Discharge Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2287A Charging Pump Stop Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2287B Charging Pump Stop Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2287C Charging Pump Stop Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2867A Boron Injection Tank Inlet Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2867B Boron Injection Tank Inlet Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2867D Boron Injection Tank Outlet Valve	Additional	Documentation in QDR	Qualified
7.		MOV-2267A Low Head Safety Injection To Charging Pump	Additional	Documentation in QDR	Qualified
7A.		MOV-2289A Charging Pump Discharge Line Stop Valve	Additional	Documentation in QDR	Qualified
7A.		MOV-2289B Charging Pump Discharge Line Stop Valve	Additional	Documentation in QDR	Qualified
7A.		MOV-2270A Low Head Safety Injection and Volume Control Tank Discharge Valve	Additional	Documentation in QDR	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
18.		LIMITORQUE MOTOR OPERATED VALVES	I.B	SIMILARITY AGING QUALIFIED LIFE	
		MOV-SW-101A Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-101B Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-101C Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-101D Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-105A Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-105B Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-105C Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-105D Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
		MOV-SW-106A Recirculation Spray Heat Exchanger Header Outlet Crossover	Replaced	Unqualified Parts	Qualified
		MOV-SW-106B Recirculation Spray Heat Exchanger Header Outlet Crossover	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-201A Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-201B Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-201C Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-201D Recirculation Spray Heat Exchanger Header Inlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-205A Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-205B Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-205C Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-205D Recirculation Spray Heat Exchanger Header Outlet	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-206A Recirculation Spray Heat Exchanger Header Outlet Crossover	Replaced	Unqualified Parts	Qualified
6.		MOV-SW-206B Recirculation Spray Heat Exchanger Header Outlet Crossover	Replaced	Unqualified Parts	Qualified
		LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
10.		MOV-SW-214A Recirculation Air Cooling Coils Supply	Deleted	R-4 Dated 9/31/81 to 0586	Deleted
10.		MOV-SW-214B Recirculation Air Cooling Coils Supply	Deleted	R-4 Dated 9/31/81 to 0588	Deleted
10.		MOV-SW-210A Recirculation Air Cooling Coils Supply	Deleted	R-4 Dated 9/31/81 to 0588	Deleted
10.		MOV-SW-210B Recirculation Air Cooling Coils Supply	Deleted	R-4 Dated 9/31/81 to 0588	Deleted

*STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2*

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
19.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
	MOV-SW-103A Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
	MOV-SW-103B Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
	MOV-SW-103C Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
	MOV-SW-103D Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
	MOV-SW-104A Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
	MOV-SW-104B Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
	MOV-SW-104D Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
4.	MOV-SW-203A Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
4.	MOV-SW-203C Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
4.	MOV-SW-203D Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
4.	MOV-SW-204B Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
4.	MOV-SW-204D Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
6.	MOV-SW-203B Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
6.	MOV-SW-204A Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
20.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
	MOV-SW-104C Service Water to Recirculation Spray Cooler		Deleted R-4 dated 8/24/81 - 79-016	Deleted
4.	MOV-SW-204C Service Water to Recirculation Spray Cooler		Additional Documentation in QDR	Qualified
21.	LIMITORQUE MOTOR OPERATED VALVES	I.B	SIMILARITY AGING QUALIFIED LIFE	
	MOV-SW-108B Component Cooling Heat Exchanger Supply Isolation Valve		Replaced Unqualified Parts	Qualified
2.	MOV-SW-208B Component Cooling Heat Exchanger Supply Isolation Valve		Replaced Unqualified Parts	Qualified
22.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
	MOV-1350 Emergency Blender By-Pass Stop Valve		Additional Documentation in QDR	Qualified
	LIMITORQUE MOTOR OPERATED VALVES	I.B	AGING QUALIFIED LIFE RADIATION	
1.	MOV-2350 Emergency Blender By-Pass Stop Valve		Replaced Unqualified Parts	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
23.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
2.	MOV-SW-113A Component Cooling Fuel Pit Coolers Return Isolation MOV-SW-213A Component Cooling Fuel Pit Coolers Return Isolation		Additional Documentation in QDR Additional Documentation in QDR	Qualified Qualified		
24.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
2.	MOV-SW-108A Component Cooling Heat Exchanger Supply Isolation MOV-SW-113B Component Cooling Fuel Pit Coolers Supply Isolation MOV-SW-208A Component Cooling Heat Exchanger Supply Isolation MOV-SW-213B Component Cooling Fuel Pit Coolers Supply Isolation		Additional Documentation in QDR Additional Documentation in QDR Additional Documentation in QDR Additional Documentation in QDR	Qualified Qualified Qualified Qualified		
25.	LIMITORQUE MOTOR OPERATED VALVES	I.B	SIMILARITY AGING QUALIFIED LIFE			
	MOV-1115C Charging Pump Suction From Volume Control Tank		Replaced Unqualified Parts	Qualified		
	LIMITORQUE MOTOR OPERATED VALVE	I.B	DOCUMENTATION			
115.	MOV-2115C Charging Pump Suction From Volume Control Tank		Replaced Unqualified Parts	Qualified		
26.	LIMITORQUE MOTOR OPERATED VALVES	II.C	AGING QUALIFIED LIFE			
11.	MOV-1380 Reactor Coolant Pump Sealwater Return MOV-2380 Reactor Coolant Pump Sealwater Return		Additional Documentation in QDR Additional Documentation in QDR	Qualified Qualified		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
27.	LIMITORQUE MOTOR OPERATED VALVES	III.A	NONE	
	MOV-1865A Accumulator Tank 1 Cold Leg	Deleted R-4 dated 8/24/81 to 79-01B		Deleted
	MOV-1865B Accumulator Tank 2 Cold Leg	Deleted R-4 dated 8/24/81 to 79-01B		Deleted
	MOV-1865C Accumulator Tank 3 Cold Leg	Deleted R-4 dated 8/24/81 to 79-01B		Deleted
13.	MOV-2865A Accumulator Tank 1 Cold Leg	Deleted R-4 dated 8/24/81 to 0588		Deleted
13.	MOV-2865B Accumulator Tank 2 Cold Leg	Deleted R-4 dated 8/24/81 to 0588		Deleted
13.	MOV-2865C Accumulator Tank 3 Cold Leg	Deleted R-4 dated 8/24/81 to 0588		Deleted
27A	RAYMOND CONTROLS MOTOR OPERATED VALVES & STRAINERS	III.A	NONE	
	MOV-HV-115-1 Flush Valve Left for Strainer	Qualified Backup Available		Qualified
	MOV-HV-115-2 Flush Valve Right for Strainer	Qualified Backup Available		Qualified
	MOV-HV-116-1 Flush Valve Left for Strainer	Qualified Backup Available		Qualified
	MOV-HV-116-2 Flush Valve Right for Strainer	Qualified Backup Available		Qualified
	HV-S-1A Chiller Room Strainer	Qualified Backup Available		Qualified
	HV-S-1B Chiller Room Strainer	Qualified Backup Available		Qualified
17.	MOV-HV-215-1 Flush Valve Left for Strainer	Qualified Backup Available		Qualified
17.	MOV-HV-216-1 Flush Valve Left for Strainer	Qualified Backup Available		Qualified
17.	MOV-HV-215-2 Flush Valve Right for Strainer	Qualified Backup Available		Qualified
17.	MOV-HV-216-2 Flush Valve Right for Strainer	Qualified Backup Available		Qualified
100.	HV-S-1A Self-cleaning Strainer	Qualified Backup Available		Qualified
100.	HV-S-1B Self-cleaning Strainer	Qualified Backup Available		Qualified
136.	LIMITORQUE MOTOR OPERATED VALVES	I.B	AGING QUALIFIED LIFE	
	MOV-1115E Charging Pump Suction - Volume Control Tank	Replaced Unqualified Parts		Qualified
	LIMITORQUE MOTOR OPERATED VALVES	I.B	DOCUMENTATION	
3.	MOV-2115E Charging Pump Suction - Volume Control Tank	Replaced Unqualified Parts		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

DESCRIPTION		NRC CATEGORY	DEFICIENCY	RESOLUTION
137.	LIMITORQUE MOTOR OPERATED VALVES	I.B	DOCUMENTATION	
	MOV-HV-100C Containment Purge Supply	Deleted R-4 dated 8/24/81 to 79-01B		Deleted
	MOV-HV-100A Containment Purge Supply	Deleted R-4 dated 8/24/81 to 79-01B		Deleted
	LIMITORQUE MOTOR OPERATED VALVES	II.A	DOCUMENTATION	
8.	MOV-HV-200A Containment Purge Supply	Deleted R-4 dated 9/31/81 to 0588		Deleted
8.	MOV-HV-200C Containment Purge Supply	Deleted R-4 dated 9/31/81 to 0588		Deleted
14.	MOV-HV-200D Reactor Coolant Purge System Exhaust Valve	Deleted R-4 dated 9/31/81 to 0588		Deleted
14.	MOV-HV-201 Reactor Coolant Purge System Bypass Valve	Deleted R-4 dated 9/31/81 to 0588		Deleted
14.	MOV-HV-200B Reactor Coolant Purge System Valve	Deleted R-4 dated 9/31/81 to 0588		Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

DESCRIPTION		NRC CATEGORY	DEFICIENCY	RESOLUTION
28.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1519 Primary Grade Water to Pressurizer Relief Tank	Replaced with ASCO NP Series		Qualified
22.	SOV-2519A Primary Grade Water to Pressurizer Relief Tank	Replaced with ASCO NP Series		Qualified
29.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1859 Safety Injection Test Line	Replaced with ASCO NP Series		Qualified
22.	SOV-2859 Safety Injection Test Line	Replaced with ASCO NP Series		Qualified
30.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1884A Boron Injection Tank to Boric Acid	Replaced with ASCO NP Series		Qualified
	SOV-1884B Boron Injection Tank to Boric Acid	Replaced with ASCO NP Series		Qualified
	SOV-1884C Boron Injection Tank to Batch Tank	Replaced with ASCO NP Series		Qualified
22.	SOV-2884A Boron Injection Tank to Boric Acid	Replaced with ASCO NP Series		Qualified
22.	SOV-2884B Boron Injection Tank to Boric Acid	Replaced with ASCO NP Series		Qualified
22.	SOV-2884C Boron Injection Tank to Batch Tank	Replaced with ASCO NP Series		Qualified
31.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-SS-100B Pressurizer Liquid Sample Space Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-101B Pressurizer Vapor Space Sample Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-112B Steam Generator Sample Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-106B Primary Coolant Hot Leg Sample Isolation Valve	Replaced with Valcor SOV-TV-SS-106		Deleted
	SOV-SS-102B Primary Coolant Cold Leg Sample Isolation Valve	Replaced with Valcor SOV-TV-SS-102B		Deleted
	SOV-SS-104B Pressurizer Relief Tank Gas Space Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-103A Residual Heat Removal Outboard Isolation Valve	Replaced with Valcor SOV-TV-SS-103A		Deleted
	SOV-SS-103B Residual Heat Removal Outboard Isolation Valve	Replaced with Valcor SOV-TV-SS-103B		Deleted
26.	SOV-SS-200B Pressurizer Liquid Sample Space Isolation Valve			Note 1
26.	SOV-SS-212B Steam Generator Sample Isolation Valve			Note 1
26.	SOV-SS-201B Pressurizer Vapor Space Sample Isolation Valve			Note 1
26.	SOV-SS-204B Pressurizer Relief Tank Gas Space Isolation Valve			Note 1
	ASCO SOLENOID OPERATED VALVES	I.B	AGING QUALIFIED LIFE AGING SIMULATION	
27.	SOV-SS-206B Primary Coolant Hot Leg Sample Isolation Valve	Replaced with Valcor SOV-TV-SS-206B		Deleted
27.	SOV-SS-202B Primary Coolant Cold Leg Sample Isolation Valve	Replaced with Valcor SOV-TV-SS-202B		Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

31A

VALCOR TRIP VALVES

NRC
CATEGORY

DEFICIENCY

RESOLUTION

I.A

None

	TV-HC-100A	Hydrogen Analyzer #1 Suction		Qualified
	TV-HC-100B	Hydrogen Analyzer #1 Suction		Qualified
	TV-HC-101A	Hydrogen Analyzer #1 Discharge		Qualified
	TV-HC-101B	Hydrogen Analyzer #1 Discharge		Qualified
	TV-HC-102A	Hydrogen Analyzer #2 Suction		Qualified
	TV-HC-102B	Hydrogen Analyzer #2 Suction		Qualified
	TV-HC-103A	Hydrogen Analyzer #2 Discharge		Qualified
	TV-HC-103B	Hydrogen Analyzer #2 Discharge		Qualified
	TV-SS-102A	Primary Coolant Cold Leg Sample		Qualified
	TV-SS-102B	Primary Coolant Cold Leg Sample		Qualified
	TV-SS-103A	Residual Heat Removal System Sample		Qualified
	TV-SS-103B	Residual Heat Removal System Sample		Qualified
	TV-SS-106A	Primary Coolant Hot Leg Sample		Qualified
	TV-SS-106B	Primary Coolant Hot Leg Sample		Qualified
	TV-SS-107A	Residual Heat Removal System Sample		Qualified
	TV-SS-107B	Residual Heat Removal System Sample		Qualified
	TV-SS-108D	Primary Coolant Hot Leg Sample		Qualified
	TV-SS-109A	Primary Coolant Cold Leg Sample		Qualified
36A	TV-HC-200A	Hydrogen Analyzer #1 Suction		Qualified
36A	TV-HC-200B	Hydrogen Analyzer #1 Suction	NuReg-0737	Note 1
36A	TV-HC-201A	Hydrogen Analyzer #1 Discharge	NuReg-0737	Note 1
36A	TV-HC-201B	Hydrogen Analyzer #1 Discharge	NuReg-0737	Note 1
36A	TV-HC-202A	Hydrogen Analyzer #2 Suction	NuReg-0737	Note 1
36A	TV-HC-202B	Hydrogen Analyzer #2 Suction	NuReg-0737	Note 1
36A	TV-HC-203A	Hydrogen Analyzer #2 Discharge	NuReg-0737	Note 1
36A	TV-HC-203B	Hydrogen Analyzer #2 Discharge	NuReg-0737	Note 1
36A	TV-SS-202A	Primary Coolant Cold Leg Sample	NuReg-0737	Note 1
36A	TV-SS-202B	Primary Coolant Cold Leg Sample	NuReg-0737	Note 1
36A	TV-SS-203A	Residual Heat Removal System Sample	NuReg-0737	Note 1
36A	TV-SS-203B	Residual Heat Removal System Sample	NuReg-0737	Note 1
36A	TV-SS-206A	Primary Coolant Hot Leg Sample	NuReg-0737	Note 1
36A	TV-SS-206B	Primary Coolant Hot Leg Sample	NuReg-0737	Note 1
36A	TV-SS-207A	Residual Heat Removal System Sample	NuReg-0737	Note 1
36A	TV-SS-207B	Residual Heat Removal System Sample	NuReg-0737	Note 1
36A	TV-SS-208D	Primary Coolant Hot Leg Sample	NuReg-0737	Note 1
36A	TV-SS-209A	Primary Coolant Cold Leg Sample	NuReg-0737	Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
32.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-CC-100A	Replaced with	ASCO NP Series	Qualified
	SOV-CC-100B	Replaced with	ASCO NP Series	Qualified
	SOV-CC-100C	Replaced with	ASCO NP Series	Qualified
	SOV-CC-101A	Replaced with	ASCO NP Series	Qualified
	SOV-BD-100A	Replaced with	ASCO NP Series	Qualified
	SOV-BD-100C	Replaced with	ASCO NP Series	Qualified
	SOV-BD-100E	Replaced with	ASCO NP Series	Qualified
	SOV-CC-102A	Replaced with	ASCO NP Series	Qualified
	SOV-CC-102C	Replaced with	ASCO NP Series	Qualified
	SOV-CC-102E	Replaced with	ASCO NP Series	Qualified
	SOV-CC-103A	Replaced with	ASCO NP Series	Qualified
	SOV-CC-103B	Replaced with	ASCO NP Series	Qualified
	SOV-CC-104A-1	Replaced with	ASCO NP Series	Qualified
	SOV-CC-104A-2	Replaced with	ASCO NP Series	Qualified
	SOV-CC-104B-1	Replaced with	ASCO NP Series	Qualified
	SOV-CC-104B-2	Replaced with	ASCO NP Series	Qualified
	SOV-CC-104C-1	Replaced with	ASCO NP Series	Qualified
	SOV-CC-104C-2	Replaced with	ASCO NP Series	Qualified
	SOV-CV-150A	Replaced with	ASCO NP Series	Qualified
	SOV-CV-150B	Replaced with	ASCO NP Series	Qualified
	SOV-CV-150C	Replaced with	ASCO NP Series	Qualified
	SOV-CV-150D	Replaced with	ASCO NP Series	Qualified
	SOV-SI-101	Replaced with	ASCO NP Series	Qualified
	SOV-SI-100B	Replaced with	ASCO NP Series	Qualified
	SOV-SI-100A	Replaced with	ASCO NP Series	Qualified
	SOV-RM-100A	Replaced with	ASCO NP Series	Qualified
	SOV-RM-100B	Replaced with	ASCO NP Series	Qualified
	SOV-RM-100D	Replaced with	ASCO NP Series	Qualified
	SOV-VG-100A	Replaced with	ASCO NP Series	Qualified
	SOV-DG-100A	Replaced with	ASCO NP Series	Qualified
	SOV-DA-100A	Replaced with	ASCO NP Series	Qualified
24.	SOV-CC-204A-1	Replaced with	ASCO NP Series	Qualified
24.	SOV-CC-204A-2	Replaced with	ASCO NP Series	Qualified
24.	SOV-CC-204B-1	Replaced with	ASCO NP Series	Qualified
24.	SOV-CC-204B-2	Replaced with	ASCO NP Series	Qualified
24.	SOV-CC-204C-1	Replaced with	ASCO NP Series	Qualified
24.	SOV-CC-204C-2	Replaced with	ASCO NP Series	Qualified
24.	SOV-DA-200A	Replaced with	ASCO NP Series	Qualified
24.	SOV-RM-200A	Replaced with	ASCO NP Series	Qualified
24.	SOV-RM-200B	Replaced with	ASCO NP Series	Qualified
24.	SOV-RM-200D	Replaced with	ASCO NP Series	Qualified
24.	SOV-CV-250A	Replaced with	ASCO NP Series	Qualified
24.	SOV-CV-250B	Replaced with	ASCO NP Series	Qualified
24.	SOV-CV-250C	Replaced with	ASCO NP Series	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
32.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
24.		SOV-CV-250D Containment Vacuum Pump Suction	Replaced with ASCO NP Series		Qualified
24.		SOV-BD-200A Steam Generator Blowdown Isolation	Replaced with ASCO NP Series		Qualified
24.		SOV-BD-200C Steam Generator Blowdown Isolation	Replaced with ASCO NP Series		Qualified
24.		SOV-BD-200E Steam Generator Blowdown Isolation	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-200A Containment Recirculation Air Cooler Outlet	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-200B Containment Recirculation Air Cooler Outlet	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-200C Containment Recirculation Air Cooler Outlet	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-201A Reactor Coolant Pump Thermal Barrier Return Header	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-202A Reactor Coolant Pump Coolers Return Header	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-202C Reactor Coolant Pump Coolers Return Header	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-202E Reactor Coolant Pump Coolers Return Header	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-203A Residual Heat Removal Heat Exchanger Return	Replaced with ASCO NP Series		Qualified
24.		SOV-CC-203B Residual Heat Removal Heat Exchanger Return	Replaced with ASCO NP Series		Qualified
24.		SOV-SI-200A Nitrogen Supply Line	Replaced with ASCO NP Series		Qualified
24.		SOV-SI-200B Nitrogen Supply Line	Replaced with ASCO NP Series		Qualified
24.		SOV-SI-201 Nitrogen Supply Line	Replaced with ASCO NP Series		Qualified
24.		SOV-VG-200A Primary Drain Transfer Tank Vent	Replaced with ASCO NP Series		Qualified
		ASCO SOLENOID OPERATED VALVES	II.A	AGING QUALIFIED LIFE AGING DEGRADATION AGING SIMULATION	
26.		SOV-DG-200A Primary Drain Transfer Pump Discharge			Note 1
33.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
		SOV-HV-115B-1 Iodine Filter Bank Isolation Supply	Replaced with ASCO NP Series		Qualified
		SOV-HV-115B-2 Iodine Filter Bank Isolation Supply	Replaced with ASCO NP Series		Qualified
19.		SOV-HV-215B-1 Iodine Filter Bank Isolation Supply	Replaced with ASCO NP Series		Qualified
19.		SOV-HV-215B-2 Iodine Filter Bank Isolation Supply	Replaced with ASCO NP Series		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT					
ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
34.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
		SOV-LM-101D Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
		SOV-LM-101C Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
		SOV-LM-101B Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
		SOV-LM-101A Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
23.		SOV-LM-201A Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
23.		SOV-LM-201B Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
23.		SOV-LM-201C Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
23.		SOV-LM-201D Containment Leakage Monitoring		Replaced with ASCO NP Series	Qualified
35.		ASCO SOLENOID OPERATED VALVES	II.C	QUALIFIED LIFE	
		SOV-DA-103A Post Accident Sample System Containment Return Line		Conax Seal Installed	Qualified
		SOV-DA-103B Post Accident Sample System Containment Return Line		Conax Seal Installed	Qualified
		ASCO SOLENOID OPERATED VALVES	II.C	AGING QUALIFIED LIFE	
28.		SOV-DA-203A Post Accident Sample System Containment Return Line			Note 1
28.		SOV-DA-203B Post Accident Sample System Containment Return Line			Note 1
36.		ASCO SOLENOID OPERATED VALVES	III.A	NONE	
		SOV-1460B Letdown Line Loop 2		Deleted R-4 dated 8/24/81 - 79-01B	Deleted
21.		SOV-2460B Letdown Line Loop 2		Deleted R-4 dated 9/3/81 - 0588	Deleted
37.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
		SOV-1200C-2 Chemical Volume Control System Isolation Valve for Letdown		Replaced with ASCO NP Series	Qualified
35.		SOV-2200C-2 Chemical Volume Control System Isolation Valve for Letdown		Replaced with ASCO NP Series	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
38.	ASCO SOLENOID OPERATED VALVES	II.C	DOCUMENTATION			
	SOV-IA-102B Containment Instrument Air Isolation Valve	Replaced with ASCO NP Series		Qualified		
	SOV-IA-102A Containment Instrument Air Isolation Valve	Replaced with ASCO NP Series		Qualified		
24.	SOV-IA-202A Containment Instrument Air Isolation Valve	Replaced with ASCO NP Series		Qualified		
24.	SOV-IA-202B Containment Instrument Air Isolation Valve	Replaced with ASCO NP Series		Qualified		
39.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION			
	SOV-MS-111A Auxilliary Feed Pump Turbine Drive	Replaced with ASCO NP Series		Qualified		
	SOV-MS-111B Auxilliary Feed Pump Turbine Drive	Replaced with ASCO NP Series		Qualified		
25.	SOV-MS-211A Auxilliary Feed Pump Turbine Drive	Replaced with ASCO NP Series		Qualified		
25.	SOV-MS-211B Auxilliary Feed Pump Turbine Drive	Replaced with ASCO NP Series		Qualified		
40.	ASCO SOLENOID OPERATED VALVES	II.C	AGING DEGRADATION			
	SOV-SW-101A-2 Air Cooler Emergency Supply Valve	Replaced with ASCO NP Series		Qualified		
	SOV-SW-101A-1 Air Cooler Emergency Supply Valve	Replaced with ASCO NP Series		Qualified		
	SOV-SW-101B-1 Air Cooler Emergency Return Valve	Replaced with ASCO NP Series		Qualified		
	SOV-SW-101B-2 Air Cooler Emergency Return Valve	Replaced with ASCO NP Series		Qualified		
26.	SOV-SW-201A-1 Air Cooler Emergency Supply Valve			Note 1		
26.	SOV-SW-201A-2 Air Cooler Emergency Supply Valve			Note 1		
26.	SOV-SW-201B-1 Air Cooler Emergency Return Valve			Note 1		
26.	SOV-SW-201B-2 Air Cooler Emergency Return Valve			Note 1		
41.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION			
	SOV-MS-101C-2 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified		
22.	SOV-MS-201C-2 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified		
22.	SOV-MS-201C-4 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified		
22.	SOV-MS-201C-5 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
42.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
		SOV-MS-101C-1 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
		SOV-MS-101B-2 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
		SOV-MS-101B-1 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
		SOV-MS-101A-2 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
		SOV-MS-101A-1 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
27.		SOV-MS-201A-1 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201A-2 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201A-4 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201A-5 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201B-1 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201B-2 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201B-4 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201B-5 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
22.		SOV-MS-201C-1 Main Steam Line Trip	Replaced with ASCO NP Series		Qualified
43.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
		SOV-MS-109A Main Steam Line Drains to Condenser	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-209A Main Steam Line Drains to Condenser	Replaced with ASCO NP Series		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
44.		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
		SOV-MS-113C1 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-MS-113C2 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-MS-113B1 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-MS-113B2 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-MS-113A1 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-MS-113A2 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-MS-109B Main Steam Line Letdown Control	Replaced with ASCO NP Series		Qualified
		SOV-SV-102-1 Air Ejector Discharge Trip Valve	Replaced with ASCO NP Series		Qualified
		SOV-SV-103 Air Ejector Discharge Trip Valve	Replaced with ASCO NP Series		Qualified
		ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION SIMILARITY AGING QUALIFIED LIFE AGING SIMULATION	
18.		SOV-MS-213A-1 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-213A-2 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-213B-1 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-213B-2 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-213C-1 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-213C-2 Steam Generator Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-MS-209B Main Steam Line Letdown Control	Replaced with ASCO NP Series		Qualified
18.		SOV-SV-202-1 Air Ejector Discharge Trip Valve	Replaced with ASCO NP Series		Qualified
18.		SOV-SV-203 Air Ejector Discharge Trip Valve	Replaced with ASCO NP Series		Qualified
45.		ASCO SOLENOID OPERATED VALVES	II.B	AGING DEGRADATION	
		SOV-BD-100D Steam Generator Blowdown Isolation Valve	Replaced with ASCO NP Series		Qualified
		SOV-BD-100F Steam Generator Blowdown Isolation Valve	Replaced with ASCO NP Series		Qualified
29.		SOV-BD-200D Steam Generator Blowdown Isolation Valve			Note 1
29.		SOV-BD-200F Steam Generator Blowdown Isolation Valve			Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
46.	ASCO SOLENOID OPERATED VALVES	II.C	AGING DEGRADATION			
	SOV-VG-100B Primary Drain Transfer Tank Vent	Replaced with ASCO NP Series		Qualified		
	SOV-DG-100B Primary Drain Transfer Pump Discharge	Replaced with ASCO NP Series		Qualified		
	SOV-BD-100G Steam Generator Blowdown Isolation Valve	Replaced with ASCO NP Series		Qualified		
	SOV-BD-100B Steam Generator Blowdown Isolation Valve	Replaced with ASCO NP Series		Qualified		
	ASCO SOLENOID OPERATED VALVES	II.A	DOCUMENTATION AGING QUALIFIED LIFE			
29.	SOV-BD-200B Steam Generator Blowdown Isolation Valve			Note 1		
29.	SOV-BD-200G Steam Generator Blowdown Isolation Valve			Note 1		
29.	SOV-VG-200B Primary Drain Transfer Tank Vent			Note 1		
	ASCO SOLENOID OPERATED VALVES	I.B	PEAK TEMPERATURE			
31.	SOV-DG-200B Primary Drain Transfer Pump Discharge	Replaced with ASCO NP Series		Qualified		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
47.	ASCO SOLENOID OPERATED VALVES	II.C	AGING DEGRADATION	
	SOV-BD-100H Steam Generator Blowdown Isolation Valve		Replaced with ASCO NP Series	Qualified
	SOV-BD-100J Steam Generator Blowdown Isolation Valve		Replaced with ASCO NP Series	Qualified
	SOV-RM-100C Radiation Monitoring Isolation Supply		Replaced with ASCO NP Series	Qualified
	SOV-DA-100B Containment Sump Pump Discharge Isolation Valve		Replaced with ASCO NP Series	Qualified
	SOV-CC-105C Containment Recirculation Air Cooler Outlet		Replaced with ASCO NP Series	Qualified
	SOV-CC-105B Containment Recirculation Air Cooler Outlet		Replaced with ASCO NP Series	Qualified
	SOV-CC-105A Containment Recirculation Air Cooler Outlet		Replaced with ASCO NP Series	Qualified
	SOV-CC-102F Reactor Coolant Pump Cooler Return Header		Replaced with ASCO NP Series	Qualified
	SOV-CC-102D Reactor Coolant Pump Cooler Return Header		Replaced with ASCO NP Series	Qualified
	SOV-CC-102B Reactor Coolant Pump Cooler Return Header		Replaced with ASCO NP Series	Qualified
	SOV-CC-101B Reactor Coolant Pump Thermal Barrier Return Header		Replaced with ASCO NP Series	Qualified
	ASCO SOLENOID OPERATED VALVES	II.A	DOCUMENTATION AGING QUALIFIED LIFE	
29.	SOV-BD-200H Steam Generator Blowdown Isolation Valve			Note 1
29.	SOV-CC-202B Reactor Coolant Pump Bearing Cooling Water			Note 1
29.	SOV-CC-202D Reactor Coolant Pump Bearing Cooling Water			Note 1
29.	SOV-CC-202F Reactor Coolant Pump Bearing Cooling Water			Note 1
29.	SOV-CC-201B Reactor Coolant Pump Thermal Barrier Header			Note 1
29.	SOV-CC-205A Containment Recirculation Air Cooler Outlet			Note 1
29.	SOV-CC-205B Containment Recirculation Air Cooler Outlet			Note 1
29.	SOV-CC-205C Containment Recirculation Air Cooler Outlet			Note 1
29.	SOV-DA-200B Containment Sump Pump Discharge Isolation Valve			Note 1
29.	SOV-RM-200C Radiation Monitoring Isolation Supply			Note 1
	ASCO SOLENOID OPERATED VALVE	I.B	PEAK TEMPERATURE	
31.	SOV-BD-200J Steam Generator Blowdown Isolation Valve		Replaced with ASCO NP Series	Qualified
48.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1842 Accumulator Test Line Isolation		Replaced with ASCO NP Series	Qualified
32.	SOV-2842 Accumulator Test Line Isolation		Replaced with ASCO NP Series	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
48A	ASCO SOLELOID OPERATED VALVES	I.A	NONE	
	SOV-HC-104A Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation			Qualified
	SOV-HC-104B Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation			Qualified
	SOV-HC-105A Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation			Qualified
	SOV-HC-105B Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation			Qualified
	SOV-HC-106A Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation			Qualified
	SOV-HC-106B Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation			Qualified
	SOV-HC-107A Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation			Qualified
	SOV-HC-107B Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation			Qualified
48B	SOV-HC-204A Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-204B Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-205A Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-205B Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-206A Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-206B Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-207A Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation	NuReg-0737		Note 1
48B	SOV-HC-207B Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation	NuReg-0737		Note 1
49.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-SS-112A Steam Generator Surface Sample Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-100A Pressurizer Liquid Space Sample Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-106A Primary Coolant Hot Leg Sampling Containment Isolation Valve	Replaced with Valcor SOV-TV-SS-106A		Deleted
	SOV-SS-104A Pressurizer Relief Tank Gas Space Sample Isolation Valve	Replaced with ASCO NP Series		Qualified
	SOV-SS-102A Primary Coolant Cold Leg Sample Containment Isolation Valve	Replaced with Valcor SOV-TV-SS-102A		Deleted
	SOV-SS-101A Pressurizer Vapor Space Sample Isolation Valve	Replaced with ASCO NP Series		Qualified
29.	SOV-SS-200A Pressurizer Liquid Space Sample Isolation Valve			Note 1
29.	SOV-SS-201A Pressurizer Vapor Space Sample Isolation Valve			Note 1
29.	SOV-SS-204A Pressurizer Relief Tank Gas Space Sample Isolation Valve			Note 1
29.	SOV-SS-212A Steam Generator Sample Isolation Valve			Note 1
30.	SOV-SS-202A Primary Coolant Cold Leg Sample Containment Isolation Valve	Replaced with Valcor SOV-TV-SS-202A		Deleted
34.	SOV-2311 Auxiliary Spray Line	Deleted Sept. 3, 1981 Submittal		Deleted
36.	SOV-SS-207A Residual Heat Removal Sample Line	Replaced with Valcor SOV-TV-SS-207A		Deleted
36.	SOV-SS-207B Residual Heat Removal Sample Line	Replaced with Valcor SOV-TV-SS-207B		Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
50.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-LM-100C Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100D Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100E Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100F Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100G Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100H Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100B Containment Open Tap	Replaced with ASCO NP Series		Qualified
	SOV-LM-100A Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200A Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200B Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200C Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200D Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200E Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200F Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200G Containment Open Tap	Replaced with ASCO NP Series		Qualified
20.	SOV-LM-200H Containment Open Tap	Replaced with ASCO NP Series		Qualified
51.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1936 Accumulator Vent Line Flow Control	Replaced with ASCO NP Series		Qualified
33.	SOV-2936 Accumulator Vent Line Flow Control	Replaced with ASCO NP Series		Qualified
52.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1200A-1 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified
34.	SOV-2200A-1 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified
53.	ASCO ₂ SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1200B-2 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified
35.	SOV-2200B-2 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified
54.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION	
	SOV-1200A-2 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified
35.	SOV-2200A-2 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
55.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION			
	SOV-1200C-1 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified		
	SOV-1200B-1 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified		
34.	SOV-2200B-1 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified		
34.	SOV-2200C-1 Chemical Volume Control System Isolation Valve for Letdown	Replaced with ASCO NP Series		Qualified		
24.	SOV-IA-201B Containment Instrument Air Isolation Valve	Replaced with ASCO NP Series		Qualified		
55A	VALCOR SOLENOID OPERATED VALVES	I.A	NONE			
	TV-HC-108A Containment Atmospheric Sampling Isolation			Qualified		
	TV-HC-108B Containment Atmospheric Sampling Isolation			Qualified		
	TV-HC-109A Containment Atmospheric Sampling Isolation			Qualified		
	TV-HC-109B Containment Atmospheric Sampling Isolation			Qualified		
36A	TV-HC-208A Containment Atmospheric Sampling Isolation			Note 1		
36A	TV-HC-208B Containment Atmospheric Sampling Isolation			Note 1		
36A	TV-HC-209A Containment Atmospheric Sampling Isolation			Note 1		
36A	TV-HC-209B Containment Atmospheric Sampling Isolation			Note 1		
56.	ASCO SOLENOID OPERATED VALVES	I.B	DOCUMENTATION			
	SOV-1204 Regenerative Heat Exchanger Outlet Valve	Replaced with ASCO NP Series		Qualified		
22.	SOV-2204 Regenerative Heat Exchanger Outlet Valve	Replaced with ASCO NP Series		Qualified		
56A	TARGET ROCK SOLENOID OPERATED VALVES	I.C	DOCUMENTATION			
	SOV-RC-101A-1 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-101A-2 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-101B-1 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-101B-2 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-102A-1 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-102A-2 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-102B-1 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
	SOV-RC-102B-2 Reactor Coolant System Venting Isolation	Conax Seals Installed		Qualified		
56B	SOV-RC-201A-1 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-201A-2 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-201B-1 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-201B-2 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-202A-1 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-202A-2 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-202B-1 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		
	SOV-RC-202B-2 Reactor Coolant System Venting Isolation	NuReg-0737		Note 1		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NPC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
57.		WESTINGHOUSE VENTILATION FANS	III.A	NONE	
		1-HV-F-8C Auxiliary Building Central Area Exhaust Fan	Deleted	08/24/81 Submittal	Deleted
72.		1-HV-F-8C Auxiliary Building Central Area Exhaust Fan	Deleted	09/03/81 Submittal	Deleted
58.		WESTINGHOUSE VENTILATION FANS	III.A	NONE	
		HV-F-8A Auxiliary Building Central Area Exhaust Fan	Deleted	08/24/81 Submittal	Deleted
		HV-F-8B Auxiliary Building Central Area Exhaust Fan	Deleted	08/24/81 Submittal	Deleted
72.		HV-F-8A Auxiliary Building Central Area Exhaust Fan	Deleted	09/03/81 Submittal	Deleted
72.		HV-F-8B Auxiliary Building Central Area Exhaust Fan	Deleted	09/03/81 Submittal	Deleted
58A		WESTINGHOUSE VENTILATION FANS	III.A	NONE	
		HV-F-24 Equipment Room Supply Fan	Qualified	Backup Available	Qualified
68.		HV-F-24 Equipment Room Supply Fan	Qualified	Backup Available	Qualified
59.		HONEYWELL MOTOR OPERATED DAMPERS	III.B	NONE	
		MOD-HV-163C Central Area Exhaust Discharge Damper	Deleted	08/24/81 Submittal	Deleted
75.		MOD HV 163C Central Area Exhaust Discharge Damper	Deleted	09/03/81 Submittal	Deleted
60.		HONEYWELL MOTOR OPERATED DAMPERS	III.B	NONE	
		MOD-HV-163B Central Area Exhaust Discharge Damper	Deleted	08/24/81 Submittal	Deleted
		MOD-HV-163A Central Area Exhaust Discharge Damper	Deleted	08/24/81 Submittal	Deleted
75.		MOD-HV-163A Central Area Exhaust Discharge Damper	Deleted	09/03/81 Submittal	Deleted
75.		MOD-HV-163B Central Area Exhaust Discharge Damper	Deleted	09/03/81 Submittal	Deleted
61.		MARATHON ELECTRIC PUMP MOTORS	I.B	DOCUMENTATION	
		1-SW-P-5 Radiation Monitoring Pump	Motor Windings	Rewound	Qualified
		1-SW-P-6 Radiation Monitoring Pump	Motor Windings	Rewound	Qualified
69.		2-SW-P-5 Radiation Monitoring Pump	Motor Windings	Rewound	Qualified
69.		2-SW-P-6 Radiation Monitoring Pump	Motor Windings	Rewound	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
62.	WESTINGHOUSE PUMP MOTORS	I.A	NONE	
	SI-P-1A Low Head Safety Injection, Pump A, Including Lubricant Exxon Teresstic 46			Qualified
	SI-P-iB Low Head Safety Injection, Pump B, Including Lubricant Exxon Teresstic 46			Qualified
73.	SI-P-1A Low Head Safety Injection, Pump B, Including Lubricant Exxon Teresstic 46			Qualified
73.	SI-P-1B Low Head Safety Injection, Pump B, Including Lubricant Exxon Teresstic 46			Qualified
63.	WESTINGHOUSE PUMP MOTORS	III.B	NONE	
	CH-P-1B Charging Pump B (High Head Safety Injection Pump) Including Lubricant Exxon Terestic 46		QDR File is Available	Qualified
	CH-P-1C Charging Pump C (High Head Safety Injection Pump) Including Lubricant Exxon Terestic 46		QDR File is Available	Qualified
74.	CH-P-1B Charge Pump B (High Head Safety Injection Pump) Including Lubricant Exxon Terestic 46		QDR File is Available	Qualified
74.	CH-P-1C Charge Pump B (High Head Safety Injection Pump) Including Lubricant Exxon Terestic 46		QDR File is Available	Qualified
63A	WESTINGHOUSE PUMP MOTORS	III.A	NONE	
	1-HV-P-20A Chiller Room Air Conditioning		Qualified Backup Available	Qualified
	1-HV-P-20B Chiller Room Air Conditioning		Qualified Backup Available	Qualified
	1-HV-P-20C Chiller Room Air Conditioning		Qualified Backup Available	Qualified
	1-HV-P-22A Chiller Room Air Conditioning		Qualified Backup Available	Qualified
	1-HV-P-22B Chiller Room Air Conditioning		Qualified Backup Available	Qualified
	1-HV-P-22C Chiller Room Air Conditioning		Qualified Backup Available	Qualified
71.	2-HV-P-20A Chiller Room Air Conditioning		Qualified Backup Available	Qualified
71.	2-HV-P-20B Chiller Room Air Conditioning		Qualified Backup Available	Qualified
71.	2-HV-P-20C Chiller Room Air Conditioning		Qualified Backup Available	Qualified
105.	2-HV-P-22A In-Line Pump Air Conditioning		Qualified Backup Available	Qualified
105.	2-HV-P-22B In-Line Pump Air Conditioning		Qualified Backup Available	Qualified
105.	2-HV-P-22C In-Line Pump Air Conditioning		Qualified Backup Available	Qualified
94.	RELIANCE PUMP MOTORS	I.B	DOCUMENTATION	
	1-SW-P-7 Radiation Monitoring Pump		Motor Windings Rewound	Qualified
69.	2-SW-P-7 Radiation Monitoring Pump		Motor Windings Rewound	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC	DEFICIENCY	RESOLUTION
		CATEGORY		
		U1	U2	
95.	RELIANCE PUMP MOTORS	I.B	DOCUMENTATION	
	1-SW-P-8 Radiation Monitoring Pump	Motor Windings Rewound		Qualified
69.	2-SW P 8 Radiation Monitoring Pump	Motor Windings Rewound		Qualified
96.	WESTINGHOUSE PUMP MOTORS	III.B	NONE	
	CH-P-1A Charging Pump A (High Head Safety Injection Pump), Including Lubricant Exxon Terrestic 46	QDR File is Available		Qualified
	WESTINGHOUSE CHARGING PUMPS	III.B	NONE	
74.	CH-P-1A Charging Pump A (High Head Safety Injection Pump), Including Lubricant Exxon Terrestic 46	QDR File is Available		Qualified
96A	WESTINGHOUSE AIR CONDITIONING CHILLERS	III.A	NONE	
	1-HV-E-4A Control and Relay Room Chiller	Qualified Backup Available		Qualified
	1-HV-E-4B Control and Relay Room Chiller	Qualified Backup Available		Qualified
	1-HV-E-4C Control and Relay Room Chiller	Qualified Backup Available		Qualified
99.	2-HV-E-4A Control and Relay Room Chiller	Qualified Backup Available		Qualified
99.	2-HV-E-4B Control and Relay Room Chiller	Qualified Backup Available		Qualified
99.	2-HV-E-4C Control and Relay Room Chiller	Qualified Backup Available		Qualified
97.	RELIANCE PROPELLER FAN MOTORS	II.A	SIMILARITY	
	1-HV-F-71A Safeguards Area Ventilation	Replacement Motors Installed		Qualified
	1-HV-F-71B Safeguards Area Ventilation	Replacement Motors Installed		Qualified
67.	2-HV-F-71A Ventilation Safeguard Area	Replacement Motors Installed		Qualified
67.	2-HV-F-71B Ventilation Safeguard Area	Replacement Motors Installed		Qualified
	BUFFALO FORGE CENTRIFUGAL FANS	III.B	NONE	
66.	HV-F-40A Safeguard Area Ventilation	Deleted R-4 dated 9/3/81 - 0588		Deleted
66.	HV-F-40B Safeguard Area Ventilation	Deleted R-4 dated 9/3/81 - 0588		Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
98.		GENERAL ELECTRIC PUMP MOTORS	I.A	NONE	
		1-RS-P-2A Recirculation Spray Pump, Including Lubricant Mobil DTE 797			Qualified
		1-RS-P-2B Recirculation Spray Pump, Including Lubricant Mobil DTE 797			Qualified
65.		2-RS-P-2A Recirculation Spray Pump, Including Lubricant Mobil DTE 797			Qualified
65.		2-RS-P-2B Recirculation Spray Pump, Including Lubricant Mobil DTE 797			Qualified
99.		GENERAL ELECTRIC PUMP MOTORS	II.A	AGING QUALIFIED LIFE AGING SIMULATION TIME DURATION SPRAY	
		1-RS-P-1A Recirculation Spray Pump, Motor A, Including Lubricant Mobil DTE 797	Documentation Submitted 4/29/83		Qualified
		1-RS-P-1B Recirculation Spray Pump, Motor B, Including Lubricant Mobil DTE 797	Documentation Submitted 4/29/83		Qualified
63.		2-RS-P-1A Recirculation Spray Pump, Motor A, Including Lubricant Mobil DTE 797	Documentation Submitted 4/29/83		Qualified
63.		2-RS-P-1B Recirculation Spray Pump, Motor B, Including Lubricant Mobil DTE 797	Documentation Submitted 4/29/83		Qualified
100.		WESTINGHOUSE HYDROGEN RECOMBINER MOTORS	I.B	DOCUMENTATION	
		1-HC-HC-1 Hydrogen Recombiner Blower Motor	Refer to IER 109 pg. 78		Deleted
100A		ALLIS-CHALMERS PUMP MOTORS	III.A	NONE	
		1-DB-P-10A Chiller Room Sump Pump	Qualified Backup Available		Qualified
		1-DB-P-10B Chiller Room Sump Pump	Qualified Backup Available		Qualified
70.		2-DB-P-10A Chiller Room Sump Pump	Qualified Backup Available		Qualified
70.		2-DB-P-10B Chiller Room Sump Pump	Qualified Backup Available		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
64.	ROSEMOUNT RESISTANCE TEMPERATURE DETECTORS	I.B	NONE	
	TE-1410 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
	TE-1413 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
	TE-1420 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
	TE-1423 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
	TE-1430 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
	TE-1433 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
	ROSEMOUNT RESISTANT TEMPERATURE DETECTORS	II.A	DOCUMENTATION AGING QUALIFIED LIFE PROFILE ENVELOPED STEAM EXPOSURE SPRAY FUNCTIONAL TESTING INSTRUMENT ACCURACY	
62.	TE-2410 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
62.	TE-2413 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
62.	TE-2420 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
62.	TE-2423 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
62.	TE-2430 Reactor Coolant System Temperature Elements (Wide-Range)			Note 1
62.	TE-2433 Reactor Coolant System Temperature Elements (Wide-Range)		Replaced with Weed RTD	Qualified
64A	ROSEMOUNT RESISTANCE TEMPERATURE DETECTORS	I.B		
	TE-CC-164 Component Cooling Temperature		Replaced with Conax RTD	Qualified
	TE-LM-100-1 Containment Temperature Monitoring		Replaced with Conax RTD	Qualified
	TE-LM-100-2 Containment Temperature Monitoring		Replaced with Conax RTD	Qualified
62A	TE-CC-264 Component Cooling Temperature			Note 2
62A	TE-LM-200-1 Containment Temperature Monitoring			Note 2
62A	TE-LM-200-2 Containment Temperature Monitoring			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	<u>DESCRIPTION</u>	<u>NRC CATEGORY</u>	<u>DEFICIENCY</u>	<u>RESOLUTION</u>
65.	ROSEMOUNT AMBIENT TEMPERATURE DETECTORS	III.A	NONE	
	TE-AM-115 Service Building Temperature Monitoring	Deleted R-4	dated 8/24/81 - 79-01B	Deleted
	TE-AM-116 Service Building Temperature Monitoring	Deleted R-4	dated 8/24/81 - 79-01B	Deleted
	TE-AM-117A Service Building Temperature Monitoring	Deleted R-4	dated 8/24/81 - 79-01B	Deleted
	TE-AM-117B Service Building Temperature Monitoring	Deleted R-4	dated 8/24/81 - 79-01B	Deleted
	TE-AM-117C Service Building Temperature Monitoring	Deleted R-4	dated 8/24/81 - 79-01B	Deleted
	TE-AM-117D Service Building Temperature Monitoring	Deleted R-4	dated 8/24/81 - 79-01B	Deleted
	ROSEMOUNT AMBIENT TEMPERATURE DETECTORS	III.B	NONE	
58.	TE-AM 215 Service Building Temperature Monitoring	Deleted R-4	dated 9/3/81 - 0588	Deleted
58.	TE-AM 216 Service Building Temperature Monitoring	Deleted R-4	dated 9/3/81 - 0588	Deleted
58.	TE-AM 217A Service Building Temperature Monitoring	Deleted R-4	dated 9/3/81 - 0588	Deleted
58.	TE-AM 217B Service Building Temperature Monitoring	Deleted R-4	dated 9/3/81 - 0588	Deleted
58.	TE-AM 217C Service Building Temperature Monitoring	Deleted R-4	dated 9/3/81 - 0588	Deleted
58.	TE-AM 217D Service Building Temperature Monitoring	Deleted R-4	dated 9/3/81 - 0588	Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
66.		ROSEMOUNT AMBIENT TEMPERATURE DETECTORS	II.A	DOCUMENTATION AGING QUALIFIED LIFE STEAM EXPOSURE TEST DURATION	
	TE-AM-100A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-101A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-102A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-103A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-104A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-105A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-106A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-107A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-108A	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-100B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-101B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-103B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-102B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-104B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-105B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-106B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-107B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
	TE-AM-108B	Auxiliary Building Ambient Air Temperature Monitor	Replaced with Conax	RTD	Qualified
		ROSEMOUNT AMBIENT TEMPERATURE MONITORS	II.A	DOCUMENTATION AGING QUALIFIED LIFE PROFILE ENVELOPED RADIATION	
59.	TE-AM-100A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-101A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-102A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-103A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-104A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-104B	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-105A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-106A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-107A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-108A	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate
59.	TE-AM-108B	Auxiliary Building Ambient Air Temperature Monitoring	Duplicate TER 66(U1)		Duplicate

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
66A	THERMO TRINITY RESISTANCE TEMPERATURE DETECTOR	I.B	DOCUMENTATION	
	TE-CC-167 Component Cooling Temperature		Replaced with Conax RTD	Qualified
	TE-RS-150A Containment Sump Temperature		Considered Cat. III - R.G. 1.97	Deleted
	TE-RS-150B Containment Sump Temperature		Considered Cat. III - R.G. 1.97	Deleted
	TE-SW-108A Pump Discharge Header Temperature			Note 2
	TE-SW-108B Pump Discharge Header Temperature			Note 2
62B	TE-CC-267 Component Cooling Temperature			Note 2
62B	TE-RS-250A Containment Sump Temperature		Considered Cat. III - R.G. 1.97	Deleted
62B	TE-RS-250B Containment Sump Temperature		Considered Cat. III - R.G. 1.97	Deleted
67.	ROSEMOUNT RESISTANCE TEMPERATURE DETECTORS	I.B	DOCUMENTATION	
	TE-1412C Change in Temperature Average Protection		Replaced with Weed RTD	Qualified
	TE-1422C Change in Temperature Average Protection		Replaced with Weed RTD	Qualified
	TE-1432C Change in Temperature Average Protection		Replaced with Weed RTD	Qualified
	ROSEMOUNT RESISTANCE TEMPERATURE DETECTORS	II.A	DOCUMENTATION AGING QUALIFIED LIFE PROFILE ENVELOPED SPRAY FUNCTIONAL TESTING INSTRUMENT ACCURACY	
60.	TE-2412C Change in Average Temperature Protection			Note 1
60.	TE-2422C Change in Average Temperature Protection			Note 1
60.	TE-2432C Change in Average Temperature Protection			Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
67A		MINICO TEMPERATUI ELEMENTS	I.A	NONE	
		TE-1313 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1314 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1315 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1316 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1317 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1318 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1319 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1323 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1324 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1325 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1326 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1327 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1328 Reactor Vessel Level Temperature Compensation			Qualified
		TE-1329 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2313 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2314 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2315 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2316 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2317 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2318 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2319 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2323 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2324 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2325 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2326 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2327 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2328 Reactor Vessel Level Temperature Compensation			Qualified
61B		TE-2329 Reactor Vessel Level Temperature Compensation			Qualified
		HONEYWELL TEMPERATURE SWITCH	III.B	NONE	
57.	TS-HV-2230	Temperature Switch for 2-HV-F-68B	Deleted	09/03/81 Submittal	Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
68.		ROSEMOUNT RESISTANCE TEMPERATURE DETECTORS	I.B	NONE	
	TE-1412B	Reactor Coolant System Temperature Narrow Range Resistant Temperature Detector		Replaced with Weed RTD	Qualified
	TE-1412D	Reactor Coolant System Temperature Narrow Range Resistant Temperature Detector		Replaced with Weed RTD	Qualified
	TE-1422B	Reactor Coolant System Temperature Narrow Range Resistant Temperature Detector		Replaced with Weed RTD	Qualified
	TE-1422D	Reactor Coolant System Temperature Narrow Range Resistant Temperature Detector		Replaced with Weed RTD	Qualified
	TE-1432B	Reactor Coolant System Temperature Narrow Range Resistant Temperature Detector		Replaced with Weed RTD	Qualified
	TE-1432D	Reactor Coolant System Temperature Narrow Range Resistant Temperature Detector		Replaced with Weed RTD	Qualified
		ROSEMOUNT RESISTANT TEMPERATURE DETECTORS	II.A	DOCUMENTATION AGING QUALIFIED LIFE PROFILE ENVELOPED SPRAY FUNCTIONAL TESTING INSTRUMENT ACCURACY	
61.	TE-2412B	Reactor Coolant System Temperature Narrow Range Resistance Temperature Detector			Note 1
61.	TE-2412D	Reactor Coolant System Temperature Narrow Range Resistance Temperature Detector			Note 1
61.	TE-2422B	Reactor Coolant System Temperature Narrow Range Resistance Temperature Detector			Note 1
61.	TE-2422D	Reactor Coolant System Temperature Narrow Range Resistance Temperature Detector			Note 1
61.	TE-2432B	Reactor Coolant System Temperature Narrow Range Resistance Temperature Detector			Note 1
61.	TE-2432D	Reactor Coolant System Temperature Narrow Range Resistance Temperature Detector			Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
68A		ROSEMOUNT TEMPERATURE ELEMENTS	I.B	NONE	
		TE-1411B Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1411C Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1411D Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1421D Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1421C Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1421B Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1431B Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1431C Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		TE-1431D Reactor Coolant System Narrow Range		Replaced with Weed RTD	Qualified
		ROSEMOUNT RESISTANCE TEMPERATURE DETECTORS	I.B		
61A		TE-2411B Reactor Coolant System Narrow Range			Note 1
61A		TE-2411C Reactor Coolant System Narrow Range			Note 1
61A		TE-2411D Reactor Coolant System Narrow Range			Note 1
61A		TE-2421B Reactor Coolant System Narrow Range			Note 1
61A		TE-2421C Reactor Coolant System Narrow Range			Note 1
61A		TE-2421D Reactor Coolant System Narrow Range			Note 1
61A		TE-2431B Reactor Coolant System Narrow Range			Note 1
61A		TE-2431C Reactor Coolant System Narrow Range			Note 1
61A		TE-2431D Reactor Coolant System Narrow Range			Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
69.		NAMCO LIMIT SWITCHES	II.C	AGING QUALIFIED LIFE	
		ZS-DA-103A-1 Auxiliary Building to Containment Sump Pump			Note 2
		ZS-DA-103B-1 Auxiliary Building to Containment Sump Pump			Note 2
69A		ZS-DA-103A-2 Auxiliary Building to Containment Sump Pump			Note 2
		ZS-DA-103B-2 Auxiliary Building to Containment Sump Pump			Note 2
		NAMCO LIMIT SWITCHES	II.A	SIMILARITY AGING QUALIFIED LIFE	
55.		ZS-DA-203A-1 Auxiliary Building to Containment Sump Pump			Note 2
55.		ZS-DA-203B-1 Auxiliary Building to Containment Sump Pump			Note 2
55A		ZS-DA-203A-2 Auxiliary Building to Containment Sump Pump			Note 2
55A		ZS-DA-203B-2 Auxiliary Building to Containment Sump Pump			Note 2
69A		FISHER LIMIT SWITCHES	I.B	NONE	
		ZS-BD-100A-A1 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100A-A2 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100C-A1 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100C-A2 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100E-A1 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100E-A2 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100G-A1 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100G-A2 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100H-A1 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100H-A2 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100J-A1 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-BD-100J-A2 Steam Generator Blowdown Isolation		Replaced with Namco Limit Switch	Qualified
		ZS-CC-101A-A1 Reactor Coolant Pump Thermal Barrier Return Header		Replaced with Namco Limit Switch	Qualified
		ZS-CC-101A-A2 Reactor Coolant Pump Thermal Barrier Return Header		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150A-A1 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150A-A2 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150B-B1 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150B-B2 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150C-A1 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150C-A2 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150D-B1 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-CV-150D-B2 Containment Vacuum Pump Suction		Replaced with Namco Limit Switch	Qualified
		ZS-DA-100A-A1 Containment Sump Pump Discharge		Replaced with Namco Limit Switch	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
69A	FISHER LIMIT SWITCHES	I.B	NONE	
	ZS-DA-100A-A2 Containment Sump Pump Discharge	Replaced with	Namco Limit Switch	Qualified
	ZS-DG-100A-A1 Primary Drain Transfer Pump Discharge	Replaced with	Namco Limit Switch	Qualified
	ZS-DG-100A-A2 Primary Drain Transfer Pump Discharge	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-109-A1 Main Steamline Drains to Condenser	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-109-A2 Main Steamline Drains to Condenser	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-109-B1 Main Steamline Letdown Control	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-109-B2 Main Steamline Letdown Control	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-111A-A1 Auxiliary Feed Pump Turbine Drive	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-111A-A2 Auxiliary Feed Pump Turbine Drive	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-111B-B1 Auxiliary Feed Pump Turbine Drive	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-111B-B2 Auxiliary Feed Pump Turbine Drive	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113A-A1 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113A-A2 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113A-B1 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113A-B2 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113B-A1 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113B-A2 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113B-B1 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113B-B2 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113C-A1 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113C-A2 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113C-B1 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-MS-113C-B2 Steam Generator Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-RM-100A-A1 Radiation Monitoring Isolation Return	Replaced with	Namco Limit Switch	Qualified
	ZS-RM-100A-A2 Radiation Monitoring Isolation Return	Replaced with	Namco Limit Switch	Qualified
	ZS-RM-100B-A1 Radiation Monitoring Isolation Supply	Replaced with	Namco Limit Switch	Qualified
	ZS-RM-100B-A2 Radiation Monitoring Isolation Supply	Replaced with	Namco Limit Switch	Qualified
	ZS-RM-100D-B1 Radiation Monitoring Isolation Return	Replaced with	Namco Limit Switch	Qualified
	ZS-RM-100D-B2 Radiation Monitoring Isolation Return	Replaced with	Namco Limit Switch	Qualified
	ZS-SI-100-A1 Nitrogen Supply Line	Replaced with	Namco Limit Switch	Qualified
	ZS-SI-100-A2 Nitrogen Supply Line	Replaced with	Namco Limit Switch	Qualified
	ZS-SI-100-B1 Nitrogen Supply Line	Replaced with	Namco Limit Switch	Qualified
	ZS-SI-100-B2 Nitrogen Supply Line	Replaced with	Namco Limit Switch	Qualified
	ZS-SI-101-A1 Nitrogen Supply Line	Replaced with	Namco Limit Switch	Qualified
	ZS-SI-101-A2 Nitrogen Supply Line	Replaced with	Namco Limit Switch	Qualified
	ZS-SV-102-1-A1 Air Ejector Discharge Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-SV-102-1-A2 Air Ejector Discharge Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-SV-103-B1 Air Ejector Discharge Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-SV-103-B2 Air Ejector Discharge Trip Valve	Replaced with	Namco Limit Switch	Qualified
	ZS-VG-100A-A1 Primary Drain Transfer Tank Vent	Replaced with	Namco Limit Switch	Qualified
	ZS-VG-100A-A2 Primary Drain Transfer Tank Vent	Replaced with	Namco Limit Switch	Qualified
56A	ZS-BD-200A-A1 Steam Generator Blowdown Isolation			Note 2
56A	ZS-BD-200A-A2 Steam Generator Blowdown Isolation			Note 2
56A	ZS-BD-200C-A1 Steam Generator Blowdown Isolation			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
69A		FISHER LIMIT SWITCHES	I.B	NONE	
56A		ZS-BD-200C-A2 Steam Generator Blowdown Isolation			Note 2
56A		ZS-BD-200E-A1 Steam Generator Blowdown Isolation			Note 2
56A		ZS-BD-200E-A2 Steam Generator Blowdown Isolation			Note 2
56A		ZS-BD-200G-A1 Steam Generator Blowdown Isolation			Note 1
56A		ZS-BD-200G-A2 Steam Generator Blowdown Isolation			Note 1
56A		ZS-BD-200H-A1 Steam Generator Blowdown Isolation			Note 1
56A		ZS-BD-200H-A2 Steam Generator Blowdown Isolation			Note 1
56A		ZS-BD-200J-A1 Steam Generator Blowdown Isolation			Note 1
56A		ZS-BD-200J-A2 Steam Generator Blowdown Isolation			Note 1
56A		ZS-CC-201A-A1 Reactor Coolant Pump Thermal Barrier Return Header			Note 2
56A		ZS-CC-201A-A2 Reactor Coolant Pump Thermal Barrier Return Header			Note 2
56A		ZS-CV-250A-A1 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250A-A2 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250B-B1 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250B-B2 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250C-A1 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250C-A2 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250D-B1 Containment Vacuum Pump Suction			Note 2
56A		ZS-CV-250D-B2 Containment Vacuum Pump Suction			Note 2
56A		ZS-DA-200A-A1 Containment Sump Pump Discharge			Note 2
56A		ZS-DA-200A-A2 Containment Sump Pump Discharge			Note 2
56A		ZS-DG-200A-A1 Primary Drain Transfer Pump Discharge			Note 2
56A		ZS-DG-200A-A2 Primary Drain Transfer Pump Discharge			Note 2
56A		ZS-MS-209-A1 Main Steam Line Drains to Condenser			Note 2
56A		ZS-MS-209-A2 Main Steam Line Drains to Condenser			Note 2
56A		ZS-MS-209-B1 Main Steam Line Drains to Condenser			Note 2
56A		ZS-MS-209-B2 Main Steam Line Drains to Condenser			Note 2
56A		ZS-MS-211A-A1 Auxiliary Feed Pump Turbine Drive			Note 1
56A		ZS-MS-211A-A2 Auxiliary Feed Pump Turbine Drive			Note 1
56A		ZS-MS-211B-B1 Auxiliary Feed Pump Turbine Drive			Note 1
56A		ZS-MS-211B-B2 Auxiliary Feed Pump Turbine Drive			Note 1
56A		ZS-MS-213A-A1 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213A-A2 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213A-B1 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213A-B2 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213B-A1 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213B-A2 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213B-B1 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213B-B2 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213C-A1 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213C-A2 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213C-B1 Steam Generator Trip Valve			Note 2
56A		ZS-MS-213C-B2 Steam Generator Trip Valve			Note 2
56A		ZS-RM-200A-A1 Radiation Monitoring Isolation Return			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
69A		FISHER LIMIT SWITCHES	I.B	NONE	
56A	ZS-RM-200A-A2	Radiation Monitoring Isolation Return			Note 2
56A	ZS-RM-200B-A1	Radiation Monitoring Isolation Supply			Note 2
56A	ZS-RM-200B-A2	Radiation Monitoring Isolation Supply			Note 2
56A	ZS-RM-200D-A1	Radiation Monitoring Isolation Return			Note 2
56A	ZS-RM-200D-A2	Radiation Monitoring Isolation Return			Note 2
56A	ZS-SI-200-A1	Nitrogen Supply Line			Note 2
56A	ZS-SI-200-A2	Nitrogen Supply Line			Note 2
56A	ZS-SI-200-B1	Nitrogen Supply Line			Note 2
56A	ZS-SI-200-B2	Nitrogen Supply Line			Note 2
56A	ZS-SI-201-A1	Nitrogen Supply Line			Note 2
56A	ZS-SI-201-A2	Nitrogen Supply Line			Note 2
56A	ZS-SV-203-B1	Air Ejector Discharge Trip Valve			Note 2
56A	ZS-SV-203-B2	Air Ejector Discharge Trip Valve			Note 2
56A	ZS-VG-200A-A1	Primary Drain Transfer Tank Vent			Note 2
56A	ZS-VG-200A-A2	Primary Drain Transfer Tank Vent.			Note 2
69B		GORDOS LIMIT SWITCHES	I.A	NONE	
	ZS-HC-100A-1	Hydrogen Analyzer #1 Suction			Qualified
	ZS-HC-100A-2	Hydrogen Analyzer #1 Suction			Qualified
	ZS-HC-102A-1	Hydrogen Analyzer #2 Suction			Qualified
	ZS-HC-102A-2	Hydrogen Analyzer #2 Suction			Qualified
	ZS-SS-106A-A1	Primary Coolant Hot Leg Sample Isolation			Qualified
	ZS-SS-106A-A2	Primary Coolant Hot Leg Sample Isolation			Qualified
	ZS-SS-106B-B1	Primary Coolant Hot Leg Sample Isolation			Qualified
	ZS-SS-106B-B2	Primary Coolant Hot Leg Sample Isolation			Qualified
	ZS-SS-107A-A1	Residual Heat Removal Sample Isolation			Qualified
	ZS-SS-107A-A2	Residual Heat Removal Sample Isolation			Qualified
	ZS-SS-107B-B1	Residual Heat Removal Sample Isolation			Qualified
	ZS-SS-107B-B2	Residual Heat Removal Sample Isolation			Qualified
	ZS-SS-108D-B1	Primary Coolant Hot Leg Sample Isolation			Qualified
	ZS-SS-108D-B2	Primary Coolant Hot Leg Sample Isolation			Qualified
	ZS-SS-102A-A1	Primary Coolant Cold Leg Sample Isolation			Qualified
	ZS-SS-102A-A2	Primary Coolant Cold Leg Sample Isolation			Qualified
	ZS-SS-102B-B1	Primary Coolant Cold Leg Sample Isolation			Qualified
	ZS-SS-102B-B2	Primary Coolant Cold Leg Sample Isolation			Qualified
	ZS-SS-103A-A1	Residual Heat Removal System Sample Isolation			Qualified
	ZS-SS-103A-A2	Residual Heat Removal System Sample Isolation			Qualified
	ZS-SS-103B-B1	Residual Heat Removal System Sample Isolation			Qualified
	ZS-SS-103B-B2	Residual Heat Removal System Sample Isolation			Qualified
	ZS-SS-109A-A1	Primary Coolant Cold Leg Sample Isolation			Qualified
	ZS-SS-109A-A2	Primary Coolant Cold Leg Sample Isolation			Qualified
	ZS-HC-108A-A1	Containment Atmosphere Sampling Isolation			Qualified
	ZS-HC-108A-A2	Containment Atmosphere Sampling Isolation			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
VALUATION
REPORT
ITEM
NUMBER
U1 U2

DESCRIPTION		NRC CATEGORY	DEFICIENCY	RESOLUTION
69B	GORDOS LIMIT SWITCHES	I.B	DOCUMENTATION	
55C	ZS-HC-200A-1 Hydrogen Analyzer #1 Suction			Note 1
55C	ZS-HC-200A-2 Hydrogen Analyzer #1 Suction			Note 1
55C	ZS-HC-200B-1 Hydrogen Analyzer #1 Suction			Note 1
55C	ZS-HC-200B-2 Hydrogen Analyzer #1 Suction			Note 1
55C	ZS-HC-201A-1 Hydrogen Analyzer #1 Discharge			Note 1
55C	ZS-HC-201A-2 Hydrogen Analyzer #1 Discharge			Note 1
55C	ZS-HC-201B-1 Hydrogen Analyzer #1 Discharge			Note 1
55C	ZS-HC-201B-2 Hydrogen Analyzer #1 Discharge			Note 1
55C	ZS-HC-202A-1 Hydrogen Analyzer #2 Suction			Note 1
55C	ZS-HC-202A-2 Hydrogen Analyzer #2 Suction			Note 1
55C	ZS-HC-202B-1 Hydrogen Analyzer #2 Suction			Note 1
55C	ZS-HC-202B-2 Hydrogen Analyzer #2 Suction			Note 1
55C	ZS-HC-203A-1 Hydrogen Analyzer #2 Discharge			Note 1
55C	ZS-HC-203A-2 Hydrogen Analyzer #2 Discharge			Note 1
55C	ZS-HC-203B-1 Hydrogen Analyzer #2 Discharge			Note 1
55C	ZS-HC-203B-2 Hydrogen Analyzer #2 Discharge			Note 1
55C	ZS-RC-201A1-A1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201A1-A2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201A2-A1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201A2-A2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201B1-B1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201B1-B2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201B2-B1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-201B2-B2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202A1-A1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202A1-A2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202B1-B1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202B1-B2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202A2-A1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202A2-A2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202B2-B1 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-RC-202B2-B2 Reactor Coolant System Venting Isolation			Note 1
55C	ZS-SS-206A-A1 Primary Coolant Hot Leg Sample Isolation			Note 1
55C	ZS-SS-206A-A2 Primary Coolant Hot Leg Sample Isolation			Note 1
55C	ZS-SS-207A-A1 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-207A-A2 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-207B-B1 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-207B-B2 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-206B-B1 Primary Coolant Hot Leg Sample Isolation			Note 1
55C	ZS-SS-206B-B2 Primary Coolant Hot Leg Sample Isolation			Note 1
55C	ZS-SS-208D-B1 Primary Coolant Hot Leg Sample Isolation			Note 1
55C	ZS-SS-208D-B2 Primary Coolant Hot Leg Sample Isolation			Note 1
55C	ZS-SS-202A-A1 Primary Coolant Cold Leg Sample Isolation			Note 1
55C	ZS-SS-202A-A2 Primary Coolant Cold Leg Sample Isolation			Note 1
55C	ZS-SS-202B-B1 Primary Coolant Cold Leg Sample Isolation			Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
69B	GORDOS LIMIT SWITCHES	I.B	DOCUMENTATION	
55C	ZS-SS-202B-B2 Primary Coolant Cold Leg Sample Isolation			Note 1
55C	ZS-SS-203A-A1 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-203A-A2 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-203B-B1 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-203B-B2 Residual Heat Removal Sample Isolation			Note 1
55C	ZS-SS-209A-A1 Primary Coolant Cold Leg Sample Isolation			Note 1
55C	ZS-SS-209A-A2 Primary Coolant Cold Leg Sample Isolation			Note 1
55C	ZS-HC-203A-A1 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-208A-A2 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-208B-B1 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-208B-B2 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-209A-A1 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-209A-A2 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-209B-B1 Containment Atmosphere Sampling Isolation			Note 1
55C	ZS-HC-209B-B2 Containment Atmosphere Sampling Isolation			Note 1
70.	NAMCO LIMIT SWITCHES	III.A	NONE	
	ZS-1842-B1 Accumulator Test Line Isolation		QDR File is Available	Qualified
	ZS-1842-B2 Accumulator Test Line Isolation		QDR File is Available	Qualified
55B	ZS-2482-B1 Accumulator Test Line Isolation		QDR File is Available	Qualified
55B	ZS-2482-B2 Accumulator Test Line Isolation		QDR File is Available	Qualified
70A	NAMCO LIMIT SWITCHES	I.A	NONE	
	ZS-BD-100B-B1 Steam Generator Blowdown Isolation			Qualified
	ZS-BD-100B-B2 Steam Generator Blowdown Isolation			Qualified
	ZS-BD-100D-B1 Steam Generator Blowdown Isolation			Qualified
	ZS-BD-100D-B2 Steam Generator Blowdown Isolation			Qualified
	ZS-BD-100F-B1 Steam Generator Blowdown Isolation			Qualified
	ZS-BD-100F-B2 Steam Generator Blowdown Isolation			Qualified
	ZS-CC-101B-B1 Reactor Coolant Pump Thermal Barrier Between Header			Qualified
	ZS-CC-101B-B2 Reactor Coolant Pump Thermal Barrier Between Header			Qualified
	ZS-CC-102B-B1 Reactor Coolant Pump Coolers Return Header			Qualified
	ZS-CC-102B-B2 Reactor Coolant Pump Coolers Return Header			Qualified
	ZS-CC-102D-B1 Reactor Coolant Pump Coolers Return Header			Qualified
	ZS-CC-102D-B2 Reactor Coolant Pump Coolers Return Header			Qualified
	ZS-CC-102F-B1 Reactor Coolant Pump Coolers Return Header			Qualified
	ZS-CC-102F-B2 Reactor Coolant Pump Coolers Return Header			Qualified
	ZS-CC-105A-A1 Containment Recirculation Air Cooler Outlet			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
70A		NAMCO LIMIT SWITCHES	I.A	NONE	
		ZS-CC-105A-A2 Containment Recirculation Air Cooler Outlet			Qualified
		ZS-CC-105B-A1 Containment Recirculation Air Cooler Outlet			Qualified
		ZS-CC-105B-A2 Containment Recirculation Air Cooler Outlet			Qualified
		ZS-CC-105C-A1 Containment Recirculation Air Cooler Outlet			Qualified
		ZS-CC-105C-A2 Containment Recirculation Air Cooler Outlet			Qualified
		ZS-DA-100B-B1 Containment Sump Pump Discharge			Qualified
		ZS-DA-100B-B2 Containment Sump Pump Discharge			Qualified
		ZS-DG-100B-B1 Primary Drain Transfer Pump Discharge			Qualified
		ZS-DG-100B-B2 Primary Drain Transfer Pump Discharge			Qualified
		ZS-RM-100C-B1 Radiation Monitoring to Reactor Containment			Qualified
		ZS-RM-100C-B2 Radiation Monitoring to Reactor Containment			Qualified
		ZS-SS-100A-A1 Pressurizer Liquid Space Sample Isolation Valve			Qualified
		ZS-SS-100A-A2 Pressurizer Liquid Space Sample Isolation Valve			Qualified
		ZS-SS-101A-A1 Pressurizer Vapor Space Sample Isolation Valve			Qualified
		ZS-SS-101A-A2 Pressurizer Vapor Space Sample Isolation Valve			Qualified
		ZS-SS-104A-A1 Pressurizer Relief Tank Gas Space Sample Isolation Valve			Qualified
		ZS-SS-104A-A2 Pressurizer Relief Tank Gas Space Sample Isolation Valve			Qualified
		ZS-SS-112A-A1 Steam Generator Surface Sample Isolation Valve			Qualified
		ZS-SS-112A-A2 Steam Generator Surface Sample Isolation Valve			Qualified
		ZS-VG-100B-B1 Primary Drain Transfer Tank Vent			Qualified
		ZS-VG-100B-B2 Primary Drain Transfer Tank Vent			Qualified
		ZS-1200A-A1 Chemical Volume Control System Isolation Valve for Letdown			Qualified
		ZS-1200A-A2 Chemical Volume Control System Isolation Valve for Letdown			Qualified
		ZS-1200B-B1 Chemical Volume Control System Isolation Valve for Letdown			Qualified
		ZS-1200B-B2 Chemical Volume Control System Isolation Valve for Letdown			Qualified
		ZS-1200C-C1 Chemical Volume Control System Isolation Valve for Letdown			Qualified
		ZS-1200C-C2 Chemical Volume Control System Isolation Valve for Letdown			Qualified
55B		ZS-BD-200B-B1 Steam Generator Blowdown Isolation			Qualified
55B		ZS-BD-200B-B2 Steam Generator Blowdown Isolation			Qualified
55B		ZS-BD-200D-B1 Steam Generator Blowdown Isolation			Qualified
55B		ZS-BD-200D-B2 Steam Generator Blowdown Isolation			Qualified
55B		ZS-BD-200F-B1 Steam Generator Blowdown Isolation			Qualified
55B		ZS-BD-200F-B2 Steam Generator Blowdown Isolation			Qualified
55B		ZS-CC-201B-B1 Reactor Coolant Pump Thermal Barrier Return Header			Qualified
55B		ZS-CC-201B-B2 Reactor Coolant Pump Thermal Barrier Return Header			Qualified
55B		ZS-CC-202B-B1 Reactor Coolant Pump Coolers Return Barrier			Qualified
55B		ZS-CC-202B-B2 Reactor Coolant Pump Coolers Return Barrier			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM

NUMBER
U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

70A

NAMCO LIMIT SWITCHES

I. A

NONE

55B	ZS-CC-202D-B1	Reactor Coolant Pump Coolers Return Barrier		Qualified
55B	ZS-CC-202D-B2	Reactor Coolant Pump Coolers Return Barrier		Qualified
55B	ZS-CC-202F-B1	Reactor Coolant Pump Coolers Return Barrier		Qualified
55B	ZS-CC-202F-B2	Reactor Coolant Pump Coolers Return Barrier		Qualified
55B	ZS-CC-205A-A1	Containment Recirculation Air Cooler Outlet		Qualified
55B	ZS-CC-205A-A2	Containment Recirculation Air Cooler Outlet		Qualified
55B	ZS-CC-205B-A1	Containment Recirculation Air Cooler Outlet		Qualified
55B	ZS-CC-205B-A2	Containment Recirculation Air Cooler Outlet		Qualified
55B	ZS-CC-205C-A1	Containment Recirculation Air Cooler Outlet		Qualified
55B	ZS-CC-205C-A2	Containment Recirculation Air Cooler Outlet		Qualified
55B	ZS-DA-200B-B1	Containment Sump Pump Discharge		Qualified
55B	ZS-DA-200B-B2	Containment Sump Pump Discharge		Qualified
55B	ZS-DG-200B-B1	Primary Drain Transfer Pump Discharge		Qualified
55B	ZS-DG-200B-B2	Primary Drain Transfer Pump Discharge		Qualified
55B	ZS-IA-201B-B1	Containment Instrument Air Isolation		Qualified
55B	ZS-IA-201B-B2	Containment Instrument Air Isolation		Qualified
55B	ZS-RM-200C-B1	Radiation Monitoring To Reactor Containment		Qualified
55B	ZS-RM-200C-B2	Radiation Monitoring To Reactor Containment		Qualified
55B	ZS-SS-200A-A1	Pressurizer Liquid Space Sample Isolation Valve		Qualified
55B	ZS-SS-200A-A2	Pressurizer Liquid Space Sample Isolation Valve		Qualified
55B	ZS-SS-201A-A1	Pressurizer Vapor Space Sample Isolation Valve		Qualified
55B	ZS-SS-201A-A2	Pressurizer Vapor Space Sample Isolation Valve		Qualified
55B	ZS-SS-204A-A1	Pressurizer Relief Tank Gas Space Sample Isolation Valve		Qualified
55B	ZS-SS-204A-A2	Pressurizer Relief Tank Gas Space Sample Isolation Valve		Qualified
55B	ZS-SS-212A-A1	Steam Generator Sample Isolation Valve		Qualified
55B	ZS-SS-212A-A2	Steam Generator Sample Isolation Valve		Qualified
55B	ZS-VG-200B-B1	Primary Draw Transfer Tank Vent		Qualified

70B

NAMCO LIMIT SWITCHES

I. B

DOCUMENTATION

ZS-IA-102A-A1	Containment Instrument Air Isolation Valve	Replaced with Namco Limit Switch	Qualified
ZS-IA-102A-A2	Containment Instrument Air Isolation Valve	Replaced with Namco Limit Switch	Qualified
ZS-IA-102B-B1	Containment Instrument Air Isolation Valve	Replaced with Namco Limit Switch	Qualified
ZS-IA-102B-B2	Containment Instrument Air Isolation Valve	Replaced with Namco Limit Switch	Qualified
ZS-MS-101A-A1	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101A-A2	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101A-B1	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101A-B2	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101B-A1	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101B-A2	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101B-B1	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified
ZS-MS-101B-B2	Main Steam Line Trip	Replaced with Namco Limit Switch	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
70B	NAMCO LIMIT SWITCHES	I.B	DOCUMENTATION	
	ZS-MS-101C-A1 Main Steam Line Trip		Replaced with Namco Limit Switch	Qualified
	ZS-MS-101C-A2 Main Steam Line Trip		Replaced with Namco Limit Switch	Qualified
	ZS-MS-101C-B1 Main Steam Line Trip		Replaced with Namco Limit Switch	Qualified
	ZS-MS-101C-B2 Main Steam Line Trip		Replaced with Namco Limit Switch	Qualified
	ZS-1204-B1 Regenerative Heat Exchanger Outlet Valve		Replaced with Namco Limit Switch	Qualified
	ZS-1204-B2 Regenerative Heat Exchanger Outlet Valve		Replaced with Namco Limit Switch	Qualified
	ZS-1519A-A1 Primary Grade Water to Pressurizer Relief Tank		Replaced with Namco Limit Switch	Qualified
	ZS-1519A-A2 Primary Grade Water to Pressurizer Relief Tank		Replaced with Namco Limit Switch	Qualified
	ZS-1859-A1 Safety Injection Test Line		Replaced with Namco Limit Switch	Qualified
	ZS-1859-A2 Safety Injection Test Line		Replaced with Namco Limit Switch	Qualified
	ZS-1884A-A1 Boron Injection Tank to Boric Acid		Replaced with Namco Limit Switch	Qualified
	ZS-1884A-A2 Boron Injection Tank to Boric Acid		Replaced with Namco Limit Switch	Qualified
	ZS-1884B-B1 Boron Injection Tank to Boric Acid		Replaced with Namco Limit Switch	Qualified
	ZS-1884B-B2 Boron Injection Tank to Boric Acid		Replaced with Namco Limit Switch	Qualified
	ZS-1884C-A1 Boron Injection Tank to Boric Acid		Replaced with Namco Limit Switch	Qualified
	ZS-1884C-A2 Boron Injection Tank to Boric Acid		Replaced with Namco Limit Switch	Qualified
	ZS-HC-104A-1 Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-104A-2 Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-104B-1 Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-104B-2 Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-105A-1 Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-105A-2 Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-105B-1 Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-105B-2 Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-106A-1 Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-106A-2 Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-106B-1 Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-106B-2 Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-107A-1 Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-107A-2 Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-107B-1 Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
	ZS-HC-107B-2 Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation		Installed Conax Seal	Qualified
70B	NAMCO LIMIT SWITCHES	I.B	NONE	
55A	ZS-2204-B1 Regenerative Heat Exchanger Outlet Valve			Note 2
55A	ZS-2204-B2 Regenerative Heat Exchanger Outlet Valve			Note 2
55A	ZS-2519A-A1 Primary Grade Water to Pressurizer Relief Tank			Note 2
55A	ZS-2519A-A2 Primary Grade Water to Pressurizer Relief Tank			Note 2
55A	ZS-2859A-A1 Safety Injection Test Line			Note 2
55A	ZS-2859A-A2 Safety Injection Test Line			Note 2
55A	ZS-2884A-A1 Boron Injection Tank to Boric Acid			Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NPC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
70B		NAMCO LIMIT SWITCHES	I.B	NONE	
55A	ZS-2884A-A2	Boron Injection Tank to Boric Acid			Note 1
55A	ZS-2884B-B1	Boron Injection Tank to Boric Acid			Note 1
55A	ZS-2884B-B2	Boron Injection Tank to Boric Acid			Note 1
55A	ZS-2884C-A1	Boron Injection Tank to Batch Tank			Note 1
55A	ZS-2884C-A2	Boron Injection Tank to Batch Tank			Note 1
55B	ZS-IA-202A-A1	Containment Instrument Air Isolation Valve			Qualified
55B	ZS-IA-202A-A2	Containment Instrument Air Isolation Valve			Qualified
55B	ZS-IA-202B-B1	Containment Instrument Air Isolation Valve			Qualified
55B	ZS-IA-202B-B2	Containment Instrument Air Isolation Valve			Qualified
55B	ZS-MS-201A-A1	Main Steam Line Trip			Qualified
55B	ZS-MS-201A-A2	Main Steam Line Trip			Qualified
55B	ZS-MS-201A-B1	Main Steam Line Trip			Qualified
55B	ZS-MS-201A-B2	Main Steam Line Trip			Qualified
55B	ZS-MS-201B-A1	Main Steam Line Trip			Qualified
55B	ZS-MS-201B-A2	Main Steam Line Trip			Qualified
55B	ZS-MS-201B-B1	Main Steam Line Trip			Qualified
55B	ZS-MS-201B-B2	Main Steam Line Trip			Qualified
55B	ZS-MS-201C-A1	Main Steam Line Trip			Qualified
55B	ZS-MS-201C-A2	Main Steam Line Trip			Qualified
55B	ZS-MS-201C-B1	Main Steam Line Trip			Qualified
55B	ZS-MS-201C-B2	Main Steam Line Trip			Qualified
55B	ZS-VG-200B-B2	Primary Draw Transfer Tank Vent			Qualified
55B	ZS-2200A-A1	Chemical Volume Control System Isolation Valve for Letdown			Note 2
55B	ZS-2200A-A2	Chemical Volume Control System Isolation Valve for Letdown			Note 2
55B	ZS-2200B-A1	Chemical Volume Control System Isolation Valve for Letdown			Note 2
55B	ZS-2200B-A2	Chemical Volume Control System Isolation Valve for Letdown			Note 2
55B	ZS-2200C-A1	Chemical Volume Control System Isolation Valve for Letdown			Note 2
55B	ZS-2200C-A2	Chemical Volume Control System Isolation Valve for Letdown			Note 2
55B	ZS-HC-204A-A1	Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-204A-A2	Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-204B-B1	Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-204B-B2	Hydrogen Recombiner (1-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-205A-A1	Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-205A-A2	Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-205B-B1	Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-205B-B2	Hydrogen Recombiner (1-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-206A-A1	Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-206A-A2	Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-206B-B1	Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-206B-B2	Hydrogen Recombiner (2-HC-HC-1) Inlet Isolation			Note 2
55B	ZS-HC-207A-A1	Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-207A-A2	Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-207B-B1	Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation			Note 2
55B	ZS-HC-207B-B2	Hydrogen Recombiner (2-HC-HC-1) Outlet Isolation			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
71.		NAMCO LIMIT SWITCHES	III.A	NONE	
		ZS-HCV-1200A Regeneration Heat Outlet	Deleted R-4 dated 8/24/83 - 79-01B		Deleted
		ZS-HCV-1200B Regeneration Heat Outlet	Deleted R-4 dated 8/24/83 - 79-01B		Deleted
		ZS-HCV-1200C Regeneration Heat Outlet	Deleted R-4 dated 8/24/83 - 79-01B		Deleted
		NAMCO LIMIT SWITCHES	II.C	AGING QUALIFIED LIFE	
56.		ZS-HCV-2200A Regeneration Heat Outlet	Deleted R-4 dated 9/3/81 - 0588		Deleted
56.		ZS-HCV-2200B Regeneration Heat Outlet	Deleted R-4 dated 9/3/81 - 0588		Deleted
56.		ZS-HCV-2200C Regeneration Heat Outlet	Deleted R-4 dated 9/3/81 - 0588		Deleted
71A		MICRO SWITCH LIMIT SWITCHES	I.B	NONE	
		ZS-CC-100A-B1 Containment Recirculation Air Cooler Outlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-100A-B2 Containment Recirculation Air Cooler Outlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-100B-B1 Containment Recirculation Air Cooler Outlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-100B-B2 Containment Recirculation Air Cooler Outlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-100C-B1 Containment Recirculation Air Cooler Outlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-100C-B2 Containment Recirculation Air Cooler Outlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-102A-A1 Reactor Coolant Pump Cooler Return Header	Replaced with Namco Limit Switch		Qualified
		ZS-CC-102A-A2 Reactor Coolant Pump Cooler Return Header	Replaced with Namco Limit Switch		Qualified
		ZS-CC-102C-A1 Reactor Coolant Pump Cooler Return Header	Replaced with Namco Limit Switch		Qualified
		ZS-CC-102C-A2 Reactor Coolant Pump Cooler Return Header	Replaced with Namco Limit Switch		Qualified
		ZS-CC-102E-A1 Reactor Coolant Pump Cooler Return Header	Replaced with Namco Limit Switch		Qualified
		ZS-CC-102E-A2 Reactor Coolant Pump Cooler Return Header	Replaced with Namco Limit Switch		Qualified
		ZS-CC-103A-A1 Residual Heat Removal Heat Exchanger Return	Replaced with Namco Limit Switch		Qualified
		ZS-CC-103A-A2 Residual Heat Removal Heat Exchanger Return	Replaced with Namco Limit Switch		Qualified
		ZS-CC-103B-B1 Residual Heat Removal Heat Exchanger Return	Replaced with Namco Limit Switch		Qualified
		ZS-CC-103B-B2 Residual Heat Removal Heat Exchanger Return	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104A-A1 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104A-A2 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104A-B1 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104A-B2 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104B-A1 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104B-A2 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104B-B1 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104B-B2 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104C-A1 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104C-A2 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104C-B1 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified
		ZS-CC-104C-B2 Reactor Coolant Pump Cooler Inlet	Replaced with Namco Limit Switch		Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
71A MICRO SWITCH LIMIT SWITCHES	I.B	NONE	
ZS-LM-100A-A1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100A-A2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100B-B1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100B-B2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100C-A1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100C-A2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100D-B1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100D-B2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100E-A1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100E-A2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100F-B1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100F-B2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100G-A1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100G-A2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100H-B1 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-100H-B2 Containment Open Tap	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101A-A1 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101A-A2 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101B-B1 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101B-B2 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101C-A1 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101C-A2 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101D-B1 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-LM-101D-B2 Containment Leakage Monitoring	Replaced with Namco Limit Switch	Qualified	
ZS-SS-100B-B1 Pressurizer Liquid Sample Space Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-100B-B2 Pressurizer Liquid Sample Space Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-101B-B1 Pressurizer Vapor Space Sample Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-101B-B2 Pressurizer Vapor Space Sample Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-104B-B1 Pressurizer Relief Tank Gas Space Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-104B-B2 Pressurizer Relief Tank Gas Space Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-112B-B1 Steam Generator Sample Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SS-112B-B2 Steam Generator Sample Isolation Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101A-A1 Air Cooler Emergency Supply Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101A-A2 Air Cooler Emergency Supply Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101A-B1 Air Cooler Emergency Supply Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101A-B2 Air Cooler Emergency Supply Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101B-A1 Air Cooler Emergency Return Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101B-A2 Air Cooler Emergency Return Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101B-B1 Air Cooler Emergency Return Valve	Replaced with Namco Limit Switch	Qualified	
ZS-SW-101B-B2 Air Cooler Emergency Return Valve	Replaced with Namco Limit Switch	Qualified	
56B ZS-CC-200A-B1 Containment Recirculation Air Cooler Outlet		Note 2	
56B ZS-CC-200A-B2 Containment Recirculation Air Cooler Outlet		Note 2	
56B ZS-CC-200B-B1 Containment Recirculation Air Cooler Outlet		Note 2	
56B ZS-CC-200B-B2 Containment Recirculation Air Cooler Outlet		Note 2	
56B ZS-CC-200C-B1 Containment Recirculation Air Cooler Outlet		Note 2	

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
71A	MICRO SWITCH LIMIT SWITCHES	I.B	NONE	
56B	ZS-CC-200C-B2			Note 2
56B	ZS-CC-202A-A1			Note 2
56B	ZS-CC-202A-A2			Note 2
56B	ZS-CC-202C-A1			Note 2
56B	ZS-CC-202C-A2			Note 2
56B	ZS-CC-202E-A1			Note 2
56B	ZS-CC-202E-A2			Note 2
56B	ZS-CC-203A-A1			Note 2
56B	ZS-CC-203A-A2			Note 2
56B	ZS-CC-203B-B1			Note 2
56B	ZS-CC-203B-B2			Note 2
56B	ZS-CC-204A-A1			Note 2
56B	ZS-CC-204A-A2			Note 2
56B	ZS-CC-204A-B1			Note 2
56B	ZS-CC-204A-B2			Note 2
56B	ZS-CC-204B-A1			Note 2
56B	ZS-CC-204B-A2			Note 2
56B	ZS-CC-204B-B1			Note 2
56B	ZS-CC-204B-B2			Note 2
56B	ZS-CC-204C-A1			Note 2
56B	ZS-CC-204C-A2			Note 2
56B	ZS-CC-204C-B1			Note 2
56B	ZS-CC-204C-B2			Note 2
56B	ZS-LM-200A-A1			Note 2
56B	ZS-LM-200A-A2			Note 2
56B	ZS-LM-200B-B1			Note 2
56B	ZS-LM-200B-B2			Note 2
56B	ZS-LM-200C-A1			Note 2
56B	ZS-LM-200C-A2			Note 2
56B	ZS-LM-200D-B1			Note 2
56B	ZS-LM-200D-B2			Note 2
56B	ZS-LM-200E-A1			Note 2
56B	ZS-LM-200E-A2			Note 2
56B	ZS-LM-200F-B1			Note 2
56B	ZS-LM-200F-B2			Note 2
56B	ZS-LM-200G-A1			Note 2
56B	ZS-LM-200G-A2			Note 2
56B	ZS-LM-200H-B1			Note 2
56B	ZS-LM-200H-B2			Note 2
56B	ZS-LM-201A-A1			Note 2
56B	ZS-LM-201A-A2			Note 2
56B	ZS-LM-201B-B1			Note 2
56B	ZS-LM-201B-B2			Note 2
56B	ZS-LM-201C-A1			Note 2
56B	ZS-LM-201C-A2			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
71A	MICRO SWITCH LIMIT SWITCHES	I.B	NONE	
56B	ZS-LM-201D-B1 Containment Leakage Monitoring			Note 2
56B	ZS-LM-201D-B2 Containment Leakage Monitoring			Note 2
56B	ZS-SS-200B-B1 Pressurizer Liquid Space Sample Isolation Valve			Note 2
56B	ZS-SS-200B-B2 Pressurizer Liquid Space Sample Isolation Valve			Note 2
56B	ZS-SS-201B-B1 Pressurizer Vapor Space Sample Isolation Valve			Note 2
56B	ZS-SS-201B-B2 Pressurizer Vapor Space Sample Isolation Valve			Note 2
56B	ZS-SS-204B-B1 Pressurizer Relief Tank Gas Space Sample Isolation Valve			Note 2
56B	ZS-SS-204B-B2 Pressurizer Relief Tank Gas Space Sample Isolation Valve			Note 2
56B	ZS-SS-212B-B1 Steam Generator Sample Isolation Valve			Note 2
56B	ZS-SS-212B-B2 Steam Generator Sample Isolation Valve			Note 2
56B	ZS-SW-201A-A1 Air Cooler Emergency Supply Valve			Note 1
56B	ZS-SW-201A-A2 Air Cooler Emergency Supply Valve			Note 1
56B	ZS-SW-201A-B1 Air Cooler Emergency Supply Valve			Note 1
56B	ZS-SW-201B-B1 Air Cooler Emergency Return Valve			Note 1
56B	ZS-SW-201B-B2 Air Cooler Emergency Return Valve			Note 1
71B	GORDOS LIMIT SWITCHES	I.A	NONE	
	ZS-HC-100B-1 Hydrogen Analyzer #1 Suction			Qualified
	ZS-HC-100B-2 Hydrogen Analyzer #1 Suction			Qualified
	ZS-HC-101A-1 Hydrogen Analyzer #1 Discharge			Qualified
	ZS-HC-101A-2 Hydrogen Analyzer #1 Discharge			Qualified
	ZS-HC-101B-1 Hydrogen Analyzer #1 Discharge			Qualified
	ZS-HC-101B-2 Hydrogen Analyzer #1 Discharge			Qualified
	ZS-HC-102B-1 Hydrogen Analyzer #2 Suction			Qualified
	ZS-HC-102B-2 Hydrogen Analyzer #2 Suction			Qualified
	ZS-HC-103A-1 Hydrogen Analyzer #2 Discharge			Qualified
	ZS-HC-103A-2 Hydrogen Analyzer #2 Discharge			Qualified
	ZS-HC-103B-1 Hydrogen Analyzer #2 Discharge			Qualified
	ZS-HC-103B-2 Hydrogen Analyzer #2 Discharge			Qualified
	ZS-RC-101A1-A1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101A1-A2 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101A2-A1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101A2-A2 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101B1-B1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101B1-B2 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101B2-B1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-101B2-B2 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102A1-A1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102A1-A2 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102B1-B1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102B1-B2 Reactor Coolant System Venting Isolation			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
71B	GORDOS LIMIT SWITCHES	I.A	DOCUMENTATION	
	ZS-RC-102A2-A1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102A2-A2 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102B2-B1 Reactor Coolant System Venting Isolation			Qualified
	ZS-RC-102B2-B2 Reactor Coolant System Venting Isolation			Qualified
	ZS-HC-108B-B1 Containment Atmosphere Sampling Isolation			Qualified
	ZS-HC-108B-B2 Containment Atmosphere Sampling Isolation			Qualified
	ZS-HC-109A-A1 Containment Atmosphere Sampling Isolation			Qualified
	ZS-HC-109A-A2 Containment Atmosphere Sampling Isolation			Qualified
	ZS-HC-109B-B1 Containment Atmosphere Sampling Isolation			Qualified
	ZS-HC-109B-B2 Containment Atmosphere Sampling Isolation			Qualified
72A	FISHER LIMIT SWITCHES	I.B	NONE	
	ZS-MS-110-A1 Main Steam Condenser Drain	Replaced with Namco Limit Switch		Qualified
	ZS-MS-110-A2 Main Steam Condenser Drain	Replaced with Namco Limit Switch		Qualified
	ZS-MS-110-B1 Main Steam Condenser Drain	Replaced with Namco Limit Switch		Qualified
	ZS-MS-110-B2 Main Steam Condenser Drain	Replaced with Namco Limit Switch		Qualified
	ZS-SV-102-2-A1 Air Ejector Discharge	Replaced with Namco Limit Switch		Qualified
	ZS-SV-102-2-A2 Air Ejector Discharge	Replaced with Namco Limit Switch		Qualified
71A	FISHER LIMIT SWITCHES	I.B	NONE	
	ZS-MS-210-A1 Main Steam Condenser Drain			Note 2
	ZS-MS-210-A2 Main Steam Condenser Drain			Note 2
	ZS-MS-210-B1 Main Steam Condenser Drain			Note 2
	ZS-MS-210-B2 Main Steam Condenser Drain			Note 2
	ZS-SV-102-2-A1 Air Ejector Discharge			Note 2
	ZS-SV-102-2-A2 Air Ejector Discharge			Note 2
73A	MICRO LIMIT SWITCHES	I.B	NONE	
	ZS-CV-100-M1 Containment Air Ejector Duct	Replaced with Namco Limit Switch		Qualified
	ZS-CV-100-M2 Containment Air Ejector Duct	Replaced with Namco Limit Switch		Qualified
72A	MICRO LIMIT SWITCHES	I.B	NONE	
	ZS-CV-200-M1 Containment Air Ejector Duct			Note 2
	ZS-CV-200-M2 Containment Air Ejector Duct			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY		DEFICIENCY	RESOLUTION
U1	U2					
72.		FOXBORO PRESSURE TRANSMITTERS	I.B	NONE		
		PT-1474 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1475 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1476 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1484 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1485 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1486 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1494 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1495 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
		PT-1496 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2476 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2486 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2496 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2474 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2484 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2494 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2475 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2485 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
38.		PT-2495 Steam Generator, Steam Pressure Transmitter	Replaced	Rosemount	1153GB9	Qualified
73.		ROSEMOUNT FLOW TRANSMITTERS	I.B	NONE		
		FT-1474 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
		FT-1475 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
		FT-1484 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
		FT-1485 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
		FT-1494 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
		FT-1495 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
54.		FT-2474 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
54.		FT-2475 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
54.		FT-2484 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
54.		FT-2485 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
54.		FT-2494 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified
54.		FT-2495 Steam Generator Flow Transmitter	Replaced	Rosemount	1153DD6	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
74.	FOXBORO FLOW TRANSMITTERS	II.A	QUALIFIED LIFE AGING DEGRADATION INSTRUMENT ACCURACY			
	FT-1945 Low Head Injection Header	Replaced Rosemount	1153DB5PA	Qualified		
	FT-1946 Low Head Injection Header	Replaced Rosemount	1153DB5PA	Qualified		
	FOXBORO FLOW TRANSMITTERS	I.B	AGING QUALIFIED LIFE			
50.	FT-2945 Low Head Injection Header			Note 1		
50.	FT-2946 Low Head Injection Header			Note 1		
74A	FOXBORO FLOW TRANSMITTERS	I.B	DOCUMENTATION			
	FT-CC-128 Component Cooling Flow	Replaced Rosemount	1153DB5PA	Qualified		
	FT-1110 Boric Acid Charging Flow			Note 2		
	FT-1122 Makeup Flow	Replaced Rosemount	1153HB5PA	Qualified		
	FT-1150 Letdown Flow	Replaced Rosemount	1153DB5PA	Qualified		
50A	FT-CC-228 Component Cooling Flow			Note 2		
50A	FT-2110 Boric Acid Charging Flow			Note 2		
50A	FT-2122 Makeup Flow			Note 2		
50A	FT-2150 Letdown Flow			Note 2		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
75.		FOXBORO FLOW TRANSMITTERS	II.A	DOCUMENTATION SIMILARITY QUALIFIED LIFE AGING DEGRADATION PEAK TEMPERATURE TIME DURATION TEST SEQUENCE	
	FT-1961	Loop 1 Cold Leg Safety Injection		Qualified Backup Available	Note 2
	FT-1962	Loop 2 Cold Leg Safety Injection		Qualified Backup Available	Note 2
	FT-1963	Loop 3 Cold Leg Safety Injection		Qualified Backup Available	Note 2
		FOXBORO FLOW TRANSMITTERS	I.B	DOCUMENTATION SIMILARITY QUALIFIED LIFE AGING DEGRADATION PEAK TEMPERATURE TIME DURATION TEST SEQUENCE INSTRUMENT ACCURACY	
51.	FT-2962	Loop 2 Cold Leg Safety Injection		Qualified Backup Available	Note 2
51.	FT-2963	Loop 3 Cold Leg Safety Injection		Qualified Backup Available	Note 2
51.	FT-2961	Loop 1 Cold Leg Safety Injection		Qualified Backup Available	Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
76.		FOXBORO FLOW TRANSMITTERS	III.A	NONE	
		FT-1414 Loop 1 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1415 Loop 1 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1416 Loop 1 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1424 Loop 2 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1425 Loop 2 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1426 Loop 2 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1434 Loop 3 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1435 Loop 3 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
		FT-1436 Loop 3 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2414 Loop 1 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2415 Loop 1 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2416 Loop 1 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2424 Loop 2 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2425 Loop 2 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2426 Loop 2 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2434 Loop 3 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2435 Loop 3 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
52.		FT-2436 Loop 3 Reactor Coolant Flow Indication	Deleted R-4	dated 8/21/81 - 79-01B	Deleted
77.		BARTON FLOW TRANSMITTERS	II.A	DOCUMENTATION	
		FT-1940 Safety Injection Header Flow, Hot Leg	Replaced Rosemount	1153HB6PA	Qualified
		FT-1943 Boron Injection Tank Header Flow	Replaced Rosemount	1153HB6PA	Qualified
53.		FT-2940 Safety Injection Header Flow Hot Leg			Note 1
53.		FT-2943 Boron Injection Tank Header Flow			Note 1
78.		GEMS LEVEL TRANSMITTERS	III.B	NONE	
		LIT-RS-151A Containment Water Level	Located Mild Environment		Deleted
79.		GEMS LEVEL TRANSMITTERS	III.B	NONE	
		LIT-RS-151B Containment Water Level	Located Mild Environment		Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

DESCRIPTION		NRC CATEGORY	DEFICIENCY	RESOLUTION
80.	BARTON LEVEL TRANSMITTERS	I.B	SIMILARITY	
	LT-1459 Pressurizer Level Transmitter		Replaced Rosemount 1153 HD5	Qualified
	BARTON LEVEL TRANSMITTERS	I.R	NONE	
49.	LT-2459 Pressurizer Level Transmitter		Replaced Rosemount 1153 HD5	Qualified
81.	GEMS LEVEL TRANSMITTERS	I.B	SUBMERGENCE FUNCTIONAL TESTING	
	LT-RS-151A-1 Containment Sump Level Transmitter A		Replaced GEM's Transmitters	Qualified
	LT-RS-151A-2 Containment Sump Level Transmitter A		Replaced GEM's Transmitters	Qualified
	GEMS LEVEL TRANSMITTERS	I.B	NONE	
44.	LT-RS-251A-1 Containment Sump Level Transmitter A		Replaced GEM's Transmitters	Qualified
	GEMS LEVEL INDICATING TRANSMITTERS	III.B	NONE	
46.	LIT-RS-251A-2 Containment Sump Level Transmitter A		Located in Mild Environment	Deleted
82.	GEMS LEVEL TRANSMITTERS	I.B	SUBMERGENCE FUNCTIONAL TESTING	
	LT-RS-151B-1 Containment Sump Level Transmitter B		Replaced GEM's Transmitters	Qualified
	LT-RS-151B-2 Containment Sump Level Transmitter B		Replaced GEM's Transmitters	Qualified
44.	LT-RS-251B-1 Containment Sump Level Transmitter B		Replaced GEM's Transmitters	Qualified
46.	LT-RS-251B-2 Containment Sump Level Transmitter B		Replaced GEM's Transmitters	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
83.	GEMS LEVEL TRANSMITTERS	II.B	DOCUMENTATION AGING QUALIFIED LIFE PEAK TEMPERATURE TIME DURATION PROFILE ENVELOPED STEAM EXPOSURE TEST SEQUENCE SPRAY SUBMERGENCE ANOMALIES FUNCTIONAL TESTING	
	LT-DA-110A Containment Sump Level Narrow Range		Qualified Backup Available	Deleted
	LT-DA-110B Containment Sump Level Narrow Range		Qualified Backup Available	Deleted
	GEMS LEVEL TRANSMITTERS	II.B	DOCUMENTATION AGING QUALIFIED LIFE PEAK TEMPERATURE TIME DURATION PROFILE ENVELOPED STEAM EXPOSURE SPRAY SUBMERGENCE TEST SEQUENCE ANOMALIES FUNCTIONAL TESTING	
64.	LT-DA-210A Containment Sump Level Narrow Range		Qualified Backup Available	Deleted
64.	LT-DA-210B Containment Sump Level Narrow Range		Qualified Backup Available	Deleted
83A	GEMS LEVEL MODULAR RECEIVERS	III.A	NONE	
	LQ/LS-DA-110A Modular Receiver, Containment & Sump Level (Narrow Range)		Qualified Backup Available	Deleted
	LQ/LS-DA-110B Modular Receiver, Containment & Sump Level (Narrow Range)		Qualified Backup Available	Deleted
64A	LQ/LS-DA-210A Modular Receiver, Containment & Sump Level (Narrow Range)		Qualified Backup Available	Deleted
64A	LQ/LS-DA-210B Modular Receiver, Containment & Sump Level (Narrow Range)		Qualified Backup Available	Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM

NUMBER
U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

84. FOXBORO LEVEL TRANSMITTERS

II.A

DOCUMENTATION
SIMILARITY
QUALIFIED LIFE
AGING DEGRADATION
PEAK TEMPERATURE
TIME DURATION
TEST SEQUENCE
INSTRUMENT ACCURACY

LT-1477 Steam Generator 1 Wide Range Level
LT-1487 Steam Generator 1 Wide Range Level
LT-1497 Steam Generator 1 Wide Range Level

Replaced Rosemount 1153DD5PA
Replaced Rosemount 1153DD5PA
Replaced Rosemount 1153DD5PA

Qualified
Qualified
Qualified

FOXBORO LEVEL TRANSMITTERS

I.B

DOCUMENTATION
SIMILARITY
QUALIFIED LIFE
AGING DEGRADATION
PEAK TEMPERATURES
TIME DURATION
TEST SEQUENCE
INSTRUMENT ACCURACY

47. LT-2477 Steam Generator Wide Range Level
47. LT-2487 Steam Generator Wide Range Level
47. LT-2497 Steam Generator Wide Range Level

Note 1
Note 1
Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER

U1 U2

ITEM NUMBER	DESCRIPTION	NRC CATEGORY		DEFICIENCY	RESOLUTION
		I.B	NONE		
85.	ROSEMOUNT LEVEL TRANSMITTERS				
	LT-1474 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1476 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1486 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1494 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1495 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1475 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1484 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1485 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
	LT-1496 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2475 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2484 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2485 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2496 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2474 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2494 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2495 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2476 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
48.	LT-2486 Steam Generator Narrow Range Level Transmitter	Replaced	Rosemount	1153DD4	Qualified
86.	BARTON LEVEL TRANSMITTERS				
	LT-1460 Pressurizer Level Transmitter	Replaced	Rosemount	1153HD5	Qualified
49.	LT-2460 Pressurizer Level Transmitter	Replaced	Rosemount	1153HD5	Qualified
87.	BARTON LEVEL TRANSMITTERS				
	LT-1461 Pressurizer Level Transmitter	Replaced	Rosemount	1153HD5	Qualified
49.	LT-2461 Pressurizer Level Transmitter	Replaced	Rosemount	1153HD5	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM

NUMBER
U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
87A	BARTON LEVEL TRANSMITTERS	II.A	RADIATION	
	LT-1310 Coolant Level in Reactor Vessel			Qualified
	LT-1311 Coolant Level in Reactor Vessel			Qualified
	LT-1312 Coolant Level in Reactor Vessel			Qualified
	LT-1320 Coolant Level in Reactor Vessel			Qualified
	LT-1321 Coolant Level in Reactor Vessel			Qualified
	LT-1322 Coolant Level in Reactor Vessel			Qualified
49A	LT-2310 Coolant Level in Reactor Vessel			Qualified
49A	LT-2311 Coolant Level in Reactor Vessel			Qualified
49A	LT-2312 Coolant Level in Reactor Vessel			Qualified
49A	LT-2320 Coolant Level in Reactor Vessel			Qualified
49A	LT-2321 Coolant Level in Reactor Vessel			Qualified
49A	LT-2322 Coolant Level in Reactor Vessel			Qualified
88	FOXBORO PRESSURE TRANSMITTERS	II.A	AGING QUALIFIED LIFE INSTRUMENT ACCURACY	
	PT-LM-110A Containment Pressure (Wide Range)		Documentation Submitted 4/29/83	Qualified
	PT-LM-110B Containment Pressure (Wide Range)		Documentation Submitted 4/29/83	Qualified
	FOXBORO PRESSURE TRANSMITTERS	I.A	NONE	
37A	PT-LM-210A Containment Pressure (Wide Range)			Qualified
37A	PT-LM-210B Containment Pressure (Wide Range)			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM

NUMBER
U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

89.	FOXBORO PRESSURE TRANSMITTERS		II.C	QUALIFIED LIFE AGING DEGRADATION	
	PT-LM-100A Containment Pressure		Replaced	Rosemount 1153AB6PA	Qualified
	PT-LM-100B Containment Pressure		Replaced	Rosemount 1153AB6PA	Qualified
	PT-LM-100C Containment Pressure		Replaced	Rosemount 1153AB6PA	Qualified
	PT-LM-100D Containment Pressure		Replaced	Rosemount 1153AB6PA	Qualified
	FOXBORO PRESSURE TRANSMITTERS		III.B	NONE	
37.	PT-LM-200A Containment Pressure				Note 1
37.	PT-LM-200B Containment Pressure				Note 1
37.	PT-LM-200C Containment Pressure				Note 1
37.	PT-LM-200D Containment Pressure				Note 1
	FOXBORO PRESSURE TRANSMITTERS		II.A	AGING QUALIFIED LIFE INSTRUMENT ACCURACY	
39.	PT-LM-100A Containment Pressure		Duplicate	TER Item 89(U1)	Duplicate
39.	PT-LM-100B Containment Pressure		Duplicate	TER Item 89(U1)	Duplicate
90.	FOXBORO PRESSURE TRANSMITTERS		II.A	QUALIFIED LIFE AGING DEGRADATION INSTRUMENT ACCURACY	
	PT-RS-156A Recirculation Spray Pump Discharge		Replaced	Rosemount 1153GB7PA	Qualified
	PT-RS-156B Recirculation Spray Pump Discharge		Replaced	Rosemount 1153GB7PA	Qualified
	FOXBORO PRESSURE TRANSMITTERS		I.B	AGING QUALIFIED LIFE	
40.	PT-RS-256A Recirculation Spray Pump Discharge				Note 1
40.	PT-RS-256B Recirculation Spray Pump Discharge				Note 1

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM

NUMBER
U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

90A	FOXBORO PRESSURE TRANSMITTERS	III.A	NONE	
	PT-1921 Accumulator Pressure	Considered Cat. III	R.G. 1.97	Deleted
	PT-1925 Accumulator Pressure	Considered Cat. III	R.G. 1.97	Deleted
	PT-1929 Accumulator Pressure	Considered Cat. III	R.G. 1.97	Deleted
40A	PT-2921 Accumulator Pressure	Considered Cat. III	R.G. 1.97	Deleted
40A	PT-2925 Accumulator Pressure	Considered Cat. III	R.G. 1.97	Deleted
40A	PT-2929 Accumulator Pressure	Considered Cat. III	R.G. 1.97	Deleted
91.	BARTON PRESSURE TRANSMITTERS	I.B	DOCUMENTATION	
	PT-1402 Reactor Coolant System Wide Range	Replaced Rosemount	1153GD9PA	Qualified
41.	PT-2402 Reactor Coolant System Wide Range			Note 1
92.	ROSEMOUNT PRESSURE TRANSMITTERS	I.B	AGING QUALIFIED LIFE PEAK TEMPERATURE TEST SEQUENCE FUNCTIONAL TESTING	
	PT-1403 Reactor Coolant System Wide Range	Replaced Rosemount	1153GD9PA	Qualified
	ROSEMOUNT PRESSURE TRANSMITTERS	I.B	AGING QUALIFIED LIFE PEAK TEMPERATURE TEST SEQUENCE INSTRUMENT ACCURACY	
43.	PT-2403 Reactor Coolant System Wide Range			Note 1
93.	BARTON PRESSURE TRANSMITTERS	I.B	NONE	
	PT-1457 Pressurizer Pressure Protection	Replaced Rosemount	1153GD9	Qualified
	PT-1455 Pressurizer Pressure Protection	Replaced Rosemount	1153GD9	Qualified
	PT-1456 Pressurizer Pressure Protection	Replaced Rosemount	1153GD9	Qualified
42.	PT-2455 Pressurizer Pressure Protection	Replaced Rosemount	1153GD9	Qualified
42.	PT-2456 Pressurizer Pressure Protection	Replaced Rosemount	1153GD9	Qualified
42.	PT-2457 Pressurizer Pressure Protection	Replaced Rosemount	1153GD9	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
93A	MASON NEILAN TRANSMITTERS	I.B	DOCUMENTATION	
	LT-1115 Volume Control Tank Level	Considered Cat. III	R.G. 1.97	Deleted
	MASON NEILAN LEVEL TRANSMITTERS			
48A	LT-2115 Volume Control Tank Level	Considered Cat. III	R.G. 1.97	Deleted
107.	GEMS LEVEL TRANSMITTERS	I.B	DOCUMENTATION	
	LIT-DA-110A Containment Sump Level (Narrow Range)	Qualified Backup Available		Deleted
45.	LIT-DA-210A Containment Sump Level (Narrow Range)	Qualified Backup Available		Deleted
108.	GEMS LEVEL TRANSMITTERS	I.B	DOCUMENTATION	
	LIT-DA-110B Containment Sump Level (Narrow Range)	Qualified Backup Available		Deleted
45.	LIT-DA-210B Containment Sump Level (Narrow Range)	Qualified Backup Available		Deleted

*STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2*

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

DESCRIPTION		NRC CATEGORY	DEFICIENCY	RESOLUTION
101.	KLOCKNER-MOELLER MOTOR CONTROL CENTERS	II.C	AGING QUALIFIED LIFE	I
	-MC-19 Supplies Power to Safety System		Additional Documentation in QDR	Qualified
	EP-MC-20 Supplies Power to Safety System		Additional Documentation in QDR	Qualified
	EP-MC-21 Supplies Power to Safety System		Additional Documentation in QDR	Qualified
	EP-MC-22 Supplies Power to Safety System		Additional Documentaiton in QDR	Qualified
79.	EP-MC-19 Supplies Power to Safety Systems		Additional Documentation in QDR	Qualified
79.	EP-MC-20 Supplies Power to Safety Systems		Additional Documentation in QDR	Qualified
79.	EP-MC-21 Supplies Power to Safety Systems		Additional Documentation in QDR	Qualified
	KNOCKNER-MOELLER MOTORE CONTROL CENTERS	I.A	NONE	
79A	EP-MC-22 Supplies Power to Safety System			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT

ITEM

NUMBER

U1 U2

DESCRIPTION

NRC
CATEGORY

DEFICIENCY

RESOLUTION

ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
110.	CONAX ELECTRIC PENETRATION	I.A	NONE	
	TYPE-IA Low Voltage Power			Qualified
	TYPE-IB Low Voltage Power			Qualified
	TYPE-IC Low Voltage Power			Qualified
	TYPE-11A Low Voltage Power			Qualified
	TYPE-11B Low Voltage Power			Qualified
	TYPE-11C Low Voltage Power			Qualified
	TYPE-11D Low Voltage Power			Qualified
	TYPE-11E Low Voltage Power			Qualified
	TYPE-III Triaxial			Qualified
	TYPE-IV Thermocouples			Qualified
80.	TYPE-IA Low Voltage Power			Qualified
80.	TYPE-IB Low Voltage Power			Qualified
80.	TYPE-IC Low Voltage Power			Qualified
80.	TYPE-11A Low Voltage Power			Qualified
80.	TYPE-11B Low Voltage Power			Qualified
80.	TYPE-11C Low Voltage Power			Qualified
80.	TYPE-11D Low Voltage Power			Qualified
80.	TYPE-11E Low Voltage Power			Qualified
108.	Type IV Thermocouples			Qualified
109.	TYPE III Triaxial			Qualified
	CONAX PENETRATION ASSEMBLIES	I.A	NONE	
81.	TYPE-IA Low Voltage Power			Duplicate
81.	TYPE-IB Low Voltage Power			Duplicate
81.	TYPE-IC Low Voltage Power			Duplicate
81.	TYPE-11A Low Voltage Power			Duplicate
81.	TYPE-11B Low Voltage Power			Duplicate
81.	TYPE-11C Low Voltage Power			Duplicate
81.	TYPE-11D Low Voltage Power			Duplicate
81.	TYPE-11E Low Voltage Power			Duplicate

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
111.	OKONITE INSIDE RECIRCULATION SPRAY PUMP MOTOR SPLICES	I.A	NONE	
	SP-62-1 Engineered Safety Function Design Basis Accident Mitigation			1 Qualified
88.	SP-62-1 Engineered Safety Function Design Basis Accident Mitigation			Qualified
	OKONITE 3M INSIDE RECIRCULATION SPRAY PUMP MOTOR SPLICES	II.A	DOCUMENTATION SIMILARITY	
114.	SP-26B Engineered Safety Feature Design Basis Accident Mitigation	Documentation Submitted 4/29/83		Qualified
112.	RAYCHEM SPLICING MATERIAL	I.A	NONE	
	WCSFN Field Splicing Material			Qualified
86.	WCSFN Field Splicing Material			Qualified
113.	OKONITE TAPED SPLICES	I.A	NONE	
	T-95 Insulating Tape			Qualified
	T-35 Jacketing Tape			Qualified
87.	T-95 Insulating Tape			Qualified
87.	T-35 Jacketing Tape			Qualified
	CONAX SPLICES	I.A	NONE	
85.	KAPTON Supplies Power to Safety Systems			Qualified
114.	ITE 480 VOLT SWITCHGEARS	IV	NONE	
	EE-SS-04 480 Volt Switchgear (2J1)	QDR File is Available		Qualified
	ITE IMPERIAL 480 VOLT SWITCHGEAR (2H1)	III.B	NONE	1
78.	EE SS-03 Supplies Power to Safety Systems	Deleted R-4 dated 9/31/81 - 0588		Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
	ITE IMPERIAL 480 VOLT SWITCHGEAR (2J1)	II.C	AGING QUALIFIED LIFE AGING DEGRADATION	
77.	EE-SS-04 480 Volt Switchgear (2J1)		Additional Documentation in QDR	Qualified
	ITE IMPERIAL 480 VOLT TRANSFORMER (2J1)	III.B	NONE	
107.	EE-ST-01 480 Volt Transformer		Deleted R-4 dated 9/31/81 - 0588	Deleted
115.	ITE 480 VOLT SWITCHGEARS	IV	NONE	
	EE-ST-02 480 Volt Switchgear (2J1)		QDR File is Available	Qualified
	ITE IMPERIAL 480 VOLT TRANSFORMER (2J1)	II.C	AGING QUALIFIED LIFE AGING DEGRADATION	
106.	EE-ST-02 480 Volt Transformer		Additional Documentation in QDR	Qualified
116.	WESTINGHOUSE TERMINAL BLOCKS	I.B	RADIATION	
	Model TBAL Supplies Power To Safety System		Nylon Blocks Removed	Deleted
113.	TB-32E Supplies Power to Safety System		Nylon Blocks Removed	Deleted
117.	GENERAL ELECTRIC TERMINAL BLOCKS	I.A	NONE	
	Model			
	EB-5/EB-25 Supplies Power to Safety System			Qualified
112.	EB-5/EB-25 Supplies Power to Safety System			Qualified
118.	THERMO-ELECTRIC TERMINAL BLOCKS	I.A	NONE	
	Model 3225 Supplies Power to Safety System		Not Used on Master List Equipment	Deleted
111.	Model 3225 Supplies Power to Safety System		Not Used on Master List Equipment	Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
119.	CONNECTRON TERMINAL BLOCKS	I.B	RADIATION	
	Model NSE-3/NSS-3/PSU Containment Electrical Penetration		Nylon Blocks Removed	Deleted
		I.A	NONE	
120.	MARATHON TERMINAL BLOCKS	I.A	NONE	
	Model 200/1500 Supplies Power to Safety System			Qualified
83.	Model 200/1500 Supplies Power to Safety System			
	CONNECTRON TERMINAL BLOCKS	I.B	RADIATION	
110.	NSE-3, NSS-3 Supplies Power to Safety System		Nylon Blocks Removed	Deleted
121.	CONNECTRON TERMINAL BLOCKS	I.A	NONE	
	Model NSS3 PLYSL Containment Electrical Penetrations			Qualified
84.	NSS3 PLYSL Supplies Power to Safety System			Qualified
122.	RAYCHEM TERMINATIONS	I.A	NONE	
	HVT/HVMC Supplies Power to Safety Systems			Qualified
122A	HVT/HVMC Supplies Power to Safety Systems			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
123.		BOSTON INSULATED WIRE AND CABLE 300 VOLT INSTRUMENT CABLES	I.A	NONE	
		NGA-67 19/C #16 AWG, Cable			Qualified
		NGA-68 12/C #16 AWG, Cable			Qualified
		NGA-69 2/C #16 AWG, Cable			Qualified
		NGA-70 18/C #16 AWG, Cable			Qualified
		NGB-35 2/C #16 AWG, Cable			Qualified
		NGB-39 3/C #16 AWG, Cable			Qualified
		NGB-40 4/C #16 AWG, Cable			Qualified
		NGB-55 45/C #16 AWG, Cable			Qualified
91.		NGA-67 19/c #16 AWG, Cable			Qualified
91.		NGA-68 12/c #16 AWG, Cable			Qualified
91.		NGA-69 2/c #16 AWG, Cable			Qualified
91.		NGA-70 18/c #16 AWG, Cable			Qualified
91.		NGB-35 2/c #16 AWG, Cable			Qualified
91.		NGB-39 3/c #16 AWG, Cable			Qualified
91.		NGB-40 4/c #16 AWG, Cable			Qualified
91.		NGB-55 45/c #16 AWG, Cable			Qualified
124.		BOSTON INSULATED WIRE AND CABLE 300 VOLT INSTRUMENT CABLES	I.A	NONE	
		NGB-35 2/c, #16 AWG, Cable			Duplicate
		NGA-69 2/c, #16 AWG, Cable			Duplicate
125		CERRO WIRE AND CABLE COMPANY HIGH TEMPERATURE CABLES	II.A	FUNCTIONAL TESTING	
		NGA-15 Triplex 250 MCM, Cable	Documentation Submitted	04/29/83	Qualified
93.		NGA-15 Recirculation Spray Pumps	Documentation Submitted	04/29/83	Qualified
126.		CERRO WIRE AND CABLE COMPANY 300 VOLT INSTRUMENT CABLES	II.A	FUNCTIONAL TESTING	
		NGA-67 19/c, #16 AWG, Cable	Documentation Submitted	04/29/83	Qualified
		NGA-68 12/c, #16 AWG, Cable	Documentation Submitted	04/29/83	Qualified
		NGA-70 18/c, #16 AWG, Cable	Documentation Submitted	04/29/83	Qualified
		NGB-39 3/c, #16 AWG, Cable	Documentation Submitted	04/29/83	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
127.	CERRO WIRE AND CABLE COMPANY 300 VOLT INSTRUMENT CABLES	II.A	FUNCTIONAL TESTING	
	NGB-35 2/c #16 AWG, Cable		Documentation Submitted 04/29/83	Qualified
127A	CERRO WIRE AND CABLE COMPANY 300 VOLT INSTRUMENT CABLES	I.A	NONE	
	NJK-47 7/c #14 AWG, Cable			Qualified
	NJK-48 5/c #14 AWG, Cable			Qualified
	NJK-46 9/c #14 AWG, Cable			Qualified
94A	NJK-46 9/c #14 AWG	I.A	NONE	Qualified
94A	NJK-47 7/c #14 AWG			Qualified
127B	CONAX SEALING GLANDS	I.A	NONE	
	N-11000 Series Electric Conductor Seal Assembly (Inside Containment)			Qualified
	PL-Series Electric Conductor seal Assembly (Outside Containment)			Qualified
100B	CONAX SEALING GLANDS			
	N-11000 Series Electric Conductor Seal Assembly (Inside Containment)			Qualified
	PL-Series Electric Conductor seal Assembly (Outside Containment)			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER U1 U2	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
128.	CERRO WIRE AND CABLE COMPANY 600 VOLT COPPER CONTROL CABLES	II.A	FUNCTIONAL TESTING	
	NGA-19 2/c #2 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-34 1/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-35 2/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-36 3/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-37 5/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-38 7/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-39 9/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-40 12/c #14 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-44 1/c #12 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-45 2/c #12 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-47 4/c #12 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-49 7/c #12 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-57 4/c #10 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGA-77 4/c #10 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGB-43 2/c #8 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGB-44 2/c #6 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
	NGB-45 4/c #6 AWG, Cable	Documentation	Submitted 4/29/83	Qualified
94.	NGA-19 2/c #2 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-34 1/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-35 2/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-36 3/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-37 5/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-38 7/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-39 9/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-40 12/c #14 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-44 1/c #12 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-45 2/c #12 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-47 4/c #12 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-49 7/c #12 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-57 4/c #10 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-77 4/c #10 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGB-43 2/c #8 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGB-44 2/c #6 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGB-45 4/c #6 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-67 19/c #16 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-68 12/c #16 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGA-70 18/c #16 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGB-35 2/c #16 AWG	Documentation	Submitted 4/29/83	Qualified
94.	NGB-39 3/c #16 AWG	Documentation	Submitted 4/29/83	Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION		
					U1	U2
128A	RAYCHEM 300 VOLT INSTRUMENT CABLE	I.A	NONE			
	NJK-64 4/c #16 AWG, Cable			Qualified		
	NJK-65 3/c #16 AWG, Cable			Qualified		
	NJK-66 2/c #16 AWG, Cable			Qualified		
	NJK-67 2/c #16 AWG, Cable			Qualified		
129.	ENDEVCO HARDLINE COAXIAL CABLES	I.B	NONE			
	Low Noise Cable Pressurizer Safety Valve/Power Operated Relief Valve Position			Note 2		
92.	Low Noise Cable Pressurizer Safety Valve/Power Operated Relief Valve Position			Note 2		
130.	GENERAL CABLE 600 VOLT ALUMINUM POWER CABLES	II.C	AGING QUALIFIED LIFE			
	NGB-5 Triplex 500 MCM, Cable	Additional	Documentation in QDR	Qualified		
	NGB-7 Triplex 250 MCM, Cable	Additional	Documentation in QDR	Qualified		
	NGB-11 Triplex 2/0 AWG, Cable	Additional	Documentation in QDR	Qualified		
	NGB-12 Triplex #1 AWG, Cable	Additional	Documentation in QDR	Qualified		
90.	NGB-5 Triplex 500 MCM	Additional	Documentation in QDR	Qualified		
90.	NGB-7 Triplex 250 MCM	Additional	Documentation in QDR	Qualified		
90.	NGB-11 Triplex 250 MCM	Additional	Documentation in QDR	Qualified		
90.	NGB-12 Triplex 250 MCM	Additional	Documentation in QDR	Qualified		
131.	GENERAL CABLE 5,000 VOLT ALUMINUM POWER CABLES	II.C	AGING QUALIFIED LIFE			
	NGA-3 Triplex 1000 MCM	Additional	Documentation in QDR	Qualified		
	NGA-4 3/C 500 MCM Aluminum Armor, Cable	Additional	Documentation in QDR	Qualified		
	NGA-5 3/C 1250 MCM Steel Armor, Cable	Additional	Documentation in QDR	Qualified		
	NGA-6 3/C 500 MCM Aluminum Armor, Cable	Additional	Documentation in QDR	Qualified		
	NGA-9 1/c 1500 MCM, Cable	Additional	Documentation in QDR	Qualified		
	NGA-10 1/c 2000 MCM, Cable	Additional	Documentation in QDR	Qualified		
	NGA-12 3/c 1000 MCM Aluminum Armor, Cable	Additional	Documentation in QDR	Qualified		
	NGA-13 3/c 4/0 AWG Aluminum Armor, Cable	Additional	Documentation in QDR	Qualified		
89.	NGA-3 Triplex 1000 MCM	Additional	Documentation in QDR	Qualified		
89.	NGA-4 3/c 500 MCM Aluminum Armor	Additional	Documentation in QDR	Qualified		
89.	NGA-5 3/c 1250 MCM Steel Armor	Additional	Documentation in QDR	Qualified		
89.	NGA-6 3/c 1250 MCM Aluminum Armor	Additional	Documentation in QDR	Qualified		
89.	NGA-9 1/c 1500 MCM	Additional	Documentation in QDR	Qualified		
89.	NGA-10 1/c 2000 MCM	Additional	Documentation in QDR	Qualified		
89.	NGA-12 3/c 1000 MCM Aluminum Armor	Additional	Documentation in QDR	Qualified		
89.	NGA-13 3/c 4/0 AWG Aluminum Armor	Additional	Documentation in QDR	Qualified		

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
132.		OKONITE 600 VOLT COPPER CABLES	I.A	NONE	
		NGB-01 2/c #10 AWG, Cable			Qualified
95.		NGB-01 2/c #10 AWG			Qualified
133.		OKONITE 600 VOLT POWER CABLES	I.A	NONE	
		NGA-20 1/c 250 MCM, Cable			Qualified
		NGA-21 1/c 2/0 AWG Cable			Qualified
		NGB-15 Triplex #4 AWG, Cable			Qualified
		NGB-16 Triplex #6 AWG, Cable			Qualified
		NGB-17 3/c, #8 AWG, Cable			Qualified
		NGB-18 3/c, #10 AWG, Cable			Qualified
		NGB-19 3/c, #12 AWG, Cable			Qualified
95.		NGA-20 1/c 250 MCM			Qualified
95.		NGA-21 1/c 2/0 AWG			Qualified
95.		NGB-15 Triplex #4 AWG			Qualified
95.		NGB-16 Triplex #6 AWG			Qualified
95.		NGB-17 3/c #8 AWG			Qualified
95.		NGB-18 3/c #10 AWG			Qualified
95.		NGB-19 3/c #12 AWG			Qualified
134.		OKONITE 600 VOLT ALUMINUM POWER CABLES	I.A	NONE	
		NGB-5 Triplex 500 MCM, Cable			Qualified
		NGB-7 Triplex 250 MCM, Cable			Qualified
		NGB-11 Triplex #2/0 AWG, Cable			Qualified
		NGB-12 Triplex #1 AWG, Cable			Qualified
95.		NGB-5 Triplex 500 MCM			Qualified
95.		NGB-7 Triplex 250 MCM			Qualified
95.		NGB-11 Triplex #2/0 AWG			Qualified
95.		NGB-12 Triplex #1 AWG			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM
NUMBER
U1 U2

DESCRIPTION		NRC CATEGORY	DEFICIENCY	RESOLUTION
135.	OKONITE 5000 VOLT ALUMINUM POWER CABLES	I.A	NONE	
	NGA-3 Triplex 1000 MCM, Cable			Qualified
	NGA-4 3/c 500 MCM, Cable			Qualified
	NGA-13 3/c 4/0 AWG, Cable			Qualified
	NGA-14 Triplex 4/0 AWG, Cable			Qualified
96.	NGA-4 3/c 500 MCM			Qualified
96.	NGA-14 Triplex 4/0 AWG			Qualified
96.	NGA-3 Triplex 1000 MCM			Qualified
96.	NGA-13 3/c #4/0 AWG			Qualified

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL
EVALUATION
REPORT
ITEM

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
102.	ENDEVCO ACCELEROMETERS	I.B	DOCUMENTATION	
	YE-VMS-101B-1 Pressurizer Pilot Operated Relief Valve Position			Note 2
	YE-VMS-101B-2 Pressurizer Pilot Operated Relief Valve Position			Note 2
97.	YE-VMS-201B-1 Pressurizer Pilot Operated Relief Valve Position			Note 2
97.	YE-VMS-201B-2 Pressurizer Pilot Operated Relief Valve Position			Note 2
103.	ENDEVCO ACCELEROMETERS	I.B	DOCUMENTATION	
	YE-VMS-100A-1 Pressurizer Safety Valve Position			Note 2
	YE-VMS-100A-2 Pressurizer Safety Valve Position			Note 2
	YE-VMS-100B-1 Pressurizer Safety Valve Position			Note 2
	YE-VMS-100B-2 Pressurizer Safety Valve Position			Note 2
	YE-VMS-100C-1 Pressurizer Safety Valve Position			Note 2
	YE-VMS-100C-2 Pressurizer Safety Valve Position			Note 2
	YE-VMS-101A-1 Pressurizer Pilot Operated Relief Valve Position			Note 2
	YE-VMS-101A-2 Pressurizer Pilot Operated Relief Valve Position			Note 2
97.	YE-VMS-200A-1 Acoustical Monitoring			Note 2
97.	YE-VMS-200A-2 Acoustical Monitoring			Note 2
97.	YE-VMS-200B-1 Acoustical Monitoring			Note 2
97.	YE-VMS-200B-2 Acoustical Monitoring			Note 2
97.	YE-VMS-200C-1 Acoustical Monitoring			Note 2
97.	YE-VMS-200C-2 Acoustical Monitoring			Note 2
97.	YE-VMS-201A-1 Acoustical Monitoring			Note 2
97.	YE-VMS-201A-2 Acoustical Monitoring			Note 2
103A	VICTOREEN RADIATION MONITORS	I.A	NONE	
	RM-RMS-165 High Range Radiation Detector			Qualified
	RM-RMS-166 High Range Radiation Detector			Qualified
103B	RM-RMS-265 High Range Radiation Detector	NuReg-0737		Note 1
	RM-RMS-266 High Range Radiation Detector	NuReg-0737		Note 1
104.	BENDIX HYDROGEN ANALYZERS	I.B	DOCUMENTATION	
	H2A-HC-100 Hydrogen Analyzer		Deleted R-4 dated 8/24/83 - 79-018	Deleted
	H2A-HC-200 Hydrogen Analyzer		Deleted R-4 dated 8/24/83 - 79-018	Deleted
103.	H2-A-HC-200 Hydrogen Analyzer		Deleted R-4 dated 09/03/81 - 0588	Deleted
103.	H2-A-HC-100 Hydrogen Analyzer		Deleted R-4 dated 09/31/81 - 0588	Deleted

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER		DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
U1	U2				
104A		COMPSIP - DELPHI HYDROGEN ANALYZER	I.B	DOCUMENTATION	
		H2-HC-101 Hydrogen Concentration			Note 2
103A		H2-HC-201	NuReg-0737		Note 2
105.		WESTINGHOUSE RADIATION MONITORS	I.B	DOCUMENTATION	
		RM-SW-124 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
		RM-SW-125 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
		RM-SW-126 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
		RM-SW-127 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
101.		RM-SW-224 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
101.		RM-SW-225 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
101.		RM-SW-226 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
101.		RM-SW-227 Recirculation Spray Heat Exchanger Outlet	Documentation Submitted	4/29/83	Qualified
106.		UNHOLTZ-DICKIE REMOTE CHARGE PREAMPLIFIERS	I.B	DOCUMENTATION	
		YY-VMS-100A-1 Pressurizer Safety Valve Position			Note 2
		YY-VMS-100A-2 Pressurizer Safety Valve Position			Note 2
		YY-VMS-100B-1 Pressurizer Safety Valve Position			Note 2
		YY-VMS-100B-2 Pressurizer Safety Valve Position			Note 2
		YY-VMS-100C-1 Pressurizer Safety Valve Position			Note 2
		YY-VMS-100C-2 Pressurizer Safety Valve Position			Note 2
		YY-VMS-101A-1 Pressurizer Pilot Operated Relief Valve Position			Note 2
		YY-VMS-101A-2 Pressurizer Pilot Operated Relief Valve Position			Note 2
		YY-VMS-101B-1 Pressurizer Pilot Operated Relief Valve Position			Note 2
		YY-VMS-101B-2 Pressurizer Pilot Operated Relief Valve Position			Note 2
98.		YY-VMS-200A-1 Acoustical Monitoring			Note 2
98.		YY-VMS-200A-2 Acoustical Monitoring			Note 2
98.		YY-VMS-200B-1 Acoustical Monitoring			Note 2
98.		YY-VMS-200B-2 Acoustical Monitoring			Note 2
98.		YY-VMS-200C-1 Acoustical Monitoring			Note 2
98.		YY-VMS-200C-2 Acoustical Monitoring			Note 2
98.		YY-VMS-201A-1 Acoustical Monitoring			Note 2
98.		YY-VMS-201A-2 Acoustical Monitoring			Note 2
98.		YY-VMS-201B-1 Acoustical Monitoring			Note 2
98.		YY-VMS-201B-2 Acoustical Monitoring			Note 2

"STATUS OF ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT AT
NORTH ANNA POWER STATION FOR UNITS 1 AND 2"

TECHNICAL EVALUATION REPORT ITEM NUMBER	DESCRIPTION	NRC CATEGORY	DEFICIENCY	RESOLUTION
109.	ROCKWELL HYDROGEN RECOMBINERS	I.B	DOCUMENTATION	
	1-HC-HC-1 Hydrogen Recombiner			Note 1
104.	2-HC-HC-1 Hydrogen Recombiner			Note 1
109A	GAMMA METRICS FLUX MONITORS	III.A	DOCUMENTATION	
	NFD-190 Neutron Flux			Note 2
	NFD-1270 Neutron Flux			Note 2
57A	NFD-290 Neutron Flux			Note 2
57A	NFD-2270 Neutron Flux			Note 2
109B	WESTINGHOUSE THERMOCOUPLE SYSTEM	I.B	DOCUMENTATION	
	TC-00 Thermocouples			Note 3
62C	TC-00 Thermocouples			Note 3
109C	COPEES VULCAN ELECTRICAL TO PRESSURE FOR FLOW CONTROL VALVE	III.A	NONE	
76.	FC-2122 Charging Flow Control to Regenerate Heat Exchange	Deleted R-4 dated 9/3/81 - 0588		Deleted
109D	FISHER ELECTRICAL TO PRESSURE FOR HAND CONTROL VALVE	III.A	NONE	
102.	AB-244A Seal Water Flow Control	Deleted R-4 dated 9/3/81 - 0588		Deleted

ATTACHMENT 2
NORTH ANNA JCO
HYDROGEN RECOMBINERS

NORTH ANNA JUSTIFICATION FOR CONTINUED OPERATION

1. Hydrogen Recombiners*

1-HC-HC-1, 2-HC-HC-1

Two recombiners are available for North Anna Units 1 and 2. The recombiners are redundant and can be used on either unit. The experience detailed in Rockwell International review document AI-N139TI120010, p. 42-44, "Three Mile Island Recombiner Post-LOCA Operation," shows that the TMI-2 operational experience of a recombinder with the same or similar (e.g., insulation class) components performed for as long as it was needed and in an environment more severe than specified for either North Anna Unit. The North Anna hydrogen recombiners can therefore be relied upon until the above qualification/replacement activities are completed.

Based on the above, no significant degradation of the safety function or misleading information to the operator as a result of failure of the equipment under the accident environment resulting from a design basis event should occur.

*Exemption Request submitted to NRC on June 18, 1984 letter serial no. 298.