

JUL 28 1975

Jersey Central Power and Light Company  
Attention: Mr. Ivan R. Finfrock Jr.  
Vice President  
Madison Avenue at Punch Bowl Road  
Morristown, New Jersey 07960

License No. DPR-16  
Inspection No. 75-12  
Docket No. 50-219

Reference: Your letter dated June 18, 1975  
In response to our letter dated May 23, 1975

Gentlemen:

Thank you for informing us of the corrective and preventive actions you documented in response to our correspondence. These actions will be examined during a subsequent inspection of your licensed program.

Based on a telephone discussion between Mr. Meyer of this office and Mr. Reeves of your staff, it is our understanding that the liquid monitors have been properly calibrated and are currently capable of performing their intended function. With respect to the recalibration referenced in your closing paragraph, it is our understanding that this is intended to establish reference values of the new sources for future verifications that the monitors remain in calibration.

Your cooperation with us is appreciated.

Sincerely,

Paul R. Nelson, Chief  
Radiological and Environmental  
Protection Branch

cc: J. T. Carroll, Station Superintendent  
A. Z. Roisman, Counsel for Citizens Committee for  
Protection of the Environment

W.P.C.  
Panzarino/mid  
7/23/75 *hmv*

  
Knapp

*Nelson*  
Nelson  
7/24/75

*O'Reilly*  
*7/28*  
*Brunner*  
*7/23*  
*B1781*

Jersey Central Power and Light Company

-2-

bcc:

IE Chief, FS&EB

IE:HQ (4)

IE Files

Central Mail & Files

Directorate of Licensing (4)

Regulatory Standards (1)

PDR

Local PDR

NSIC

WIC

REG:I Reading Room

~~Regional Directors (II, III, IV)~~

ELD

State of New Jersey

A. Z. Roisman, Counsel for Citizens Committee for  
Protection of the Environment