

PEACH BOTTOM ATOMIC POWER STATION

THERMAL MAPPING REPORT NO. 84-3

FOR

OCTOBER 1, 1984

FOR

THERMAL MONITORING REQUIREMENTS

UNITS NO. 2 AND 3

PHILADELPHIA ELECTRIC COMPANY

8411050419 841013
PDR ADDCK 05000277
R PDR

COO
111

SUMMARY

On October 1, 1984, one cooling tower was in operation and the river flow was less than 15,000 cfs, therefore, thermal plume mapping was performed.

The following table list conditions on October 1, 1984:

River Flow (cfs)	:	7,200
Heat Discharge (BTU/hr)	:	6.11×10^9
# of C.W. Pumps Operating	:	3
# of Cooling Towers	:	1
Temp. Discharge Canal °F ⁽¹⁾	:	82.2
Temp. State Line °F ⁽²⁾	:	69.4
Temp. Holtwood Dam °F	:	67.3

$$\begin{aligned}\Delta T_{Plant} &= [(STA23-STA1-TCL)] 1.8 \\ &= [(20.8 - 19.0 - 1.8)] 1.8 \\ &= 0°F\end{aligned}$$

(1) Bulk temperature of water discharged to Conowingo Pond from Discharge Canal.

(2) Pennsylvania/Maryland State Line.

MA/dg/10238484-3

TABLE
BOAT SURVEY INFORMATION

SURVEY DATE 10/01/84

TIME:

Survey Start (EST)	0834
State Line (EST)	1013
Survey Finish (EST)	1240

HYDRAULIC DATA:

Pond Elevation Start (Ft.)	107.50
Pond Elevation Finish (Ft.)	107.66
Natural Flow (24 hr. ave., CFS)	7,200
Conowingo Inflow (24 hr. ave., CFS)	8,175
Conowingo Dam Draft (24 hr. ave., CFS)	8,450

PBAPS Power Output:

Unit 2: Thermal (MW)	0
Electrical (MW)	-4.6
Unit 3: Thermal (MW)	3144
Electrical (MW)	1004


METEOROLOGICAL DATA:

Time (EST)	1013
Air Temperature (°F)	51
Dew Point (°F)	45
Precipitation (24 hr. total, In)	.33
Wind Speed (mph)	9
Cloud Cover	Cloudy
Location:	Weather Station #1
Wind Direction	10°

WATER TEMPERATURE (SURVEY)

PBAPS Discharge	°C, (°F)	27.9 (82.2)
Intake	°C, (°F)	18.8 (65.9)
ΔT	°C, (°F)	9.1 (16.3)
Pond Surface Max.	°C, (°F)	27.9 (82.2)
Min.	°C, (°F)	18.3 (64.9)
Pond Bottom Max.	°C, (°F)	27.8 (82.0)
Min.	°C, (°F)	17.9 (64.2)
No. of C.W. Pumps Operating		3
No. of Cooling Towers Operating		1

MA/dg/10238484-3



PEACH BOTTOM ATOMIC POWER STATION

THERMAL MAPPING REPORT NO. 84-4

FOR

OCTOBER 6, 1984

FOR

THERMAL MONITORING REQUIREMENTS

UNITS NO. 2 AND 3

PHILADELPHIA ELECTRIC COMPANY

SUMMARY

On October 6, 1984, one cooling tower was in operation and the river flow was less than 15,000 cfs, therefore, thermal plume mapping was performed.

The following table list conditions on October 6, 1984:

River Flow (cfs)	:	6,500
Heat Discharge (BTU/hr)	:	4.72×10^9
# of C.W. Pumps Operating	:	3
# of Cooling Towers	:	1
Temp. Discharge Canal °F ⁽¹⁾	:	77.8
Temp. State Line °F ⁽²⁾	:	66.7
Temp. Holtwood Dam °F	:	62.4

$$\begin{aligned}\Delta T_{Plant} &= [(STA23-STA1-TCL)] 1.8 \\ &= [(19.3 - 17.5 - 0.7)] 1.8 \\ &= 1.98°F\end{aligned}$$

(1) Bulk temperature of water discharged to Conowingo Pond from Discharge Canal.

(2) Pennsylvania/Maryland State Line.

MA/dg/10238484-4

TABLE
BOAT SURVEY INFORMATION

SURVEY DATE 10/06/84

TIME:

Survey Start (EST)	0545
State Line (EST)	0710
Survey Finish (EST)	0840

HYDRAULIC DATA:

Pond Elevation Start (Ft.)	108.05
Pond Elevation Finish (Ft.)	108.03
Natural Flow (24 hr. ave., CFS)	6,500
Conowingo Inflow (24 hr. ave., CFS)	6,475
Conowingo Dam Draft (24 hr. ave., CFS)	2,250

PBAPS Power Output:

Unit 2: Thermal (MW)	0
Electrical (MW)	-4.7
Unit 3: Thermal (MW)	3167
Electrical (MW)	1032


METEOROLOGICAL DATA:

Time (EST)	0545
Air Temperature (°F)	47
Dew Point (°F)	29
Precipitation (24 hr. total, In)	0
Wind Speed (mph)	7
Cloud Cover	Clear
Location:	Weather Station #1
Wind Direction	360°

WATER TEMPERATURE (SURVEY)

PBAPS Discharge	°C, (°F)	25.5 (77.8)
Intake	°C, (°F)	18.5 (65.2)
ΔT	°C, (°F)	7.0 (12.6)
Pond Surface Max.	°C, (°F)	27.0 (80.6)
Min.	°C, (°F)	17.2 (63.0)
Pond Bottom Max.	°C, (°F)	24.3 (75.7)
Min.	°C, (°F)	16.7 (62.1)
<hr/>		
No. of C.W. Pumps Operating		3
No. of Cooling Towers Operating		1
<hr/>		

MA/dg/10238484-4



HORIZONTAL ISOTHERMS
CONOWINGO POND
DATE 10/6/84
TIME 0545 - 0840

PEACH BOTTOM ATOMIC POWER STATION

THERMAL MAPPING REPORT NO. 84-5

FOR

OCTOBER 13, 1984

FOR

THERMAL MONITORING REQUIREMENTS

UNITS NO. 2 AND 3

PHILADELPHIA ELECTRIC COMPANY

SUMMARY

On October 13, 1984, two cooling towers were in operation and the river flow was less than 15,000 cfs, therefore, thermal plume mapping was performed.

The following table lists conditions on October 13, 1984:

River Flow (cfs)	:	5,300
Heat Discharge (BTU/hr)	:	5.32×10^9
# of C.W. Pumps Operating	:	3
# of Cooling Towers	:	2
Temp. Discharge Canal °F ⁽¹⁾	:	77.3
Temp. State Line °F ⁽²⁾	:	66.4
Temp. Holtwood Dam °F	:	62.2

$$\begin{aligned} T_{Plant} &= [(STA23-STA1-TCL)] 1.8 \\ &= [(19.1 - 17.0 - 0.9)] 1.8 \\ &= 2.16^\circ F \end{aligned}$$

(1) Bulk temperature of water discharged to Conowingo Pond from Discharge Canal.

(2) Pennsylvania/Maryland State Line.

MA/dg/10238484-5

TABLE
BOAT SURVEY INFORMATION

SURVEY DATE 10/13/84

TIME:

Survey Start (EST)	0715
State Line (EST)	0827
Survey Finish (EST)	1030

HYDRAULIC DATA:

Pond Elevation Start (Ft.)	108.53
Pond Elevation Finish (Ft.)	108.53
Natural Flow (24 hr. ave., CFS)	5,300
Conowingo Inflow (24 hr. ave., CFS)	4,525
Conowingo Dam Draft (24 hr. ave., CFS)	2,225

PBAPS Power Output:

Unit 2: Thermal (MW)	0
Electrical (MW)	-7.3
Unit 3: Thermal (MW)	3147
Electrical (MW)	1019.2


METEOROLOGICAL DATA:

Time (EST)	0827
Air Temperature (°F)	59.5
Dew Point (°F)	46
Precipitation (24 hr. total, in)	0
Wind Speed (mph)	9
Cloud Cover	Cloudy
Location:	Weather Station #1A
Wind Direction	352°

WATER TEMPERATURE (SURVEY)

PBAPS Discharge	°C, (°F)	25.2	(77.3)
Intake	°C, (°F)	17.3	(63.1)
ΔT	°C, (°F)	7.9	(14.2)
Pond Surface Max.	°C, (°F)	25.2	(77.4)
Min.	°C, (°F)	17.0	(62.6)
Pond Bottom Max.	°C, (°F)	25.1	(77.2)
Min.	°C, (°F)	16.9	(62.4)
<hr/>			
No. of C.W. Pumps Operating		3	
No. of Cooling Towers Operating		2	
<hr/>			

Ma/dg/10238484-5



PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4000

October 30, 1984

Mr. Thomas A. Ippolito
Operation Reactors Branch 3
Division of Reactor Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Ippolito:

Enclosed are copies of Thermal Mapping Reports 84-3, 84-4, and 84-5 covering the Isotherm surveys for October 1, October 6, and October 13, 1984.

The information has been completed in compliance with the reporting requirements set forth in Appendix B to the Peach Bottom Operating License Environmental Technical Specification and Bases.

Yours truly,
Aileen T. Gallagher
for WBW

W. B. Willsey
Director
Environmental Affairs

WBW:htr
Enclosure

cc: Dr. Thomas E. Murley
Regional Administrator, Region I
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

coa