

Enclosure 1

Notice of Violation

Jersey Central Power and Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

License No. DPR-16
Docket No. 50-219

Based on the results of an NRC inspection conducted on March 25-28, 1975, it appears that one of your activities was not conducted in full compliance with conditions of your license as indicated below.

Contrary to the requirements of 10 CFR 50 Appendix B, Criterion VI, the Oyster Creek Operational Quality Assurance Plan Section V, and Technical Specification Section 6.2.F, temporary changes to eight (8) operating procedures were not reviewed and approved.

This infraction had the potential for causing or contributing to an occurrence related to safety.