

1-23

D

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

APR 10 1975

DOCKET NO.: 50-219

LICENSEE: JERSEY CENTRAL POWER & LIGHT COMPANY

FACILITY: OYSTER CREEK NUCLEAR GENERATING STATION

SUMMARY OF MEETING WITH JERSEY CENTRAL POWER & LIGHT COMPANY HELD ON
MARCH 17, 1975

On March 17, 1975, a meeting was held in Bethesda with representatives of Jersey Central Power & Light Company (JCP&L). The purpose of the meeting was to discuss our concerns regarding JCP&L's proposed revisions to Section 6, "Administrative Controls", of the Oyster Creek Technical Specifications. A list of attendees is enclosed.

By letter dated October 22, 1974, we requested JCP&L to submit an application for amendment to the Oyster Creek facility operating license that would revise Section 6, "Administrative Controls" of the Technical Specifications to be consistent with the standard technical specifications that we developed. By letter dated January 10, 1975, JCP&L submitted a proposed Technical Specification change request in response to our letter of October 22, 1974. JCP&L's letter of January 10, 1975 also identified those areas of departure from the standard technical specifications.

We discussed those areas where JCP&L's proposed Section 6 of the Technical Specifications differ from the standard technical specifications dated September 1, 1974:

a. Qualified Radiation Protection Personnel

JCP&L had omitted Section 6.2.2d of the standard technical specifications which requires that an individual qualified in radiation protection procedures be on site when fuel is in the reactor. Both the licensee and we agreed that this specification should be included in the Oyster Creek Technical Specifications.

b. Assignment of Senior Licensed Operator for Refueling Operation

Section 6.2.2e of the standard technical specifications states:

"All core alterations after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation."



B/858

APR 10 1975

However, Section 6.2.2d of JCP&L's proposed Technical Specifications differs from the above cited specification and states as follows:


"Apparatus and mechanisms other than controls, the operation of which may affect the reactivity or power level of the reactor, shall be manipulated only with the knowledge and consent of a licensed operator or senior operator at the controls."

The above JCP&L specification is taken from 10 CFR Part 50, paragraph 50.54(j).

During the discussion of JCP&L's conduct of operation for refueling, JCP&L stated that there may be occasions during fuel movements when a licensed operator in the control room would give instructions via a head set to an unlicensed foreman who in turn would relay the instructions to the man who moves the fuel (also unlicensed). We stated that we did not agree with the above method of operation involving direct supervision of fuel movements by unlicensed personnel. A letter to JCP&L is being prepared stating our position regarding the qualifications of personnel involved in fuel handling operations.

c. Revision of Sections on "Review and Audit" and "Procedures"

The JCP&L representatives stated that Section 6.5, "Review and Audit", and Section 6.8, "Procedures", are currently being revised. The above sections that are proposed in JCP&L's submittal of January 10, 1975 are essentially unchanged from the current Technical Specifications. We stated that the above sections, when revised, should be in accord with the principles of ANSI N18.7 and also that Section 6.8 should be in accordance with the provisions of Regulatory Guide 1.33.



Walter A. Paulson
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosure:
Attendance List

APR 10 1975

ENCLOSURE

LIST OF ATTENDEES
MEETING WITH JERSEY CENTRAL POWER & LIGHT COMPANY
MARCH 17, 1975

Nuclear Regulatory Commission

F. Allenspach
W. Paulson

Jersey Central Power & Light Company

D. Ross
J. Carroll
T. Madden