

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 11, 1975

Docket No. 50-219

Jersey Central Power & Light Company  
ATTN: Mr. I. R. Finfrock, Jr.  
Vice President - Generation  
Madison Avenue at Punch Bowl Road  
Morristown, New Jersey 07960

Gentlemen:

Our letter to you of February 15, 1975, discussed the Steam Vent Clearing Phenomenon and the Steam Quenching Vibration Phenomenon at various BWR plants with Mark I containments. We also requested in our letter of February 15, 1975, that you initiate action in accordance with a prescribed schedule of major events set forth in the letter. The first action to be accomplished was your submittal of proposed technical specifications to revise the suppression pool water temperature limits. Your letter of April 1, 1975 proposed no such changes to the Technical Specifications. Accordingly in our letter of July 16, 1975, we informed you of our intention to initiate steps to issue changes to the Technical Specifications, for the Oyster Creek Nuclear Generating Station, regarding revised suppression pool water temperature limits and surveillance requirements. By letter dated August 8, 1975, you provided comments on the proposed changes. Subsequently, we modified the proposed Technical Specifications by making a few mutually acceptable changes. Your staff indicated that the comments in your letter of August 8, 1975, were then resolved, and that the Technical Specifications, as modified, were acceptable. On October 15, 1975, we placed a notice in the Federal Register stating our intention to issue these technical specifications.


Accordingly, the Commission has issued the enclosed Amendment No. 11 to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station. The amendment includes Change No. 27 in the Technical Specifications which revises the provisions in the Technical Specifications relating to temperature limits and surveillance requirements for the pressure suppression pool water.

0/7/14

I

A copy of the Federal Register Notice is also enclosed. A copy of our Safety Evaluation relating to this license amendment was enclosed in our letter of October 6, 1975.

Sincerely,

A handwritten signature in cursive script that reads "George Leal".

George Leal, Chief  
Operating Reactors Branch #3  
Division of Reactor Licensing

Enclosures:

1. Amendment No. 11
2. Federal Register Notice

cc:

G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
Barr Building  
910 17th Street, N. W.  
Washington, D. C. 20006

The Honorable W. M. Mason  
Mayor, Lacey Township  
P. O. Box 475  
Forked River, New Jersey 08731

Jersey Central Power & Light Company  
ATTN: Mr. Thomas M. Crimmins, Jr.  
Safety and Licensing Manager  
GPU Service Corporation  
260 Cherry Hill Road  
Parsippany, New Jersey 07054

Honorable Wm. F. Hyland  
Attorney General  
State of New Jersey  
State House Annex  
Trenton, New Jersey 08601

Anthony Z. Roisman, Esquire  
Roisman, Kessler and Cashdan  
1712 N Street, N. W.  
Washington, D. C. 20036

Paul Rosenberg, Esquire  
Daniel Rappoport, Esquire  
2323 S. Broad Street  
Trenton, New Jersey 08610

Honorable Joseph W. Ferraro, Jr.  
Deputy Attorney General  
State of New Jersey  
101 Commerce Street - Room 208  
Newark, New Jersey 07102

George F. Kugler, Jr.  
Attorney General  
State of New Jersey  
State House Annex  
Trenton, New Jersey 08625

Ocean County Library  
15 Hooper Avenue  
Toms River, New Jersey 08753