

Jersey Central Power & Light Company



MADISON AVENUE

PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111

MEMBER OF THE

General



Public Utilities Corporation

March 24, 1975

James P. O'Reilly, Director
Office of Inspection and Enforcement, Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Subject: Oyster Creek Station
Docket No. 50-219
I&E Inspection Report No. 50-219/75/04

Dear Mr. O'Reilly:

This letter is in reply to your letter of February 27, 1975 to Mr. Ivan R. Finfrock regarding the inspection conducted by Mr. Greenman on January 29 to January 31, 1975.

In response to the item of non-compliance listed in Enclosure 1 involving the failure of the Plant Operations Review Committee (PORC) to conduct quarterly reviews of the status and applicability of all standing orders, we wish to advise you of the following:

A formal schedule has been established for those items requiring periodic review by the PORC. In addition, the completion of these reviews will be signed off by the PORC Secretary on a special review record sheet. These measures should ensure that required periodic PORC reviews are conducted at the specified frequencies.

Very truly yours,

Donald A. Ross
Manager, Generating Stations - Nuclear

DAR/bg