

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 26 1975


Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Gentlemen:

Enclosed for your information is a copy of the Advisory Committee on Reactor Safeguards' letter report entitled "Emergency Core Cooling Systems Evaluation Model (ECCS-EM) for the Nonjet-Pump Boiling Water Reactor".

Sincerely,



George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosure:
ACRS Letter Report

cc: See next page



B/868

Mr. I. R. Finfrock, Jr.

- 2 -

MAR 26 1975

cc: w/enclosure

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts, Trowbridge
and Madden
Barr Building
910 17th Street, N. W.
Washington, D. C. 20006

Jersey Central Power & Light Company
ATTN: Mr. Thomas M. Crimmins, Jr.
Safety and Licensing Manager
GPU Service Corporation
260 Cherry Hill Road
Parsippany, New Jersey 07054

Anthony Z. Roisman, Esquire
Berlin, Roisman & Kessler
1712 N Street, N. W.
Washington, D. C. 20036

Paul Rosenberg, Esquire
Daniel Rappoport, Esquire
2323 S. Broad Street
Trenton, New Jersey 08610

Honorable Joseph W. Ferraro, Jr.
Deputy Attorney General
State of New Jersey
101 Commerce Street - Room 208
Newark, New Jersey 07102

Burtis W. Horner, Esquire
Stryker, Tams and Dill
55 Madison Avenue
Morristown, New Jersey 07960

George F. Kugler, Jr.
Attorney General
State of New Jersey
State House Annex
Trenton, New Jersey 08625

Ocean County Library
15 Hooper Avenue
Toms River, New Jersey 08753

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

CLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

75 MAR 10 1975 AM 9:20

OFFICE OF THE SECRETARY

Honorable William A. Anders
Chairman
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Subject: EMERGENCY CORE COOLING SYSTEMS EVALUATION MODEL (ECCS-EM) FOR THE
NONJET-PUMP BOILING WATER REACTOR

Dear Mr. Anders:

At its 179th meeting, March 6-8, 1975, the Advisory Committee on Reactor Safeguards completed its review of the Exxon Nuclear Company's ECCS Nonjet-Pump Boiling Water Reactor Fuel Heatup Model. The initial application of this model is for the evaluation of a reload core at the Oyster Creek Nuclear Generating Station and requires the proper coupling with the approved General Electric Emergency Core Cooling Systems Evaluation Model (ECCS-EM) for the nonjet-pump boiling water reactor. The Jersey Central Power and Light Company is responsible for obtaining the overall ECCS-EM which meets the requirements of 10 CFR 50.46, Appendix K. Subcommittee meetings were held with the NRC Staff and the representatives of the Exxon Nuclear Company in Washington, D.C., on February 1 and 22, 1975, with attendance at the second meeting expanded to include participation by representatives from the Jersey Central Power and Light Company. The Committee previously reported on Evaluation Models for Commission Criteria for Emergency Core Cooling Systems for Light-Water-Cooled Nuclear Power Reactors on November 20, 1974. The Committee also had the benefit of the documents listed below.

The ACRS believes that the Exxon Nuclear Company's portion of the ECCS-EM with the additional modifications required by the NRC Staff and when properly coupled with the approved General Electric nonjet-pump boiling water reactor model will conform to 10 CFR 50.46, Appendix K. Although the Committee believes that the coupling procedure is acceptable for the present application, the Committee recommends that future applications be based upon an integrated set of approved models.

Sincerely yours,



William Kerr
Chairman

References:

1. XN-73-34 (Rev 2), "HUXY: A Generalized Multirod Heatup Code"
2. XN-74-25 (Rev 1), "2DQ: A Two Dimensional Quenching Model"
3. XN-74-27 (Rev 1), "BULGEX: A Computer Code to Determine the Deformation and the Onset of Bulging of Zircaloy Fuel Rod Cladding"
4. XN-74-51, "ECCS Analysis for Oyster Creek Fuel Types IIIA, IIIE, and IIIF with the Exxon Nuclear Evaluation Model for BWR Loss of Coolant Accidents"
5. XN-174 and Suppl 1, "Densification Effects on Exxon Nuclear Boiling Water Reactor Fuel"
6. XN-235, "Exxon Nuclear Evaluation Model for BWR Loss of Coolant Accidents"
7. Report Regarding the Exxon Nuclear Company ECCS Non-Jet-Pump-BWR Fuel Heatup Model by the Office of Nuclear Reactor Regulation March 6, 1975