

FEB 20 1985

CONFIRMATORY ACTION LETTER

Docket No. 50-373
Docket No. 50-374

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

This letter confirms the telephone conversation on February 20, 1985, between you and E. Greenman of my staff regarding the discovery of a mispositioned valve on the air start system of a Unit 1 Diesel Generator on February 18, 1985 and the mispositioned breaker on a Unit 2 safety bus found on February 19, 1985. With regard to the matters discussed, we understand that you have taken or will complete the following actions:

1. Walkdown and verify the correct positioning of all manual valves and electrical lineups for the Unit 1 and 2 Diesel Generators and re-perform this verification on a daily basis.
2. Complete a walkdown and verify the locked valve checklists, excluding those valves located in high radiation areas, for both units and then on a weekly basis thereafter.
3. Increase the number of patrols by security officers to double the frequency of surveillance in the Reactor and Auxiliary Buildings so that the random patrols will be completed at least once each hour.
4. All operating shifts will be informed of the recent events, reemphasizing reviews for proper system lineups during valve/breaker manipulations and under off-normal alarm conditions.
5. Any findings with respect to these actions shall be reported to the NRC Region III office immediately.

8502260320 850220
 PDR ADOCK 05000373
 S PDR

CONFIRMATORY ACTION LETTER

1/0
IE01

CONFIRMATORY ACTION LETTER

Commonwealth Edison Company

2

FEB 20 1985

The actions described above shall remain in effect until Region III has reviewed and concurred in any determination by CECO for modification or cancellation. Also, we further understand that after your investigation is completed you will provide a written summary to this office covering the actions taken and the results achieved.

Please let us know immediately if your understanding differs from that set forth above.

"Original signed by A. B. Davis for"

James G. Keppler
Regional Administrator

cc: D. L. Farrar, Director
of Nuclear Licensing
G. J. Diederich, Station
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Phyllis Dunton, Attorney
General's Office, Environmental
Control Division

(DRP 85-01)

RIII
[Signature]
Chrissotimos/rr
02/20/85

RIII
[Signature]
Shefer

RIII
[Signature]
Norelius
2/20

RIII
WWS
Schultz
2-20-85

RIII
[Signature]
Hind
2/20/85

RIII
[Signature]
Davis
2/20

RIII
[Signature]
for Keppler
2/20

CONFIRMATORY ACTION LETTER