

APPENDIX A

NOTICE OF VIOLATIONS

Jersey Central Power and Light Company
Docket No. 50-219
License No. DPR-16

Based on the results of the NRC inspection of your facility on November 12 and 13, 1975, it appears that certain of your activities were not conducted in full compliance with the conditions of your license as set forth below:

- A. Contrary to 10 CFR 50, Appendix E, Item IV.D and Section V.D of the Oyster Creek Emergency Plan, there were no arrangements for ambulance service confirmed in writing.

This is a Deficiency.

However, based on the facsimile copy of a letter of agreement dated November 14, 1975 between the licensee and a local ambulance service received at Region I on November 17, 1975, no additional response is required on this item.

- B. Contrary to 10 CFR 50, Appendix E, Item IV.E and Sections VI.A and VI.D of the Oyster Creek Emergency Plan, the Emergency Plan had not been reviewed, revised and approved annually or more frequently as required since the Plan's acceptance by the NRC on September 23, 1974.

This is a Deficiency.