

ENCLOSURE 1

NOTICE OF VIOLATION

Jersey Central Power and Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960
Docket No. 50-219
License No. DPR-16

Based on the results of an NRC inspection conducted on January 14, 15, 17 and 20, 1975, it appears that one activity was not conducted in full compliance with conditions of your license and Commission requirements as indicated below:

1. Contrary to 10 CFR 50.59(c) which requires in part that: "The holder of a license authorizing operation of a production or utilization facility who desires....(2) to make a change in the facility or the procedures described in the safety analysis report..., shall submit an application for amendment of his licensee pursuant to 50.90" and additionally, the licensee's Supplement No. 2 to Amendment No. 68 - Application for a Full Term License pp 15-16 dated December 12, 1974, which stated that exceptions regarding the crane five ton hook, cab ladder and railing and a crane warning device to signal movement were in the process of being corrected, the corrections had not been made at the time of the inspection and no change had been requested or authorized to the listed commitment.

This infraction was identified by the inspector and had the potential for causing or contributing to an occurrence with safety significance.

We note that a crane warning device was installed and observed to be functional prior to commencing spent fuel shipping operations. We have no further question regarding this item at this time.