


Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111



July 3, 1975

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement, Region 1
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
IE Bulletin No. 75-06

In reference to IE Bulletin No. 75-06 dated May 30, 1975, it has been ascertained that Westinghouse Type OT-2 switches are not utilized in safety systems at the Oyster Creek Nuclear Generating Station; therefore, no further action is planned.

Very truly yours,

Donald A. Ross, Manager
Generating Stations-Nuclear

cs