


FEB 27 1975

D. L. Caphton, Senior Reactor Inspector, IE:I Reactor Operations Branch

OYSTER CREEK
DOCKET NO. 50-219
IE INSPECTION 50-219/75-04

This was a routine unannounced inspection for review of AOs, Administration and Organization and Plant Operations. One deficiency related to PORC's failure to review Standing Orders was identified.

With respect to uniformity, I spent six (6) hours on site fielding questions and in contact with IE:I re IE Bulletin 75-01. An additional four hours was required to pursue contamination levels concerning a cask shipment of January 28, 1975. Projects is sending a memorandum to R&EP on this subject.



E. G. Greenman
Reactor Inspector