

September 27, 1984
(NMP2L 0172)


Mr. R. W. Starostecki, Director
U. S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point - Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report, in accordance with 10CFR50.55(e), for the problem concerning Rosemount master trip units. This condition was reported via tel-con to S. Collins of your staff on August 28, 1984.

Very truly yours,



C. V. Mangar
Vice President
Nuclear Engineering and Licensing

CVM/GG/pbd

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, NRC Resident Inspector

Project File (2)

8411070311 840927
PDR ADDCK 05000410
S PDR

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem
Concerning Rosemount Master Trip Units
(55(e)-84-34)

Description of the Problem

During the field acceptance test on the Rosemount master trip units, it was noticed that some of the units exhibited a spurious and random operation of the setpoints. These units are used in Nuclear Steam Supply System safety-related systems.

Corrective Action

The corrective action is still being investigated by General Electric Company and a final report will be submitted by December 12, 1984.