

DMB-016

FEB 14 1985

Dockets Nos. 50-321  
and 50-366

Distribution	PMcKee
<del>Docket File</del>	JPartlow
NRC PDR	ACRS-10
L PDR	Ringram
ORB#4 Rdg	GRivenbark
HThompson	Gray File
OELD	
EJordan	

Mr. J. T. Beckham, Jr.  
Vice President - Nuclear Generation  
Georgia Power Company  
P. O. Box 4545  
Atlanta, Georgia 30302

Dear Mr. Beckham:

Based on our evaluation of the documentation that you have submitted regarding the Safety Parameter Display System (SPDS) for Hatch Units 1 and 2, we have concluded that it is acceptable for Georgia Power Company to continue implementing its SPDS program for Hatch Units 1 and 2 on the condition that the SPDS is provided with suitable electrical and electronic isolation from the equipment and sensors used in safety systems. Our Safety Evaluation is enclosed.

Section E of the enclosed Safety Evaluation lists additional information concerning this electrical and electronic isolation of the SPDS that is needed by the staff for confirmatory review of GPC verbal commitments to provide suitable isolation. You are requested to submit this information within 60 days of the date of this letter.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

\*ORIGINAL SIGNED BY  
JOHN F. STOLZ\*

John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

Enclosure:  
As stated

cc: w/enclosure:  
See next page

ORB#4:NL	ORB#4:DE
GRivenbark;cr	JStolz JNF
2/13/85	2/14/85

8502260427 850214  
PDR ADOCK 05000321  
F PDR

Hatch 1/2  
Georgia Power Company

50-321/366

cc w/enclosure(s):

G. F. Trowbridge, Esq.  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Ruble A. Thomas  
Vice President  
P. O. Box 2625  
Southern Company Services, Inc.  
Birmingham, Alabama 35202

Louis B. Long  
Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202

Chairman  
Appling County Commissioners  
County Courthouse  
Baxley, Georgia 31513

Mr. L. T. Gucwa  
Georgia Power Company  
Engineering Department  
P. O. Box 4545  
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr. General Manager  
Edwin I. Hatch Nuclear Plant  
Georgia Power Company  
P. O. Box 442  
Baxley, Georgia 31513

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Route 1, P. O. Box 279  
Baxley, Georgia 31513

Mr. James P. O'Reilly, Regional  
Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Charles H. Badger  
Office of Planning and Budget  
Room 610  
270 Washington Street, S.W.  
Atlanta, Georgia 30334

J. Leonard Ledbetter, Commissioner  
Department of Natural Resources  
270 Washington Street, N.W.  
Atlanta, Georgia 30334